

LINE OUTAGES FOR THE WEEK

FROM 15-Nov-10 TO 21-Nov-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole II Padgha	16-Nov-10	06.21	16-Nov-10	10.20	Inspection of OLTC mechanism problem.
400KV	Karad - Kolhapur - I	6-Nov-10	00.11	15-Nov-10	11:53	Over Voltage.
400KV	Kolhapur - Mapusa - I	11-Nov-10	22.30	18-Nov-10	09.17	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	13-Nov-10	23.05	15-Nov-10	06:34	Over Voltage.
400KV	Parli - Chandrapur - III	14-Nov-10	10.26	18-Nov-10	15.31	Breaker Maintenance,Line on TBC.
400KV	Karad-Lamboti	14-Nov-10	15.50	15-Nov-10	13:49	Dist.Prot. Z-I B Ph - Earth.
400KV	Bhusawal- Aurangabad	14-Nov-10	23.50	15-Nov-10	06.12	Over Voltage.
400KV	Karad-New Koyna II	14-Nov-10	20.30	15-Nov-10	08:16	Dist.Prot.B Ph,Ready for Charging from 02.06 on dt 15.11.10.
400KV	Dhule-Sar'Sarovar - II	14-Nov-10	23.41	17-Nov-10	09.16	Over Voltage
400KV	Lonikand- Koyna Stage IV	15-Nov-10	21:36	16-Nov-10	08.16	Dist.Prot.
400KV	Jejuri-Koyna STG-IV	15-Nov-10	15:29	16-Nov-10	08.03	Dist.Prot.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	15-Nov-10	21:36	16-Nov-10	07.39	Differential Prot.
400KV	400/132 KV 200 MVA ICT - II @ Khadka	15-Nov-10	08:22	15-Nov-10	14:02	Hot Spot on T/F Isolator.
400KV	Karad - Kolhapur - II	15-Nov-10	23:07	17-Nov-10	17.43	For Over Voltage.
400KV	Bhusawal- Aurangabad	15-Nov-10	23:15	16-Nov-10	09.03	For Over Voltage.
400KV	Dhule-S'Sarovar I	15-Nov-10	23.35	16-Nov-10	17.34	Over Voltage.
400KV	Karad-Lamboti	16-Nov-10	01:12	16-Nov-10	09.14	For Over Voltage.
400KV	400/132KV 200 MVA ICT- I @ Bhusawal	16-Nov-10	09.18	16-Nov-10	15.11	Attending hot spot.
400KV	Dhule-Sar'Sarovar - I	17-Nov-10	01.55	19-Nov-10	09.09	Over Voltage.
400KV	Karad - Kolhapur - I	17-Nov-10	21.46	19-Nov-10	06.47	Over Voltage
400KV	Dhule-Sar'Sarovar - II	17-Nov-10	23.04	20-Nov-10	09.54	Over Voltage
400KV	Karad-Lamboti	17-Nov-10	23.54	18-Nov-10	07.59	Over Voltage
400KV	Bhusawal- Aurangabad	17-Nov-10	23.35	18-Nov-10	05.56	Over Voltage
400KV	Karad-Kolhapur-II	17-Nov-10	23.35	18-Nov-10	06.45	Over Voltage.
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	18-Nov-10	08.29	18-Nov-10	18.03	Hot Spot attending
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	18-Nov-10	12.10	18-Nov-10	14.56	Maint.work
400KV	400/220 KV 300 MVA ICT-I @ Koradi	18-Nov-10	09.20	18-Nov-10	19.10	Q.M.work
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	18-Nov-10	09.45	18-Nov-10	19.19	SFR work
400KV	Bhusawal- Aurangabad	18-Nov-10	23.32	19-Nov-10	06.27	Over Voltage
400KV	Kolhapur-Mapusa-II	18-Nov-10	23.20	19-Nov-10	10.59	Over Voltage
400KV	Karad - Kolhapur - II	19-Nov-10	01.51	20-Nov-10	09.40	Over Voltage
400KV	Karad-Lamboti	19-Nov-10	01.51	19-Nov-10	06.32	Over Voltage
400KV	STG IV-N.Koyna -I	19-Nov-10	05.04	19-Nov-10	05.11	CB tripped at Stage-IV on PDR
400KV	Bhusawal- Aurangabad	19-Nov-10	10.00	19-Nov-10	18.39	For Controlling A'bad ICT Loading.
400KV	Padgha-Tarapur - II	19-Nov-10	10.07	19-Nov-10	18.47	Q.M.Work.

400KV	400/220KV,500 MVA ICT-III At A'bad.	19-Nov-10	10.03	19-Nov-10	18.23	Revision of WTI,OTI Setting & Maint.Work.
400KV	400/220KV 315MVA ICT- I @ Kharghar	19-Nov-10	14.13	19-Nov-10	15.35	Hot Spot Attending Work.
400KV	Dhule - Babaleshwar - II	19-Nov-10	15.57	19-Nov-10	16.16	Hot Spot Attending Work.
400KV	Dhule-SarSarovar - I	19-Nov-10	23.52	20-Nov-10	08.59	Over Voltage.
400KV	Kolhapur - Mapusa - I	19-Nov-10	23.35	20-Nov-10	10.00	Over Voltage.
400KV	Bhusawal- Aurangabad	19-Nov-10	22.32	20-Nov-10	05.34	Over Voltage.
400KV	Dhule - Babaleshwar - II	20-Nov-10	01.14	20-Nov-10	19.10	Over Voltage.
400KV	Karad-Lamboti	20-Nov-10	01.20	20-Nov-10	05.49	Over Voltage.
400KV	Kolhapur-Mapusa-II	20-Nov-10	21.49		Continued.	Over Voltage.
400KV	Karad - Kolhapur - I	20-Nov-10	22.45	21-Nov-10	14:34	Over Voltage.
400KV	Dhule-SarSarovar - I	20-Nov-10	22.33	21-Nov-10	09:02	Over Voltage.
400KV	Dhule-SarSarovar - II	20-Nov-10	23.02		Continued.	Over Voltage.
400KV	Chandrapur - Parli - I	20-Nov-10	23.05	21-Nov-10	05.02	To Attend Hot Spot @ C'pur end.
400KV	Bhusawal- Aurangabad	20-Nov-10	23.47	21-Nov-10	05.52	Over Voltage.
400KV	Karad-Lamboti	21-Nov-10	00.17	21-Nov-10	05.45	Over Voltage.
400KV	Dhule-S'Sarovar I	21-Nov-10	22:50		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	21-Nov-10	20:29	21-Nov-10	21:52	Taken on TBC for attending hot spot.
400KV	Bhusawal- Aurangabad	21-Nov-10	22:56	22-Nov-10	05:57	Over Voltage.
400KV	Karad - Kolhapur - II	21-Nov-10	23:35		Continued.	Over Voltage.
220KV	220/132 KV 200 MVA ICT - II @ Theur	1-Jun-10	03.57	20-Nov-10	19.21	Oil Tank Burst. NEW 200 MVA T/F Errection in progress.
220KV	220/100KV 125MVA ICT-IV @ Kalwa	2-Aug-10	10.10	20-Nov-10	14.11	Changed from HV side, kept on humming.
220KV	Borivali-Tata Borivali 4	19-Oct-10	16.41	19-Nov-10	12.44	To control ICT Kalwa loading.
220KV	Bus coupler @ Bableshwar	11-Nov-10	08.15	15-Nov-10	15:48	Replacement of Breaker.
220KV	SPCL - IPCL	13-Nov-10	12.41	15-Nov-10	16:06	C B Overhalling Work @ IPCL End.
220KV	Wadkhal-IPCL-II	14-Nov-10	09.20	15-Nov-10	17:46	Overhauling Work.
220KV	Karad-Pedambe	14-Nov-10	19.39	15-Nov-10	16:50	Dist.Prot. R Ph -E Ckt Tripped Both end,Declared Faulty.
220KV	Kalwa - Ghatghar	15-Nov-10	16:28	15-Nov-10	17:24	Dist.Prot.
220KV	Ghatghar-Nasik	15-Nov-10	16:28	15-Nov-10	17:41	Dist.Prot.
220KV	Kalwa-Colourchem	15-Nov-10	19:30	15-Nov-10	19:41	Dist.Prot.
220KV	Temghar-Colourchem	15-Nov-10	19:40	15-Nov-10	20:10	Dist.Prot.
220KV	220/100 KV 125MVA ICT-II @ Borivali	15-Nov-10	20:00	16-Nov-10	11.30	OLTC Buchholz Trip.
220KV	Nasik-Navsari-I	15-Nov-10	15:20	17-Nov-10	22.37	Due to outage on 220 KV Kawas-Navsare I and II.
220KV	Nasik - Navsari - II	15-Nov-10	15:31	17-Nov-10	23.06	Due to outage on 220 KV Kawas-Navsare-I and II.
220KV	Kolhapur - Karad - II	15-Nov-10	12:06	15-Nov-10	18:40	Replacement of C.C.
220KV	Jejuri - Baramati	15-Nov-10	11:10	17-Nov-10	16.01	Taken on own CB.
220KV	220/132 KV 200 MVA ICT -IV. at Padegaon.	15-Nov-10	10:40	15-Nov-10	17:17	LA replacement work.
220KV	Kalwa-Colourchem	16-Nov-10	06.11	16-Nov-10	07.41	Attending hot spot.
220KV	Wadkhal-IPCL I	16-Nov-10	09.51	16-Nov-10	18.56	Q.M.Work
220KV	Nagothane-IPCL	16-Nov-10	11.48	17-Nov-10	19.07	C.B.overhauling work.
220KV	Bableswhar-Nasik-I	16-Nov-10	15.03	16-Nov-10	22.34	Isolator work.Line on TBC.

220KV	Tillari-Amona-II	16-Nov-10	12.43		Continued.	To attend breakdown.
220KV	Chandrapur - Rly TSS - I	16-Nov-10	11.21	16-Nov-10	17.41	Replacement of energy meter.
220KV	220/132 KV 100MVA ICT I at Pusad	16-Nov-10	09.07	16-Nov-10	18.40	Replacement of Y and B Ph.CTs.
220KV	Warora - Wardha Power - II	16-Nov-10	12.35	16-Nov-10	20.05	C.T.replacement and Testing work.
220KV	Karad-Vita-II	16-Nov-10	10.14	16-Nov-10	18.56	Q.M.Work
220KV	Kalwa-Mulund-I	17-Nov-10	09.15	17-Nov-10	18.58	Commissioning of back up relay.
220KV	Wadkhal-IPCL I	17-Nov-10	12.20	17-Nov-10	18.27	Hot spot on isolator.
220KV	New Koyna-Pedambe-II	17-Nov-10	10.45	17-Nov-10	11.16	Trip from New Koyna end.
220KV	220/132 KV 50 MVA ICT @ Gadchiroli	17-Nov-10	10.23	17-Nov-10	16.50	Q.M.Work
220KV	Warora - Wardha Power - II	17-Nov-10	07.00	17-Nov-10	22.05	Replacement of CT
220KV	Bhosari - Lonikand	18-Nov-10	07.05	18-Nov-10	18.15	Replacement of Conductor
220KV	Mudshingi - Peth	18-Nov-10	09.40	18-Nov-10	11.20	Tand delta work
220KV	Kalwa - Borivali	18-Nov-10	09.55	18-Nov-10	17.45	Commissioning of Numerical relay
220KV	Jejuri-Phursungi	18-Nov-10	06.16	18-Nov-10	06.47	Distance Protection
220KV	Vita - Lamboti	18-Nov-10	00.05	18-Nov-10	18.07	Distance Protection
220KV	Bhosari-C'enka	18-Nov-10	18.27	18-Nov-10	19.45	Hot spot attending
220KV	220/132 KV 125 MVA ICT - II @ Borivali.	18-Nov-10	17.45	18-Nov-10	18.10	Tripped due to occurrence
220KV	Babaleshwar - Babaleshwar - II	18-Nov-10	09.02		Continued.	Isolator replacement work, Line on TBC
220KV	Trombay - Salsett - I	18-Nov-10	17.40	18-Nov-10	18.12	Tripped due to occurrence
220KV	Boiser-Versova	18-Nov-10	17.45	18-Nov-10	18.15	Tripped due to occurrence
220KV	Boisor - Dahanu	18-Nov-10	17.45	18-Nov-10	18.03	Tripped due to occurrence
220KV	Borivali - Aarey - I	18-Nov-10	17.45	18-Nov-10	17.55	Tripped due to occurrence
220KV	Borivali-Aarey-II	18-Nov-10	17.45	18-Nov-10	17.55	Tripped due to occurrence
220KV	Trombay-Salset-II	18-Nov-10	17.45	18-Nov-10	17.48	Tripped due to occurrence
220KV	Main Bus at Magarpatta	18-Nov-10	10.15	18-Nov-10	16.20	Q.M.Work
220KV	220/100KV 125MVA ICT-I at Borivali	18-Nov-10	17.45	18-Nov-10	18.06	Tripped due to occurrence
220KV	Khaperkheda - Wardha.	18-Nov-10	08.43	18-Nov-10	18.36	Laying of Earth Wire
220KV	Pusad-Parbhani	18-Nov-10	10.17	18-Nov-10	15.25	To control line loading
220KV	Jejuri-Phursungi	19-Nov-10	05.40	19-Nov-10	06.00	Distance Protection
220KV	220 KV Main Bus - II @ 400 KV Kalwa	19-Nov-10	07.15	19-Nov-10	20.29	Maintenance Work.
220KV	Temghar - Padgha	19-Nov-10	09.41	19-Nov-10	18.11	Attending Hot Spot.
220KV	Kalwa-Mahape	19-Nov-10	10.11	19-Nov-10	17.44	For Commissioning Numerical Backup Relay
220KV	Chalisgaon - Malegaon	19-Nov-10	10.00	19-Nov-10	15.01	Replacement of Distance Protection Relay & Q.M.
220KV	Nagothane - SPCL	19-Nov-10	10.17	19-Nov-10	19.15	Line Isolator Allinment Work.
220KV	220 KV Main Bus - II @ Jejuri.	19-Nov-10	11.04	20-Nov-10	17.32	Testing & Maint.Work.
220KV	Babaleshwar - Babaleshwar - I	19-Nov-10	22.00	20-Nov-10	00.46	Distance Protection.
220KV	Babaleshwar - Babaleshwar - II	19-Nov-10	22.00	20-Nov-10	00.45	Distance Protection.
220KV	Khaperkheda - Wardha.	19-Nov-10	08.25	19-Nov-10	16.31	Laying of Earthwire from Loc.113 (Cut Point) to 125 (Cut Point).
220KV	Bhosari-C'enka	20-Nov-10	06.00	20-Nov-10	08.27	Oil Leakage of R Ph.C T.
220KV	Kharghar-TSS	20-Nov-10	10.37	20-Nov-10	14.17	B Ph. Wave Trap Clamp Hot Spot Work.

220KV	Kalwa-Ghatghar	20-Nov-10	10.50	20-Nov-10	19.15	Insulator Replacement.
220KV	Aurangabad - Babaleshwar	20-Nov-10	09.45	20-Nov-10	19.52	Overtiead Striging Work of 400 KV.
220KV	Aurangabad - Bhenda	20-Nov-10	09.26	20-Nov-10	18.40	Earthwire Striging Work.
220KV	220/100 KV125 MVA ICT-III @Trombay	20-Nov-10	16.24	20-Nov-10	16.45	Bus Operated, Tripped Without Indication.
220KV	Trombay-Kalwa	20-Nov-10	16.24	20-Nov-10	16.33	Bus Operated, Tripped Without Indication.
220KV	Trombay Sonkhar	20-Nov-10	16.24	20-Nov-10	16.44	Bus Operated, Tripped Without Indication.
220KV	Trombay-Kharghar	20-Nov-10	16.24	20-Nov-10	16.43	Bus Operated, Tripped Without Indication.
220KV	Bus section - I @ Trombay	20-Nov-10	16.24	20-Nov-10	16.36	Bus Operated, Tripped Without Indication.
220KV	Bus-Section - II @ Trombay	20-Nov-10	16.24	20-Nov-10	16.36	Bus Operated, Tripped Without Indication.
220KV	Trombay - Tata Tie - II	20-Nov-10	16.24	20-Nov-10	16.57	Bus Operated, Tripped Without Indication.
220KV	220/132 KV 200 MVA ICT - II @ Theur	20-Nov-10	21.32		Continued.	Differential Protection.
220KV	220 KV A Bus @ Kharghar	20-Nov-10	10.15	20-Nov-10	18.45	Maint.Work.
220KV	Halkarni - Hemres	20-Nov-10	17.20		Continued.	Distance Protection.
220KV	Halkarni - Hemres	20-Nov-10	14.30		Continued.	New Line Charged.
220KV	Lamboti-Bale-I	21-Nov-10	03.26	21-Nov-10	07:42	Distance Protection Z-I 17 KM from Lamboti.
220KV	Boisor - Dahanu	21-Nov-10	06:21	21-Nov-10	06:30	To change Bus for Bus outage.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	21-Nov-10	07:13	21-Nov-10	07:22	To Shifting 'A' Bus.
220KV	Trombay - Sonkar	21-Nov-10	07:40	21-Nov-10	09:25	Attending hot spot on Rph CT.
220KV	Boiser - Tarapur	21-Nov-10	08:40	21-Nov-10	14:15	Isolator work Bus B,Bph.
220KV	BOISER - PGCIL-II	21-Nov-10	12:48	21-Nov-10	14:30	Taken on TBC.
220KV	Aarey-Borivali-I	21-Nov-10	16:24	21-Nov-10	17:18	Dist. Prot.
220KV	Dharavi - Trombay - 5	21-Nov-10	17:05	21-Nov-10	17:27	Dist. Prot.
220KV	Dharavi - Trombay - 6	21-Nov-10	17:05	21-Nov-10	17:50	Dist. Prot.
220KV	Trombay-Salset-II	21-Nov-10	17:05	21-Nov-10	18:04	Dist. Prot.
220KV	Raymond-Washala	21-Nov-10	19:35		Continued.	Dist. Prot.
220KV	Kolhapur - Amona	21-Nov-10	20:40		Continued.	Dist. Prot.
220KV	Tillari-Amona-II	21-Nov-10	21:25		Continued.	Dist. Prot.
220KV	BOISER - PGCIL-II	21-Nov-10	07:03	21-Nov-10	08:26	For Transfer from Bus B to Bus A.
220KV	B - Bus at Boiser	21-Nov-10	09:02		Continued.	Maintenance Isolator alignment and Hot spot.
132KV	Kallamb - Bhoom	13-Nov-10	17:50	15-Nov-10	16:13	Cut point Tower no.81 collapsed from Bhoom distance 25 K.M.
132KV	Pusad-Jambazar	15-Nov-10	20:43	15-Nov-10	20:53	Distance Protection Operated.
132KV	Pusad - Digras	15-Nov-10	20:43	15-Nov-10	20:59	Backup Protection Operated.
132KV	Harangul - Latur - I	16-Nov-10	10.35	16-Nov-10	15.10	Q.M.Work
132KV	Pusad-Jambazar	17-Nov-10	11.02	17-Nov-10	17.58	Replacement of disc insulator string.
132KV	Ambazari - Mankapur	18-Nov-10	07.31	18-Nov-10	18.44	Replacement of Damaged conductor
110KV	Pedambe-- Ratnagiri	15-Nov-10	17:05	16-Nov-10	18.05	Dist.Prot. line faulty.
110KV	Tata MSETCL-Borivali - I	21-Nov-10	10:00	21-Nov-10	17:44	Insulator replacement.
100KV	Chinchwad - Talegaon	15-Nov-10	17:29	15-Nov-10	17:31	Dist.Prot.
100KV	Chinchwad - Talegaon	18-Nov-10	07.00	18-Nov-10	14.42	Dismantalling of old Ckt work
100KV	Borivali-Tata-I	18-Nov-10	17.45	18-Nov-10	18.15	Tripped at Tata end only
100KV	Borivali-Tata-II	18-Nov-10	17.45	18-Nov-10	18.13	Tripped at Tata end only