

LINE OUTAGES FOR THE WEEK

FROM 13-Dec-10 TO 19-Dec-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Kolhapur - Mapusa - I	6-Dec-10	09.14	13-Dec-10	16.06	Over Voltage.
400KV	Wardha - Akola - I	6-Dec-10	23.13	15-Dec-10	16.31	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	10-Dec-10	22.44	13-Dec-10	10.31	Over Voltage.
400KV	Bhusawal- Aurangabad	12-Dec-10	20.00	13-Dec-10	05.59	Over Voltage.
400KV	Karad - Kolhapur - II	12-Dec-10	23.47	13-Dec-10	10.02	Over Voltage.
400KV	400/220KV 500MVA ICT II at Kalwa	13-Dec-10	14.12	13-Dec-10	18.02	To attend Nitrogen leakage in CTR.
400KV	Bablsr-Padgha Ckt I	13-Dec-10	18.16	13-Dec-10	18.36	R-Ph to E/F.
400KV	Karad - Kolhapur - I	13-Dec-10	18.48	14-Dec-10	08.57	Over Voltage.
400KV	Dhule - S'Sarovar- II	13-Dec-10	20.06	14-Dec-10	11.26	Over Voltage.
400KV	Kolhapur-Mapusa-II	13-Dec-10	20.11	16-Dec-10	16.16	Over Voltage.
400KV	Bhusawal- Aurangabad	13-Dec-10	22.30	14-Dec-10	06.11	Over Voltage.
400KV	600 MVA 21/400 KV GT VII at Chandrapur	13-Dec-10	09.03	13-Dec-10	11.58	To attend air leakage of main CB,GTR-7 was on TBC.
400KV	Karad-Kolhapur-II	14-Dec-10	19.26	15-Dec-10	06.30	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	14-Dec-10	19.26	15-Dec-10	10.05	Over Voltage.
400KV	Bablsr-Padgha Ckt I	14-Dec-10	12.48	14-Dec-10	17.14	Due to sparking of R-Ph line isolator.
400KV	Karad - Kolhapur - I	14-Dec-10	14.16	14-Dec-10	14.26	Due to R-Ph Isolator sparking.
400KV	Karad-Lamboti	14-Dec-10	09.32	14-Dec-10	18.44	Erection of Tower@Loc.No.321 for 400KV Jaigad-Karad D/C ckt.
400KV	Dhule - S'Sarovar- II	14-Dec-10	22.47	16-Dec-10	07.32	Over Voltage.
400KV	Bhusawal- Aurangabad	14-Dec-10	23.05	15-Dec-10	06.09	Over Voltage.
400KV	Main Bus - I @ Kolhapur	14-Dec-10	15.02		Continued.	Isolator Alignment and Testing Work.
400KV	Karad-Lamboti	15-Dec-10	07.31	15-Dec-10	17.16	Errection of Tower At Loc.321 for Karad-Jaigad D/C line.
400KV	Kolhapur TBC	15-Dec-10	13.15		Continued.	CT Tan Delta Testing Work.
400KV	Lonikand- Koyna Stage IV	15-Dec-10	14.35	15-Dec-10	18.31	Own breaker work.Line on TBC
400KV	Karad - Kolhapur - I	15-Dec-10	20.45	16-Dec-10	06.32	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	15-Dec-10	22.04		Continued.	Over Voltage.
400KV	Wardha - Akola - II	15-Dec-10	21.41		Continued.	Over Voltage.
400KV	400/220KV 315MVA ICT-II @ Kharghar	15-Dec-10	10.00	17-Dec-10	13:05	Own brkr of ICT II for CB testing taken on TBC
400KV	M.B-II At 400KV Parli	16-Dec-10	05.45	17-Dec-10	20.05	Gear Box replacement.
400KV	400/220KV,315 MVA ICT-I At Lonikand.	16-Dec-10	07.21	16-Dec-10	19.18	For Topping up of oil.
400KV	Karad-Lamboti	16-Dec-10	08.11	17-Dec-10	06.45	Errection of tower at Loc.321 for 400KV Jaigad-Karad D/C line.
400KV	Dabhol - New Koyna - I	16-Dec-10	11.20	17-Dec-10	10.13	For attending sparking at 29A isolator(Line taken on TBC)
400KV	Kolhapur - Mapusa - I	16-Dec-10	22.01	18-Dec-10	14.14	Over Voltage.
400KV	Karad-Kolhapur-II	16-Dec-10	23.57	17-Dec-10	06.42	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	16-Dec-10	23.57	17-Dec-10	07.54	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	16-Dec-10	23.34	18-Dec-10	14.13	Over Voltage.
400KV	Lonikand- Koyna Stage IV	17-Dec-10	00.30	17-Dec-10	06.43	For Over Voltage.
400KV	Karad - Kolhapur - I	17-Dec-10	21.19	18-Dec-10	06.50	Over Voltage
400KV	400/220KV 315 MVA ICT- II @ Padgha	17-Dec-10	09.10	17-Dec-10	18.49	Bay Maint.and attending Hot Spot
400KV	New Koyna - Koyna Stage IV - II	17-Dec-10	23.55	18-Dec-10	08.30	Over Voltage
400KV	Lonikand- Koyna Stage IV	17-Dec-10	23.05	18-Dec-10	06.35	Over Voltage
400KV	Bhusawal- Aurangabad	17-Dec-10	22.30	18-Dec-10	05.53	Over Voltage
400KV	400/220 KV 300 MVA ICT-I @ Koradi	17-Dec-10	11.51	17-Dec-10	15.11	Oil Top up work
400KV	Karad-Lamboti	18-Dec-10	07.03	18-Dec-10	18.32	Tower Erection Work of Karad-Jaigad D/C Work.
400KV	Bableswhar-Aurangabad	18-Dec-10	09.43	18-Dec-10	17.56	Q. M. Work.
400KV	Bus Coupler @ Kharghar	18-Dec-10	12.58	18-Dec-10	22.04	Replacement of Y Ph C T Due to Oil Leakage from Bottom Tank.

400KV	Koradi-Satpur	18-Dec-10	08.39	18-Dec-10	18.54	Repl.of Old Bkr.and Cable Work
400KV	Karad-Kolhapur-II	18-Dec-10	18.26	19-Dec-10	07.32	Over Voltage.
400KV	Kolhapur - Mapusa - II	18-Dec-10	21.17	18-Dec-10	23.40	Over Voltage.
400KV	Kolhapur - Mapusa - I	18-Dec-10	23.46		Continued.	Due to SF6 Gas Pressure Alarm
400KV	Chandrapur 400 KV HVDC-II	18-Dec-10	21.48	19-Dec-10	00.45	To attend Hot Spot and R.M.work
400KV	Chandrapur-HVDC CKT-I	18-Dec-10	09.29	18-Dec-10	11.40	To attend Hot Spot,Ckt on TBC II
400KV	Bhusawal- Aurangabad	18-Dec-10	22.51	19-Dec-10	06.01	Over Voltage
400KV	Dhule - S'Sarovar- II	18-Dec-10	23.09		Continued.	Over Voltage
400KV	Lonikand- Koyna Stage IV	18-Dec-10	23.21	19-Dec-10	07.30	Over Voltage
400KV	New Koyna - Koyna Stage IV - II	18-Dec-10	23.51	19-Dec-10	07.35	Over Voltage
400KV	400/220 KV 315 MVA ICT- II @ Chakan	18-Dec-10	23.06	18-Dec-10	23.46	Due to tripping of Volkaswagaon line
400KV	Karad - Kolhapur - I	19-Dec-10	19.30		Continued.	Over Voltage.
400KV	Kalwa - Padgha - I	19-Dec-10	09.13	19-Dec-10	19.44	Replacement of Faulty Disc Insulator & Rusted Earthwire.
400KV	Bhusawal- Aurangabad	19-Dec-10	22.10	20-Dec-10	05.56	Over Voltage.
400KV	Lonikand- Koyna Stage IV	19-Dec-10	22.34		Continued.	Over Voltage.
400KV	Karad-Lamboti	19-Dec-10	22.43		Continued.	Over Voltage.
400KV	Karad - Kolhapur - II	19-Dec-10	22.43	20-Dec-10	06.07	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	19-Dec-10	23.52		Continued.	Over Voltage.
220KV	220/100 125 MVA ICT - II @ Trombay	23-Aug-10	12.17	14-Dec-10	15.10	Dismantling of Old ICT & commissioning of New 200MVA ICT
220KV	Main Bus - II Talangde	6-Dec-10	10.35	13-Dec-10	09.47	Alignment of isolator and testing work for 400 KV Solapur.
220KV	Babaleshwar - Ranjangaon	12-Dec-10	23.01	13-Dec-10	01.25	Distance Protection.
220KV	Pedambe-Mahad	13-Dec-10	08.50	13-Dec-10	18.35	Replacement of Isolator.
220KV	Babaleshwar - Ranjangaon	13-Dec-10	10.02	13-Dec-10	22.34	Control ICT LOading.
220KV	Mudshini - Talangade - II	13-Dec-10	09.03	13-Dec-10	17.41	Replacement of Isolator.
220KV	Apta - Taloja	13-Dec-10	09.00	13-Dec-10	16.00	R.M.Work
220KV	220/132 KV 150 MVA T/F @ Boiser	13-Dec-10	09.12	13-Dec-10	15.40	Hot Spot and OLTC Work.
220KV	Vita-Maisal	13-Dec-10	13.38	14-Dec-10	03.10	Distance Protection.
220KV	Pophali - KDPH	13-Dec-10	19.27	13-Dec-10	20.30	Distance Protection.
220KV	Trombay - Tifil	13-Dec-10	20.06	14-Dec-10	00.21	R to B-Ph, Z-I.
220KV	Chandrapur - Chandrapur MIDC	13-Dec-10	14.38	13-Dec-10	16.43	To attend SF6 gas leakage of Main CB.Ckt.was on TBC.
220KV	Shendra-Jalna Ckt.	13-Dec-10	11.23	13-Dec-10	12.56	To attend sparking on Y-Ph Bus Isolator.
220KV	Paras - Akola - II	13-Dec-10	09.56	13-Dec-10	16.07	Main Bkr.Overhaul work.Ckt was on TBC.
220KV	Mudshingi - Chikodi	14-Dec-10	09.00	14-Dec-10	17.30	C.B.Work
220KV	220/100KV 125 MVA ICT- III @ Kalwa	14-Dec-10	08.39		Continued.	For Augumentation from 125MVA to 200MVA.
220KV	Talangade-Mudshingi-II	15-Dec-10	08.40	15-Dec-10	16.45	Insulator replacement
220KV	Babaleshwar - Chalisgaon	15-Dec-10	13.42		Continued.	Conversion of S/C to D/C(Six Month Outage.)
220KV	220/132 KV 150 MVA ICT - IV @ Bale	15-Dec-10	10.00	15-Dec-10	16.40	Q.M.Work
220KV	Boiser-Taps	15-Dec-10	13.42	15-Dec-10	14.11	Distance protection Z 1,B-E.
220KV	220/132 KV,200 MVA ICT-II At Chalisgaon	15-Dec-10	14.30	15-Dec-10	20.38	Tripped on R-E.F protection(Restricted E/F protection)
220KV	New Parli -Beed - II	15-Dec-10	10.30	15-Dec-10	13.20	Q.M.Work
220KV	Girwali - Parly - IV	15-Dec-10	09.02	15-Dec-10	21.58	Replacement of LAs and CTs under LES.
220KV	Badnera - Akola - I	15-Dec-10	22.52	18-Dec-10	12.25	To Attend Main CB Air Pressure Leakage Problem.Ckt on TBC.
220KV	Miraj-Maisal	16-Dec-10	04.26	16-Dec-10	05.10	Distance protection.
220KV	Vita-Maisal	16-Dec-10	04.26	16-Dec-10	05.10	Distance protection.
220KV	Uran-Kharghar-II	16-Dec-10	09.36	16-Dec-10	18.59	Isolator alignment work.
220KV	Nasik-Raymond	16-Dec-10	09.35	18-Dec-10	17.02	Relay Retrofitting Work.
220KV	220/100 KV 200 MVA ICT- I @ Kolshet	16-Dec-10	12.12	16-Dec-10	17.41	Tan delta measurement of bushing,CT and R.M.Work
220KV	220/22 KV 50 MVA T/F III at Kolshet	16-Dec-10	13.24	16-Dec-10	17.13	Oil top up work
220KV	Kalwa-Mulund-I	16-Dec-10	10.38	16-Dec-10	12.49	Taken on TBC to attend hot spot of 29A isolator.

220KV	220/132 KV 200 MVA ICT @ Kurkumb	16-Dec-10	09.10	16-Dec-10	17.10	'B'ph LA replacement.
220KV	Kandalgaon - Lonand	16-Dec-10	12.11	16-Dec-10	19.25	Distance protection Y ph.to earth,Zone-1
220KV	220/132KV 100 MVA ICT- I @ Parbhani	16-Dec-10	13.25	16-Dec-10	14.53	Oil top up.
220KV	Pedambe-Tambati	17-Dec-10	08.40	17-Dec-10	18.10	Replacement of Earth Wire
220KV	Mudshini - Talangade - II	17-Dec-10	09.50	17-Dec-10	19.05	Replacement of Insulators
220KV	220/22KV 50 MVA T/F- II @ Kandalgaon	17-Dec-10	10.51	17-Dec-10	13.33	To attend Oil Leakage
220KV	220/33 KV 50 MVA T/F I @ Boisar II	17-Dec-10	11.45	17-Dec-10	16.55	To attend Hot Spot
220KV	220/132KV 100MVA ICT-II at Parli-I	17-Dec-10	09.21	17-Dec-10	12.15	To attend Oil Leakage
220KV	220/66KV 150 MVA ICT- II @ Gadchandur	17-Dec-10	11.08	17-Dec-10	15.56	To attend Hot Spot
220KV	Kandalgaon-Lonand	18-Dec-10	05.30	18-Dec-10	05.55	Distance Protection
220KV	Apta-Nagothane	18-Dec-10	08.09	18-Dec-10	20.03	Replacement of Earthwire.
220KV	Pedambe - Tambati	18-Dec-10	08.30		Continued.	Overhauling of C B.
220KV	Babaleshwar - Bhenda	18-Dec-10	10.30	18-Dec-10	13.45	Replacement of Flashover Insulator String.
220KV	220/132 KV 200 MVA ICT-II @ Nagar.	18-Dec-10	10.55	18-Dec-10	16.40	Q.M.Work.
220KV	Chakan-Volkswagen	18-Dec-10	23.06	18-Dec-10	23.41	Distance Protection
220KV	Bus Coupler at Chakan	18-Dec-10	23.06	18-Dec-10	23.40	Due to tripping of Volkasgaon line
220KV	Kalwa - Borivali	19-Dec-10	06.44	19-Dec-10	11.22	Replacement of Old Jumper,R M Work.
220KV	Apta-Nagothane	19-Dec-10	08.11	19-Dec-10	21.05	Replacement of Earthwire.
220KV	Kandalgaon - Pirangut	19-Dec-10	08.16	19-Dec-10	18.55	Stringing of Earthwire.
220KV	Bhusawal-Chalisgaon-I	19-Dec-10	07.54	19-Dec-10	16.47	Line Work Loc. No.32 (For Deepnagar - Khadka Line).
220KV	Bhusawal-Chalisgaon-II	19-Dec-10	08.10	19-Dec-10	17.03	Line Work Loc. No.32 (For Deepnagar - Khadka Line).
220KV	Kandalgaon-Mhasale	19-Dec-10	10.25	19-Dec-10	12.25	Red Hot Work Attending Y Ph Bus Isolator.
220KV	Sahara-B'dying	19-Dec-10	03.55	19-Dec-10	07.45	Distnace Protection, Y Ph Decapping.
220KV	Airoli-Knowledge park-Nasik	19-Dec-10	07.20	19-Dec-10	08.11	Crow Fault.
220KV	Kandalgaon - ONGC	19-Dec-10	13.43	19-Dec-10	14.33	Distnace Protection,R Ph to E.
220KV	ONGC-TSS	19-Dec-10	13.43	19-Dec-10	18.10	R Ph L A Burst @ TSS End.
220KV	Tarapur - Zone - III	19-Dec-10	09.51	19-Dec-10	20.36	Repair Work of Main Bus Side Isolator.
132KV	Paras - Akot	13-Dec-10	17.57	13-Dec-10	18.20	Distance Protection.
132KV	Parbhani - Pathri	14-Dec-10	02.18	14-Dec-10	02.36	Distance Protection.
132KV	132/33KV,50 MVA T/F.I At Narayangaon	15-Dec-10	13.45	15-Dec-10	14.00	33KV GMRT Br B pole burst.Both T/F trip on Y and B ph.E/F.
132KV	132/33 KV,50 MVA T/F.II At Narayangaon.	15-Dec-10	13.45	15-Dec-10	14.05	33KV GMRT Br B pole burst.Both T/F trip on Y and B ph.E/F.
132KV	TBC AT 400KV Bhusawal-II	15-Dec-10	08.55	17-Dec-10	17.10	Replacement of Aux.bus isolator.
132KV	Phursungi-Kothrud	16-Dec-10	09.50	16-Dec-10	17.06	Line maintenance work.
132KV	132 KV Bus At Savda	16-Dec-10	12.20	16-Dec-10	13.50	Reconnection of 132KV isolator of 50 MVA T/F.
132KV	Boiser - MIDC	17-Dec-10	09.04	17-Dec-10	18.40	Replacement of Conductor
132KV	Harsul-I - Padegaon	17-Dec-10	11.00	17-Dec-10	15.10	Q.M.Work
100KV	Chinchwad - Talegaon	16-Dec-10	07.42	16-Dec-10	17.17	Tower erection work.
100KV	Kalwa-Kalyan	17-Dec-10	08.29	17-Dec-10	11.57	Bus Outage
100KV	Bus Section Breaker at Kalwa	17-Dec-10	08.36	17-Dec-10	11.50	Bay Maint.Work
132KV	Mundawa-Kalyani	1-Dec-10	12.48	1-Dec-10	13.20	132 KV Bus Bar Prot.operated.
132KV	Mundawa-Bharat forge	1-Dec-10	12.48	1-Dec-10	13.20	132 KV Bus Bar Prot.operated.
132KV	132/11 KV 16 MVA T/F @ Kalmeshwar	5-Dec-10	10.08	5-Dec-10	13.25	To Attend Main Bkr Air Lkg,ICT HV Side on TBC.