

LINE OUTAGES FOR THE WEEK

FROM 21-Feb-11 TO 27-Feb-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Dhule-Sar'Sarovar - I	18-Feb-11	23.27	21-Feb-11	08.34	Over Voltage
400KV	Chandrapur - Parli - I	18-Feb-11	16.45	25-Feb-11	18:35	Replacement of Damaged Pivot of 29 D Isolator.(Ckt is on TBC)
400KV	Dhule - S'Sarovar- II	19-Feb-11	23.15	21-Feb-11	11.00	Over Voltage
400KV	400/220 KV 300 MVA ICT-I @ Koradi	19-Feb-11	10.42	27-Feb-11	08.53	For Releasing Air from Air Releasing Plugs of R Phase
400KV	Kolhapur-Mapusa-II	20-Feb-11	21.47	21-Feb-11	09.16	Over Voltage
400KV	Wardha - Akola - I	20-Feb-11	21.58	21-Feb-11	08.47	Over Voltage
400KV	Karad - Kolhapur - II	20-Feb-11	08.49	21-Feb-11	11.00	Relay retrofitting work(ready for charging at 18.30Hrs)
400KV	Padgha -Tarapur - I	21-Feb-11	10.43	21-Feb-11	19.45	Preventive Maint.of C B & L A.
400KV	Main Bus-II @ Kolhapur	21-Feb-11	09.59	23-Feb-11	17.05	Alignment of Isolator.(3 Day's)
400KV	Bhusawal- Aurangabad	21-Feb-11	21.27	22-Feb-11	05.22	Over Voltage.
400KV	Kolhapur - Mapusa - I	21-Feb-11	21.56	22-Feb-11	09.06	Over Voltage.
400KV	Wardha - Akola - II	21-Feb-11	22.06	22-Feb-11	16.04	Over Voltage.
400KV	Karad - Kolhapur - I	21-Feb-11	21.56	21-Feb-11	07.19	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	21-Feb-11	23.15	26-Feb-11	06.37	Over Voltage.
400KV	Bhusawal- Aurangabad	22-Feb-11	20.53	23-Feb-11	03.32	Over Voltage.
400KV	Karad - Kolhapur - II	22-Feb-11	10.53	23-Feb-11	07.38	C T Replacement Ready for Charging @ 21.50 Hrs.
400KV	400/220 KV 315 MVA ICT- I @ Nagothane	22-Feb-11	14.27	22-Feb-11	15.59	Maintenance Work.
400KV	Padgha -Tarapur - I	22-Feb-11	09.07	22-Feb-11	21.04	Breakers Testing.
400KV	400/220 KV 315 MVA ICT-II @ Lonikand	22-Feb-11	23.09	23-Feb-11	05.51	Hot Spot Jaw of R Ph 29D L V Side Isolator.
400KV	Kolhapur - Mapusa - II	22-Feb-11	23.40	23-Feb-11	08.33	Over Voltage.
400KV	Wardha - Akola - I	23-Feb-11	00.04	23-Feb-11	07.26	Over Voltage.
400KV	Bhusawal- Aurangabad	23-Feb-11	21.32	24-Feb-11	05.17	Over Voltage.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	23-Feb-11	18.23	23-Feb-11	18.43	NDR
400KV	Kolhapur - Mapusa - II	23-Feb-11	23.10	24-Feb-11	09.38	Over Voltage.
400KV	400/220 KV 315 MVA ICT-II @ Chandrapur	23-Feb-11	11.52	23-Feb-11	13.23	To removed bird nest from LV side gantry.
400KV	Karad - Kolhapur - II	24-Feb-11	00.02	24-Feb-11	09.22	Over Voltage.
400KV	Lonikand - Jejuri	24-Feb-11	08.37		Continued.	Increasing height at crossing point,upto 03-03-2011.
400KV	Lonikand- Koyna Stage IV	24-Feb-11	10.10		Continued.	Increasing height at crossing point,upto 03-03-2011.
400KV	400/220 KV 315 MVA ICT-II @ Lonikand	24-Feb-11	08.10	24-Feb-11	11.11	Red Hot LV Side Isolator.
400KV	Koradi-Satpur	24-Feb-11	07.56	24-Feb-11	14.33	Maintenance work.
400KV	Karad - Kolhapur - I	24-Feb-11	23.00	25-Feb-11	09:04	Over Voltage.
400KV	Bhusawal- Aurangabad	24-Feb-11	23.20	25-Feb-11	07:02	Over Voltage
400KV	Kolhapur - Mapusa - I	24-Feb-11	23.03	25-Feb-11	08:52	Over Voltage.
400KV	Jejuri-Koyna STG-IV	24-Feb-11	10.10	25-Feb-11	00.21	Afterbunching.
400KV	400/6.9KV 80 MVA Stn T/F at Deepnagar.	24-Feb-11	11.02	24-Feb-11	16.26	R.M.Work.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	25-Feb-11	07:17	25-Feb-11	17:24	To attend Red Hot Spot.
400KV	Chandrapur - Parli - I	25-Feb-11	10:46	25-Feb-11	18:35	Connecting IPS Tube.
400KV	Bhusawal- Aurangabad	25-Feb-11	22.02		Continued	Over Voltage
400KV	Karad - Kolhapur - II	25-Feb-11	21.59	26-Feb-11	07.13	Taken on TBC at Kolhapur end
400KV	Kolhapur-Mapusa-II	25-Feb-11	22.57	26-Feb-11	09.25	Over Voltage
400KV	Dhule-Sar'Sarovar - I	25-Feb-11	22.59	27-Feb-11	07.47	Over Voltage
400KV	400/220KV,315MVA ICT-I at Karad	25-Feb-11	23.47	26-Feb-11	01.30	To attend Red Hot Spot
400KV	Bhusawal- Aurangabad	25-Feb-11	22:02	26-Feb-11	05:29	Over Voltage
400KV	Karad - Kolhapur - I	26-Feb-11	05.12	26-Feb-11	12.12	Distance Protection
400KV	C'pur-Parli II	26-Feb-11	12.17	26-Feb-11	13.15	Distance Protection

400KV	Karad - Kolhapur - I	26-Feb-11	22.03	27-Feb-11	07.16	Over Voltage
400KV	Dhule-Sar'Sarovar - II	26-Feb-11	23.07	27-Feb-11	14.14	Over Voltage
400KV	Kolhapur - Mapusa - I	26-Feb-11	23.04	27-Feb-11	09.23	Over Voltage
400KV	Bhusawal- Aurangabad	26-Feb-11	22.46	27-Feb-11	04.50	Over Voltage
400KV	Bhusawal- Aurangabad	27-Feb-11	21.30	28-Feb-11	04.37	Over Voltage
400KV	Dhule - S'Sarovar- II	27-Feb-11	18.07		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - II	27-Feb-11	21.08		Continued.	Over Voltage
400KV	Kalwa - Padgha - II	27-Feb-11	08.37	27-Feb-11	16.55	Replacement of LA
400KV	Karad-Kolhapur-II	27-Feb-11	23.49		Continued.	Over Voltage
220KV	Dhule-Chalisgaon	18-Jan-11	15.53	25-Feb-11	10:00	To control O/L Dhule ICT's.
220KV	220/132KV 50MVA ICT-I @Peth	4-Feb-11	08.45	27-Feb-11	14.45	Augmentation by 100MVA ICT
220KV	220/100KV, 200MVA T/F-IV at Kalwa	6-Feb-11	20.32	27-Feb-11	16.25	For Thermovision inspection
220KV	New Paras TPS - Chikhali - II	19-Feb-11	13.09	21-Feb-11	11.21	Breaker Overhaul work(Ckt is on TBC)
220KV	Koradi-Ambazari-I	20-Feb-11	18.43	21-Feb-11	11.33	To Control Koradi ICT Loading
220KV	Hingoli-Pusad	21-Feb-11	16.14	23-Feb-11	00.16	In View of 400 KV Koradi ICT-I Outage,To Control Load on Ict-II.
220KV	Pedambe-Mahad	21-Feb-11	08.50	21-Feb-11	19.37	Replacement of Insulators.
220KV	Pedambe - Pophali - II	21-Feb-11	09.30	21-Feb-11	11.10	Conductor Replacement of Isolator to Circuit Breaker.
220KV	220 KV Bus Coupler at Pedambe.	21-Feb-11	09.30	21-Feb-11	11.10	Conductor Replacement of Isolator to Circuit Breaker.
220KV	Trombay - Tata Tie - II	21-Feb-11	07.54	21-Feb-11	08.52	Maint. Work of C B.
220KV	Main Bus @ Halkarni	21-Feb-11	12.15	21-Feb-11	18.05	C T Replacement Work.
220KV	Lonikand-Kathapur	21-Feb-11	09.11	21-Feb-11	09.45	Dist.Prot.
220KV	Taloja-OCIL - 1	21-Feb-11	11.30	21-Feb-11	17.17	C V T Oil Leakage Attending.
220KV	Koradi-Ambazari-I	21-Feb-11	18.30	21-Feb-11	20.23	To Control Koradi ICT Loading.
220KV	Ambazari-Wardha	21-Feb-11	09.44	21-Feb-11	17.04	Making LILO Arrangement for Abhijeet Power.
220KV	Kalwa - Airoli - Knowledge Park.	21-Feb-11	12.30	21-Feb-11	18.55	Commissioning of Diff.Relay.
220KV	Khaperkheda - Wardha.	21-Feb-11	18.41	21-Feb-11	20.18	In View of 400 KV Koradi-I Outage,To Control Load on ICT-II.
220KV	TBC @ Jalna	21-Feb-11	11.15	24-Feb-11	17.00	Breaker Overhauling Work
220KV	Ambazari - Abhijeet	21-Feb-11	18.27	23-Feb-11	17.29	Due to Koradi ICT - I Outage.
220KV	BBLSR-Waluj	22-Feb-11	08.34	22-Feb-11	22.13	To Control Babaleshwar ICT IOADING.
220KV	Bale-Osmanbad	22-Feb-11	11.58	23-Feb-11	08.56	To Control Parli ICT Loading.
220KV	Mahad-Nagothane	22-Feb-11	08.48	22-Feb-11	18.35	Replacement of Faulty Disc Insulator.
220KV	Talangade - Mudshingi - I	22-Feb-11	08.54	22-Feb-11	17.09	Replacement of Insulator.
220KV	Bus Section - I @ Nasik GCR	22-Feb-11	09.46	22-Feb-11	16.50	Ten Delta Measurment of C T's.
220KV	Uran - HOCL	22-Feb-11	09.49	22-Feb-11	19.14	Replacement of Insulator.
220KV	Nagothane-IPCL	22-Feb-11	13.33	22-Feb-11	18.17	Hot Spot Attending.
220KV	Wardha-Badnera	22-Feb-11	10.11	22-Feb-11	15.15	Maintenance Work.
220KV	Khaperkheda - Wardha.	22-Feb-11	17.24	22-Feb-11	21.36	To Control ICT-II @ Koradi(ICT-I Outage)
220KV	Koradi-Ambazari-I	22-Feb-11	17.24	22-Feb-11	19.04	To Control ICT-II @ Koradi(ICT-I Outage)
220KV	Chinchwad-Parvati	22-Feb-11	22.40	23-Feb-11	06.05	Dut to Lonikand ICT-II Outage.
220KV	Lonikand-Ranjangaon	22-Feb-11	22.44	23-Feb-11	05.54	Dut to Lonikand ICT-II Outage.
220KV	Pusad-Parbhani	23-Feb-11	10.58	23-Feb-11	18.16	To Control Warora-Hinganghat line loading.
220KV	Mahad-Nagothane	23-Feb-11	08.50	23-Feb-11	18.25	Replacement of Insulator.
220KV	Jambhul - Anandnagar	23-Feb-11	10.06	23-Feb-11	16.21	Replacement of R-Ph damage conductor.
220KV	Aurangabad - Babaleshwar	23-Feb-11	09.03	24-Feb-11	21.20	To Control BBLSR ICT Loading.
220KV	Parli(Ext.)-Beed I	23-Feb-11	06.21	23-Feb-11	21.02	Stringing of 400 Kv B'vati-Parli PG Line.
220KV	Parly (Ext.) - Beed - II	23-Feb-11	06.19	23-Feb-11	21.10	Stringing of 400 Kv B'vati-Parli PG Line.
220KV	Lamboti - Pandharpur	23-Feb-11	12.34	23-Feb-11	14.35	R-Ph CT Red Hot.
220KV	220/100 KV 200 MVA T/F IV @ Apta	23-Feb-11	12.37	23-Feb-11	17.15	Testing Work.
220KV	Kalwa-Mulund II	23-Feb-11	12.16	23-Feb-11	15.30	Compressor Problem at Mulund.

220KV	220/110KV 100MVA T/F- I @ Miraj	23-Feb-11	18.50	23-Feb-11	23.20	Y-Ph LV Side LA Burst.
220KV	Warora-Wardha	23-Feb-11	10.45	23-Feb-11	18.55	To Provide Special Protection System.
220KV	Hingoli-Pusad	23-Feb-11	10.58	23-Feb-11	18.16	Koradi ICT-I Outage.
220KV	Bale-Usmanabad	23-Feb-11	22.52	25-Feb-11	04.33	To Control O/V.
220KV	Bale-Murud	23-Feb-11	22.52		Continued.	To Control O/V.
220KV	Wardha - Deoli (PGCIL)	23-Feb-11	09.38	23-Feb-11	15.31	Annual Maintenance Work.
220KV	220/132 KV 100 MVA ICT @ Parli - I	23-Feb-11	09.29	23-Feb-11	13.48	Red Hot.
220KV	220/132 KV 150 MVA ICT-I @ Akola.	24-Feb-11	00.43	24-Feb-11	02.19	To attend oil leakage from LV bushing.
220KV	Warora-Hinganghat	24-Feb-11	10.53	24-Feb-11	18.06	To provide SPS Protection Scheme.
220KV	Kalwa-Mulund II	24-Feb-11	12.25	24-Feb-11	19.57	Alignment of 29 D Isolator.
220KV	Karad-Mudsingi-IV	24-Feb-11	09.30	24-Feb-11	15.36	Insulator string replacement.
220KV	Chinchwad - Hinjewadi	24-Feb-11	11.16	24-Feb-11	17.33	Gantry erection for new T/F.
220KV	Khargar-Topworth	24-Feb-11	09.22	24-Feb-11	18.59	Replacement of Insulator.
220KV	Lonikand-Bhosari	24-Feb-11	09.50	24-Feb-11	19.30	LA Replacement Work.
220KV	Kandalgaon - Dasturi	24-Feb-11	09.10	24-Feb-11	19.30	LA Replacement Work.
220KV	Main Bus - I @ Ghodbunder	24-Feb-11	07.37	24-Feb-11	18.36	Annual Maintenance work.
220KV	Nasik-Padgha	24-Feb-11	09.47	24-Feb-11	17.47	CT Replacement Work.
220KV	220/7KV 40 MVA Main C.B. Stn T/F-II @ 220KV	24-Feb-11	15.35	24-Feb-11	16.44	Breaker testing work.(unit charged through TBC).
220KV	220/7 KV 40MVA Stn.T/F-I @ C'Pur	24-Feb-11	09.48	24-Feb-11	11.43	Breaker testing work.(unit charged through TBC).
220KV	220/132 KV 200 MVA ICT @ Kawlewada	24-Feb-11	19.53	24-Feb-11	18.21	Repair of Nitrogen Fire Protection system.
220KV	220/100 KV 200 MVA ICT-I at Raymond	24-Feb-11	09:38	26-Feb-11	11.40	Replacement of LA
220KV	Pophali - Kandalgaon - I	25-Feb-11	09:01	25-Feb-11	19:35	Replacement of disc insulator under LES.
220KV	Wardha-Abhijeet I	25-Feb-11	00.48	25-Feb-11	01.20	Wardha end only.
220KV	Wardha-Abhijeet II	25-Feb-11	00.48	25-Feb-11	02.38	R-Ph LA Burst.
220KV	Wardha - Yawatmal	25-Feb-11	00.48	25-Feb-11	04.18	R-Ph LA Burst.
220KV	Parli-Usmanabad	25-Feb-11	04.30	25-Feb-11	07.26	For Girvali ICT Loading.
220KV	220 KV Bus @ Kalwa	25-Feb-11	08:17	25-Feb-11	10:01	y-phase CT Bus coupler testing work.
220KV	Temghar-Colourchem	25-Feb-11	09:35	25-Feb-11	17:03	R/M Work.
220KV	Kamba - Kolshet	25-Feb-11	10:00	25-Feb-11	16:28	R/M Work.
220KV	Dhule - Malegaon	25-Feb-11	10:12	25-Feb-11	14:02	Replacement of Isolator.
220KV	Pophali - Pedambe - I	25-Feb-11	13.20	25-Feb-11	17.35	Maintenance work
220KV	Ghatghar - Washala	25-Feb-11	09:00	25-Feb-11	18:50	Relay testing work.
220KV	Ghatghar-Jindal	25-Feb-11	09.55	25-Feb-11	19.25	Annual Relay testing
220KV	Trombay-Kalwa	25-Feb-11	12.39	25-Feb-11	16.10	New Jumper work
220KV	Karad-Kolhapur-III	25-Feb-11	10:48	25-Feb-11	15:39	Insulator Replacement Work.
220KV	Karad-Wathar	25-Feb-11	10:48	25-Feb-11	15:39	Insulator String Replacement.
220KV	Bale-Usmanabad	25-Feb-11	06.25	26-Feb-11	20.58	Distance Protection(charged from U'bad end only)
220KV	Babhaleswar-Nasik-II	25-Feb-11	20.14	25-Feb-11	21.35	Bus Fault at Nasik
220KV	Nasik - Airoli - Knowledge Park	25-Feb-11	20.14	25-Feb-11	21.40	Bus Fault
220KV	Nasik - Ghatghar	25-Feb-11	20.14	25-Feb-11	22.24	Bus Fault
220KV	Babhaleswar-Nasik-I	25-Feb-11	20.14	25-Feb-11	21.29	Bus Fault at Nasik
220KV	220/132 KV,200MVA ICT-I at Nasik GCR	25-Feb-11	20.14	25-Feb-11	21.25	Bus Fault
220KV	220/132 KV 150 MVA ICT- II @ Nasik	25-Feb-11	20.14	25-Feb-11	21.28	Bus Fault
220KV	220/132KV 200MVA ICT-VI at Nasik GCR	25-Feb-11	20.14	25-Feb-11	21.48	Bus Fault
220KV	Uran - HOCL	25-Feb-11	09:41	25-Feb-11	16:42	Replacement of Insulator.
220KV	Bus Section-II Breaker at Nasik GCR	25-Feb-11	20.14	27-Feb-11	18.35	B Phase Breaker Burst
220KV	220 KV Main Bus - II at Nagothane.	25-Feb-11	11:04	25-Feb-11	23.04	Erection of Isolator.
220KV	220/132 KV 200 MVA T/F- I @ Boiser	25-Feb-11	11:10	25-Feb-11	12:10	Bus Isolator Maintenance work.
220KV	Chinchwad - Parvati	25-Feb-11	10:35	25-Feb-11	21:56	To control Lonikand ICT Loading.

220KV	Kalwa-Mulund II	25-Feb-11	07:46	25-Feb-11	16:10	Erection of cross arm.
220KV	Koradi-Ambazari-I	25-Feb-11	09.53	25-Feb-11	17.44	Replacement of E/W
220KV	Butibori-Indorama	25-Feb-11	12.15	25-Feb-11	15.40	Primary Injection of CT
220KV	Bus Coupler at Aurangabad	25-Feb-11	11.52	25-Feb-11	13.47	Comm.of Numerical Relay
220KV	220/33 KV 100 MVA ICT - I @ Jamde	25-Feb-11	10.10	25-Feb-11	14.25	For shifting of Incomer CT Conductor
220KV	220/132KV 200 MVA ICT- III @ Padegaon	25-Feb-11	10.15	25-Feb-11	16.03	To attend Oil Leakage and Q.M.work
220KV	220/33 KV 50 MVA T/F- II @ Yavatmal	25-Feb-11	14.09	25-Feb-11	17.15	Measurement of Tan Delta
220KV	220/33KV 50 MVA T/F - I @ Yavatmal	25-Feb-11	09.50	25-Feb-11	13.00	Measurement of Tan Delta
220KV	Hingoli-Pusad	25-Feb-11	01.00	25-Feb-11	04.23	To control L/L Bhugaon-Pusad
220KV	Dhule-Chaligaon	25-Feb-11	14.04		Continued.	To control Dhule ICT Load
220KV	220/33KV 50 MVA T/F @ Aurangabad	25-Feb-11	16.42	25-Feb-11	20.42	R phase LA Burst
220KV	Karad-Wathar	26-Feb-11	04.05	26-Feb-11	14.34	Distance Protection
220KV	Finolex - Kharepatan	26-Feb-11	14.10	26-Feb-11	15.15	Distance Protection
220KV	Pophali - Pedambe - II	26-Feb-11	08.05	26-Feb-11	15.40	R.M.Work
220KV	Apta-Taloja	26-Feb-11	09.46	26-Feb-11	18.28	Replacement of Insulator
220KV	Kandalgaon - Dasturi	26-Feb-11	09.10	26-Feb-11	18.30	Replacement of Insulator
220KV	Babaleshwar - Nagar - I	26-Feb-11	09.45	26-Feb-11	19.20	R phase 200KV CT Leakage
220KV	Mudshingi-Talangade - I	26-Feb-11	16.25	26-Feb-11	20.11	Replacement of quoted Insulator
220KV	Mudsungi-Amona	26-Feb-11	07.40	26-Feb-11	09.50	Distance Protection
220KV	220/22KV 50MVA T/F-I at Ranjangaon	26-Feb-11	14.55	26-Feb-11	15.07	Overload
220KV	220/22KV 50MVA T/F-II at Ranjangaon	26-Feb-11	14.55	26-Feb-11	15.28	Main Buchholz Oil Temp.trip
220KV	Bhandara - Sunflag - II	26-Feb-11	15.15	26-Feb-11	16.59	To attend Hot Spot
220KV	220/132 KV 150 MVA ICT-I @ Dhule	26-Feb-11	10.55		Continued.	Repl.of 150MVA ICT by 200MVA ICT
220KV	Koradi-Ambazari-I	26-Feb-11	08.37	26-Feb-11	18.49	Replacement of E/W
220KV	Aurangabad - Babaleshwar	26-Feb-11	08.21	28-Feb-11	04.50	To control BBLSR ICT load
220KV	Pophali-New Koyna	27-Feb-11	08.10	27-Feb-11	16.20	R.M.work
220KV	Kandalgaon - Dasturi	27-Feb-11	09.05	27-Feb-11	18.43	Replacement of Faulty Disc Insulator
220KV	Khargar-Topworth	27-Feb-11	09.50	27-Feb-11	18.30	Replacement of Insulator
220KV	Finolex - Kharepatan	27-Feb-11	17.39	27-Feb-11	19.32	Replacement of Insulator
220KV	Main Bus II @ Aarey	27-Feb-11	07.27	27-Feb-11	17.52	Annual Maint.work
132KV	Harangul - Latur - I	21-Feb-11	17.32	21-Feb-11	18.00	On Dist.Prot.Harangul End Only.
132KV	Harangul - Latur - II	21-Feb-11	17.32	21-Feb-11	21.30	Dist.Prot. R Ph. N.
132KV	Chikali - Dusar Bid	21-Feb-11	09.30	21-Feb-11	10.24	To Attend Hot Glow on R Ph Bkr Jumper @ Dusarbeed.
132KV	Chitegaon - Garware	21-Feb-11	12.30	21-Feb-11	18.07	Armouring Work @ Loc.No.40 @ 41.
132KV	Harangul - Latur - I	22-Feb-11	09.40	22-Feb-11	10.12	Dist.Prot.Operated Zone-I B Ph to E.
132KV	Jalna - Jalna MIDC	22-Feb-11	18.20	22-Feb-11	21.39	Dist.Prot.Operated Z-I B Ph @ Loc 18 Insulator String Damaged.
132KV	Paras - Warwat Bakal	23-Feb-11	23.22	24-Feb-11	02.26	Due to Akola ICT-I outage.
132KV	Akola-Akola MIDC	23-Feb-11	23.24	24-Feb-11	02.22	Due to Akola ICT-I outage.
132KV	Bhandara - Madgi - I	23-Feb-11	03.05	23-Feb-11	03.35	Distance Protection.
132KV	Bhandara - Madgi - I	23-Feb-11	05.05	23-Feb-11	05.16	Distance Protection.
132KV	Deepnagar - Jalgaon - I	26-Feb-11	10.15	26-Feb-11	10.58	Distance Protection
132KV	Deepnagar-Jalgaon-II	26-Feb-11	10.15	26-Feb-11	10.48	Distance Protection
132KV	Nanded - Umri	26-Feb-11	19.38	26-Feb-11	19.48	Distance protection
132KV	Bhusawal - Nimbhora	26-Feb-11	11.14	26-Feb-11	13.10	To attend Hot Spot
132KV	Paras-Akot	26-Feb-11	11.50	26-Feb-11	11.56	Over Current Protection
100KV	Kalwa-Washi	25-Feb-11	13.58	25-Feb-11	18.50	Stringing of New Ckt.
100KV	Kalwa-Standard	25-Feb-11	14.20	25-Feb-11	19.20	Conductor replacement
100KV	Vasai - Padgha	25-Feb-11	09.45	25-Feb-11	18.47	Stringing work of Interconnection
100KV	Tata - Borivali - II	26-Feb-11	08.45	26-Feb-11	23.16	Replacement of CT