

LINE OUTAGES FOR THE WEEK

FROM 21-Feb-11 TO 27-Feb-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE I -CHDPR	24-Mar-11	23.20	25-Mar-11	01.58	R ph.Conv.T/F testing work.
400KV	Dhule-Sar'Sarovar - I	14-Mar-11	23.35	21-Mar-11	12.31	Over Voltage
400KV	Kolhapur - Mapusa - I	19-Mar-11	23.43	21-Mar-11	10.46	Over Voltage.
400KV	Bhusawal- Aurangabad	20-Mar-11	10:00	21-Mar-11	04:38	H/T for O/V.
400KV	Dhule - S'Sarovar- II	20-Mar-11	13:55	23-Mar-11	07:15	H/T For O/V.
400KV	400/132KV 200 MVA ICT- I @ Bhusawal	20-Mar-11	13:42	23-Mar-11	13.50	Replacement of Main Bus I and II Isolator .
400KV	50 MVAR Reactor on 400KV Parli Ckt.I at C	21-Mar-11	17.15	26-Mar-11	05.28	OIL Filtration Work.
400KV	Akola - Wardha - I	21-Mar-11	00:30	21-Mar-11	10.06	H/T For O/V.
400KV	Karad - Kolhapur - I	21-Mar-11	01:14	21-Mar-11	07.15	H/T For O/V.
400KV	Bhusawal- Aurangabad	21-Mar-11	20.25	22-Mar-11	04.52	Over Voltage.
400KV	400/220KV,315 MVA ICT-I at Kolhapur.	21-Mar-11	20.27	21-Mar-11	22.47	Bus Bar Protection Operated at K'pur.
400KV	Bus Coupler @ 400 KV Kolhapur	21-Mar-11	20.27	21-Mar-11	23.33	Bus Bar Protection Operated at K'pur.
400KV	Karad - Kolhapur - I	21-Mar-11	20.27	21-Mar-11	22.20	Bus Bar Protection Operated at K'pur.
400KV	Kolhapur - Mapusa - I	21-Mar-11	20.27	22-Mar-11	07.57	Bus Bar Protection Operated at K'pur.
400KV	Chandrapur - Parli - I	21-Mar-11	16.50	21-Mar-11	17.15	To take reactor out at C'pur(4 days).
400KV	Main Bus - I @ Kolhapur	21-Mar-11	20.27	21-Mar-11	22.20	Bus Bar Protection Operated.
400KV	Akola - Wardha - II	21-Mar-11	11.03	21-Mar-11	20.33	Annual maintenance by PGCIL.
400KV	Karad-Kolhapur-II	21-Mar-11	23.56	22-Mar-11	07.20	Over Voltage.
400KV	Karad-Kolhapur-II	22-Mar-11	09.45	22-Mar-11	13.25	C T Replacement.
400KV	Dhule-Sar'Sarovar - I	22-Mar-11	00.15	22-Mar-11	06.40	Over Voltage.
400KV	Bhusawal- Aurangabad	22-Mar-11	20.16	23-Mar-11	04.57	Over Voltage.
400KV	Chandrapur - Parli - I	22-Mar-11	17.45	22-Mar-11	18.25	Direct Carrier Received.
400KV	Wardha - Akola - I	22-Mar-11	23.20	23-Mar-11	09.45	Over Voltage.
400KV	80 MVAR Reactor @ Kharghar	22-Mar-11	08.55	22-Mar-11	19:48	R.M. & Testing Work.
400KV	Akola - Wardh - II Main Breaker	22-Mar-11	10.14	22-Mar-11	21.38	Taken on Tie C B for Main C B Work.
400KV	Dhule-Sar'Sarovar - I	22-Mar-11	23.21	23-Mar-11	10.29	Over Voltage.
400KV	Kolhapur - Mapusa - II	22-Mar-11	23.25	23-Mar-11	07:14	Over Voltage.
400KV	400/220 KV 315 MVA ICT - II @ Koradi.	22-Mar-11	12.15	22-Mar-11	13.45	SF-6 Gas Filling,H V Side Taken on TBC.
400KV	Karad - Kolhapur - II	22-Mar-11	10.09	23-Mar-11	08.45	Y Ph C T Replacement.
400KV	Main Bus- I @ Nagothane	23-Mar-11	10.54	24-Mar-11	14.38	Exection of P G Isolator of Bus-I & IPS Tube.
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	23-Mar-11	10.09	23-Mar-11	18.42	To Attend Oil Leakage & Tan Delta & C Measurment.
400KV	Dhule-Sar'Sarovar - II	23-Mar-11	18.04	24-Mar-11	12.06	Over Voltage.
400KV	Bhusawal- Aurangabad	23-Mar-11	21.24	24-Mar-11	05.56	Over Voltage.
400KV	Kolhapur - Mapusa - I	23-Mar-11	22.16	24-Mar-11	10.44	Over Voltage
400KV	400/132KV 200 MVA ICT-II @ Bhusawal	23-Mar-11	13.42	23-Mar-11	13.50	Replacement of Main Bus I and II Isolator .(ICT LV side is on TBC)
400KV	Koradi - Kaparkheda	23-Mar-11	09.39	23-Mar-11	17.14	400 KV K'Kheda Main Bus-II Outage.
400KV	Chandrapur - Khaparkheda	23-Mar-11	09.33	23-Mar-11	16.26	400 KV K'Kheda Main Bus-II Outage.
400KV	400 KV Main Bus-II Khaparkheda	23-Mar-11	09.33	23-Mar-11	16.28	Throughing of Main Bus-II .
400KV	Akola - Wardha - II	23-Mar-11	22.16	24-Mar-11	09.52	Over Voltage.
400KV	400/220KV,100 MVA Spare Unit at Korady	23-Mar-11	11.45	24-Mar-11	13.02	Painting work.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	24-Mar-11	00.15	24-Mar-11	16.10	To disconnect R-Ph of ICT-II & install spare ICT as R-Ph unit.
400KV	Main Bus- I @ Jejuri	24-Mar-11	00.36	24-Mar-11	17.57	Remove Y-Ph jumper of spare ICT and connecting to R-Ph.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	24-Mar-11	16.28	24-Mar-11	18.14	Tertiary winding unloading problem.
400KV	Dhule - S'Sarovar- II	24-Mar-11	18.28	24-Mar-11	19.18	Over Voltage.
400KV	Kolhapur - Mapusa - II	24-Mar-11	22.51	25-Mar-11	08.33	Over Voltage

400KV	Akola - Wardha - I	24-Mar-11	22.55	25-Mar-11	06.30	Over Voltage
400KV	Dhule-Sar'Sarovar - I	24-Mar-11	22.55	25-Mar-11	12.12	Over Voltage.
400KV	Bhusawal- Aurangabad	24-Mar-11	22.15	25-Mar-11	17.16	Over Voltage
400KV	Chandrapur - Bhadravati - III	24-Mar-11	11.36	25-Mar-11	21.21	Bhadravati-Parli D.C.bay work.
400KV	50 MVAR 400KV Bus Reactor At 400KV Kd	24-Mar-11	08.20	24-Mar-11	17.35	Painting work.
400KV	Karad - Kolhapur - I	25-Mar-11	01.00	25-Mar-11	07.02	Over Voltage
400KV	Chandrapur - Bhadravati-IV	25-Mar-11	06.34	25-Mar-11	21.27	PGCIL work
400KV	Chandrapur - Parli - I	25-Mar-11	06.00	26-Mar-11	05.28	Replacement of R&B Phase CVT
400KV	Akola - Wardha - II	25-Mar-11	10.21	25-Mar-11	11.04	Distance protection.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	25-Mar-11	08.06	25-Mar-11	21.32	SFRA testing work.
400KV	C'pur-Parli II	25-Mar-11	17.58	25-Mar-11	18.34	Distance protection.
400KV	Dhule-Sar'Sarovar - II	25-Mar-11	18.02	26-Mar-11	07.43	Over Voltage.
400KV	Bhusawal- Aurangabad	25-Mar-11	18.04	26-Mar-11	05.20	Over Voltage.
400KV	Karad - Solapur (PGCIL)	25-Mar-11	19.17	26-Mar-11	00.11	To attend VT fuse failure.
400KV	Kolhapur-Mapusa-II	25-Mar-11	23.43	26-Mar-11	09.32	Over Voltage
400KV	Dhule-Sar'Sarovar - I	26-Mar-11	00.02	26-Mar-11	10.58	Over Voltage
400KV	Akola - Wardha - I	26-Mar-11	01.08	26-Mar-11	09.21	Over Voltage
400KV	Babaleshwar - Dhule - II	26-Mar-11	09.36	26-Mar-11	18.40	Attending Y ph.jumper.
400KV	Dabhol - New Koyna - I	26-Mar-11	12.06	26-Mar-11	12.25	Taken on TBC for SF6 gas filling.
400KV	Chandrapur-Bhadravati-II	26-Mar-11	10.09	26-Mar-11	22.05	PGCIL work of 400KV Bhadravati-Parli ckt.
400KV	Karad - Kolhapur - I	26-Mar-11	21.18	27-Mar-11	06.37	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	26-Mar-11	17.56	27-Mar-11	08.19	Over Voltage.
400KV	Bhusawal- Aurangabad	26-Mar-11	21.45	27-Mar-11	05.21	Over Voltage.
400KV	Akola - Wardha - II	27-Mar-11	23.20	27-Mar-11	07.12	Over Voltage
400KV	Newkoyna - Jaigad - I	27-Mar-11	02.00	27-Mar-11	04.13	Distance protection.
400KV	Kolhapur - Mapusa - I	27-Mar-11	23.08	27-Mar-11	08.14	Over Voltage
400KV	Bhusawal- Aurangabad	27-Mar-11	20.44	28-Mar-11	05.36	Over Voltage
400KV	Dhule - S'Sarovar- II	27-Mar-11	23.24		Continued.	Over Voltage
220KV	Tifil-Trombay	13-Feb-11	09.50	25-Mar-11	17.07	Stringing of New Ckt.Between loc.no.22-39 on New Towers.
220KV	Hingoli-Pusad	19-Mar-11	17.24	24-Mar-11	06.18	To control Wardha-Y'mal ckt loading.
220KV	Babaleshwar - Nagar - I	21-Mar-11	16.45	21-Mar-11	17.10	Distance Protection.
220KV	Wada-Kolshet	21-Mar-11	14.07	21-Mar-11	20.07	To replace distance protection relay.
220KV	Kharghar-TSS-Panvel	21-Mar-11	16.27	21-Mar-11	18.32	CRM measuring work(line on TBC).
220KV	Bus Section - I @ Pedambe	21-Mar-11	06.50	21-Mar-11	18.30	Main Bus Isolator work and Replacement of damaged insulators.
220KV	Pedambe-Newkoyna	21-Mar-11	06.34	21-Mar-11	18.50	For Pedambe Main Bus Outage.
220KV	Pedambe-Mahad	21-Mar-11	06.28	21-Mar-11	19.10	For Pedambe Main Bus Outage.
220KV	Pedambe-Pophali I	21-Mar-11	06.32	21-Mar-11	19.40	For Pedambe Main Bus Outage.
220KV	Main Bus at Tilwani	21-Mar-11	09.47	21-Mar-11	17.32	Replacement of PT.
220KV	Tilawni-Talangade-I	21-Mar-11	09.47	21-Mar-11	17.33	For Tilawani Bus Outage.
220KV	Tilwani - Talandge - II	21-Mar-11	09.45	21-Mar-11	17.34	For Tilawani Bus Outage.
220KV	Miraj - Tilwani	21-Mar-11	09.40	21-Mar-11	17.32	For Tilawani Bus Outage.
220KV	Chinchwad-Parvati	21-Mar-11	08.54	22-Mar-11	21.43	To control Lonikand ICT.
220KV	Bale-Murud	21-Mar-11	10.50	25-Mar-11	18.52	To control Parli ICT.
220KV	Bale-Osmanbad	21-Mar-11	10.50	25-Mar-11	18.52	To control Parli ICT.
220KV	Ambazari-Amravati	21-Mar-11	07.15	21-Mar-11	16.19	Construction of 765 KV SEONI-WARDHA CKT II LINE BY PGCIL.
220KV	Kanhan - Bhandara - II	21-Mar-11	08.56	21-Mar-11	17.25	Replacement of DISC insulators.
220KV	Pusad - Nanded	21-Mar-11	10.22	21-Mar-11	10.55	Distance Protection Operated Z-I,B-Ph E/F.
220KV	Miraj-Karad	22-Mar-11	09.45	22-Mar-11	13.25	Q.M.Work.
220KV	Karad-Oglewadi-I	22-Mar-11	11.47	22-Mar-11	12.47	Bus Outage.
220KV	Karad - Ogalewadi - II	22-Mar-11	11.47	22-Mar-11	12.47	Bus Outage.

220KV	Vankushwadi - MIDC Satara.	22-Mar-11	12.15	22-Mar-11	18.30	Annual Maint.Work.
220KV	Vankuswade-Malharpeth	22-Mar-11	11.45	22-Mar-11	17.45	Annual Maint.Work.
220KV	220/100KV 200MVA T/F - I at Apta	22-Mar-11	12.02	22-Mar-11	13.12	OLTC Bucloze Fault.
220KV	220/100KV 200MVA T/F - I at Apta	22-Mar-11	13.15	22-Mar-11	22.12	Internal Fault OLTC Bucholz.
220KV	Boiser - Tarapur	22-Mar-11	08.55	22-Mar-11	16.01	Zone - III Outage.
220KV	Miraj - Tilwani	22-Mar-11	14.00	22-Mar-11	18.00	Q.M.Work.
220KV	220/110 KV 200 MVA T/F @ Ogalewadi	22-Mar-11	11.47	22-Mar-11	16.09	Bus Outage.
220KV	220/110 KV 100 MAV T/F - I @ Ogalewadi	22-Mar-11	11.47	22-Mar-11	16.11	Bus Outage.
220KV	220/110 KV 100 MAV T/F - II @ Ogalewadi	22-Mar-11	11.47	22-Mar-11	16.14	Bus Outage.
220KV	Aurangabad - Babaleshwar	22-Mar-11	07.54	25-Mar-11	08.02	To Control Babaleshwar ICT Load.
220KV	Jambul - Pal	23-Mar-11	10.25	23-Mar-11	17.54	R.M.Work.
220KV	220/132 KV,200 MVA ICT @ Bale	23-Mar-11	10.05	23-Mar-11	13.42	Q.M.Work.
220KV	Dhule-Chalisgaon	23-Mar-11	12.48		Continued.	To Control Dhule ICT Loading.
220KV	220 KV Bus Coupler @ New Koyna	23-Mar-11	14.43	23-Mar-11	17.57	Testing Work.
220KV	220/22 KV 50 MVA T/F - II @ Chakan	23-Mar-11	11.38	23-Mar-11	13.26	Differential Protection.
220KV	Dhamangaon - Rly TSS - I	23-Mar-11	10.15	23-Mar-11	15.25	Replacement of O/C back up relay.
220KV	Dhamangaon-RLY TSS Ckt II	23-Mar-11	15.35	23-Mar-11	18.46	Replacement of O/C back up relay.
220KV	Badnera-Amravati	23-Mar-11	15.32	23-Mar-11	15.40	PDR Operated.
220KV	Hinganghat-Bhugaon	23-Mar-11	10.25	25-Mar-11	13.15	Main breaker O/H work.
220KV	Parbhani-Parli	24-Mar-11	06.37	24-Mar-11	16.27	Stringing of 400KV Bhadrawati-Parli PG crossing.
220KV	Chinchwad-Bhosari	24-Mar-11	07.05	24-Mar-11	19.14	Work of LILO arrangement for Chakan.
220KV	Bhosari-Telco	24-Mar-11	07.10	24-Mar-11	19.29	Work of LILO arrangement for Chakan.
220KV	220 KV Main Bus - II @ Jejuri.	24-Mar-11	10.30	24-Mar-11	20.04	Connecting new main bus-II to existing 220KV main bus-II.
220KV	Kandalgaon-Bhira	24-Mar-11	12.55	24-Mar-11	15.45	Tan delta measurement.
220KV	Mudshingi-Karad - IV	24-Mar-11	09.26	24-Mar-11	14.19	Replacement of insulator.
220KV	Mudsungi-Amona	24-Mar-11	08.47	24-Mar-11	10.40	PDR
220KV	22/6.6 KV,40 MVA Stn.T/F-I at Khaparkhed	24-Mar-11	08.06	24-Mar-11	16.12	Measurement of tan delta CT.
220KV	New Parli-Nanded	24-Mar-11	06.45	24-Mar-11	16.29	For erection of 220KV LA CC.
220KV	New Paras TPS-Alola-II	24-Mar-11	11.42	24-Mar-11	11.53	Distance protection.
220KV	Kalmeshwar-Ambazari	24-Mar-11	12.17	26-Mar-11	04.31	Distance protection.
220KV	Badnera - Deoli (PGCIL)	24-Mar-11	18.28	25-Mar-11	15.49	Distance protection.
220KV	220/132KV,200 MVA ICT-II at C'gaon	25-Mar-11	03.25	25-Mar-11	04.28	Bus bar protection operated
220KV	220/132 KV,200 MVA ICT-II At Chalisgaon	25-Mar-11	04.35	25-Mar-11	05.20	Bus Bar Prot.Operated
220KV	Pawas-Kharepatan	25-Mar-11	09.25	25-Mar-11	18.15	Replacement of bus insulator string of Bus section III.
220KV	Pedambe - Pophali - II	25-Mar-11	09.15	25-Mar-11	14.58	Attending hot spot.
220KV	Main Bus-II at Nagothane	25-Mar-11	10.43	25-Mar-11	20.50	Stringing of Bus.
220KV	Padgha - Nalasopara	25-Mar-11	11.14	26-Mar-11	07.58	Insulator replacement at Loc.No.101 and 104.
220KV	Uran-Kharghar-II	25-Mar-11	08.56	25-Mar-11	17.12	Attending hot spot and tan delta measurement.
220KV	Kharghar-Topworth	25-Mar-11	08.34	25-Mar-11	19.55	Earth wire replacement work.
220KV	Kandalgaon - ONGC	25-Mar-11	08.40	25-Mar-11	19.05	Earth wire replacement work.
220KV	Wada-Kolshet	25-Mar-11	11.45	25-Mar-11	19.40	Insulator replacement.
220KV	Ghodbandar-Versova-I	25-Mar-11	12.05	25-Mar-11	14.15	Jumper measurement.
220KV	Wadhkal-Ispat II	25-Mar-11	13.17	25-Mar-11	13.57	Hot line washing.
220KV	Bhigwan-BILT	25-Mar-11	09.50	25-Mar-11	16.45	Replacement of insulator.
220KV	Padgha-Jambhul	25-Mar-11	09.52	25-Mar-11	17.33	Attending hot spot.
220KV	Kandalgaon-Bhira	25-Mar-11	15.20	25-Mar-11	18.40	C.B.air leakage.
220KV	Kolhapur - Peth	25-Mar-11	18.40	25-Mar-11	18.55	Distance protection.
220KV	MUDSHINGI-CHIKODI	25-Mar-11	12.15	25-Mar-11	23.10	Wave trap replacement work.
220KV	Dhamangaon - Badnera	25-Mar-11	15.58	25-Mar-11	19.36	Relay retrofitting work.
220KV	Butibori-INOX	25-Mar-11	10.40	25-Mar-11	17.35	R.M.Work
220KV	Kaparkheda-Kalmeshwar	25-Mar-11	16.08	25-Mar-11	22.06	Distance protection.
220KV	220/7KV,6.5 MVA Stn.T/F-IV at Nasik GCR	25-Mar-11	09.00	25-Mar-11	16.30	Tan delta measurement.and R.M.work
220KV	Boiser - Tarapur	26-Mar-11	02.35	26-Mar-11	03.32	Over current.
220KV	Apta - Tambati	26-Mar-11	09.50	26-Mar-11	15.21	R.M.Work

220KV	220/132 KV 200 MVA ICT- II @ Boiser	26-Mar-11	02.28	26-Mar-11	08.40	Bus insulator flashover.
220KV	M'Peth -Vankuswade	26-Mar-11	12.25	26-Mar-11	19.15	Distance protection.Declared faulty.
220KV	Tarapur - Boiser	26-Mar-11	09.39	26-Mar-11	18.53	Maintenance work.
220KV	Khargar-Topworth	27-Mar-11	08.25	27-Mar-11	18.49	E/W replacement work
220KV	Boiser-Versova	27-Mar-11	07.32	27-Mar-11	13.05	R.M.Work
220KV	Kandalgaon - ONGC	27-Mar-11	08.30	27-Mar-11	18.41	E/W Stringing work
220KV	Kharghar-Nerul	27-Mar-11	07.20	27-Mar-11	14.30	Alignment of Isolator
220KV	Tarapur - Boiser	27-Mar-11	09.08	27-Mar-11	18.59	Relay Work
220KV	Trombay - Salsette - II Dharavi	27-Mar-11	08.35	27-Mar-11	20.20	Conductor Tighting work
220KV	Pusad - Nanded	27-Mar-11	09.25	27-Mar-11	15.40	Stringing of Bhadravati-Parli PG Crossing at Loc 373.374.
220KV	Parli Ext.-Nanded	27-Mar-11	09.22	27-Mar-11	16.24	Stringing of Bhadravati-Parli PG Crossing at Loc.373.374.
220KV	Chakan-Volkswagen	27-Mar-11	15.31	27-Mar-11	18.56	Stringing Work.
132KV	Chalisgaon - Manmad	19-Mar-11	23.55	21-Mar-11	08.40	R-Ph CT Burst.
132KV	Girwali - Latur MIDC	21-Mar-11	10.24	21-Mar-11	10.31	load trimming scheme operated - tripping of 220 kV Nanded-Pusad
132KV	Girwali - Gangakhed	21-Mar-11	10.24	21-Mar-11	10.30	load trimming scheme operated - tripping of 220 kV Nanded-Pusad
132KV	Girwali - Kej	21-Mar-11	10.24	21-Mar-11	10.33	load trimming scheme operated - tripping of 220 kV Nanded-Pusad
132KV	Nanded - Tamsa	21-Mar-11	10.25	21-Mar-11	10.55	To control PRL-Nanded line loading.
132KV	Dahanu - MIDC - II	23-Mar-11	09.10	23-Mar-11	15.20	Conductor Replacement.
132KV	Solapur - Naldurg	23-Mar-11	01.40	23-Mar-11	13.25	Distance Protection.
132KV	Amravati - Achalpur	23-Mar-11	19.14	23-Mar-11	19.20	Distance Protection.
132KV	Pachora - Chalisgaon - I	25-Mar-11	03.25	25-Mar-11	04.26	Bus bar protection operated
132KV	132 KV Bus at 220KV C'gaon	25-Mar-11	03.25	25-Mar-11	04.26	Bus bar protection operated.
132KV	Pachora-Chalisgaon Ckt.II.	25-Mar-11	03.25	25-Mar-11	04.30	Bus bar protection operated
132KV	Chalisgaon-Chalisgaon-I	25-Mar-11	03.25	25-Mar-11	06.05	Bus bar protection operated
132KV	Chalisgaon - Chalisgaon - II	25-Mar-11	03.25	25-Mar-11	04.28	Bus bar protection operated
132KV	Chalisgaon - Manmad - I	25-Mar-11	03.25	25-Mar-11	04.35	Bus bar protection operated
132KV	Chalisgaon-Pimpermhed	25-Mar-11	03.25	25-Mar-11	04.32	Bus bar protection operated
132KV	Chalisgaon - Kannad	25-Mar-11	03.25	25-Mar-11	06.05	Bus Bar Prot.operated
132KV	Chalisgaon - Dhule	25-Mar-11	03.25	25-Mar-11	08.25	bus Bar Prot.operated
132KV	132 KV Main Bus @ 220 KV C'gaon	25-Mar-11	04.35	25-Mar-11	05.15	Bus Bar Prot.Operated
132KV	Chalisgaon - Manmad - I	25-Mar-11	04.35	25-Mar-11	05.16	Bus Bar prot.operated
132KV	Pachora-Chalisgaon Ckt.II.	25-Mar-11	04.35	25-Mar-11	05.16	Bus Bar Prot.Operated at C'Gaon
132KV	Chalisgaon-Pimpermhed	25-Mar-11	04.35	25-Mar-11	05.30	Bus Bar prot.Operated
132KV	Pachora - Chalisgaon - I	25-Mar-11	04.35	25-Mar-11	05.15	Bus Bar Prot.Operated at C'Gaon
132KV	Boisar-MIDC	25-Mar-11	10.32	25-Mar-11	18.19	Hot spot attending work.
132KV	Chalisgaon - Chalisgaon - II	25-Mar-11	12.40	25-Mar-11	12.58	Bus bar protection operated
132KV	Chalisgaon - Dhule	25-Mar-11	12.40	25-Mar-11	13.00	Bus bar protection operated
132KV	Chalisgaon-Pimpermhed	25-Mar-11	12.40	25-Mar-11	12.59	Bus bar protection operated
132KV	Chalisgaon - Kannad	25-Mar-11	12.40	25-Mar-11	12.58	Bus bar protection operated
132KV	Pachora - Chalisgaon - I	25-Mar-11	12.40	25-Mar-11	12.57	Bus bar protection operated
132KV	Pachora-Chalisgaon Ckt.II.	25-Mar-11	12.40	25-Mar-11	12.57	Bus bar protection operated
132KV	132 KV Bus at 220KV C'gaon	25-Mar-11	12.40	25-Mar-11	13.00	Bus bar protection operated.
132KV	Chalisgaon - Manmad - I	25-Mar-11	12.44	26-Mar-11	03.05	R ph.CT replacement work.
132KV	Main Bus at 220KV Chitegaon	25-Mar-11	09.05	25-Mar-11	16.00	Connecting the bus isolator jumper.
100KV	Kandalgaon-Roha-I	22-Mar-11	11.12	22-Mar-11	15.06	Q.M.Work.
100KV	Kandalgaon-Roha-II	22-Mar-11	15.02	22-Mar-11	19.49	Tand Measurment.