

LINE OUTAGES FOR THE WEEK

FROM 25-Apr-11 TO 1-May-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	400/220 KV 315 MVA ICT - II @ Parli	21-Apr-11	23.01	28-Apr-11	10.39	To Attend L V Side Main Bkr.Problem.L V Side of ICT Taken on TB
400KV	Bhusawal- Aurangabad	24-Apr-11	21.02	25-Apr-11	05.32	Over Voltage.
400KV	Bablswr-Padgha Ckt I	24-Apr-11	17.54	25-Apr-11	09.38	Distance protection.
400KV	Dhule-Sar'Sarovar - I	24-Apr-11	17.36	26-Apr-11	09.40	Over Voltage.
400KV	Bhusawal- Aurangabad	25-Apr-11	21.54	26-Apr-11	06.00	Over Voltage
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	25-Apr-11	09.53	25-Apr-11	17.32	To attend Hot Spot
400KV	New Koyna - Jaigad - II	26-Apr-11	03.26	26-Apr-11	22.21	H/T due to sparking
400KV	Dhule-Sar'Sarovar - II	26-Apr-11	09.29	26-Apr-11	11.55	Distance Protection
400KV	Bhusawal- Aurangabad	26-Apr-11	22.59	27-Apr-11	06.14	Over Voltage
400KV	Dhule - S'Sarovar- II	26-Apr-11	23.00	27-Apr-11	11.04	Over Voltage
400KV	400 KV TBC - II @ Chandrapur	27-Apr-11	09.38	27-Apr-11	13.09	CRM Work of Breaker.
400KV	New Koyna - Jaigad - II	27-Apr-11	10.26	27-Apr-11	18.00	Alingment of Y Ph D Isolator.
400KV	Karad - Kolhapur - II	27-Apr-11	21.12	27-Apr-11	23.32	Red Hot @ Line Side Isolator IPS Tube Clamp.
400KV	Padgha -Tarapur - I	27-Apr-11	09.03	27-Apr-11	20.18	Annual Maint.Work @ Tarapur.
400KV	Kolhapur - Mapusa - I	27-Apr-11	15.45	27-Apr-11	21.20	Distance Protection.
400KV	Kolhapur-Mapusa-II	27-Apr-11	15.52	27-Apr-11	16.38	Distance Protection.
400KV	400/220 KV 315 MVA ICT - I @ Chakan	28-Apr-11	00.18	28-Apr-11	05.33	Replacement of 3 No's of Buchholz Relays.
400KV	Chandrapur - Khaparkheda	28-Apr-11	08.16	28-Apr-11	17.21	Ten Delta & C Measurment of C T's.
400KV	Padgha -Tarapur - I	28-Apr-11	08.50	28-Apr-11	20.01	Maint.Work. On TBC @ Padgha.
400KV	Parli-Lonikand -I	28-Apr-11	16.05	28-Apr-11	16.32	Distance Protection Operated R Ph.
400KV	Dhule-Sar'Sarovar - I	29-Apr-11	04.14	29-Apr-11	08.51	Over Voltage.
400KV	Main Bus- I @ Aurangabad	29-Apr-11	08.55	29-Apr-11	19.26	Replacement of PG isolator.
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	29-Apr-11	14.21	29-Apr-11	19.10	L.V.side.taken on TBC.CRM Work.
400KV	Bhusawal- Aurangabad	29-Apr-11	20.46	30-Apr-11	05.39	Over Voltage.
400KV	400/220KV,500 MVA ICT-III At A'bad.	29-Apr-11	10.20	29-Apr-11	19.42	Replacement of PG isolator.ICT on TBC.
400KV	Dhule-Sar'Sarovar - II	29-Apr-11	22.56	30-Apr-11	11.52	Over Voltage.
400KV	Kalwa - Padgha - I	30-Apr-11	05.26	30-Apr-11	06.03	Removing crow nest.
400KV	400/220KV 315MVA ICT-II @ BBLSR	30-Apr-11	11.25	30-May-11	15.00	For attending B ph.HV side CT oil leakage.
400KV	Koradi-Bhilai	30-Apr-11	17.43	30-Apr-11	18.04	No indication.
400KV	Dhule-Sar'Sarovar - I	30-Apr-11	22.19	1-May-11	11.11	Over Voltage.
400KV	400/220KV 315MVA ICT- I @ Chandrapur	30-Apr-11	09.27	30-Apr-11	15.44	Main breaker CRM work.(ICT HV side on TBC)
400KV	Karad - Kolhapur - II	1-May-11	17.18		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	1-May-11	20.39		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - II	1-May-11	17.37		Continued.	Over Voltage
400KV	Dhule - S'Sarovar- II	1-May-11	17.50		Continued.	Over Voltage
220KV	Borivali-Boisar	3-Apr-11	09.48	30-Apr-11	15.56	LILO work of 220KV Borivali-Boiser at 220KV Ghodbandar
220KV	Dhule-Chalisgaon	9-Apr-11	15.54	29-Apr-11	09.38	H/T to control Dhule ICTs over loading.
220KV	Chandrapur-Warora - I	17-Apr-11	15.00	26-Apr-11	13.55	To control Warora-Hinganghat line loading.
220KV	Hingoli-Pusad	18-Apr-11	13.07	1-May-11	10.39	To control Wardha-Yavatmal load
220KV	Babhaleshwar-Nasik-II	25-Apr-11	12.10	25-Apr-11	14.33	Distance Protection
220KV	Dhule-Chalisgaon	25-Apr-11	10.42	25-Apr-11	17.58	Line Isolator Alignment work
220KV	Shendra-Jalna Ckt.	25-Apr-11	11.52	25-Apr-11	15.54	Isolator Alignment work
220KV	Khaparkheda-Ambazari - I	25-Apr-11	11.02	25-Apr-11	12.40	Erection of Main Bus-II Isolator(Ckt is on TBC)
220KV	Wardha-Abhijeet II	25-Apr-11	17.04	1-May-11	10.39	To control Koradi ICT Load
220KV	Wardha-K'Kheda	25-Apr-11	18.58	26-Apr-11	10.14	To control Koradi ICT Load
220KV	Bale-Murud	26-Apr-11	11.41	29-Apr-11	10.34	To control Parli ICT Load
220KV	Bale-Usmanabad	26-Apr-11	11.41	29-Apr-11	10.34	To control Parli ICT Load

220KV	220/100 KV,200 MVA ICT-I @ Apta	26-Apr-11	09.45	26-Apr-11	19.00	Testing work
220KV	220/33 KV 50 MVA T/F- I @ Vita	26-Apr-11	10.28	26-Apr-11	12.30	Q.M.Work
220KV	220/33 KV,100 MVA ICT - I @ Ghatnandrai	26-Apr-11	10.47	26-Apr-11	12.21	Q.M.Work
220KV	Khaperkheda - Wardha.	26-Apr-11	13.10	1-May-11	10.33	To control Koradi ICT Load
220KV	220KV Main Bus - II @ Parly-I	26-Apr-11	10.41	26-Apr-11	11.25	Bus Bar Prot.operated
220KV	Parly - Harangool - II	26-Apr-11	10.41	26-Apr-11	11.28	Bus Bar Prot.Operated
220KV	Parly - Girwali - II	26-Apr-11	10.41	26-Apr-11	11.27	Bus Bar Prot.Operated
220KV	Parli GCR - Parli EXTN.II	26-Apr-11	10.41	26-Apr-11	11.27	Bus Bar Prot.Operated
220KV	Ambazari - Abhijeet	26-Apr-11	15.35	28-Apr-11	23.45	To Control Koradi ICT Loading.
220KV	Kolhapur-Sawantwadi	27-Apr-11	03.58	27-Apr-11	05.16	Distance Protection
220KV	KDPH-Wankuswadi	27-Apr-11	11.17	27-Apr-11	20.30	Breaker Overhauling Work of KDPH Unit-1.
220KV	Pophali - KDPH	27-Apr-11	11.15	27-Apr-11	20.30	Breaker Overhauling Work of KDPH Unit-1.
220KV	Main Bus @ Bale	27-Apr-11	09.10	27-Apr-11	18.10	R.M.Work.
220KV	Bale - Lamboti I	27-Apr-11	09.10	27-Apr-11	18.05	132KV Twin Bus Conversion Work
220KV	Bale-Lamboti II	27-Apr-11	09.10	27-Apr-11	18.05	132KV Twin Bus Conversion Work.
220KV	220/100 KV 200 MVA T/F IV @ Apta	27-Apr-11	13.00	27-Apr-11	17.00	Bus Bar Connection D C Supply Seperation Work.
220KV	Nasik-Navsari-I	27-Apr-11	08.10	27-Apr-11	20.33	C T Replacement Work @ Navasari.
220KV	Parli-Usmanabad	27-Apr-11	10.42	27-Apr-11	11.03	Distance Protection.
220KV	Parli-Usmanabad	27-Apr-11	11.10	27-Apr-11	15.26	Distance Protection.
220KV	Chinchwad-Parvati	27-Apr-11	12.49	27-Apr-11	12.55	Distance Protection.
220KV	Mumwadi - Halkarni - II	27-Apr-11	15.24	27-Apr-11	20.28	Distance Protection.
220KV	220 KV GIS Bus - II @ Aarey	27-Apr-11	07.21	30-Apr-11	22.30	GIS Bus-II Extension Work.
220KV	Chinchwad-Parvati	27-Apr-11	23.43	28-Apr-11	06:32	Due to outage on 400 KV Chakan ICT-I.
220KV	220/132KV 150 MVA ICT @ Ambazari.	27-Apr-11	10.01	27-Apr-11	14.08	Attending Oil Leakages from Top Plate.
220KV	220/132 KV 80 MVA ICT @ Hinganghat	27-Apr-11	11.15	27-Apr-11	13.50	Replacement of WT & OT Meters.
220KV	Main Bus - II @ Khaparkheda	27-Apr-11	11.37	27-Apr-11	15.30	Bus Bar Scheme Testing Work.
220KV	66 KV Main Bus @ Yavatmal	27-Apr-11	09.00	27-Apr-11	13.20	Maintainance Work.
220KV	Chandrapur-Warora - I	27-Apr-11	15.35		Continued.	To Control WRR-WRD & WRR-HGHAT Loading.
220KV	Bhosari - Chakan	28-Apr-11	00.18	28-Apr-11	05.36	Due to outage on 400 KV Chakan ICT-I.
220KV	Chinchwad-Theur	28-Apr-11	08.25	28-Apr-11	18.05	Making LILO Arangement on 220KV PRM Line for Jeor S/S.
220KV	Phursungi - Parvati	28-Apr-11	08.15	28-Apr-11	15.35	Making LILO Arengement on 220KV PRM Line for Jeor S/S.
220KV	Kandalgaon - Pirangut	28-Apr-11	09.00	28-Apr-11	18.41	Bus Outage @ Pirangut.
220KV	Pirangut-Hinjewadi	28-Apr-11	09.25	28-Apr-11	18.30	Bus Outage @ Pirangut.
220KV	Lonand - Baramati	28-Apr-11	10.10	28-Apr-11	13.55	Q.M.Work.
220KV	Lonikand -Theur - II	28-Apr-11	09.03	28-Apr-11	15.16	Q.M.Work.
220KV	Dhule-Dondaicha-II	28-Apr-11	11.17	28-Apr-11	17.25	Isolator Aligment Work.
220KV	220/132 KV 200 MVA ICT-III @ Phursungi	28-Apr-11	14.35	28-Apr-11	18.50	Replacement of Oil in OLTC.
220KV	220/132KV200MVA ICT IV @Phursungi	28-Apr-11	19.06	28-Apr-11	22.48	Oil Replacement Work.
220KV	Karkumbh-Jeur	28-Apr-11	13.29	28-Apr-11	17.20	Distance Protection.
220KV	Main Bus @ Pirngut	28-Apr-11	09.25	28-Apr-11	18.40	Replacement of B Ph Jump of 220KV Bus Section.
220KV	Magarpatta - Sirum	28-Apr-11	09.55	28-Apr-11	16.56	Q.M.Work.
220KV	Lamboti - Karkumb	28-Apr-11	13.29	28-Apr-11	14.20	Distance Protection.
220KV	Bus Coupler @ 400KV Bhusawal- II	28-Apr-11	14.33	29-Apr-11	22.25	Repl of Bus Isolators of 220KV Bus Coupler Bay
220KV	Wardha - Yawatmal	28-Apr-11	10.07	28-Apr-11	14.45	Retrofitting of Relays @ Yeotmal.
220KV	Dhule-Chalisgaon	29-Apr-11	13.19		Continued.	To control ICT loading.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	29-Apr-11	08.50	29-Apr-11	20.45	R.M.Work
220KV	Mahad-Nagothane	29-Apr-11	08.37	29-Apr-11	22.25	Replacement of damaged conductor.
220KV	Nasik-Bablsr - II	29-Apr-11	11.13	29-Apr-11	17.02	To attend red hot.
220KV						

220KV	Dhule - Malegaon	29-Apr-11	09.42	29-Apr-11	13.16	Isolator alignment work.
220KV	Kandalgaon - Pophali	30-Apr-11	09.05	1-May-11	23.08	LA replacemement.
220KV	220/132KV 200MVA ICT-V @ Nasik OCR	30-Apr-11	07.16		Continued.	Internal inspection and attending oil leakage.
220KV	220/132KV,150 MVA ICT-II at Nasik GCR	30-Apr-11	08.07	30-Apr-11	13.25	Tan delta and measurement of CTs and bay maintenance work.
220KV	Padgha - Jindal	30-Apr-11	10.03	30-Apr-11	20.34	R.M.Work.
220KV	Bus coupler at Babhaleshwar	30-Apr-11	11.20	30-May-11	15.03	For seperation of Bus-I and Bus-II at BBLSR.
220KV	Lamboti - Karkumb	30-Apr-11	12.48	30-Apr-11	13.12	Distance protection.
220KV	Karkumbh-Jeur	30-Apr-11	12.48	30-Apr-11	13.14	Distance protection
220KV	Bale-Murud	30-Apr-11	15.15		Continued.	To control Parly ICT.
220KV	Bale-Usmanabad	30-Apr-11	15.15		Continued.	To control Parly ICT.
220KV	Aarey-Versova-II	30-Apr-11	21.54	30-Apr-11	22.30	New GIS Bus-II extention work.
220KV	KDPH-Wankuswadi	1-May-11	15.15		Continued.	Y Phase LA Burst
220KV	Vita - Ghatnandre	1-May-11	14.58	1-May-11	15.30	Distance Protection
220KV	220/132 KV 200 MVA ICT- II @ Boiser	1-May-11	07.55	1-May-11	14.43	Q.M.Work
220KV	Aurangabad - Bhenda	1-May-11	12.50	1-May-11	13.14	Distance Protection
220KV	220/33KV 125 MVA T/F 4 at Ghodbandar	1-May-11	06.10		Continued.	Annual Maint.
132KV	Chikali - Dugar Bid	25-Apr-11	07.30	26-Apr-11	23.23	Erection of Tower.
132KV	Malegaon-Manmad	26-Apr-11	10.11	26-Apr-11	10.26	To attend Red Hot at Manmad
132KV	Rly TSS - Akola - II	26-Apr-11	11.30	26-Apr-11	15.24	For removal of Old Breakers at TSS Akola
132KV	Rly TSS - Akola - I	26-Apr-11	11.29	26-Apr-11	15.23	For removal of Old Breakers at TSS Akola
132KV	Ambazari - Amravati	26-Apr-11	11.15	26-Apr-11	14.35	Main Bus-II Isolator Dismantling work
132KV	Khadka-Malkapur	26-Apr-11	09.21	27-Apr-11	17.53	Replacement of Aux.Bus Isolator
132KV	Main Bus at Bale	27-Apr-11	09.10	27-Apr-11	16.12	132KV Twin Bus Conversion Work.
132KV	Harangul - Ujani - I	28-Apr-11	13.59	28-Apr-11	14.33	While Taking 132KV Cpacitor Bank in Service @ Ujani End.
132KV	Harangul-Ujani-II	28-Apr-11	13.59	28-Apr-11	14.25	While Taking 132KV Capacitor Bank in Service @ Ujani End.
132KV	Bus Section -II at Boiser	29-Apr-11	09.11	29-Apr-11	14.40	Replacement of PT under LES.
132KV	Palghar-Railway-II	29-Apr-11	11.33	29-Apr-11	19.30	Line maintenance work.
132KV	Girwali - Latur MIDC	30-Apr-11	14.35	30-Apr-11	15.20	Load trimming scheme operated at 400KV Girwali.
132KV	Giravali-Latur	30-Apr-11	14.35	30-Apr-11	15.19	Load trimming scheme operated at 400KV Girwali.
132KV	Giravali-Gangakhed	30-Apr-11	14.35	30-Apr-11	15.10	Load trimming scheme operated at 400KV Girwali.
132KV	Girwali - Kej	30-Apr-11	14.35	30-Apr-11	15.16	Load trimming scheme operated at 400KV Girwali.
132KV	Deepnagar - Jalgaon - I	1-May-11	16.58	1-May-11	17.03	Load Trimming Scheme operated at Deepnagar
132KV	Deepnagar-Jalgaon-II	1-May-11	16.58	1-May-11	17.04	Load Trimming Scheme operated at Deepnagar
132KV	Deepnagar-Nimbhora	1-May-11	16.58	1-May-11	17.13	Load Trimming Scheme operated at Deepnagar
132KV	Deepnagar - Yawal	1-May-11	16.58	1-May-11	17.17	Load Trimming Scheme operated at Deepnagar
132KV	Pusad - Gunj	1-May-11	07.07	1-May-11	07.17	Backup Protection Operated
110KV	Pedambe-- Ratnagiri	25-Apr-11	09.25	25-Apr-11	17.28	Insulator Washing
100KV	Kalwa-Kalyan	29-Apr-11	09.01	29-Apr-11	18.09	Conductor replacement work.
100KV	Kalwa-Nocil II	30-Apr-11	17.17	30-May-11	17.50	B ph.Earth fault.
132KV	Main Bus - II @ Bhusawal	18-Apr-11	10.10	20-Apr-11	21.07	Replacement of Single Conductor to Duuble Conductor of Stub Bus
132KV	Khapri - Besa	19-Apr-11	08.55	19-Apr-11	12.10	To attend Red Hot Spot
132KV	Chalisgaon - Kannad	20-Apr-11	20.15	20-Apr-11	20.20	Tripped on FTR
132KV	Chikhali - Mehakar	20-Apr-11	00.16	20-Apr-11	01.10	Y phase PT Burst at Mehkar S/S
132KV	Malegaon - Mehekar	20-Apr-11	00.16	20-Apr-11	02.15	Y Phase PT Burst at Mehkar S/S
132KV	Chinchwad-Baja Auto	21-Apr-11	08.30	21-Apr-11	17.01	Removing BusSection isolator for providing Bus Section Breaker.
132KV	Chinchwad-Rahatri	21-Apr-11	08.30	21-Apr-11	17.01	Removing BusSection isolator for providing Bus Section Breaker.
132KV	Chinchwad-Chakan	21-Apr-11	08.30	21-Apr-11	17.21	Removing BusSection isolator for providing Bus Section Breaker.
132KV	Paras-Malkapur	21-Apr-11	15.35	21-Apr-11	15.55	B-Ph PT fuse blown up.

132KV	Malkapur-Motala	21-Apr-11	15.35	21-Apr-11	15.53	B-Ph PT fuse blown up.
132KV	Malkapur-Bodwad	21-Apr-11	15.35	21-Apr-11	15.56	B-Ph PT fuse blown up.
132KV	Khadka-Malkapur	21-Apr-11	15.35	21-Apr-11	15.55	B-Ph PT fuse blown up.
132KV	Girwali - Kej	22-Apr-11	17.04	22-Apr-11	17.22	Distance Protection.
132KV	Girwali-Parli	23-Apr-11	01.30	23-Apr-11	07.25	D/P,R-Ph.
132KV	Ambazari-Khaperkheda - II	23-Apr-11	15.09	23-Apr-11	15.40	D/P,B/U E/F.
132KV	Ambazari-Manakapur Ckt.II	23-Apr-11	15.09	23-Apr-11	15.40	D/P,B/U E/F.
110KV	Borivali-Borivali (Borivali-Borivali-II)	22-Apr-11	12.45	22-Apr-11	18.40	Attending Hot Spot @ MSETCL End.
110KV	Borivali-Borivali Tata-II	24-Apr-11	09.10	24-Apr-11	16.04	To attend hot spot.
100KV	Kalwa - Salsette - II	5-Apr-11	10.56	22-Apr-11	08.42	From Kalwa End
100KV	Kalwa-Mukund I	21-Apr-11	11.44	21-Apr-11	12.07	B/Up protection.
100KV	Kalwa-Kalyan	22-Apr-11	08.48	22-Apr-11	12.45	Line Will be Open@Tata end Due to 110KV Bus Voltage @ Kalyan
100KV	Kalwa-Nocil I	22-Apr-11	10.06	22-Apr-11	10.35	Tripped on Bird Fault.
100KV	Kalwa-Nocil I	22-Apr-11	11.35	22-Apr-11	13.40	Replacement of Line Side B Ph Jumper.
132KV	Gangakhed - Kandhar	13-Apr-11	01.40	13-Apr-11	09.06	Distance Protection
132KV	Kanhan-Pardi	13-Apr-11	10.30	13-Apr-11	15.07	Q.M.Work.
132KV	Malkapur - Khamgaon	13-Apr-11	10.45	13-Apr-11	15.56	Replacement of Line Matching Unit.
132KV	Jalgaon - Dhrangaon	13-Apr-11	13.20	13-Apr-11	13.50	Distance Protection.
132KV	Pusad-Umarkhed	13-Apr-11	15.04	13-Apr-11	19.28	Stringing Work of 400KV Double Circuit Bhadrawati-Parli Line.
132KV	Talegaon-Arvi	13-Apr-11	10.10	13-Apr-11	12.25	For Attending Hot Spot on Line Isolator of Above Ckt.
132KV	Tiwsa-Talegaon Ckt.	13-Apr-11	12.45	13-Apr-11	14.20	For Attending Hot Spot on Line Isolator of Above Ckt.
132KV	Mankapur - Uppalwadi	13-Apr-11	10.15	13-Apr-11	15.39	Bus Section-I Maintainance Work @ Uppalwadi
132KV	Lonand - Phaltan - I	14-Apr-11	09.55	14-Apr-11	10.42	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Phaltan - II	14-Apr-11	09.55	14-Apr-11	10.15	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Veer	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Vai	14-Apr-11	09.55	14-Apr-11	10.13	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Polochem	14-Apr-11	09.54	14-Apr-11	10.14	Due to Occurenace @ 400KV Jejuri.
132KV	Lonand - Chavanoffwar	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/22 KV 50 MVA T/F - I @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/22 KV 50 MVA T/F - II @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/11 KV 25 MVA T/F - I @ Loanad	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	132/11 KV 25 MVA T/F - II @ Lonand	14-Apr-11	09.55	14-Apr-11	10.10	Due to Occurenace @ 400KV Jejuri
132KV	Bus Section -II at Boiser	15-Apr-11	07.20	15-Apr-11	17.00	132KV bus section-I insulator replacement.
132KV	Bus Section -I at Boiser	15-Apr-11	07.20	15-Apr-11	17.00	132KV bus insulator replacement work.
132KV	Butibori-MIDC Khapri	15-Apr-11	19.04	15-Apr-11	22.51	Dist.Prot.operated Z-I,B-Ph.
132KV	Beed - Beed	15-Apr-11	13.27	15-Apr-11	13.48	Dist.Prot.operated B-Ph.
132KV	Ujani-Umarga	17-Apr-11	17.55	17-Apr-11	18.55	Distance protection.
132KV	Chakur - Udgir	17-Apr-11	17.05	17-Apr-11	17.22	Distance protection.
132KV	Purna-Basmat	17-Apr-11	14.35	17-Apr-11	20.40	Distance protection.
132KV	Lalkhedi - Durgwada	17-Apr-11	09.07	17-Apr-11	09.15	Distance protection.
132KV	Harangul-Chakur	17-Apr-11	17.05	17-Apr-11	17.22	Distance protection
100KV	Chinchwad - Talegaon	11-Apr-11	16.37	11-Apr-11	19.15	Distance protection