

LINE OUTAGES FOR THE WEEK

FROM 23-Apr-12 TO 29-Apr-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Aux.Bus @ Kolhapur	27-Mar-12	12.51	29-Apr-12	19.15	Alignment and servicing of C bus pentagraph isolator.
400KV	Bhusawal- Aurangabad	21-Apr-12	17.06	23-Apr-12	08.21	Over Voltage
400KV	Dhule - S'Sarovar- II	22-Apr-12	16.18	24-Apr-12	10.49	Over Voltage
400KV	Kolhapur - Mapusa - I	23-Apr-12	00.35	23-Apr-12	10.08	Over Voltage
400KV	Bhusawal- Aurangabad	23-Apr-12	17.31	24-Apr-12	06.30	Over Voltage.
400KV	Kolhapur-Mapusa-II	23-Apr-12	17.15	24-Apr-12	09.37	Over Voltage.
400KV	Chandrapur - Khaparkheda	23-Apr-12	08.58	23-Apr-12	10.33	Distance Protection.
400KV	400/220KV,315 MVA ICT-I at Kolhapur.	23-Apr-12	09.05	23-Apr-12	20.43	Tan Delta Measurment of Bushing.
400KV	Newkoyna - Jaigad - I	23-Apr-12	10.16	23-Apr-12	15.32	Cold Line Insulator Washing.
400KV	Bhusawal- Aurangabad	24-Apr-12	17.02	25-Apr-12	07.37	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	24-Apr-12	15.06	25-Apr-12	18.30	Over Voltage.
400KV	Kolhapur - Mapusa - I	24-Apr-12	16.41	25-Apr-12	09.59	Over Voltage.
400KV	400/11 KV 80 MVA Station T/F 4A @ Deepn	24-Apr-12	05.20	25-Apr-12	10.28	For Fixing of Cladding Plates.
400KV	New Koyna - Jaigad - II	24-Apr-12	09.31	24-Apr-12	16.21	Cold Insulator Washing.
400KV	400/220KV 315MVA ICT-II @ New Koyna	24-Apr-12	11.14	24-Apr-12	14.57	Attending Hot Spot.
400KV	Dhule - Babhaleshwar - I	24-Apr-12	14.24	24-Apr-12	20.12	Distance Protection Zone-I.
400KV	400/220KV 500MVA ICT- III at Dhule	24-Apr-12	14.24	24-Apr-12	15.31	Back up Protection.
400KV	Bhusawal- Aurangabad	25-Apr-12	17.08	26-Apr-12	07.35	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	25-Apr-12	18.11		Continued.	Over Voltage.
400KV	Kolhapur - Mapusa - II	25-Apr-12	20.17	26-Apr-12	09.08	Over Voltage.
400KV	Karad - Newkoyna - I	25-Apr-12	23.14	27-Apr-12	20.15	Direct carrier fail indication.
400KV	400/220KV,315MVA ICT-I at Karad	25-Apr-12	23.18	26-Apr-12	11.51	While taking trial on Karad-N.Koyna I.
400KV	400/220 KV 500 MVA ICT - II @ Jejuri	26-Apr-12	01.52	26-Apr-12	16.20	Dismantling of R-Ph unit & taking spare ICT unit into service.
400KV	Kolhapur - Mapusa - I	26-Apr-12	17.58	28-Apr-12	11.07	Over Voltage.
400KV	Bhusawal- Aurangabad	26-Apr-12	16.45	27-Apr-12	06.30	Over Voltage.
400KV	Chandrapur-Bhadravti - I	26-Apr-12	09.27	26-Apr-12	15.33	Breaker timing,ckt.was on TBC.
400KV	Dhule - Babaleshwar - II	27-Apr-12	08.30	27-Apr-12	18.49	Q.M.Work
400KV	Dabhol - Nagothane - I	27-Apr-12	08.40	27-Apr-12	18.03	Bay maintenance and testing work
400KV	Bhusawal- Aurangabad	27-Apr-12	16.35	28-Apr-12	09.07	Over Voltage.
400KV	Karad-Jaigad II	28-Apr-12	15.18	28-Apr-12	22.47	Cold line Insulator washing
400KV	Bhusawal- Aurangabad	28-Apr-12	17.33		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - II	29-Apr-12	03:09	29-Apr-12	10.52	Over Voltage.
400KV	Chandrapur - Bhadravati - III	29-Apr-12	18.04		Continued.	Over Voltage
220KV	Padgha-Temghar I	16-Apr-12	10.36	28-Apr-12	11.20	To Control Padghe ICT Loading.
220KV	Phursungi - Theur	19-Apr-12	18.12	26-Apr-12	00.15	I/S To control ICT I loading of Jejuri.
220KV	Trombay-Mulund	23-Apr-12	05.43	23-Apr-12	06.30	Passing of Consignment of M/S.Godrej
220KV	Trombay-Kalwa	23-Apr-12	05.41	23-Apr-12	06.28	Passing of Consignment of M/S.Godrej
220KV	Talangade-Mudshingi-II	23-Apr-12	14.26	23-Apr-12	14.41	Distance Protection.
220KV	Miraj - Tilwani	23-Apr-12	10.07	23-Apr-12	15.32	For Attending Hot Spot on 220KV C B R Ph
220KV	220/110 KV 100 MVA T/F - II @ @ Wathar	23-Apr-12	09.15	23-Apr-12	12.45	Q.M.Work.
220KV	Uran - JNPT	23-Apr-12	10.28	23-Apr-12	17.14	String Insulator Replacement on Line.
220KV	220/110KV, 200MVA T/F-III at Mudshingi	23-Apr-12	10.01	23-Apr-12	15.23	Testing Work.
220KV	220/110KV 100 MVA ICT-II @ Miraj.	23-Apr-12	11.00	23-Apr-12	17.15	Q.M.Work.
220KV	Kalwa - Ghatghar	23-Apr-12	11.40	24-Apr-12	04.35	LILO Work @ 220KV Bapgaon S/S.
220KV	Ambazari-Amravati	23-Apr-12	07.55	25-Apr-12	15.57	Replacement of Line Insulator.
220KV	Dhule - Amalner	23-Apr-12	09.17	23-Apr-12	15.01	Stringing Work for Line Reorientation.
220KV	220/6.6 KV 40 MVA Station T/F - III @ Kora	23-Apr-12	13.20	23-Apr-12	15.53	ON TBC (Attending Air Leakage from Air Compressor).
220KV	Padgha - Temghar - II	24-Apr-12	17.56		Continued.	To Control Padgha ICT.

220KV	Dhule - Dondaicha	24-Apr-12	09.30	24-Apr-12	13.20	Line Stringing Work.
220KV	Dondaicha - Jamde - I	24-Apr-12	12.30	24-Apr-12	16.41	To Attend Red Hot on T & Y Ph. C T.
220KV	Karad - Ogalewadi - II	24-Apr-12	09.11	24-Apr-12	18.52	Conversion of Single String to Double String.
220KV	Pawas-Kharepatan	24-Apr-12	09.21	24-Apr-12	18.30	Cold Washing Insulator.
220KV	Bus Section - II @ Vita	24-Apr-12	10.00	24-Apr-12	12.35	Q.M.Work.
220KV	220/132 KV 100 MVA T/F - II @ Satara MID	24-Apr-12	10.30	24-Apr-12	17.15	Annual Maintenance.
220KV	220/110 KV 200 MVA ICT - II @ Miraj	24-Apr-12	11.07	24-Apr-12	15.25	Q.M.Work.
220KV	Aarey - Goregaon	25-Apr-12	05.11	25-Apr-12	12.16	Shifting of Control Panel.
220KV	Versova - Goregaon	25-Apr-12	05.11	25-Apr-12	12.16	Shifting of Control Panel.
220KV	Lamboti-Bale-II	25-Apr-12	07.46	25-Apr-12	15.13	Replacement of conductor.
220KV	Vita - Pandharpur	25-Apr-12	10.22	25-Apr-12	13.39	Q.M.Work
220KV	Pawas-Kharepatan	25-Apr-12	08.54	25-Apr-12	19.04	Cold washing of insulator.
220KV	Borivali (MSEB)- Borivali (T)	25-Apr-12	10.08	25-Apr-12	16.55	Attending hot spot.
220KV	Usmanabad-Barshi	25-Apr-12	10.44	25-Apr-12	17.36	Q.M.Work
220KV	Main Bus- I @ Lamboti	25-Apr-12	12.00	25-Apr-12	14.37	Q.M.Work
220KV	Vita - Lamboti	25-Apr-12	16.21	25-Apr-12	16.31	Distance Protection.
220KV	220/132KV 150 MVA ICT @ Ambazari.	25-Apr-12	09.36	25-Apr-12	11.32	Erection of Aux.isolator(HV Side).
220KV	Chandrapur - Warora	25-Apr-12	04.17	28-Apr-12	15.54	To avoid overloading of lines.
220KV	Tilawani-Miraj	26-Apr-12	04.32	26-Apr-12	05.08	Dist protection.
220KV	Jejuri (New) - Parvati	26-Apr-12	01.48	26-Apr-12	02.50	H/T from Parvati end,to control ICT I loading of Jejuri.
220KV	Theur-Jejuri	26-Apr-12	00.40	26-Apr-12	00.50	To control ICT I loading of Jejuri.
220KV	Babaleshwar - Alephata	26-Apr-12	09.56	26-Apr-12	19.12	Relay testing work.
220KV	Oni - Kharepatan	26-Apr-12	09.05	26-Apr-12	17.40	Cold line insulator washing work.
220KV	220/132KV 100MVA ICT-II at Ranjangaon	26-Apr-12	11.00	26-Apr-12	15.23	Q.M.Work
220KV	Pophali - KDPH	26-Apr-12	16.35	29-Apr-12	13.45	R-Ph CT Burst.
220KV	Talandge - Sawantwadi	26-Apr-12	16.32	26-Apr-12	19.09	Dist.Protection.
220KV	220/132KV 150 MVA ICT @ Ambazari.	26-Apr-12	09.30	26-Apr-12	22.35	Retrofitting of differential relay.
220KV	Pedambe - Mahad	27-Apr-12	06.15	27-Apr-12	17.04	Replacement of support insulator.
220KV	A'nagar-Pal	27-Apr-12	09.15	27-Apr-12	19.40	R.M.Work,tan delta measurement.
220KV	Wada-Kolshet	27-Apr-12	09.24	27-Apr-12	20.10	Erection and commissioning 220KV Bus-2 PT and PT isolator.
220KV	220/100 KV,100 MVA ICT-II at Vasai	27-Apr-12	10.04	27-Apr-12	16.35	Testing of ICT for taking on load.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	27-Apr-12	11.36	27-Apr-12	14.35	Attending hot spot.
220KV	Oni - Kharepatan	27-Apr-12	09.05	27-Apr-12	17.55	Cold washing of line insulator.
220KV	Valve-Jamde	27-Apr-12	10.15	27-Apr-12	11.50	Red hot on Y ph.and B .ph.CT
220KV	Dahanu-Versova	28-Apr-12	07.15	28-Apr-12	18.40	Q.M.Work
220KV	220/100 KV 200 MVA ICT II at Trombay	28-Apr-12	09.12	28-Apr-12	14.23	Hot Spot
220KV	220/132 KV 200 MVA ICT - I @ Babaleshwar	28-Apr-12	09.25	28-Apr-12	15.55	Q.M.Work
220KV	220/132KV 200MVA ICT-I @ Raymond	28-Apr-12	09.40	28-Apr-12	16.36	CT Oil Leakage
220KV	Babaleshwar - Nagar - I	28-Apr-12	09.00	28-Apr-12	20.21	Q.M.Work
220KV	Deepnagar - Bambhori	28-Apr-12	09.40	28-Apr-12	16.12	Hot Spot
220KV	Khadka-Bhadli-II	28-Apr-12	10.56	28-Apr-12	14.09	Replacement of LA
220KV	220/33KV 100 MVA T/F - III @ Jamde	28-Apr-12	09.13	28-Apr-12	10.44	Red Hot
220KV	Jejuri - Parvati	28-Apr-12	23:50	29-Apr-12	02:51	Y-ph CT replacement at Paravati S/S.
220KV	Tarapur - Borivali	29-Apr-12	09.54	29-Apr-12	14.26	Red Hot
220KV	Nasik-Navsari-I	29-Apr-12	08.28	29-Apr-12	14.53	Maint.work
220KV	Versova-Boiser	29-Apr-12	06.49	29-Apr-12	19.14	Replacement of Insulator String
220KV	Pedambe - Tambati	29-Apr-12	23.02	29-Apr-12	23.27	Distance Protection
132KV	Chalisgaon - Manmad	25-Apr-12	09.58	25-Apr-12	19.45	Faulty disc insulator replacement.
132KV	Akola - Paras - I	25-Apr-12	09.27	25-Apr-12	14.18	Repl.of Y & B Ph CC.

132KV	Paras-Malkapur	25-Apr-12	09.20	25-Apr-12	14.24	In view of 132 KV Paras-Akola I,outage.
132KV	Paras - Warwat Bakal	25-Apr-12	09.25	25-Apr-12	14.22	In view of 132 KV Paras-Akola I,outage.
132KV	Nanded - Umri	26-Apr-12	04.13	26-Apr-12	04.30	Dist.protection.
132KV	Boiser-Viraj-II	27-Apr-12	08.10	27-Apr-12	11.35	Attending hot spot on CT.
132KV	Dhule - Dhule	29-Apr-12	10.55	29-Apr-12	17.27	Backup Protection Operated
100KV	Creek side Bus at Kalwa	27-Apr-12	06.20	27-Apr-12	18.10	Conversion of old bus conductor from single core to twin core.