

LINE OUTAGES FOR THE WEEK

FROM 23-May-11 TO 29-May-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole I Padgha	23-May-11	04.11	24-May-11	07.27	Line fault 57.7 KM from Padgha end.
500KV	HVDC Pole I Padgha	25-May-11	05.59	25-May-11	08.31	Distance Protection
500KV	HVDC Pole I Padgha	26-May-11	05.30	26-May-11	13.24	Cold Washing of Insulator String of Pole-I.
500KV	HVDC Pole II Padgha	27-May-11	05.08	27-May-11	13.20	Cold Line Washing of Insulator.
500KV	HVDC Pole I Padgha	27-May-11	06.22	27-May-11	07.41	Line Fault.
500KV	Chandrapur - Padgha Pole-I	28-May-11	08.29	28-May-11	13.26	Cold washing of insulator.
400KV	400/220KV 105MVA Spare ICT @ Parly-II	22-Apr-11	13.50	25-May-11	11.30	To remove trip coil assembly for bus coupler.
400KV	Dhule-Sar'Sarovar - I	20-May-11	00.05	24-May-11	06.35	Over Voltage.
400KV	Bhusawal- Aurangabad	22-May-11	21.48	23-May-11	05.48	Over Voltage.
400KV	Padgha - Nagothane- II	22-May-11	14.35	23-May-11	01.45	Distance protection
400KV	Lonikand - Jejuri	23-May-11	04.02	23-May-11	06:34	Group AB,3-Ph trip.
400KV	New Koyna - Jaigad - II	23-May-11	02.45	23-May-11	03.29	Distance Protection.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	23-May-11	04.02	23-May-11	05:57	No indication.
400KV	Dabhol - New Koyna - I	23-May-11	05.38	23-May-11	06:38	Distance Protection.
400KV	Dabhol - New Koyna - I	23-May-11	08.41	23-May-11	20.34	Cold washing of insulator.
400KV	Main Bus-II at Waluj S/s.	23-May-11	10.30	23-May-11	17.50	stringing work from existing 400KV New Bhusawal I &II
400KV	400/132KV 200 MVA ICT-II @ Bhusawal	23-May-11	11.54	23-May-11	12.30	Wrapping of plastic paper cover on buchholz relay.
400KV	Newkoyna - Jaigad - I	23-May-11	10.57	23-May-11	18.59	Insulator cleaning work.
400KV	Lonikand-Karad	23-May-11	15.33	23-May-11	16.01	Distance protection.
400KV	400/132KV 200 MVA ICT- I @ Bhusawal	23-May-11	10.56	23-May-11	11.51	Wrapping of plastic paper cover on buchholz relay.
400KV	Bhusawal- Aurangabad	23-May-11	22.47	24-May-11	04.33	Over Voltage.
400KV	Kolhapur - Mapusa - I	23-May-11	09.58	24-May-11	08.11	CT and CVT connection tightening and Maint.work
400KV	Dhule-Sar'Sarovar - II	24-May-11	02.05	26-May-11	09.58	Over Voltage.
400KV	Dabhol - New Koyna - I	24-May-11	08.06	24-May-11	18.24	Cold washing of Insulator
400KV	Lonikand-Karad	24-May-11	08.13	24-May-11	17.54	Restrining of Loose overhead E/W
400KV	Bhusawal- Aurangabad	24-May-11	21.29	26-May-11	06.19	Over Voltage
400KV	Koradi-Satpur	25-May-11	01.56	25-May-11	12.37	Compressor Air Leakage(Line taken on TBC)
400KV	Lonikand - Parli - II	25-May-11	02.01	25-May-11	15.30	B phase CVT Fail at Lonikand end
400KV	Dabhol - NewKoyna - II	25-May-11	08.00	25-May-11	19.20	Insulator Replacement.
400KV	Main Bus - II @ Lamboti	25-May-11	10.15	25-May-11	14.31	Q.M.Work.
400KV	Kalwa - Lonikand	25-May-11	11.41	25-May-11	12.23	Distance Protection.
400KV	Newkoyna - Jaigad - I	25-May-11	14.11	25-May-11	17.47	Insulator Replacement.
400KV	400/220/33 KV 315 MVA ICT - I @ Akola	25-May-11	18.23	25-May-11	19.15	NDR.
400KV	Karad - Solapur (PGCIL)	25-May-11	15.30	25-May-11	16.13	For Line Recator Out.
400KV	400/220KV,500 MVA ICT-III At A'bad.	25-May-11	22.34	26-May-11	04.31	Tripped on NDR.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	26-May-11	00.09	26-May-11	06.08	Attending Oil Leakage of Y Ph ICT-I.
400KV	New Koyna - Dabhol - II	26-May-11	07.56	26-May-11	18.55	Cold Washing of Insulator.
400KV	Main Bus- I @ Jejuri	26-May-11	09.34	26-May-11	17.47	Testing Work.
400KV	Lonikand- Koyna Stage IV	26-May-11	18.10	26-May-11	18.34	Distance Protection.
400KV	400/220 KV 500 MVA ICT-II at Lamboti	26-May-11	17.40	26-May-11	23.46	NDR.
400KV	Bhusawal- Aurangabad	26-May-11	22.07	27-May-11	04.30	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	26-May-11	23.11	27-May-11	07.21	Over Voltage.
400KV	Kalwa - Lonikand	27-May-11	03.56	27-May-11	13.44	Distance Protection.
400KV	Padgha - Talegaon (PG)	27-May-11	04.23	27-May-11	10.58	Distance Protection.
400KV	400/220KV 315 MVA ICT-I @ Padgha	27-May-11	07.17	27-May-11	19.47	Replacement of 33 KV Bushings.
400KV	Dabhol - Nagothane - I	27-May-11	08.46	27-May-11	19.10	Cold line washing of insulator.
400KV	Bhusawal- Aurangabad	27-May-11	18.31	28-May-11	05.58	Over Voltage.

400KV	Lonikand- Koyna Stage IV	27-May-11	16.49	27-May-11	17.03	Distance protection.
400KV	Wardha - Seoni	27-May-11	08.36	27-May-11	19.49	Maintenance work.
400KV	Dabhol-Nagothane - II	27-May-11	11.53	27-May-11	12.29	Distance protection.
400KV	Dhule-Sar'Sarovar - I	28-May-11	00.44		Continued.	Over Voltage.
400KV	400/220 KV315 MVA ICT-I @ BBLR	28-May-11	00.54	30-May-11	13.30	Repair and inspection of R-Ph unit.(Up to 30.05.2011)
400KV	Kolhapur - Mapusa - I	28-May-11	01.52	28-May-11	09.04	Over Voltage.
400KV	Kalwa - Lonikand	28-May-11	06.19	28-May-11	06.41	Distance protection.
400KV	Bhusawal- Aurangabad	28-May-11	21.48	29-May-11	06.12	Over Voltage.
400KV	Dabhol - NewKoyna - II	28-May-11	08.34	28-May-11	17.54	Cold washing of insulators.
400KV	Chandrapur 400 KV HVDC-II	28-May-11	07.21	28-May-11	11.23	Attending Hot Spot on Y & B Ph,PG III isolator.
400KV	Wardha - Seoni	29-May-11	00.55	29-May-11	10.14	Over Voltage.
400KV	Kalwa - Lonikand	29-May-11	04.24	29-May-11	17.44	Distance protection.
400KV	Padgha - Talegaon (PG)	29-May-11	04.39	29-May-11	19.59	Distance protection.
400KV	Nagothane-Dabhol-I	29-May-11	07.35	29-May-11	20.00	Cold line washing of insulator string.
400KV	Karad - Kolhapur - II	29-May-11	18.27	30-May-11	10.07	Distance protection.
400KV	Akola - Wardha - I	29-May-11	09.24	30-May-11	13.14	Over Voltage.
220KV	Wardha-Abhijeet II	5-May-11	16.51	26-May-11	06.10	To Control Koradi ICT Load.
220KV	Padgha - Kalwa	10-May-11	09.30	25-May-11	21.11	System strenghtening work.
220KV	Temghar-Colourchem	10-May-11	10.30	25-May-11	20.57	Bunching of arrangement.
220KV	Abhijeet-Wardha-I	16-May-11	11.38	26-May-11	06.10	To control Koradi ICT loading.
220KV	220/132 KV 150 MVA T/F @ Boiser	22-May-11	22.57	25-May-11	15.32	Oil filtration work.(Taken on humming on dated 24/05/2011).
220KV	Apta-Uran-IV	23-May-11	04.02	23-May-11	12.04	Distance protection,R-Ph,E/F.
220KV	Pophali - KDPH	23-May-11	13.20	29-May-11	18.00	MOCB overhauling work at KDPH upto 28/05.2011.
220KV	Pedambe-Kharepatan	23-May-11	16.10	23-May-11	17.49	Tree cutting work.
220KV	220/100 KV 200 MVA T/F IV @ Apta	23-May-11	17.04	23-May-11	17.40	PRV leakage work.
220KV	Jejuri-Phursungi	23-May-11	15.13	23-May-11	15.43	Distance protection.
220KV	Ambazari-Amravati	23-May-11	09.00	23-May-11	14.24	Q.M.Work
220KV	Raymond-Washala	24-May-11	05.30	24-May-11	06.10	Line fault Y ph. to neutral.
220KV	Mudshingi-Wathar	24-May-11	10.00	24-May-11	12.16	Tan delta measurement
220KV	Nasik-Bablsr - II	24-May-11	09.12	24-May-11	13.07	Y phase CT Oil Leakage
220KV	Kandalgaon - ONGC	24-May-11	10.05	24-May-11	13.15	Repair of bus side Isolator
220KV	Mudshingi - Peth	24-May-11	14.58	24-May-11	17.20	Tan Delta measurement
220KV	Phursungi - Theur	24-May-11	08.32	24-May-11	18.50	E/W stringing work
220KV	Peth-Nigde	24-May-11	10.35	24-May-11	14.50	Q.M.Work
220KV	220/132 KV 200 MVA ICT @ Ambazari	24-May-11	10.48	24-May-11	13.29	For Alingement of Bus-III Isolator
220KV	Chinchwad - Parvati	25-May-11	01.28	25-May-11	09.56	Distance Protection (Declared Faulty)
220KV	Murud-Bale	25-May-11	08.00	25-May-11	18.05	Making LILO Arrangement for 220KV Tuljapur Line.
220KV	Dahanu - Ghodbandar - I	25-May-11	17.49	25-May-11	18.40	To Remove Foreign Material By Hot Sttek.
220KV	Usmanabad-Barshi	25-May-11	19.45	25-May-11	20.02	Distance Protection.
220KV	BBLSR-Waluj	25-May-11	13.55		Continued.	To Control Babaleshwar ICT Loading.
220KV	220/132 KV 100 MVA ICT @ Bhandara	25-May-11	07.20	25-May-11	12.51	Quarterly Maintainance Work.
220KV	Parbhani-Parli	26-May-11	06.09	26-May-11	19.21	Stringing Work OF 400KV Wardha-Parli PG D/C Line Crossing
220KV	Parli Ext.-Nanded	26-May-11	06.29	26-May-11	19.13	Stringing Work of 400KV Wardha-Parli.
220KV	Lonikand -Theur - II	26-May-11	10.33	26-May-11	19.50	Shifting of Line on New 220KV M/C Tower.
220KV	Kandalgaon - Lonand	26-May-11	09.00	26-May-11	14.28	Attending Red Hot Spot.
220KV	Apta-Bombay Dyeing	26-May-11	08.35	26-May-11	18.31	Overhauling of C B Drive Mechanism.
220KV	Nasik-Padgha	26-May-11	08.32		Continued.	Dismantling of Existing 2 Towers & Restrining on New Tower

220KV	Jindal - Ghatghar	26-May-11	09.05		Continued.	Dismantling of Existing 2 Towers & Restraining on New Tower
220KV	Kalwa-Mulund II	26-May-11	09.31	26-May-11	16.32	Red Hot.
220KV	Kandalgaon - Pirangut	26-May-11	19.18	26-May-11	19.35	Distance Protection.
220KV	Karad-Pedambe	26-May-11	15.17	26-May-11	15.57	Pole Discrpancy.
220KV	Talangade-Mudshingi-II	26-May-11	16.58	26-May-11	18.52	Distance Protection.
220KV	Pirangut - Hinjewadi - II	26-May-11	19.18	27-May-11	01.30	Distance Protection.
220KV	Hinjawadi-I - Hinjawadi-II	26-May-11	19.18	26-May-11	19.55	Distance Protection.
220KV	Kandalgaon - Sonalloy	26-May-11	13.17	26-May-11	13.35	Distance Protection.
220KV	220 KV TBC @ Koradi	26-May-11	08.30	26-May-11	17.10	Insulator Washing by Hotline Method.
220KV	Abhijeet-Wardha-I	26-May-11	08.36		Continued.	To Control Koradi ICT Loading.
220KV	Auxiliary Bus @ Koradi	26-May-11	08.30	26-May-11	17.10	Insulator Washing by Hotline Method.
220KV	Bus Section - I @ Pophali	27-May-11	05.30	27-May-11	16.50	Urgent Removal of Raft Entangade @ Entrance of Telrace Canel
220KV	Nasik-Navsari-I	27-May-11	08.30	27-May-11	17.15	Washing of Insulator.
220KV	Kandalgaon - Pophali	27-May-11	07.58	27-May-11	17.45	Taken out due to, Main Bus outage.
220KV	Trombay-Kalwa	27-May-11	09.35	27-May-11	17.56	Jumper nut bolt tightening and cross are painting.
220KV	Padgha - Nalasopara	27-May-11	10.43	27-May-11	17.16	Y-Ph Damaged conductor.
220KV	220/100 KV 200 MVA ICT- I @ Kolshet	27-May-11	10.52	27-May-11	18.19	R.M.Work
220KV	Ghodbandar-Varsowa	27-May-11	13.00	27-May-11	14.42	Hot Spot B-Ph.
220KV	Pedambe - Pophali	27-May-11	08.30	27-May-11	17.30	132 KV Main Bus outage.
220KV	Wardha - Deoli (PGCIL)	27-May-11	15.36	27-May-11	16.20	Distance protection,Z-I,B-Ph.
220KV	Badnera - Deoli (PGCIL)	27-May-11	15.43	27-May-11	16.15	Distance protection,Z-I,B-Ph.
220KV	Wardha-Abhijeet II	27-May-11	22.40	29-May-11	14.33	To control loading of Koradi ICTs.
220KV	220/132 KV 150 MVA T/F- I @ Boiser	27-May-11	09.35	27-May-11	11.10	Pipe replacement work.
220KV	Peth-Nigde	27-May-11	15.30	27-May-11	15.52	Distance protection.
220KV	Padgha - Boisar (PGCIL)	27-May-11	10.44	27-May-11	17.16	To shift load Nalasopara
220KV	Aarey-Borivali-II	28-May-11	06.08	28-May-11	07.27	Repl. of Y-Ph vibration damper
220KV	220 KV Main Bus - II @ 400 KV Kalwa	28-May-11	07.50	28-May-11	19.00	Premonsoon maintenance work and removing of crow nest.
220KV	Mudshingi-Talangade - I	28-May-11	10.00	28-May-11	14.50	Replacement of B-Ph LA.
220KV	220/132,200MVA Tr.-2 @ A' Nager	28-May-11	06.45	28-May-11	19.00	OLTC oil replacement.
220KV	220/100 KV,200 MVA,ICT at Pal	28-May-11	08.46	29-May-11	14.33	LV CB Overhauling work.
220KV	220/100KV, 200MVA T/F-IV at Kalwa	28-May-11	14.01	28-May-11	14.12	Back up protection.
220KV	Kalwa - Borivali	28-May-11	15.40	28-May-11	16.26	Distance protection.
220KV	A'nagar-Pal	28-May-11	12.06	28-May-11	14.46	Smoke observed in panel.
220KV	220/132KV 200 MVA ICT I at Chalisgaon	28-May-11	13.31	28-May-11	19.57	Attending oil leakage.
220KV	Khaperkheda - Wardha.	28-May-11	23.17	29-May-11	03.57	Distance protection,Z-I,R-Ph.
220KV	Trombay-Kalwa	28-May-11	08.58	28-May-11	12.38	29C.isolator work at Kalwa.
220KV	Borivali -Tarapur	29-May-11	08.47	29-May-11	16.41	Maintenance work.
220KV	Aarey-Borivali-I	29-May-11	08.53	29-May-11	13.34	R Ph.CVT replacement.
220KV	Kalwa-Nerul	29-May-11	12.32	29-May-11	12.45	Back up earth fault.
220KV	Trombay - Tifil	29-May-11	12.32	29-May-11	13.25	Distance protection.
220KV	Mahape-Tifil	29-May-11	12.32	29-May-11	13.05	Distance protection
220KV	Karad - Vita - I	29-May-11	17.30	29-May-11	18.06	Distance protection
220KV	Karad-M'peth	29-May-11	17.34	29-May-11	19.16	Distance protection
220KV	Vankuswade-Malharpeth	29-May-11	17.34	29-May-11	18.15	Distance protection
220KV	Vankushwadi - MIDC Satara - I	29-May-11	17.34	29-May-11	18.15	Distance protection
220KV	Vankuswadi - MIDC Satara- II	29-May-11	17.34	29-May-11	18.15	Distance protection
220KV	Vankuswadi-KDPH	29-May-11	17.34	30-May-11	16.50	Distance protection.Declared faulty.

220KV	Trombay - Tifil	29-May-11	14.29	29-May-11	17.11	Due to fire below line in M/S Yuvraj Industries premises.
220KV	Talangade - Mudshingi - I	29-May-11	19.44	30-May-11	13.45	Distance Protection. Declared faulty.
132KV	Malkapur - Bhusawal	22-May-11	13.00	23-May-11	12.28	Stringing work of 400 KV Deepnagar-Waluj D/C.
132KV	Khadka-Malkapur	22-May-11	10.18	23-May-11	14.46	Stringing work of 400 KV Deepnagar-Waluj D/C.
132KV	Partur-Mantha	23-May-11	10.10	23-May-11	17.25	Q.M.Work.
132KV	Hingna-Mankapur-I	23-May-11	22.07	24-May-11	00.51	Coupling Condensor Burst
132KV	Chalisgaon - Dhule	24-May-11	11.29	24-May-11	11.48	Distance Protection
132KV	Elichpur - Hingoli	25-May-11	18.30	26-May-11	16.00	Dist.Prot.Operated Z-I Y Ph. Dist 22.14.
132KV	Ardhapur-Kurunda	26-May-11	13.15	26-May-11	16.20	Dist.Prot. Operated R Ph 4.8 KM.
132KV	Solapur - Naldurg	26-May-11	20.37	27-May-11	13.55	Distance Protection Operated B Ph.
132KV	Padegaon-Pishor	27-May-11	09.35	27-May-11	14.16	Q.M.Work
132KV	Amravati - Akola	27-May-11	18.20	27-May-11	20.41	Distance protection,Z-I,R-Ph E/F.
132KV	Umri - Kundalwadi	27-May-11	18.06	27-May-11	18.28	Distance protection,B to E.
132KV	Karanja-Mangrulpir	27-May-11	14.53	27-May-11	15.47	Y-Ph conductor snapped.
132KV	Ambazari-Khaperkheda - II	28-May-11	17.03	28-May-11	17.57	Back up protection operated O/C & E/F.
132KV	Phursungi-Kamthali	28-May-11	07.39	28-May-11	18.10	Replacement of E/W.
132KV	A'nagar - Supa	28-May-11	08.28	28-May-11	10.25	Replacement of insulator.
132KV	Kanhan-Uppalwadi	28-May-11	17.25	28-May-11	17.40	Zone-I,Y-Ph.
132KV	Amravati - Akola	29-May-11	12.00	29-May-11	12.19	Distance protection,Z-I,R-Ph.
110KV	Bus Zone-II at 220 KV Salsette	29-May-11	00.34	29-May-11	04.45	Premansoon work.
110KV	Borivali-Tata Tie-I	29-May-11	08.40	29-May-11	16.23	Pre mansoon maintenance work.
100KV	Chinchwad - Talegaon	26-May-11	08.00	26-May-11	18.59	Maint.Work.
100KV	Kolshet-Vasai	27-May-11	09.49	27-May-11	16.25	R.M.Work
100KV	Kalwa-Kalyan	28-May-11	08.50	28-May-11	09.30	Trip,at Kalwa end.
100KV	Kalwa-Kalyan	28-May-11	11.26	28-May-11	11.54	Distance protection.
100KV	Kalwa-Mukund I	28-May-11	14.01	28-May-11	17.17	Bird fault.