

LINE OUTAGES FOR THE WEEK

FROM 21-May-12 TO 27-May-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	50 MVAR Line Reactor on 400 KV Parly Ck	22-Mar-12	11.00	26-May-12	07.19	High tan delta value of bushing.
400KV	Deepnagar-Aurangabad-I	12-May-12	15.47	21-May-12	10.03	PSB operated,Ready for Charging from 16.20 dt 12.05.2012
400KV	Seoni - Wardha -I	17-May-12	01.49	21-May-12	09.10	Over Voltage
400KV	Bhusawal- Aurangabad	20-May-12	21.43	21-May-12	07.18	Over Voltage
400KV	Kolhapur - Mapusa - I	20-May-12	17.58	21-May-12	08.27	Over Voltage
400KV	Jejuri-Koyna STG-IV	20-May-12	22.49	21-May-12	01.34	Distance Protection
400KV	Lonikand- Koyna Stage IV	20-May-12	23.07	21-May-12	11.31	Distance Protection
400KV	New Koyna-Karad-II	20-May-12	23.11	21-May-12	15.02	Distance Protection
400KV	New Koyna - Karad - I	21-May-12	00.19	21-May-12	01.40	Distance Protection
400KV	Bhusawal- Aurangabad	21-May-12	18.12	22-May-12	07.21	Over Voltage
400KV	Karad-Jaigad II	21-May-12	16.29	21-May-12	20.20	Cold Line Insulator washing
400KV	Kolhapur - Mapusa - I	21-May-12	17.56	22-May-12	09.25	Over Voltage
400KV	400/220 KV 315 MVA ICT-II @ Nagothane.	22-May-12	08.31	22-May-12	20.18	R .M.Work.
400KV	400/220 KV 315 MVA ICT- I @ Dhule	22-May-12	09.04	24-May-12	21:56	Removal of Old Conductor.
400KV	Newkoyna - Jaigad - I	22-May-12	09.21	22-May-12	13.58	Cold Line Insulator Washing.
400KV	Dabhol-Nagothane - II	22-May-12	13.04	22-May-12	13.44	Distance Protection.
400KV	New Koyna - Jaigad - II	22-May-12	14.56	22-May-12	19.00	Cold Line Insulator Washing.
400KV	Bhusawal- Aurangabad	22-May-12	18.16	23-May-12	06.11	Over Voltage.
400KV	Wardha - Seoni - I	22-May-12	08.59		Continued.	To Control Line Loading.
400KV	New Koyna-Karad-II	23-May-12	12.56	23-May-12	18.12	Insulator Replacement.
400KV	Padgha-Bhoisor (PGCIL)	23-May-12	09.58	23-May-12	19.14	Maint.Work.
400KV	Bhusawal- Aurangabad	23-May-12	18.07	24-May-12	06.24	Over Voltage.
400KV	400/220 KV,500 MVA ICT-I at Lamboti.	23-May-12	15.40	23-May-12	17.29	Hot Spot.
400KV	Dhabhol - Nagothane - I	23-May-12	21.45	23-May-12	23.02	Distance Protection.
400KV	New Koyna - Jaigad - II	24-May-12	04.12	24-May-12	04.41	Distanace Protection.
400KV	Dabhol - Nagothane - I	24-May-12	04.22	25-May-12	09.38	Distanace Protection,Decl.Faulty.
400KV	Newkoyna - Jaigad - I	24-May-12	04.37	24-May-12	15:37	Distanace Protection,Decl. Faulty.
400KV	New Koyna - Jaigad - II	24-May-12	15:51	24-May-12	21:44	Replacement of Insulator.
400KV	Lonikand - Jejuri	24-May-12	08:05	24-May-12	18:44	Testing work.
400KV	Akola - Wardha - II	24-May-12	13:44	24-May-12	21:47	Extension of Gantry beam of M/S APTCL bay and bus extension.
400KV	Main Bus-II at Akola	24-May-12	13:50	24-May-12	21:48	Extension of Gantry Beams of M/S APTCL Bay and bus extension.
400KV	Bhusawal- Aurangabad	24-May-12	18:00	25-May-12	07.28	Over Volatge.
400KV	New Koyna - Jaigad - II	25-May-12	02:40	25-May-12	03:05	Distanance Protection.
400KV	New Koyna - Jaigad - II	25-May-12	04:05	25-May-12	04:23	Distanance Protection.
400KV	Newkoyna - Jaigad - I	25-May-12	03:27	25-May-12	03:45	Distanance Protection.
400KV	New Koyna - Dabhol - I	25-May-12	06:14	25-May-12	15.08	Distance Protection.
400KV	Newkoyna - Jaigad - I	25-May-12	10.03	25-May-12	17.04	Replacement of insulator.
400KV	Akola - Aurangabad - I	25-May-12	08.34	25-May-12	08.56	H/T to taken out line reactor.
400KV	Bhusawal- Aurangabad	25-May-12	18.05	27-May-12	10.47	Over Voltage.
400KV	New Koyna-Jaigad II	25-May-12	17.10	25-May-12	23.04	To attend insulator decapping at various locations.
400KV	Akola - Bhusawal	25-May-12	09.47	26-May-12	07.19	R.M.Work.(Ready for charging on 25.05.2012 at 18.57 hrs.)
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	25-May-12	07.00	25-May-12	12.01	To attend hot spot.
400KV	Padgha - Kharghar	25-May-12	08.32	25-May-12	18.22	Repl.of B-Ph damaged jumper.
400KV	New Koyna - Jaigad - II	26-May-12	05.05	26-May-12	17.08	Y-Ph,E/F declared faulty.
400KV	Akola - Wardha - I	26-May-12	08.07		Continued.	765KV Koradi-Akola stringing work
400KV	Akola - Wardha - II	26-May-12	08.31		Continued.	765KV Koradi-Akola stringing work.
400KV	Kolhapur - Mapusa - I	26-May-12	18.05	27-May-12	09.31	Over Voltage.
400KV	400/220KV 500MVA ICT-III at Bableshwar	26-May-12	15.55		Continued.	Faulty cable replacement work.

400KV	Akola - Aurangabad - I	26-May-12	18.49	26-May-12	19.22	To take reactor in service at Akola end.
400KV	Kalwa-Kharghar	26-May-12	10.30	26-May-12	16.47	Hot spot attending work.
400KV	Newkoyna - Jaigad - I	27-May-12	08.05	27-May-12	20.34	Replacement of porcellain insulator with polymer.
400KV	Deepnagar-Aurangabad-I	27-May-12	10.52	27-May-12	15.35	Attending sparking problem.
400KV	Parly(PG) - Wardha (PG) - I	27-May-12	08.07		Continued.	To control load on Wardha-Deoli.
400KV	Parli (PG) - Wardha (PG) - II	27-May-12	08.28		Continued.	To control load on Wardha-Deoli.
400KV	Bhusawal- Aurangabad	27-May-12	16.16		Continued.	Over Voltage
400KV	Aurangabad-Deepnagar-II	27-May-12	18.18		Continued.	Over Voltage.
400KV	Kolhapur - Mapusa - I	27-May-12	17.29		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	27-May-12	00.13		Continued.	Over Voltage.
220KV	Nerul-Kharghar	19-Feb-12	07.50	21-May-12	17.52	Mumbai Strengthing work
220KV	Auxiliary Bus @ Babhleshwar	8-May-12	09.20	24-May-12	08:30	Conductor Replacement Work.
220KV	Pawas-Kharepatan	21-May-12	04.05	21-May-12	04.23	Distance Protection
220KV	Badnera - Deoli (PGCIL)	21-May-12	10.02	21-May-12	21.15	IPS Tube replacement at Deoli
220KV	Wardha - Deoli (PGCIL)	21-May-12	09.56	21-May-12	21.13	IPS Tube replacement at Deoli
220KV	Kharepatan-Pawas	21-May-12	09.20	21-May-12	16.54	Bus Outage
220KV	Apta-Kalwa	21-May-12	11.34	21-May-12	12.37	Distance Protection
220KV	Nivali-N'koyna	21-May-12	13.00	21-May-12	14.06	Distance Protection
220KV	Kharepatan-Pawas	22-May-12	03.05	22-May-12	03.36	Distance Protection
220KV	Vita - Karad II	22-May-12	10.11	22-May-12	14.37	Q.M.Work.
220KV	Pawas-Kharepatan	22-May-12	09.30	22-May-12	20.58	Outage.
220KV	Phursungi - Theur	22-May-12	12.50	22-May-12	16.35	Testing Work.
220KV	Miraj - Mhaisal	22-May-12	14.15	23-May-12	18:40	R.M.Work.
220KV	220/132 KV 100 MVA ICT - I @ Paranda	22-May-12	15.14	22-May-12	16.25	To Attend OLTC Problem.
220KV	220/132KV 100MVA ICT II at Paranda	22-May-12	15.54	22-May-12	16.27	To Attend OLTC Problem.
220KV	220/66 KV 150 MVA ICT- I @ Gadchandur	22-May-12	21.38	22-May-12	22.37	Tripped.
220KV	Vankuswadi-KDPH	23-May-12	03.30	23-May-12	12.20	Distance Protection.
220KV	Pophali - KDPH	23-May-12	03.30	23-May-12	04.15	Distance Protection.
220KV	Pedambe-Tambati	23-May-12	08.50	23-May-12	18.50	Replacement of Faulty Disc Insulator.
220KV	Miraj - Mhaisal	23-May-12	15.00	23-May-12	18.40	Replacement of B Ph. C T.
220KV	Badnera - Deoli (PGCIL)	23-May-12	11.42	23-May-12	12.27	Without Indication.
220KV	Vita - Lamboti	23-May-12	11.16	23-May-12	19.36	Due to Restraining Work of 132KV Pandarpur-Mangalwedha I & II.
220KV	Vita - Pandharpur	23-May-12	11.00	23-May-12	18.34	Due to Restraining Work of 132KV Pandarpur-Mangalwedha I & II.
220KV	Bus Coupler Bay @ Uran	23-May-12	11.16	23-May-12	17.41	Q.M.Work.
220KV	220/132 KV ICT @ Jeur	23-May-12	10.30	23-May-12	19.47	R.M.Work.
220KV	Khaparkheda-Ambazari - I	23-May-12	07.11	23-May-12	11.31	Removal of Auxilary Isolator & Jumper.
220KV	Kalmeshwar-RLY TSS-II	23-May-12	07.11	23-May-12	11.31	Quarterly Maintainance Work.
220KV	Amalner-Deepnagar	23-May-12	15.21	23-May-12	15.55	Distanace Protection,Z-I,B Ph.-E,@ Deepnagar End.
220KV	Lonikand - Bhosari	24-May-12	15:47	24-May-12	16:41	To take Auto recloser in service.
220KV	Chakan - Bhosari	24-May-12	16:36	24-May-12	17:56	To take Auto recloser in service.
220KV	Warora-Wardha	24-May-12	07:56	24-May-12	16:12	Stringing work of 400 KV Mouda - Wardha D/C.
220KV	Hinganghat-Bhugaon	24-May-12	07:56	24-May-12	16:19	Stringing work of 400 KV Mouda - Wardha D/C.
220KV	Karad-Pedambe	24-May-12	08:55	24-May-12	20:04	Restraining of Conductor.
220KV	Pedambe - Oni	24-May-12	09:10	24-May-12	16:30	Q. M. Work.
220KV	Bus - II at Phursungi.	24-May-12	09:15	24-May-12	18:10	Hot Spot.
220KV	Apta-Uran-IV	24-May-12	09:52	24-May-12	18:31	Q. M. Work.
220KV	Bus Section - I at Chinchwad.	24-May-12	11:12	24-May-12	14:29	Hot Spot.
220KV	220/100 KV,200MVA ICT - I at Padgha	24-May-12	10:29	24-May-12	19:18	Hot Spot.
220KV	Kalwa-Trombay	24-May-12	09:21	24-May-12	18:27	R. M. Work.

220KV	Usmanabad --Bale	24-May-12	11:38	24-May-12	19:48	Distanace Protection.
220KV	220/132 KV 200 MVA ICT - I @ Parbhani	24-May-12	09:34	24-May-12	11:51	PRV and Buchholz Terminal maintenance work.
220KV	220/132 KV 100 MVA ICT-II @ Parbhani	24-May-12	12:07	24-May-12	13:17	PRV and Buchholz Terminal maintenance work.
220KV	Dhule - Dondaicha	24-May-12	18:20	25-May-12	02:30	O/C, Y-ph - E, Jumper out from Wavetrap.
220KV	Sahara-B'dying	25-May-12	06:27	25-May-12	07:51	Distance Protection.
220KV	Padgha-Wada	25-May-12	10:39	25-May-12	18:00	Premansoon maintenance.
220KV	Kalwa-Taloja	25-May-12	09:05	25-May-12	17:05	R.M.Work
220KV	Apta-Uran-III	25-May-12	09:12	25-May-12	18:32	Removal of rusted.
220KV	Kalwa - Ghatghar	25-May-12	08:59	25-May-12	20:34	Old damage conductor.
220KV	220 KV Interconnector @ Kalwa	25-May-12	09:00	25-May-12	19:20	Replacement of CT.
220KV	Pedambe-Tambati	25-May-12	09:00	25-May-12	17:43	Repl.of damaged suspension clamp.
220KV	Khaperkheda - Koradi	25-May-12	10:16	25-May-12	17:50	Measurement of tan delta of CT and Bkr timings.
220KV	220/132KV 200MVA ICT-III at Padegaon	25-May-12	10:15	25-May-12	18:19	Half yearly maintenance.
220KV	Girwali - Parly - IV	25-May-12	06:54	25-May-12	13:11	Tightening of arching horn at Loc no 27.
220KV	Babaleshwar - Alephata	26-May-12	13:53		Continued.	To control load at BBLSR.
220KV	Jindal-Ghatghar	26-May-12	10:07	26-May-12	22:26	R.M.Work.
220KV	Pedambe - Mahad	26-May-12	08:48	26-May-12	17:48	Replacement of disc insulator.
220KV	220/132KV 150 MVA ICT II @ Nasik	26-May-12	10:00	26-May-12	12:10	R.M.Work
220KV	220/132 KV 200 MVA ICT - V @ Nasik (OC	26-May-12	08:30	26-May-12	12:20	Q.M.Work
220KV	Bale-Usmanabad	26-May-12	13:24	26-May-12	16:04	Testing work.
220KV	Bus Coupler at Varsova	27-May-12	08:09	27-May-12	19:56	Maintenance work.
220KV	Dahanu-Bhoisor	27-May-12	09:48	27-May-12	18:12	Breaker pole overhauling work.
132KV	Pandharpur - Mangalwedha - I & II	23-May-12	11:10	23-May-12	19:10	Restranging of Earthwire.
132KV	Jeur - Karjat	23-May-12	10:30	23-May-12	19:47	R.M.Work.
132KV	Main Bus @ Malinagar	23-May-12	10:20	23-May-12	14:40	Q.M.Work.
132KV	Bhandara-Mouda	23-May-12	11:56	23-May-12	12:12	Tripped @ Bhandara End Only,B/U,O/C,R Ph.-E.
132KV	Kanhan - Bhandara	23-May-12	11:56	23-May-12	12:15	Distanace Protection Z-I,R Ph. - E.
132KV	Ranjangaon - Kuruli	24-May-12	10:51	24-May-12	15:00	R. M. Work.
132KV	Chalisingaon-Dhule	24-May-12	11:40	25-May-12	10:17	Dist. Prot., Zone-1, R-ph, condr snapped at loc.no.38 and 39.
132KV	Bhusawal - Suprim	24-May-12	14:24	24-May-12	15:07	Dist. Prot., Zone - 1, 3 km. B-ph.
132KV	132/7 KV 31.5 MVA Station T/F- I at Bhusawal	24-May-12	14:24	24-May-12	14:51	Dist. Prot., Zone - 1,3 KM., B-ph.