

LINE OUTAGES FOR THE WEEK

FROM 21-Jun-10 TO 27-Jun-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole II Padgha	27-Jun-10	16.12	28-Jun-10	06.18	Tripped,Ready for Charging @ 00.21 Hrs dt 28.06.2010.
400KV	Akola - Aurangabad - II	12-Jun-10	23.02	25-Jun-10	14.09	Main Breaker Problem at A,Bad end
400KV	Dhule-S'Sarovar I	17-Jun-10	00.15	24-Jun-10	11.48	H/T for O/V
400KV	Lonikand - Chakan	19-Jun-10	20.37	21-Jun-10	18.27	Ready For Charging from dt 19/06/10.
400KV	Dhule-Sar'Sarovar - II	20-Jun-10	00.01	24-Jun-10	10.36	Over Voltage
400KV	Lonikand-Karad	20-Jun-10	20.32	21-Jun-10	18.40	For Over Voltage.
400KV	Karad-Kolhapur CKT II	20-Jun-10	20.36	22-Jun-10	10.46	For Over Voltage.
400KV	C'pur-Parli CKT .I	21-Jun-10	07.50	21-Jun-10	19.35	Replacement of Faulty Disc Insulator.Line is Ready for Charging.
400KV	400/220kv 315MVA ICT-II at Karad.	21-Jun-10	10.05	21-Jun-10	21.00	L A Replacement Work.
400KV	Bus Coupler @ Padgha	21-Jun-10	15.47	21-Jun-10	17.03	Tan'd Measurment.
400KV	C'pur-Parli CKT .I	22-Jun-10	07.39	22-Jun-10	19.53	Faulty insulator replacement.
400KV	Lonikand-Parli-I	22-Jun-10	08.53	22-Jun-10	21.04	Damper and Spacer replacement.
400KV	400/220KV 315MVA ICT-III at Karad.	22-Jun-10	10.38	22-Jun-10	18.50	L.A.replacement.
400KV	Koradi-Satpur	22-Jun-10	13.10	22-Jun-10	15.28	Trip from Sarni end,on Pole disceprency.
400KV	400 Kv HVDC AC-II at Padgha	22-Jun-10	09.31	22-Jun-10	21.54	Tan delta measurement of CT in tie Bus.
400KV	400/220KV 315MVA ICT-III at Karad.	22-Jun-10	22.47	22-Jun-10	23.20	To attend bus side isolator sparking.
400KV	C'pur-Parli CKT .I	23-Jun-10	06.47	24-Jun-10	19.41	Replacement of Insulator.
400KV	Lonikand - Parly - II	23-Jun-10	06.50	23-Jun-10	18.03	Spacer/Damper replacement.
400KV	Main Bus - I @ Lamboti.	23-Jun-10	10.14	23-Jun-10	17.46	Connection of IPS tube jumpers.
400KV	400 kv main Bus - II @ Bhusawal	23-Jun-10	11.45	23-Jun-10	18.04	Commissioning of 400/220 KV,105MVA Spare unit.
400KV	Karad-Kolhapur CKT I	23-Jun-10	01.27	23-Jun-10	09.41	H/T For O/V.
400KV	Dhule-Khandwa I	23-Jun-10	06.47	23-Jun-10	07.32	To take reactor I/S.
400KV	400 KV Bus Coupler @ Kalwa	23-Jun-10	15.45	23-Jun-10	18.38	Tan delta measurement.
400KV	Karad-Kolhapur-II	23-Jun-10	23.38	27-Jun-10	09.51	H/T For O/V.
400KV	Nagothane-Dabhol-I	24-Jun-10	17.22	24-Jun-10	19.03	CB problem at Dabhol.
400KV	Dhule-Sar'Sarovar - II	24-Jun-10	16.17		Continued.	H/T for O/V.
400KV	Karad-Lonikand.	24-Jun-10	15.01	24-Jun-10	16.21	Attending CB problem.
400KV	Nagothane-Dabhol-I	24-Jun-10	10.00	24-Jun-10	16.30	B Ph.CVT replacement.
400KV	Dhule-Sar'Sarovar - I	24-Jun-10	23.32	25-Jun-10	08.50	H/T for O/V
400KV	Lonikand-Karad	25-Jun-10	00.58	25-Jun-10	09.15	H/T for O/V.
400KV	Dhule-Sar'Sarovar - I	25-Jun-10	18.32	26-Jun-10	08.36	Over Voltage
400KV	Chandrapur - Parli - II	25-Jun-10	09.00	27-Jun-10	16.36	Replacement of Insulator,ready for charging at 17.59Hrs
400KV	Akola - Aurangabad - I	25-Jun-10	14.10		Continued.	To control Aurangabad ICT loading
400KV	400/220 KV,315 MVA ICT-II at Chandrapur	25-Jun-10	21.25	25-Jun-10	22.09	Bus Bar Prot.operated
400KV	Akola - Wardha - I	26-Jun-10	15.31	26-Jun-10	16.12	Distance Protection
400KV	400/220KV,315MVA ICT-I at Karad	26-Jun-10	11.03	26-Jun-10	18.35	LA replacement work
400KV	Dhule-Sar'Sarovar - I	26-Jun-10	17.37		Continued.	Over Voltage
400KV	400/220 KV 315 MVA ICT-II DHULE	26-Jun-10	10.01	26-Jun-10	20.10	Premansoon maint.and CT Tan Delta testing work
400KV	Bus coupler at Koradi	26-Jun-10	11.10		Continued.	Breaker repl.work of CT repl.removal of cable wiring.
400KV	Koradi - Kaparkheda	27-Jun-10	15.12	27-Jun-10	19.25	Tripped on Over Voltage.
400KV	Khaparkheda-Chandrapur.	27-Jun-10	15.12	27-Jun-10	19.25	Tripped on Over Voltage.
400KV	Koradi - Kaparkheda	27-Jun-10	23.08		Continued.	Over Voltage.
400KV	Khaparkheda-Chandrapur.	27-Jun-10	23.08		Continued.	Over Voltage.
400KV	Karad-Kolhapur CKT I	27-Jun-10	23.32		Continued.	Over Voltage.
400KV	C'pur-Parli II	27-Jun-10	23.43		Continued.	Over Voltage.

220KV	220/132 KV, 100 MVA -ICT @ Bale.	3-Jun-10	13.15	24-Jun-10	12.52	Augmentation of ICT by 200MVA
220KV	Khaparkheda-Kawlewada-II	20-Jun-10	16.04	21-Jun-10	10.43	Distance Protection,Z-2 B Ph E/F.
220KV	220/33 KV Tr.II at Kharghar	21-Jun-10	11.11	21-Jun-10	14.32	CRM,Relay Testing.
220KV	Apta-Kalwa	21-Jun-10	14.27	21-Jun-10	16.08	Insulator Replacement.
220KV	Kalwa-Mahape	21-Jun-10	09.25	21-Jun-10	13.53	Insulator Replacement.
220KV	Momewadi-Halkarni	21-Jun-10	08.32	21-Jun-10	16.50	LILo Work @ Halkarni.
220KV	HALKARNI-TILLARY	21-Jun-10	08.15	21-Jun-10	17.45	LILo Work @ Halkarni.
220KV	Chinchwad - Parvati	21-Jun-10	16.26	21-Jun-10	17.26	Dist.Prot.,Zone-I.
220KV	Bus section - I at Trombay	21-Jun-10	14.18	21-Jun-10	14.20	Bus Bar Protection Operated.
220KV	Bus-Sec-II at Trombay	21-Jun-10	14.18	21-Jun-10	14.20	Bus Bar Protection Operated.
220KV	Trombay - Sonkar	21-Jun-10	14.18	21-Jun-10	14.22	Bus Bar Protection Operated.
220KV	Trombay-Kalwa	21-Jun-10	14.18	21-Jun-10	14.20	Bus Bar Protection Operated.
220KV	Tifli-Trombay	21-Jun-10	14.18	21-Jun-10	14.23	Bus Bar Protection Operated.
220KV	220/100 125 MVA ICT - II @ Trombay	21-Jun-10	14.18	21-Jun-10	14.30	Bus Bar Protection Operated.
220KV	220/100 KV,125 MVA ICT-III at Trombay S/S.	21-Jun-10	14.18	21-Jun-10	14.32	Bus Bar Protection Operated.
220KV	KANHAN - BHANDARA CKT II	21-Jun-10	19.40	22-Jun-10	13.28	Distance Protection Z-I Y Ph E/F.
220KV	Kharghar-Nerul	22-Jun-10	08.59	22-Jun-10	13.37	Replacement of old insulator.
220KV	Mudshingi - Peth	22-Jun-10	12.30	22-Jun-10	16.16	Conductor replacement.
220KV	Bableshtar-Nasik-I	22-Jun-10	09.17	22-Jun-10	19.49	Insulator replacement.
220KV	220/100KV 200MVA ICT-II at Kolshet	22-Jun-10	13.30	22-Jun-10	17.32	SFRA test.
220KV	220KV Creekside Bus at Kalwa	22-Jun-10	13.04	22-Jun-10	13.44	B/B Prot.operated(Crow fault)
220KV	220/100KV 125 MVA ICT-I at Kalwa	22-Jun-10	13.04	22-Jun-10	13.44	B/B Prot.operated(Crow fault).
220KV	220/100KV 125 MVA ICT-II at Kalwa	22-Jun-10	13.04	22-Jun-10	13.47	B/B Prot.Operated(Crow fault)
220KV	Nasik-Kalwa	22-Jun-10	13.04	22-Jun-10	13.48	B/B Prot.Operated(Crow fault).
220KV	220 KV Interconnector at Kalwa	22-Jun-10	13.04	22-Jun-10	13.58	B/B Prot.Operated(Crow fault).
220KV	Wardha - Deoli (PGCIL)	22-Jun-10	13.10	22-Jun-10	15.07	Trip on Dist.Protection.
220KV	Badnera - Deoli (PGCIL)	22-Jun-10	13.10	22-Jun-10	15.07	Trip on Dist.Protection.
220KV	Khadka - Bhadli RLY - I	22-Jun-10	10.04	22-Jun-10	17.23	To attend Red Hot at Loc.no.42
220KV	Dhamangaon - Badnera	22-Jun-10	09.23	22-Jun-10	13.50	Fixing of repairs sleeves of R-Ph damaged conductor.
220KV	Khaparkheda - Kanhan - II	22-Jun-10	11.04	22-Jun-10	12.11	To remove E/W.
220KV	Khaparkheda - Kanhan - I	22-Jun-10	12.37	22-Jun-10	13.05	To remove E/w.
220KV	Bhugaon-Pusad	22-Jun-10	12.26	22-Jun-10	16.59	Replacement of Y-Ph CT.
220KV	Parli-Usmanabad	22-Jun-10	07.08	22-Jun-10	15.40	Q.M.Work and Repl.of LA.
220KV	Padgha-Kamba	23-Jun-10	02.52	23-Jun-10	03.23	Dist.prot.operated.
220KV	Padgha-Wada	23-Jun-10	02.56	23-Jun-10	03.16	Dist.prot.operated.
220KV	Nasik-Bablsr Ckt I	23-Jun-10	08.52	23-Jun-10	19.55	Insulator replacement.
220KV	Lonikand-Ranjangaon	23-Jun-10	10.10	23-Jun-10	12.52	To attend Hot Spot.
220KV	Kolhapur-Karad-IV	23-Jun-10	10.19	23-Jun-10	19.50	LA replacement.
220KV	220/132KV,150 MVA ICT at Ambazari.	23-Jun-10	10.48	23-Jun-10	14.16	Q.M.Work
220KV	220/132KV 200MVA ICT at Beed	23-Jun-10	09.09	23-Jun-10	11.25	Attending oil leakages of ICT.
220KV	220/132 kv,100 MVA ICT at Bhugaon.	23-Jun-10	12.40	23-Jun-10	17.00	Replacement of LA.
220KV	Virur - Gadchiroli	23-Jun-10	11.12	23-Jun-10	14.43	Q.M.Work
220KV	Kanhan - Bhandara - I	23-Jun-10	08.39	23-Jun-10	18.44	Replacement of Insulator string.
220KV	Hinjawadi-I - Hinjawadi-II	24-Jun-10	17.10	24-Jun-10	20.53	To attend sparking of coupling condenser.
220KV	Lonikand - Bhosari	24-Jun-10	07.58	24-Jun-10	18.53	Replacement of R Ph.L.A.
220KV	Chinchwad-Theur	24-Jun-10	09.38	24-Jun-10	18.19	Q.M.Work.
220KV	Nasik-Bablsr Ckt II	24-Jun-10	09.14	24-Jun-10	19.38	Insulator replacement.
220KV	Karad - Miraj	24-Jun-10	10.20	24-Jun-10	17.19	Replacement of L.A.
220KV	Jejuri-Phursungi	24-Jun-10	08.55	24-Jun-10	17.50	Breaker overhauling.
220KV	220/132 KV 200 MVA ICT @ Kurkumb	24-Jun-10	12.20	24-Jun-10	19.05	Testing work.

220KV	Bhandara-Kanhan ckt-I	24-Jun-10	07.00	24-Jun-10	16.32	Repl.of Insu.string.
220KV	New parly-Nanded	24-Jun-10	10.22	24-Jun-10	13.07	Q.M.Work
220KV	Nasik-Navsari-I	25-Jun-10	09.00	25-Jun-10	17.55	Maintenance work
220KV	Uran-Kharghar-II	25-Jun-10	09.06	25-Jun-10	20.12	Commissioning of Auto Recloser Scheme
220KV	Kalwa - Khargar	25-Jun-10	08.48	25-Jun-10	19.09	Replacement of Insulator
220KV	Karad - Vita - I	25-Jun-10	09.51	25-Jun-10	18.03	Testing work
220KV	Sonkar - Nerul	25-Jun-10	10.16	25-Jun-10	15.53	Red Hot
220KV	Wada-Kolshet	25-Jun-10	14.23	25-Jun-10	18.32	Testing Work
220KV	Mahad - Century Enka	25-Jun-10	18.30	25-Jun-10	20.02	Distance protection
220KV	Main Bus-II at Kharghar	25-Jun-10	11.22	25-Jun-10	19.02	Replacement of Jumper
220KV	Aurangabad-Chitegaon-II	25-Jun-10	06.47	25-Jun-10	20.32	Removal of E/W
220KV	Aurangabad-Chitegaon-I	25-Jun-10	06.43	25-Jun-10	20.11	Dismantling and restringing of ckt I&II and removal of E/W
220KV	Kanhan - Bhandara - I	25-Jun-10	06.58	25-Jun-10	16.22	Insulator replacement
220KV	Warora-Wardha Power CKT.II	25-Jun-10	21.22	25-Jun-10	22.55	Directional E/F relay operated
220KV	Chandrapur-Warora - I	25-Jun-10	21.25	25-Jun-10	22.20	Bus Bar protection Operated
220KV	C'pur-Sicom-I	25-Jun-10	21.25	26-Jun-10	19.57	Bus Bar Prot.operated,Y phase CT Burst.
220KV	C'pur-Sicom-II	25-Jun-10	21.25	25-Jun-10	22.04	Distance protection
220KV	Chandrapur-Gadchandur	25-Jun-10	21.25	25-Jun-10	22.18	Bus Bar prot.operated
220KV	Chandrapur MIDC - Gadchandur	25-Jun-10	21.28	25-Jun-10	22.05	Distance Protection
220KV	220 KV Main Bus - I @ Chandrapur.	25-Jun-10	21.25	25-Jun-10	22.01	Bus Bar Prot.operated
220KV	220/66KV 50MVA T/F at Chandrapur	25-Jun-10	21.25	25-Jun-10	22.05	Bus Bar prot.operated
220KV	Mudshingi - Peth	26-Jun-10	10.20	26-Jun-10	16.45	Replacement of CC at Peth end
220KV	Babaleshwar - Babaleshwar - II	26-Jun-10	09.25	26-Jun-10	17.53	Q.M.Work
220KV	Nasik-Navsari -II	26-Jun-10	08.45	26-Jun-10	17.51	Q.M.Work
220KV	Borivali-Boisar	26-Jun-10	15.30		Continued.	To control Bhoisor-Bhoisor(PGCIL)
220KV	Kalwa-Colourchem	26-Jun-10	13.31	26-Jun-10	13.41	Distance Protection
220KV	Kalwa-Padgha I	26-Jun-10	13.33	26-Jun-10	14.03	Distance Protection
220KV	Murud - Girawli.	26-Jun-10	08.41	26-Jun-10	15.02	To attending Hot Spot on B phase CT Clamp
132KV	Arvi-Talegaon	21-Jun-10	17.45	23-Jun-10	15.05	To Attend Main Bkr Trip Ckt Faulty Indication.
132KV	Harsool-Padegaon-Kagzipura	21-Jun-10	14.10	21-Jun-10	21.10	Breaker Overhaul.
132KV	Dhule-Dondaicha Ckt.I	22-Jun-10	14.30	22-Jun-10	14.55	Dist.Protection operated.
132KV	Harangul-Ujani Ckt.-I	23-Jun-10	05.45	23-Jun-10	06.00	Dist.protection operated.
132KV	Akola-Drugwada	24-Jun-10	15.42	24-Jun-10	16.23	Distance Protection
132KV	Mankapur - Uppalwadi	26-Jun-10	13.55	26-Jun-10	14.12	Distance protection
132KV	Kalmeshwar - Katol	26-Jun-10	16.17	26-Jun-10	16.43	Distance protection
132KV	Pachora - Chalisgaon CKT -I.	26-Jun-10	16.58	26-Jun-10	17.23	Distance Protection
132KV	Chalisgaon-Chalisgaon-I	26-Jun-10	09.10	26-Jun-10	11.37	Q.M.Work
220KV	Kalwa-Padgha I	20-Jun-10	08.35	20-Jun-10	18.10	Polymer Insulator Change Work.
220KV	Kharghar - Panvel	20-Jun-10	16.43	20-Jun-10	19.18	Distanace Protection, Y Ph E/F.
220KV	Lonikand-Ranjangaon	20-Jun-10	19.18	20-Jun-10	19.37	Distanace Protection.
132KV	132 KV Main Bus @ Amravati	14-Jun-10	07.08	14-Jun-10	11.38	Attending Bus Isolator of 132KV Achalpur Line.
132KV	Amravati-Morshi	14-Jun-10	23.05	15-Jun-10	13.55	Main Breaker Air Preaure Low,Ckt on TBC
132KV	A A Energy - Wadsa	14-Jun-10	01.17	14-Jun-10	01.55	Dist.Prot.
132KV	A A Energy - Wadsa	14-Jun-10	06.05	14-Jun-10	07.00	Dist.Prot.
132KV	Chikhali - Khamgaon	14-Jun-10	11.25	14-Jun-10	11.36	Transient Fault.
132KV	Mehkar - Malegaon	15-Jun-10	20.10	16-Jun-10	17.45	R-Ph LA burst at Mehkar.
132KV	Paras-Patur	15-Jun-10	20.10	15-Jun-10	20.32	Dist.Protection
132KV	M.B.I at 132 KV Bale	16-Jun-10	09.20	16-Jun-10	14.40	Jumpering and Testing work
132KV	Bhandara-Mouda	17-Jun-10	06.52	17-Jun-10	07.16	Tripped.
132KV	Kanhan - Mouda	17-Jun-10	06.52	17-Jun-10	07.16	Tripped.
132KV	Khadka-Malkapur	17-Jun-10	16.40	17-Jun-10	16.45	Tripped at both end due to heavy lightning
132KV	Kanhan-Pardi	17-Jun-10	17.07	18-Jun-10	12.50	B PH.burst at Pardi end.
132KV	Dhule-Nardhane	19-Jun-10	13.05	19-Jun-10	15.25	Q.M.Work
132KV	Ambazari - Amravati	19-Jun-10	15.53	19-Jun-10	16.03	Distance protection
132KV	Bhandara-Ambhora	19-Jun-10	20.17	20-Jun-10	02.14	B phase CC Burst at Ambhora S/S
100KV	Kandalgaon-Roha-I	15-Jun-10	21.20	16-Jun-10	09.10	Tripped on Dist.Protection
100KV	Kalwa-Kalyan	16-Jun-10	11.10	16-Jun-10	15.38	Guard wire work.