

LINE OUTAGES FOR THE WEEK

FROM 25-Jun-12 TO 1-Jul-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	Chandrapur - Padgha Pole-I	25-Jun-12	05.02	25-Jun-12	05.53	Distance protection.
400KV	Dhule-Sar'Sarovar - I	20-Jun-12	23.49	25-Jun-12	08.59	Over Voltage.
400KV	Aurangabad-Deepnagar-II	21-Jun-12	18.05	28-Jun-12	11.02	Over Voltage.
400KV	Karad - Kolhapur - II	24-Jun-12	20.40	26-Jun-12	09.17	Over Voltage.
400KV	Karad - Lonikand	24-Jun-12	13.26	25-Jun-12	11.19	Tripped from Karad .
400KV	Bhusawal- Aurangabad	24-Jun-12	16.29	25-Jun-12	08.38	Over Voltage.
400KV	Kolhapur - Mapusa - II	24-Jun-12	17.12	27-Jun-12	10.57	Over Voltage.
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	25-Jun-12	10.38	25-Jun-12	15.53	Relay Testing
400KV	Bhusawal- Aurangabad	25-Jun-12	17.10	26-Jun-12	10.28	Over Voltage
400KV	Karad-New Koyna II	25-Jun-12	23.38	26-Jun-12	08.23	B Phase CVT heavy oil leakage
400KV	Parli-Parli (PGCIL) I	26-Jun-12	00.32	26-Jun-12	09.49	Tripped
400KV	Main Bus - I @ Karad	26-Jun-12	02.12	27-Jun-12	16.22	B Phase CVT heavy oil leakage
400KV	Karad - Newkoyna - I	26-Jun-12	02.05	26-Jun-12	09.59	B Phase CVT heavy oil leakage
400KV	400/220KV 315MVA ICT-III at Karad.	26-Jun-12	02.10	26-Jun-12	03.42	B Phase CVT heavy oil leakage(Shifted on Main Bus-II)
400KV	Karad - Solapur (PGCIL)	26-Jun-12	01.32	26-Jun-12	11.44	B Phase CVT heavy oil leakage
400KV	Karad - Kolhapur - I	26-Jun-12	01.43	30-Jun-12	08.53	B Phase CVT heavy oil leakage(Taken on TBC)
400KV	Bablsr-Padgha Ckt I	26-Jun-12	09.52	26-Jun-12	18.37	Insulator replacement work
400KV	Newkoyna - Jaigad - I	26-Jun-12	12.19	26-Jun-12	13.49	ABT Meter Installation Work.
400KV	New Koyna - Jaigad - II	26-Jun-12	14.10	26-Jun-12	15.14	For New ABT Meter Installation @ Jaigad.
400KV	Karad-Jaigad I	26-Jun-12	15.27	26-Jun-12	20.10	For New ABT Meter Installation @ Jaigad.
400KV	Bhusawal- Aurangabad	26-Jun-12	16.31	27-Jun-12	07.55	Over Voltage.
400KV	400/220KV,500MVA ICT-II at Khaparkheda.	26-Jun-12	20.43		Continued.	R Phase LV side CT Burst
400KV	400/220KV 500MVA ICT- I at Khaparkheda	26-Jun-12	22.48	28-Jun-12	19.48	Heavy Red Hot on Y Phase LV Side Breaker
400KV	Parli-Lonikand -I	26-Jun-12	22.55	27-Jun-12	02.58	C Phase Line Reactor Burnt at Lonikand(The same is bypassed)
400KV	Karad - Kolhapur - II	27-Jun-12	05.27	27-Jun-12	08.47	Over Voltage
400KV	Bhusawal- Aurangabad	27-Jun-12	17.04		Continued.	Over Voltage,
400KV	Kolhapur - Mapusa - I	27-Jun-12	22.06		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	27-Jun-12	22.19	30-Jun-12	10.49	Over Voltage.
400KV	Karad - Kolhapur - II	27-Jun-12	14.50	27-Jun-12	15.03	Without Indication,Tripped @ Karad Only.
400KV	400/220KV 315MVA ICT- I @ Chandrapur	27-Jun-12	15.15	27-Jun-12	22.19	Testing Work.
400KV	Karad-New Koyna II	27-Jun-12	10.42	28-Jun-12	08.37	Maintenance Work.
400KV	Padgha - Babaleshwar - II	27-Jun-12	09.40	27-Jun-12	20.25	Replacement of Insulator.
400KV	Karad-Kolhapur-II	27-Jun-12	15.08	28-Jun-12	09.15	Over Voltage.
400KV	Deepnagar-Aurangabad-I	28-Jun-12	12.05		Continued.	Over Voltage.
400KV	Karad-Kolhapur-II	28-Jun-12	18.10	29-Jun-12	10.16	Over Voltage.
400KV	Kalwa - Lonikand	29-Jun-12	11.56	29-Jun-12	12.30	Connecting C.T Ckt of Lonikand line to PMV unit of WAMS.
400KV	400/220 KV 315 MVA ICT - I @ Aurangaba	29-Jun-12	10.26	29-Jun-12	18.41	Half yearly maint.and commissining of CTR fire Protection system.
400KV	400/220KV 315 MVA ICT-I @ Padgha	29-Jun-12	11.00	29-Jun-12	15.30	To check tan delta on LV side B-Ph CT.
400KV	Padgha - Kharghar	29-Jun-12	12.57	29-Jun-12	15.14	Attending heavy sparking of Y ph.LA.
400KV	Karad-Kolhapur-II	29-Jun-12	17.44	30-Jun-12	07.32	Over Voltage.
400KV	Aux,Bus at 400KV BBLSR.	29-Jun-12	12.05	29-Jun-12	19.45	Extension of Aux.bus for India bull bay.
400KV	400/220KV 500 MVA ICT I at Lonikand Ph.I	30-Jun-12	17.20	30-Jun-12	17.22	First time charged from HV side kept on humming.
400KV	Dhule-Khandwa-II	30-Jun-12	11.51	30-Jun-12	16.17	Hot spot attending work.
400KV	400/220KV 500 MVA ICT I at Lonikand Ph.I	30-Jun-12	19.43	1-Jul-12	11.45	NDR.
400KV	Lonikand - Parli - I	30-Jun-12	20.20	30-Jun-12	20.39	During testing and scada work.
400KV	Lonikand II-Parli II	30-Jun-12	20.20	1-Jul-12	11.40	During testing and scada work.
400KV	Chandrapur - Parly - III	30-Jun-12	20.20	30-Jun-12	20.53	During testing and scada work.
400KV	Lonikand- Koyna Stage IV	30-Jun-12	20.20	30-Jun-12	20.34	During testing and scada work.

400KV	Karad-Jaigad I	30-Jun-12	09.08	30-Jun-12	09.37	Due to non working of TBC on line shifting.
400KV	Karad - Solapur (PGCIL)	30-Jun-12	09.45	30-Jun-12	10.04	For shifting main bus-II to main bus-I.
400KV	Karad - Kolhapur - II	30-Jun-12	16.27	1-Jul-12	11.11	Over Voltage.
400KV	400 KV Inter connector at Lonikand II	30-Jun-12	20.20	1-Jul-12	00.12	During testing and scada work.
400KV	Kolhapur-Solapur(PGCIL)-I	30-Jun-12	23.50	30-Jul-12	23.56	First time charge.
400KV	Kolhapur-Solapur(PGCIL)-I	30-Jun-12	23.55	30-Jun-12	23.56	First time charge.
400KV	Kolhapur-Solapur(PGCIL)-I	1-Jul-12	00.37		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	1-Jul-12	00.26		Continued.	Over Voltage.
400KV	Dhule-Khandwa-II	1-Jul-12	10.31	1-Jul-12	15.16	To attend Hot Spot.
400KV	Kolhapur-Solapur (PG) II	1-Jul-12	11.20	1-Jul-12	11.28	First time charging.
400KV	Karad-Kolhapur-II	1-Jul-12	16.10		Continued.	Over Voltage.
400KV	Kolhapur-Solapur (PG) II	1-Jul-12	21.59		Continued.	Over Voltage.
400KV	Akola - Wardha - II	1-Jul-12	14.48	1-Jul-12	15.16	Dist.Prot.Z-I.
400KV	Parli-Parli (PGCIL) I	1-Jul-12	23.51		Continued.	Over Voltage.
220KV	Mumewadi-Mudshingi	25-Jun-12	08.48	25-Jun-12	10.22	Red Hot
220KV	Malegaon - Satana - I	25-Jun-12	07.03	25-Jun-12	10.20	Red Hot
220KV	Miraj - Mhaisai	25-Jun-12	10.50	25-Jun-12	17.50	Replacement of String Insulator
220KV	Taloja-OCIL-I	25-Jun-12	10.02	25-Jun-12	15.05	Jumper replacement
220KV	Bale-Lamboti II	25-Jun-12	19.17	25-Jun-12	19.28	Isolator Sparking
220KV	ICL - Harangool Ckt.II	25-Jun-12	10.23	25-Jun-12	12.24	Replacement of LA
220KV	Kalwa-Temghar	26-Jun-12	03.10	26-Jun-12	04.10	Compressor problem
220KV	Apta-Uran-IV	26-Jun-12	07.59	29-Jun-12	21.48	Shifting of Equipments.
220KV	220 KV TBC @ Kharghar	26-Jun-12	09.33	26-Jun-12	16.45	RCC to New G I Structure
220KV	Miraj - Mhaisai	26-Jun-12	09.52	26-Jun-12	19.55	Replacement of Faulty String Insulator
220KV	Nasik - Airoli - Knowledge Park	26-Jun-12	11.17	26-Jun-12	13.54	For Passing ODC From Sinnar-Ghoti Highway
220KV	Nasik - Ghatghar	26-Jun-12	11.23	26-Jun-12	13.34	For Passing ODC From Sinnar-Ghoti Highway
220KV	Jejury - Lonand	26-Jun-12	13.42	26-Jun-12	17.25	Installation of New 220KV CT & P T.
220KV	Khaparkheda New - Khaparkheda Old - II	26-Jun-12	20.43	27-Jun-12	20.15	Bus Bar prot.operated
220KV	Girwali-New Parly TPS	26-Jun-12	20.53	26-Jun-12	21.34	Distance Protection
220KV	220/132 150MVA ICT- II @ Nanded	26-Jun-12	10.30	26-Jun-12	11.42	132KV Bus Bar Prot.operated
220KV	220/132KV,200MVA ICT-III At Nanded.	26-Jun-12	10.30	26-Jun-12	11.45	132KV Bus Bar Prot.operated
220KV	Pedambe - Pophali - II	27-Jun-12	06.20	27-Jun-12	17.40	Replacement of Support Insulator.
220KV	Miraj - Mhaisai	27-Jun-12	11.45	27-Jun-12	17.56	Insulator Replacement.
220KV	Talandge - Sawantwadi	27-Jun-12	08.54	27-Jun-12	13.51	Red Hot.
220KV	Kalwa-Trombay	27-Jun-12	12.30	27-Jun-12	16.15	Jumper Replacement.
220KV	Lonand - Jejuri	27-Jun-12	11.30	27-Jun-12	14.46	Replacement of C T.
220KV	Khaperkheda - Ambazari - II	27-Jun-12	09.51	27-Jun-12	12.34	Tighting of Nut Bolts of Y Ph. Jumpers @ Loc.No.40,
220KV	Pusad-Nanded	28-Jun-12	10.03	28-Jun-12	15.54	Attending Red Hot on Y & B Ph. @ Loc.44.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	28-Jun-12	03.57	28-Jun-12	07.11	Internal Fault.
220KV	Bhosari - Chakan	28-Jun-12	08.11	28-Jun-12	13.07	Replacement of Damage Conductor.
220KV	Miraj - Mhaisai	28-Jun-12	10.07	28-Jun-12	19.30	Repl.of Faulty String Insu.@ all Cut Points.
220KV	Phursungi - Theur	28-Jun-12	11.22	28-Jun-12	18.16	Half Yearly Maint.Work.
220KV	Lonikand-Bhosari	28-Jun-12	13.16	28-Jun-12	17.29	R.M.Work,C T Tan Delta.
220KV	Tarapur-Borivali	28-Jun-12	09.38	28-Jun-12	17.35	For Attending Hot Clamp on B Ph. Jumper @ Take off Tower.
220KV	Nasik-Navsari-I	28-Jun-12	10.51	28-Jun-12	16.37	Replacement of Damage Conductor @ Loc.No. 158,159.
220KV	220/22 KV,50 MVA T/F-II at Colourchem	28-Jun-12	14.53	28-Jun-12	23.10	Distance Protection.
220KV	220/100 KV 100 MVA ICT - I @ Vasai	28-Jun-12	15.43	28-Jun-12	17.14	PRV Operated.
220KV	220/132KV 100 MVA ICT-II at Dondaicha	28-Jun-12	11.58	28-Jun-12	14.55	Measurment of Tan Delta of ICT Bushing.
220KV	220/132 KV 200 MVA ICT - I @ Nanded	28-Jun-12	14.33	28-Jun-12	16.50	Auxiliary C T Testing Work.

220KV	220/132 KV 200 MVA ICT - II @ Nanded	28-Jun-12	16.53	28-Jun-12	19.06	Testing Work.
220KV	Wardha - Yawatmal	28-Jun-12	11.42	28-Jun-12	15.48	Auxiliary Isolator Maintenance Work.
220KV	Interconnector - II @ Dhule	28-Jun-12	09.58	28-Jun-12	13.42	Jumpering Work.
220KV	Pophali - Pedambe	29-Jun-12	13.10	29-Jun-12	13.35	Dist.Protection.
220KV	Main Bus- I @ 400 KV Kalwa	29-Jun-12	09.33	29-Jun-12	17.11	Removal of bird nest and attend hot spot.
220KV	Bus Coupler at 400KV Kalwa.	29-Jun-12	09.33	29-Jun-12	17.11	Removal of bird nest and attend hot spot.
220KV	220/100 KV,100 MVA ICT-II at Vasai	29-Jun-12	14.20	29-Jun-12	16.52	M.O.G.alarm checking.
220KV	Miraj - Mhaisai	29-Jun-12	10.30	29-Jun-12	19.02	Replacement of insulator.
220KV	Apta-Kalwa	29-Jun-12	11.00	29-Jun-12	11.58	For tree cutting.
220KV	Trombay - Tifil	29-Jun-12	13.00	29-Jun-12	16.20	Removal of old E/W.at Loc.No.739.
220KV	Trombay Sonkhar	29-Jun-12	13.01	29-Jun-12	16.04	Removal of old E/W.at Loc.No.739.
220KV	220/66KV 50 MVA ICT- I @ Wardha.	29-Jun-12	07.10	29-Jun-12	07.24	E/F,O/C.Relay.
220KV	220/66KV 50 MVA ICT- II @ Wardha	29-Jun-12	07.10	29-Jun-12	07.24	E/F,O/C.Relay.
220KV	Dhule-Chalisgaon	29-Jun-12	08.57	29-Jun-12	13.12	Attending red hot at wave trap,and Q.M.work.
220KV	220/132 KV 200 MVA ICT- II @ Harangul	29-Jun-12	12.05	29-Jun-12	18.25	Transformer painting and tan delta measurement.
220KV	220/132 KV 200 MVA ICT -IV. at Padegaon	29-Jun-12	10.30	29-Jun-12	19.25	Measurement of tan delta of ICT bushings and Q.M.Work.
220KV	Apta-Uran-III	30-Jun-12	07.58		Continued.	Shifting the aux.isolator,CT line isolator to new G.I.structure.
220KV	Uran-Kharghar-I	30-Jun-12	09.40	30-Jun-12	17.21	Replacement of flashover insulator string.at Loc.59B.
220KV	BBLSR-A"Nagar II	30-Jun-12	08.58	30-Jun-12	13.50	Armouring of conductor.
220KV	Babaleshwar - Nagar - I	30-Jun-12	14.25	30-Jun-12	16.40	Armouring of conductor at tower Loc.No.22-23 B phase.
220KV	Miraj -Ichalkarajni	30-Jun-12	18.41	30-Jun-12	19.57	To reduce voltage @ 400kV Kolhapur to charge Solapur(PGCIL)-I and II.
220KV	Wardha - Yawatmal	30-Jun-12	16.35	1-Jul-12	18.32	Dist.Protection Z-I.
220KV	Khaparkheda-Kawlewada-I	30-Jun-12	16.20	1-Jul-12	14.43	Dist.Protection.
220KV	Babaleshwar - Ranjangaon	1-Jul-12	02.20	1-Jul-12	02.32	Distance protection.
220KV	Borivali-Ghodbandar	1-Jul-12	10.00	1-Jul-12	12.25	Removing bird nest and R.M.Work.
132KV	Nandurbar - Visarwadi	25-Jun-12	18.15	25-Jun-12	23.10	Distance Protection
132KV	Main Bus @ Nanded	26-Jun-12	10.30	26-Jun-12	10.55	132KV Bus Bar Prot.operated
132KV	Nanded - Umri	26-Jun-12	10.30	26-Jun-12	10.55	132KV Bus Bar Prot.operated
132KV	Nanded - Narsi	26-Jun-12	10.30	26-Jun-12	12.35	132KV Bus Bar Prot.operated
132KV	Nanded - Tamsa	26-Jun-12	10.30	26-Jun-12	13.04	132KV Bus Bar Prot.operated
132KV	Boiser - MIDC	27-Jun-12	16.35	27-Jun-12	16.46	Distance Protection.
132KV	Boiser - Viraj	27-Jun-12	16.35	27-Jun-12	17.47	Back up Protection.
132KV	Boiser - MIDC	28-Jun-12	06.35	28-Jun-12	06.56	Distance Protection.
132KV	Chinchwad-Rahatri	28-Jun-12	11.07	28-Jun-12	13.32	Attending Hot Spot of Y & B Ph. C B.
132KV	Waghala- Jangamwadi	28-Jun-12	10.41	28-Jun-12	16.19	Auxiliary C T Testing Work.
132KV	Parbhani-Jintur	28-Jun-12	11.38	28-Jun-12	16.39	Measurment of Tan Delta of C T.
132KV	Main Bus @ Nanded	28-Jun-12	18.16	28-Jun-12	18.35	Bus Bar Protection Operated Fault @ 33 KV Vidyut Bhavan Feeder.
132KV	Viraj-Jindal	29-Jun-12	09.20	29-Jun-12	19.21	Repl.of CT,PT and Meter installation asked by M/S Viraj.
132KV	Boiser - Viraj	29-Jun-12	09.20	29-Jun-12	19.20	Repl.of CT,PT and Meter installation asked by M/S Viraj.
132KV	Amravati - Morshi	29-Jun-12	14.25	29-Jun-12	15.40	Distance Protection.
132KV	Dhule-Sakri	1-Jul-12	21.18	1-Jul-12	22.00	Main BKR Problem.(charged on TBC)
132KV	Bhusawal - Nimbhora	1-Jul-12	18.31	1-Jul-12	18.36	Dist.Protection Z-I.
132KV	Nandurbar-Visarwadi	1-Jul-12	20.15	1-Jul-12	20.45	Dist.Protection Z-I.
100KV	Kalwa-Salshet - II	22-Jun-12	09.30	25-Jun-12	12.58	Repl.of line side isolator.
100KV	Kalwa-Kalyan	29-Jun-12	10.28	29-Jun-12	15.01	To removing bird nest.
100KV	Kalwa - Salshet - I	29-Jun-12	15.40	29-Jun-12	17.50	Hot Spot attending work.