

**LINE OUTAGES FOR THE WEEK**

**FROM 26-Jul-10 TO 1-Aug-10**

| Voltage | Name                                  | date_trip | time_trip | date_sync | time_sync  | reason                                                           |
|---------|---------------------------------------|-----------|-----------|-----------|------------|------------------------------------------------------------------|
| 500KV   | HVDC Pole-I                           | 27-Jul-10 | 06.50     | 27-Jul-10 | 07.28      | Rectification of Capacitor Sparking & Chattering Noise @ Padgha. |
| 400KV   | Bhusawal- Aurangabad                  | 19-Jun-10 | 22.51     | 31-Jul-10 | 18.01      | Over Voltage                                                     |
| 400KV   | Kolhapur-Mapusa Ckt I                 | 16-Jul-10 | 18.43     | 28-Jul-10 | 19.45      | Over Voltage                                                     |
| 400KV   | Karad - Kolhapur - I                  | 19-Jul-10 | 19.52     | 26-Jul-10 | 09.42      | Over Voltage.                                                    |
| 400KV   | Dhule-Sar'Sarovar - I                 | 20-Jul-10 | 23.24     | 26-Jul-10 | 12.50      | Over Voltage.                                                    |
| 400KV   | New Koyna - StageIV - I               | 23-Jul-10 | 12.36     | 27-Jul-10 | 08.09      | Over Voltage                                                     |
| 400KV   | Karad-Lamboti                         | 23-Jul-10 | 19.33     | 27-Jul-10 | 09.23      | Over Voltage                                                     |
| 400KV   | Koradi - Kaparkheda                   | 24-Jul-10 | 19.54     | 26-Jul-10 | 10.38      | Trip on O/V.                                                     |
| 400KV   | Koyna IV - Jejuri                     | 25-Jul-10 | 23.26     | 27-Jul-10 | 09.35      | Over Voltage                                                     |
| 400KV   | New Koyna - Koyna Stage IV - II       | 26-Jul-10 | 03.30     | 26-Jul-10 | 08.29      | Over Voltage                                                     |
| 400KV   | Karad-Kolhapur-II                     | 26-Jul-10 | 01.02     | 26-Jul-10 | 16.57      | Over Voltage                                                     |
| 400KV   | Padgha - Kalwa - II                   | 26-Jul-10 | 07.29     | 26-Jul-10 | 17.33      | Dist.Prot.Z-1,B Ph.                                              |
| 400KV   | Karad - Kolhapur - I                  | 26-Jul-10 | 10.02     | 27-Jul-10 | 08.37      | Over Voltage.                                                    |
| 400KV   | Karad-Kolhapur-II                     | 26-Jul-10 | 23.50     | 28-Jul-10 | 09.11      | Over Voltage.                                                    |
| 400KV   | Jejuri-Koyna STG-IV                   | 26-Jul-10 | 23.11     | 27-Jul-10 | 09.27      | Over Voltage.                                                    |
| 400KV   | Dhule-S'Sarovar I                     | 27-Jul-10 | 00.54     | 27-Jul-10 | 18.33      | Over Voltage.                                                    |
| 400KV   | C'pur-Parli II                        | 27-Jul-10 | 00.08     | 27-Jul-10 | 05.36      | Over Voltage.                                                    |
| 400KV   | New Koyna - Koyna Stage IV - II       | 27-Jul-10 | 03.10     | 31-Jul-10 | 10.23      | Over Voltage.                                                    |
| 400KV   | Padgha - Kharghar                     | 27-Jul-10 | 08.37     | 27-Jul-10 | 19.03      | R.M.Work.                                                        |
| 400KV   | Karad - Kolhapur - I                  | 27-Jul-10 | 12.56     | 27-Jul-10 | 13.09      | Over Voltage.                                                    |
| 400KV   | Karad - Kolhapur - I                  | 27-Jul-10 | 18.42     |           | Continued. | Over Voltage.                                                    |
| 400KV   | New Koyna - Dabhol - II               | 27-Jul-10 | 16.39     | 28-Jul-10 | 17.03      | Decapping @ Loc.-10 Y Ph.46.97KM from Newkoyna end.              |
| 400KV   | 400 KV A.C. - 2 @ Chandrapur          | 27-Jul-10 | 12.18     | 27-Jul-10 | 12.37      | Trip.                                                            |
| 400KV   | Jejuri-Koyna STG-IV                   | 27-Jul-10 | 23.49     | 28-Jul-10 | 09.33      | Over Voltage.                                                    |
| 400KV   | Dhule-S'Sarovar I                     | 28-Jul-10 | 00.19     | 28-Jul-10 | 07.45      | Over Voltage.                                                    |
| 400KV   | C'pur-Parli II                        | 28-Jul-10 | 13.08     | 29-Jul-10 | 07.39      | H/T For O/V.                                                     |
| 400KV   | 80 MVAR Bus Reactor @ Nagothane       | 28-Jul-10 | 09.53     | 28-Jul-10 | 14.59      | To attend Y-Ph Bus isolator Hot Spot.                            |
| 400KV   | Karad-Lamboti                         | 28-Jul-10 | 21.29     | 31-Jul-10 | 14.21      | H/T For O/V.                                                     |
| 400KV   | Kolhapur-Mapusa Ckt I                 | 28-Jul-10 | 21.55     |           | Continued. | H/T For O/V.                                                     |
| 400KV   | Jejuri-Koyna STG-IV                   | 29-Jul-10 | 00.01     | 29-Jul-10 | 10.50      | Over Voltage.                                                    |
| 400KV   | Lonikand - Parli - I                  | 29-Jul-10 | 10.27     | 29-Jul-10 | 14.02      | Distance Protection.                                             |
| 400KV   | 400/220 KV 315MVA ICT-II @ Karad      | 29-Jul-10 | 11.35     | 29-Jul-10 | 12.25      | Sparking Problem.                                                |
| 400KV   | 400/220 KV 315 MVA ICT @ Chakan       | 29-Jul-10 | 12.46     | 29-Jul-10 | 19.47      | OLTC Bucholz.                                                    |
| 400KV   | Jejuri-Koyna STG-IV                   | 29-Jul-10 | 23.28     | 31-Jul-10 | 16.38      | Over Voltage.                                                    |
| 400KV   | 400/220KV 105MVA Spare ICT @ Parly-II | 29-Jul-10 | 10.29     | 29-Jul-10 | 18.55      | OLTC Bucholz.                                                    |
| 400KV   | Karad-Kolhapur-II                     | 30-Jul-10 | 01.37     | 31-Jul-10 | 14.02      | Over Voltage.                                                    |
| 400KV   | Padgha - Nagothane- II                | 30-Jul-10 | 08.45     | 30-Jul-10 | 17.12      | Bay Maintenance work.                                            |
| 400KV   | New Koyna - StageIV - I               | 31-Jul-10 | 10.25     | 1-Aug-10  | 16.34      | For relay setting.                                               |
| 400KV   | Akola - Wardha - I                    | 31-Jul-10 | 17.57     | 1-Aug-10  | 09.54      | Trip O/V.                                                        |
| 400KV   | Seoni - Wardha                        | 31-Jul-10 | 17.57     | 31-Jul-10 | 19.53      | H/T                                                              |
| 400KV   | Karad - Lonikand                      | 31-Jul-10 | 16.22     | 31-Jul-10 | 17.30      | H.T for Bus-I outage charged through TBC M.B-II.                 |
| 400KV   | Bhusawal- Aurangabad                  | 31-Jul-10 | 22.27     |           | Continued. | H/t O/V.                                                         |
| 400KV   | Jejuri-Koyna STG-IV                   | 31-Jul-10 | 23.25     | 1-Aug-10  | 09.09      | Tripped O/V.                                                     |
| 400KV   | Karad-Kolhapur CKT II                 | 31-Jul-10 | 22.57     | 1-Aug-10  | 09.27      | H/T O/V.                                                         |
| 400KV   | Karad-Lamboti                         | 31-Jul-10 | 18.27     |           | Continued. | H/T for O/V.                                                     |
| 400KV   | Karad - Lonikand                      | 1-Aug-10  | 09.47     | 1-Aug-10  | 18.58      | Tripped due to sparking on TBC isolator at Karad end.            |
| 400KV   | Dhule-S'Sarovar I                     | 1-Aug-10  | 00.49     | 1-Aug-10  | 18.24      | H/T O/V.                                                         |
| 400KV   | New Koyna - Koyna Stage IV - II       | 1-Aug-10  | 16.38     |           | Continued. | H/T for O/V                                                      |
| 400KV   | Main Bus - I @ Karad                  | 1-Aug-10  | 12.35     |           | Continued. | Bus side isolator maintence work.                                |
| 400KV   | 400/220 KV 315MVA ICT-II @ Karad      | 1-Aug-10  | 13.20     |           | Continued. | Bus side isolator maintenance work.                              |
| 400KV   | Jejuri-Koyna STG-IV                   | 1-Aug-10  | 23.23     |           | Continued. | Trip O/V                                                         |
| 400KV   | Karad-Kolhapur CKT II                 | 1-Aug-10  | 22.40     |           | Continued. | H/T for O/V.                                                     |
| 400KV   | Dhule-S'Sarovar I                     | 1-Aug-10  | 22.50     |           | Continued. | H/T for O/V                                                      |
| 220KV   | 220/100 KV125 MVA ICT-III @Trombay    | 26-Jul-10 | 12.21     | 26-Jul-10 | 14.26      | To Attend Heavy Noister in 11KV Breaker.                         |
| 220KV   | Talangade-Mudshingi                   | 26-Jul-10 | 09.57     | 26-Jul-10 | 10.32      | Dist.Prot.                                                       |

|       |                                          |           |       |           |            |                                                           |
|-------|------------------------------------------|-----------|-------|-----------|------------|-----------------------------------------------------------|
| 220KV | Kalmeshwar - Pandurna                    | 26-Jul-10 | 07.39 | 26-Jul-10 | 08.54      | Trip.                                                     |
| 220KV | 220/100 KV 100 MVA T/F - IV @ Kandalgaon | 26-Jul-10 | 14.40 | 26-Jul-10 | 22.08      | Differential Protection.                                  |
| 220KV | Kalwa - Salshet - IV                     | 27-Jul-10 | 00.21 | 27-Jul-10 | 05.20      | To Attend Hot Spot on A Ph on Loc-2.                      |
| 220KV | Trombay-Kalwa                            | 27-Jul-10 | 21.01 | 27-Jul-10 | 21.36      | One end Tripping.                                         |
| 220KV | Nagothane-Mahad                          | 27-Jul-10 | 09.22 | 27-Jul-10 | 17.34      | R.M.Work,Testing Work.                                    |
| 220KV | Vita - Miraj                             | 27-Jul-10 | 10.22 | 27-Jul-10 | 17.38      | Attending Red Hot & Q.M.Work.                             |
| 220KV | Talangaade - Mudshingi - I               | 27-Jul-10 | 10.35 | 27-Jul-10 | 14.06      | Realy Retrofitting & Comissioning Work.                   |
| 220KV | Karad-Pophali                            | 28-Jul-10 | 09.30 | 28-Jul-10 | 14.20      | Insulator replacement.                                    |
| 220KV | Bale - Lamboti I                         | 28-Jul-10 | 10.05 | 28-Jul-10 | 11.55      | Q.M.Work                                                  |
| 220KV | 220/132 KV 200 MVA ICT- I @ Bale         | 28-Jul-10 | 12.01 | 28-Jul-10 | 18.02      | Testing work.                                             |
| 220KV | Padgha-Jambhul-I                         | 28-Jul-10 | 12.25 | 28-Jul-10 | 14.19      | To attend DC leakage.                                     |
| 220KV | Bhandara - RLY TSS - I                   | 28-Jul-10 | 16.34 | 28-Jul-10 | 16.46      | HV Bus Bar prot'n operated.                               |
| 220KV | Bhandara - Rly TSS - II                  | 28-Jul-10 | 16.34 | 28-Jul-10 | 16.46      | HV Bus Bar prot'n operated.                               |
| 220KV | Bhandara-Kanhan ckt-I                    | 28-Jul-10 | 16.34 | 28-Jul-10 | 16.40      | HV Bus Bar prot'n operated.                               |
| 220KV | Bhandara - Sunflag - I                   | 28-Jul-10 | 16.34 | 28-Jul-10 | 16.45      | HV Bus Bar prot'n operated.                               |
| 220KV | 220/132 KV 150 MVA ICT @ Bhandara        | 28-Jul-10 | 16.34 | 28-Jul-10 | 16.55      | HV Bus Bar prot'n operated.                               |
| 220KV | 220/132 KV 100 MVA ICT at Bhandara       | 28-Jul-10 | 16.34 | 28-Jul-10 | 17.00      | HV Bus Bar prot'n operated.                               |
| 220KV | Kanhan - Bhandara - II                   | 28-Jul-10 | 16.34 | 28-Jul-10 | 16.47      | HV Bus Bar prot'n operated, PDR operated.                 |
| 220KV | Main Bus at Bhandara                     | 28-Jul-10 | 16.34 | 28-Jul-10 | 16.40      | HV Bus Bar prot'n. operated.                              |
| 220KV | Khaparkheda-Kawlewada-II                 | 28-Jul-10 | 08.54 | 28-Jul-10 | 15.33      | Q.M.Work                                                  |
| 220KV | Bhandara-Kanhan ckt-I                    | 28-Jul-10 | 09.30 | 28-Jul-10 | 11.42      | Q.M.Work                                                  |
| 220KV | Jejuri I-Jejuri II                       | 29-Jul-10 | 08.20 | 29-Jul-10 | 16.27      | Q.M.Work                                                  |
| 220KV | Chinchwad - Hinjewadi                    | 29-Jul-10 | 09.10 | 29-Jul-10 | 11.53      | Erection of new gantry for new 50 MVA T/F.                |
| 220KV | Lonikand - Theur - II                    | 29-Jul-10 | 08.41 | 29-Jul-10 | 17.23      | Q.M.Work                                                  |
| 220KV | Lonikand-Kathapur                        | 29-Jul-10 | 09.16 | 29-Jul-10 | 12.34      | Attending problem of NIT switch.                          |
| 220KV | Kalwa - Nasik III                        | 29-Jul-10 | 11.01 | 29-Jul-10 | 17.12      | Earthwire fixing.                                         |
| 220KV | Alephata-Kathapur                        | 29-Jul-10 | 14.32 | 29-Jul-10 | 16.50      | R.M.Work                                                  |
| 220KV | 220/100 KV125 MVA ICT-III @ Trombay      | 29-Jul-10 | 13.08 | 29-Jul-10 | 14.34      | Diff.Protection.                                          |
| 220KV | Kandalgaon - Pophali                     | 29-Jul-10 | 11.15 | 29-Jul-10 | 11.35      | Dist.Protection                                           |
| 220KV | 220/132 KV 200 MVA ICT @ Amravati        | 29-Jul-10 | 09.23 | 29-Jul-10 | 11.07      | Testing work.                                             |
| 220KV | 220/132KV 100 MVA ICT- I @ Parly-II      | 29-Jul-10 | 10.11 |           | Continued. | LV BKR replacement work.                                  |
| 220KV | Kalmeshwar-Ambazari                      | 29-Jul-10 | 12.39 | 29-Jul-10 | 13.00      | Dist.protection                                           |
| 220KV | Kaparkheda-Kalmeshwar                    | 29-Jul-10 | 12.49 | 29-Jul-10 | 12.59      | Dist.protection                                           |
| 220KV | Dondaicha - Jamde - I                    | 29-Jul-10 | 18.10 | 29-Jul-10 | 19.00      | Due to DC leakage problem in BKR.                         |
| 220KV | Nasik-Bablsr - I                         | 30-Jul-10 | 08.19 | 30-Jul-10 | 17.45      | Replacement of wave trap.                                 |
| 220KV | Boisor - Dahanu                          | 30-Jul-10 | 10.25 | 30-Jul-10 | 16.57      | Replacement of wave trap.                                 |
| 220KV | Usmanabad-Barshi                         | 30-Jul-10 | 10.00 | 30-Jul-10 | 13.58      | Fixing new blade TP central rotating ARM of Aux.isolator. |
| 220KV | M'Peth -Vankuswade                       | 30-Jul-10 | 19.20 | 30-Jul-10 | 21.30      | PDR,Trip.                                                 |
| 220KV | Alephata 220/132 KV,100 MVA Emco make T  | 30-Jul-10 | 17.17 | 30-Jul-10 | 18.30      | Taken on load 25 MW,Test charged.                         |
| 220KV | Khaparkheda-Kawlewada-I                  | 30-Jul-10 | 23.41 | 31-Jul-10 | 10.58      | Tripped on PDR.Ckt taken on TBC at 00.19 Hrs.             |
| 220KV | Babaleshwar - Nagar - II                 | 31-Jul-10 | 03.51 | 31-Jul-10 | 04.15      | Dist.protection                                           |
| 220KV | Dhule-Dondaicha-II                       | 31-Jul-10 | 09.45 | 31-Jul-10 | 14.25      | Jumper replacement work.                                  |
| 220KV | BBLSR-A"Nagar II                         | 31-Jul-10 | 09.22 | 31-Jul-10 | 17.15      | C.T. replacement.                                         |
| 220KV | Kalwa-Taloja                             | 31-Jul-10 | 12.35 | 31-Jul-10 | 16.20      | Jumper replacement.                                       |
| 220KV | Amona-Ponda-II                           | 31-Jul-10 | 04.10 | 31-Jul-10 | 16.58      | Trip O/V.                                                 |
| 220KV | Amona-ponda- I                           | 31-Jul-10 | 04.10 | 31-Jul-10 | 17.08      | Trip O/V.                                                 |
| 220KV | 220/132 KV 200 MVA ICT-III @ Phursungi   | 31-Jul-10 | 17.00 | 31-Jul-10 | 18.12      | "Y" Ph.jumper replaced.                                   |
| 220KV | 220/132 KV 100 MVA ICT @ Shahada         | 31-Jul-10 | 09.00 | 31-Jul-10 | 10.40      | For attending oil leakage by cold welding.                |
| 220KV | 220/132 KV 200 MVA ICT-I @ Harangul      | 31-Jul-10 | 15.00 | 31-Jul-10 | 19.30      | Main buchholz protection operated.                        |
| 220KV | 220/132 KV 100 MVA ICT @ Chitegaon       | 31-Jul-10 | 09.25 | 1-Aug-10  | 12.00      | HV main breaker overhauling work.HV side on TBC.          |
| 220KV | Baramati - Lonand                        | 1-Aug-10  | 14.50 | 1-Aug-10  | 23.30      | A person climbed on D/C Tower at loc.No.111.              |
| 220KV | Jejuri - Baramati                        | 1-Aug-10  | 16.50 | 1-Aug-10  | 22.50      | A person climbed on D/C Tower at Loc.No.111.              |
| 220KV | 220/100 KV ICT-II @ Borivali.            | 1-Aug-10  | 09.55 | 1-Aug-10  | 12.40      | Attending hot spot.                                       |
| 220KV | Aurangabad-Chitegaon-I                   | 1-Aug-10  | 12.00 |           | Continued. | Ckt on TBC,main CB O/H work.                              |
| 132KV | Paras - Akot                             | 29-Jul-10 | 05.10 | 29-Jul-10 | 05.50      | Dist.protection                                           |
| 132KV | Bhandara - Madgi -I                      | 30-Jul-10 | 00.52 | 30-Jul-10 | 01.50      | Dist.protection.                                          |
| 132KV | Boiser - MIDC                            | 1-Aug-10  | 09.49 | 1-Aug-10  | 12.16      | Hot Spot attending.                                       |