

LINE OUTAGES FOR THE WEEK

FROM 23-Aug-10 TO 29-Aug-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE - II	18-Aug-10	08.06	25-Aug-10	22.09	Annual Maintenance.
500KV	Chandrapur-Padaghe Pole - II	26-Aug-10	08.25	27-Aug-10	19.01	Annual maintenance.
500KV	Chandrapur - Padgha Pole-I	26-Aug-10	08.25	27-Aug-10	19.11	Annual Maintenance
400KV	Wardha - Akola - II	11-Jul-10	13.07	28-Aug-10	12.25	Over Voltage
400KV	Chandrapur - Khaparkheda	24-Jul-10	19.54	25-Aug-10	14.10	Over Voltage.
400KV	Karad - Kolhapur - I	27-Jul-10	18.42	27-Aug-10	11.25	Over Voltage.
400KV	Lonikand- Koyna Stage IV	19-Aug-10	18.11	25-Aug-10	13.30	H/T for O/V.
400KV	Karad-Lamboti	20-Aug-10	10.28	23-Aug-10	12.03	New ICT Commissioning work.
400KV	Dhule - S'Sarovar - II	21-Aug-10	10.54	24-Aug-10	10.08	H/T for O/V.
400KV	400/220 KV,500 MVA ICT-II At Lamboti.	21-Aug-10	12.42	25-Aug-10	15.38	Trip NDR,Charged from L V Side.(Kept on humming.)
400KV	400 KV Main Bus - II @ Aurangabad	23-Aug-10	09.42	23-Aug-10	18.45	Erection of IPS tubes 400KV Pune-II Bay
400KV	Kalwa - Padgha - II	23-Aug-10	14.52	23-Aug-10	15.01	Distance protection
400KV	Karad-Lamboti	23-Aug-10	22.52	24-Aug-10	09.50	Over Voltage
400KV	Dabhol - Nagothane - I	24-Aug-10	05.58	24-Aug-10	07.49	Distance Protection
400KV	Dhule-Sar'Sarovar - II	24-Aug-10	15.10	25-Aug-10	08.28	Over Voltage
400KV	Karad-Lamboti	24-Aug-10	22.05	25-Aug-10	9:20	Over Voltage
400KV	400/220KV,315 MVA ICT-I At Lonikand.	24-Aug-10	08.56	24-Aug-10	14.56	Air Leakage in control valve of Y and B phase, LV side taken on TBC
400KV	Dhule-Khandwa-II	25-Aug-10	02.38	26-Aug-10	07.23	H/T B phase CVT failed
400KV	400/220 KV 315 MVA ICT - I @ Chakan	25-Aug-10	10.48	25-Aug-10	18.36	Putting in Service Fire Fighting System.
400KV	400/220 KV,315 MVA ICT-I At Jejuri	26-Aug-10	08.25	26-Aug-10	20.30	Q.M.Work.
400KV	400/220 KV 315 MVA ICT - I @ Chakan	26-Aug-10	10.15	27-Aug-10	18.45	For putting I/S fire fighting protection system.
400KV	Lonikand - Jejuri	26-Aug-10	12.10	26-Aug-10	13.33	Tripped at Lonikand end. Taken on TBC.
400KV	Lonikand-Karad	26-Aug-10	16.32	26-Aug-10	17.26	Over voltage.
400KV	Dhule - S'Sarovar- II	26-Aug-10	07.10	26-Aug-10	08.40	H/T for O/V.
400KV	Dhule - S'Sarovar- II	26-Aug-10	22.08		Continued.	H/T for O/V.
400KV	Dhule - Babhaleshwar - I	27-Aug-10	00.21	27-Aug-10	08.40	H/T for O/V.
400KV	Karad-Lamboti	27-Aug-10	21.23	28-Aug-10	11.52	H/T for O/V.
400KV	Karad - Kolhapur - II	27-Aug-10	23.01		Continued.	H/T for O/V.
400KV	400/132 KV 200 MVA ICT - II @ Bhusawal	27-Aug-10	09.26	27-Aug-10	22.32	Testing wrk.
400KV	Chandrapur - Parly - III	28-Aug-10	00.15	28-Aug-10	01.10	Distance protection.
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	28-Aug-10	20.20	28-Aug-10	22.01	Checking of B Phase Buchhloz relay
400KV	Wardha - Akola - I	28-Aug-10	12.25		Continued.	Change Over
400KV	Karad-Lamboti	28-Aug-10	22.44		Continued.	Over Voltage
400KV	Lonikand-Karad	29-Aug-10	06.20		Continued.	Over Voltage
220KV	Dondaicha - Jamde - I	22-Aug-10	22.24	25-Aug-10	21.54	Distance Protection
220KV	Dondaicha - Jamde - II.	22-Aug-10	22.24	25-Aug-10	23.05	Distance Protection
220KV	Pedambe-Tambati	23-Aug-10	09.20	23-Aug-10	18.15	Disc Insulator replacement
220KV	220/100 125 MVA ICT - II @ Trombay	23-Aug-10	12.17		Continued.	Dismentaling of existing ICT and commissioning of New 200MVA ICT
220KV	Tarapur - Borivali	23-Aug-10	14.25	23-Aug-10	14.43	Distance protection
220KV	Kalwa-Salsatt - II	23-Aug-10	18.31	23-Aug-10	18.44	Distance protection
220KV	220 KV Bus Coupler @ New Koyna	23-Aug-10	15.24	23-Aug-10	18.39	Attending problem in pressure switch of 220KV C.B.
220KV	220/132 KV 100 MVA ICT - I @ Ranjangao	23-Aug-10	11.45	24-Aug-10	17.15	Own Breaker Overhauling work,taken on TBC
220KV	220/132KV 200 MVA ICT- III @ Padegaon	23-Aug-10	14.35	23-Aug-10	15.50	Replacement of Mercury switch of W.T.I.Alarm
220KV	Kalwa - Ghatghar	24-Aug-10	10.20	24-Aug-10	12.09	To attend Hot Spot
220KV	Bale-Osmanbad	24-Aug-10	12.00	24-Aug-10	18.12	Line Maintenance

220KV	Kalmeshwar - Pandurna	24-Aug-10	10.56	24-Aug-10	11.40	Distance protection
220KV	Uran-Kharghar-II	24-Aug-10	14.18	24-Aug-10	15.47	To attend Hot Spot,Line on TBC
220KV	220/110KV 100MVA T/F- I @ Miraj	24-Aug-10	09.45	24-Aug-10	16.10	Q.M.Work
220KV	Parli-I - Harangul - II	24-Aug-10	15.00	24-Aug-10	17.53	Q.M.Work
220KV	Parly - New Parly TPS - I	24-Aug-10	09.26	24-Aug-10	17.28	Q.M.Work
220KV	Bus Section - II at Harangul	24-Aug-10	15.00	24-Aug-10	17.53	Q.M.Work
220KV	220/100KV 125 MVA ICT-I @ Kalwa	25-Aug-10	06.20	25-Aug-10	07.50	To Attend Red Hot.
220KV	Bale-Osmanabad	25-Aug-10	10.30	25-Aug-10	19.35	Replacement of Wave Trap @ Osmanabad.
220KV	Apta-Nagothane	25-Aug-10	10.29	25-Aug-10	17.48	R.M.Work.
220KV	Pedambe - Pophali	25-Aug-10	12.20	25-Aug-10	15.25	Red Hot B Ph C T.
220KV	220/100 ICT- I @ Kolshet	25-Aug-10	10.55	25-Aug-10	20.30	Abnormal Sound Observed in Y Ph Bushing L V Side.
220KV	Usmanabad-Barshi	25-Aug-10	14.00	25-Aug-10	17.31	Wave Trap Replacement Work.
220KV	Kanhan - Bhandara - II	25-Aug-10	04.08	28-Aug-10	17.25	Air Compressor Leakage Problem
220KV	Valve-Jamde	25-Aug-10	22.24	25-Aug-10	22.40	Due to Tripping of Both 220 KV Dondaicha-Jamde.
220KV	Kanhan - Bhandara - II	25-Aug-10	03.19	25-Aug-10	04.08	Distance Protection Operated Z-I.
220KV	Parli-Usmanabad	25-Aug-10	10.59	25-Aug-10	12.04	Distance Protection Operated Z-II.
220KV	Kalmeshwar - Pandurna	25-Aug-10	23.51	26-Aug-10	05.32	Distance Protection R-E, Tripped @ Kalmeshwar end only.
220KV	220/66 KV 50 MVA ICT-I @ Warora	25-Aug-10	19.05	25-Aug-10	19.31	Backup Protection.
220KV	220/66KV 50 MVA ICT- II @ Warora	25-Aug-10	19.05	25-Aug-10	19.31	No Indication Except B2 Four Meter Relay
220KV	220 KV TBC @ Dhamangaon	25-Aug-10	10.45	26-Aug-10	15.30	Bkr Overhaul Work.
220KV	Jejuri-Phursungi	26-Aug-10	09.50	26-Aug-10	19.50	Replacement of disc insulator.
220KV	Phursungi - Parvati	26-Aug-10	09.29	26-Aug-10	20.05	Replacement of disc insulator.
220KV	Main Bus @ Alephata	26-Aug-10	09.38	26-Aug-10	13.20	Maintenance work.
220KV	Jejuri-Jejuri I	26-Aug-10	12.12	26-Aug-10	13.15	Bus fault.
220KV	Nasik-Raymond	26-Aug-10	14.05	26-Aug-10	15.34	Distance protection.
220KV	Jejuri-Phursungi	26-Aug-10	18.25	26-Aug-10	23.02	Distance protection.
220KV	220 KV Aux. Bus At 400KV Chandrapur	26-Aug-10	09.25	26-Aug-10	11.07	Maintenance work.
220KV	Chandrapur MIDC - Gadchandur	26-Aug-10	16.20	26-Aug-10	17.46	Relay testing work.
220KV	220/33KV 100 MVA ICT - I @ Walve	26-Aug-10	11.15	26-Aug-10	13.25	Tripped on P.R.V.indication
220KV	Ambazari-Wardha	26-Aug-10	14.38	26-Aug-10	14.53	Distance protection.
220KV	Pusad - Nanded	26-Aug-10	19.41	26-Aug-10	19.58	Distance protection.
220KV	Bableshwar - Ahmednagar - I	27-Aug-10	02.15	27-Aug-10	10.38	Distance protection.
220KV	220/100KV 125 MVA ICT- III @ Kalwa	27-Aug-10	06.32	27-Aug-10	09.38	Attended red hot.
220KV	150 MVA ICT- I @ Boiser	27-Aug-10	08.57	27-Aug-10	17.34	Testing work.
220KV	Main Bus Section- I @ Pedambe	27-Aug-10	09.46	27-Aug-10	11.26	Replacement of damaged conductor for R Ph.isolator.
220KV	Pophali - Pedambe - I	27-Aug-10	09.43	27-Aug-10	11.46	To attend emergency outage of main bus section at Pedambe.
220KV	Pedambe - Mahad	27-Aug-10	09.42	27-Aug-10	13.15	To attend emergency outage of main bus section at pedambe.
220KV	Pedambe-Newkoyana	27-Aug-10	09.44	27-Aug-10	10.49	To attend emergency outage of main bus section at pedambe.
220KV	Kalwa - Ghatghar	27-Aug-10	12.19	27-Aug-10	15.33	To attend hot spot at R Ph.wave trap clamp at kalwa end.
220KV	220/100KV 125 MVA ICT-I @ Kalwa	27-Aug-10	21.07	28-Aug-10	00.24	Repl.of back up prot.relay.
220KV	Borivali (MSEB)- Borivali (T)	27-Aug-10	16.30	27-Aug-10	16.30	Newly charged commissioning line.
220KV	220/132 KV 200 MVA ICT @ Kawlewada	27-Aug-10	11.06	27-Aug-10	11.27	Bus fault.
220KV	220/132 KV 100 MVA ICT @ Kawlewada	27-Aug-10	11.06	27-Aug-10	11.45	Bus fault.
220KV	132 KV Main Bus At Kawlewada	27-Aug-10	11.06	27-Aug-10	11.27	Bus fault.
220KV	Ambazari-Wardha	27-Aug-10	13.55	27-Aug-10	18.28	220KV R Ph.PT burst.
220KV	Bhugaon-Wardha	27-Aug-10	13.55	28-Aug-10	16.27	Bus fault.
220KV	Warora-Wardha	27-Aug-10	13.55	27-Aug-10	18.30	Bus fault.
220KV	Butibori - Wardha	27-Aug-10	13.55	28-Aug-10	16.25	Bus fault.
220KV	Khaperkheda - Wardha.	27-Aug-10	13.55	28-Aug-10	16.26	Bus fault.
220KV	Wardha-Dhamangaon	27-Aug-10	13.55	28-Aug-10	16.28	Bus fault.

220KV	Wardha-Deoli	27-Aug-10	13.55	28-Aug-10	17.03	Bus fault.
220KV	Wardha - Yawatmal	27-Aug-10	13.55	28-Aug-10	16.41	Bus fault.
220KV	Wardha-RLY TSS I	27-Aug-10	13.55	27-Aug-10	18.44	Bus fault.
220KV	Wardha-Rly,TSS-II	27-Aug-10	13.55	27-Aug-10	18.44	Bus fault.
220KV	220/66KV 50 MVA ICT- I @ Wardha.	27-Aug-10	13.55	27-Aug-10	18.44	Bus fault.
220KV	220/66KV 50 MVA ICT- II @ Warora	27-Aug-10	13.55	27-Aug-10	18.44	Bus fault.
220KV	Main Bus At Wardha	27-Aug-10	13.55	27-Aug-10	18.28	Bus fault.
220KV	Babaleshwar - Ranjangaon	28-Aug-10	04.10	28-Aug-10	04.36	Distance protection.
220KV	Nerul-Kharghar	28-Aug-10	06.17	28-Aug-10	10.57	Replacement of Jumper
220KV	220/132 KV 200 MVA ICT-IV @ Nasik OCR	28-Aug-10	08.40	28-Aug-10	17.20	SFRA Testing
220KV	Babaleshwar - Nagar - I	28-Aug-10	09.30	28-Aug-10	16.32	Q.M.Work
220KV	Apta-Uran-II	28-Aug-10	09.45	28-Aug-10	18.19	Replacement of Insulator
220KV	Lonikand-Kathapur	28-Aug-10	09.48	28-Aug-10	15.39	Replacement of Insulator
220KV	Nasik-Raymond	28-Aug-10	10.04	28-Aug-10	16.21	Q.M.Work
220KV	Kandalgaon-Kharghar	28-Aug-10	11.21	28-Aug-10	19.02	LILO for Top work
220KV	Nasik-Navsari-I	28-Aug-10	09.05	28-Aug-10	11.10	Distance Protection
220KV	Babaleshwar - Ranjangaon	28-Aug-10	20.04	29-Aug-10	10.44	Distance Protection
220KV	Khadka - Bhadli RLY - II	28-Aug-10	11.43	28-Aug-10	18.03	Q.M.Work
220KV	Dondaicha - Sahada	28-Aug-10	16.20	28-Aug-10	21.30	Distance Protection
220KV	Kanhan - Bhandara - I	28-Aug-10	19.30	28-Aug-10	19.44	Distance Protection
220KV	Kandalgaon-Kharghar	28-Aug-10	19.02	29-Aug-10	11.11	Flashover of disc insulator.
220KV	220/132KV 100MVA ICT-II @ Chalisgaon	29-Aug-10	03.40	29-Aug-10	19.58	Tripped on Buchholz
220KV	Kharghar-TSS	29-Aug-10	06.51	29-Aug-10	11.17	To attend the breakdown of Kandalgaon-Kharghar line.
220KV	Padgha - Nalasopara	29-Aug-10	10.02	29-Aug-10	10.29	Distance protection.
220KV	Padgha-Kamba	29-Aug-10	09.56	29-Aug-10	10.50	Distance protection.
220KV	Wada-Kolshet	29-Aug-10	09.56	29-Aug-10	11.10	Distance protection.
220KV	Kolshet - Kamba	29-Aug-10	09.56	29-Aug-10	19.57	Distance protection.
220KV	Boiser-Taps	29-Aug-10	08.29	29-Aug-10	12.47	CRM and timing of CB.
220KV	Padgha - Boisar (PGCIL)	29-Aug-10	10.02	29-Aug-10	11.38	Distance protection.
220KV	PADGHA-BOISER (PGCIL)	29-Aug-10	15.56	29-Aug-10	20.23	H/T to attend hot spot Kamba-kolshet line.
220KV	Kalwa-Mulund II	29-Aug-10	23.59	30-Aug-10	00.39	Tripped.taaken on TBC.
132KV	Umri - Kundalwadi	23-Aug-10	19.42	23-Aug-10	20.05	Distance Protection
132KV	Amravati - Morshi	23-Aug-10	06.10	23-Aug-10	06.35	Distance Protection
132KV	Bhandara - Ambhora - I	24-Aug-10	21.05	24-Aug-10	21.14	Distance Protection
132KV	Malkapur-RLY TSS - II	24-Aug-10	11.00	24-Aug-10	21.45	CT Replacement work
132KV	Kanhan - Bhandara	25-Aug-10	21.40	25-Aug-10	22.05	Back up Protection Operated.
132KV	Bus Section - I @ Madgi	25-Aug-10	13.05	25-Aug-10	17.05	Rehealthening of 132KV Bus Insulators & Replacement Damaged Insulators.
132KV	Nardhane - Shirpur	27-Aug-10	05.15	27-Aug-10	19.10	Distance protection.
132KV	Nardhane-Dhule	27-Aug-10	04.25	27-Aug-10	11.35	Distance protection.
132KV	Kawlewadi-Madgi-I	27-Aug-10	11.06	27-Aug-10	11.55	Bus bar protection operated.
132KV	Madgi-Kawlewada-II	27-Aug-10	110.06	27-Aug-10	11.57	Bus fault.
132KV	Kawalewada-Gondia-I	27-Aug-10	11.06	27-Aug-10	11.48	Bus fault.
132KV	Kawlewada-Gondia-II	27-Aug-10	11.06	27-Aug-10	11.38	Bus fault.
132KV	Kawalewada - Kachewani Rly	27-Aug-10	11.06	27-Aug-10	11.32	Bus fault.
132KV	Paras-Malkapur	27-Aug-10	01.26	27-Aug-10	01.45	Distance protection.
132KV	Malkapur - Khamgaon	27-Aug-10	01.26	27-Aug-10	01.50	Distance protection.
132KV	Amravati - Lalkhedi	27-Aug-10	02.27	27-Aug-10	02.40	Distance protection.
132KV	Lalkhedi - Durgwada	27-Aug-10	02.27	27-Aug-10	02.58	Backup protection.
132KV	Durgwada - Akola MIDC	27-Aug-10	02.27	27-Aug-10	03.02	Backup protection.
132KV	Parbhani-Parthur	27-Aug-10	02.28	27-Aug-10	02.44	Distance protection.

132KV	Bhandara-Mouda	27-Aug-10	03.48	27-Aug-10	04.20	Distance protection.
132KV	Kanhan - Bhandara	27-Aug-10	03.48	27-Aug-10	04.09	Backup protection.
132KV	Bhandara-Ambhora	27-Aug-10	04.20	27-Aug-10	04.35	Distance protection
132KV	Bhandara - Madgi -I	27-Aug-10	11.00	27-Aug-10	23.14	Distance protection.
132KV	Bhandara - Madgi - II	27-Aug-10	11.00	27-Aug-10	23.16	Distance protection.
132KV	Bhandara - Madgi - II	28-Aug-10	02.10	28-Aug-10	02.19	Distance Protection
132KV	Kalmeshwar-Hingna-II	28-Aug-10	14.10		Continued.	Distance Protection
132KV	Khapri - Besa	28-Aug-10	14.10	28-Aug-10	16.10	Backup Protection Operated
132KV	Ambazari-Kalmeshwar	28-Aug-10	17.12		Continued.	Tripped
132KV	Amravati - Achalpur	28-Aug-10	18.20	28-Aug-10	18.34	Distance Protection
100KV	Kalwa - Salshet - I	27-Aug-10	21.07	28-Aug-10	00.22	To control load of kalwa ICT.