

LINE OUTAGES FOR THE WEEK

FROM 22-Aug-11 TO 28-Aug-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole-I	21-Aug-11	11.19	28-Aug-11	17.53	Annual Maintenance Work.
400KV	Wardha - Akola - I	19-Aug-11	23.33	27-Aug-11	10.06	Over Voltage
400KV	Kolhapur - Mapusa - II	19-Aug-11	18.22	22-Aug-11	11.10	Over Voltage
400KV	400/220 KV315 MVA ICT-I @ BBLR	19-Aug-11	23.35	22-Aug-11	07.15	Oil Filtration work
400KV	Bhusawal- Aurangabad	20-Aug-11	18.36	22-Aug-11	11.48	Over Voltage
400KV	Karad - Kolhapur - II	21-Aug-11	00.23	23-Aug-11	05.51	Over Voltage
400KV	Dhule-Khandwa I	21-Aug-11	00.38	22-Aug-11	08.36	Over Voltage
400KV	Karad - Solapur (PGCIL)	21-Aug-11	22.07	22-Aug-11	08.17	Over Voltage.
400KV	Bhusawal- Aurangabad	22-Aug-11	18.37	23-Aug-11	10.22	Over Voltage.
400KV	Kolhapur - Mapusa - I	22-Aug-11	17.59	24-Aug-11	11.41	Over Voltage.
400KV	Karad - Solapur (PGCIL)	22-Aug-11	18.40	23-Aug-11	06.55	Over Voltage.
400KV	Dabhol - New Koyna - I	22-Aug-11	08.50	22-Aug-11	17.28	Replacement of Broken Insulator String.
400KV	Lonikand- Koyna Stage IV	22-Aug-11	12.55	22-Aug-11	16.02	For Hot Spot Attending Line on TBC.
400KV	Babaleshwar - Bhusawal	22-Aug-11	11.42	22-Aug-11	18.32	Termination of Cables of 500 MVA ICT.
400KV	Padgha - Kalwa- I	22-Aug-11	22.18	23-Aug-11	06.07	Retrofitting of Main-II Protection Relay.
400KV	Lonikand- Koyna Stage IV	22-Aug-11	12.50	22-Aug-11	13.15	Tripped @ Stage-IV End.
400KV	400/220KV 105 MVA Spare ICT at Parly II	22-Aug-11	13.50		Continued.	To Remove Trip Coil Assembly for Bus Coupler.
400KV	Karad-New Koyna II	23-Aug-11	04.45	23-Aug-11	09.05	Due to R Ph Pole CB Burst,While Opening Karad-New Koyna-II
400KV	Karad - Lonikand	23-Aug-11	04.45	23-Aug-11	09.52	Due to R Ph Pole CB Burst,While Opening Karad-New Koyna-II
400KV	Karad - Kolhapur - I	23-Aug-11	04.45		Continued.	Due to R Ph Pole CB Burst,While Opening Karad-New Koyna-II
400KV	400/220KV,315MVA ICT-I at Karad	23-Aug-11	04.45	23-Aug-11	10.33	Due to R Ph Pole CB Burst,While Opening Karad-New Koyna-II
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	23-Aug-11	08.50	23-Aug-11	17.29	Bay Maint.and R.M.Work
400KV	400/220KV 315 MVA ICT-II at Korady	23-Aug-11	15.18	23-Aug-11	15.41	Bus side isolator problem.
400KV	Karad - Solapur (PGCIL)	23-Aug-11	20.49	24-Aug-11	06.51	Over Voltage.
400KV	Bhusawal- Aurangabad	23-Aug-11	19.53	24-Aug-11	10.07	Over Voltage.
400KV	Dhule-Khandwa-II	23-Aug-11	22.25	25-Aug-11	12.28	Dist.Protection operated,Z-I,B-Ph.
400KV	Parli - Solapur	24-Aug-11	09.01	25-Aug-11	09.16	Crossing work of New 400KV Parly PG line
400KV	Kolhapur - Mapusa - II	24-Aug-11	22.34	25-Aug-11	11.10	Over Voltage.
400KV	Bhusawal- Aurangabad	24-Aug-11	20.16	28-Aug-11	08.33	Over Voltage.
400KV	New Koyna - Stage IV	24-Aug-11	09.40	24-Aug-11	16.12	R.M.Work
400KV	400/220 KV 500 MVA ICT-I @ Deepnagar	24-Aug-11	10.29	24-Aug-11	19.04	SFRA Test Of ICT.
400KV	400/220 KV,500MVA ICT-II at Deepnagar.	24-Aug-11	10.30	24-Aug-11	18.44	SFRA Test Of ICT.
400KV	Main Bus- II @ Jejuri	25-Aug-11	16.00	25-Aug-11	23.33	R and B phase CVT replacement.
400KV	Karad - Solapur (PGCIL)	25-Aug-11	21.39		Continued.	Over Voltage
400KV	Kolhapur - Mapusa - I	25-Aug-11	21.55	27-Aug-11	11.07	Over Voltage.
400KV	Lonikand- Koyna Stage IV	25-Aug-11	23.42	26-Aug-11	07.26	Over Voltage.
400KV	Dhule-Khandwa-II	25-Aug-11	23.34		Continued.	Over Voltage.
400KV	Akola - Aurangabad - II	26-Aug-11	21.28		Continued.	Over Voltage
400KV	Bableshwar-Aurangabad	26-Aug-11	03.40	26-Aug-11	08.22	Tripped on Over Voltage.
400KV	New Koyna-Karad-II	26-Aug-11	09.37	26-Aug-11	13.10	B Phase CVT Testing
400KV	Padgha - Nagothane - I	26-Aug-11	14.31	26-Aug-11	18.34	Red Hot
400KV	Koradi - Akola	27-Aug-11	09.36	28-Aug-11	08.08	Line Maint.work,(Ready for charging at 17.55Hrs)
400KV	Akola - Wardha - II	27-Aug-11	03.20		Continued.	Over Voltage
400KV	Lonikand - Jejuri	27-Aug-11	01.55	27-Aug-11	09.25	Distance Protection
400KV	Padgha - Nagothane- II	27-Aug-11	09.54	27-Aug-11	10.59	Fault on Main Bus-II at Nagothane
400KV	Dabhol-Nagothane-II	27-Aug-11	09.54	27-Aug-11	10.48	Fault on Main Bus-II at Nagothane
400KV	400/220 KV 315 MVA ICT-II @ Nagothane.	27-Aug-11	09.54	27-Aug-11	10.36	Fault on Main Bus-II at Nagothane

400KV	Main Bus -II @ Nagothane	27-Aug-11	09.54	27-Aug-11	20.36	Tripped
400KV	Kolhapur - Mapusa - II	27-Aug-11	22.09		Continued.	Over Voltage
400KV	Koyna IV - Jejuri	27-Aug-11	02.47	28-Aug-11	19.12	Distance Protection
400KV	Akola - Bhusawal	28-Aug-11	04.20	28-Aug-11	08.15	Over Voltage
400KV	Lonikand- Koyna Stage IV	28-Aug-11	00.49	28-Aug-11	08.23	Over Voltage
400KV	Akola - Wardha - I	28-Aug-11	04.20		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	28-Aug-11	16.03		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	28-Aug-11	22.53		Continued.	Over Voltage.
220KV	Khaparkheda - Kanhan - I	16-Aug-11	09.36	23-Aug-11	19.45	Tower height extension work up to 24.08.2011.
220KV	Kanhan - Bhandara - I	16-Aug-11	09.23	23-Aug-11	19.47	Tower height extension work up to 24.08.2011.
220KV	Padgha - Temghar - II	20-Aug-11	15.22	24-Aug-11	11.27	To Control Padgha ICT Load
220KV	220/132KV 100 MVA ICT- I @ Kanhan	20-Aug-11	13.31	23-Aug-11	10.51	Breaker Overhaul(ICT LV side is on TBC)
220KV	Nasik-Bablsr - II	21-Aug-11	19.15	25-Aug-11	12.12	To Control Babaleshwar ICT Loading.
220KV	220 KV Main Bus @ Bhosari	22-Aug-11	00.19	22-Aug-11	03.48	To Attend Hot Spot on Bus Side Isolator of 220KV Chakan Line.
220KV	Mahape-Tifil	22-Aug-11	22.00	22-Aug-11	23.23	To Attend Oil Leakage of B Ph. C T.
220KV	Hinjewadi-I-Chinchwad	22-Aug-11	11.14	22-Aug-11	12.09	Distance Protection.
220KV	220/22KV 50MVA T/F-I at Ranjangaon	22-Aug-11	19.10	22-Aug-11	20.50	Due to D C Leakage & Master Trip Relay.
220KV	Pawas-Kharepatan	22-Aug-11	12.40	22-Aug-11	12.56	Distance Protection.
220KV	Nivali-Pawas	22-Aug-11	12.40	22-Aug-11	13.02	Tripped Alongwith Kharephtan Line.
220KV	220/33 KV 50 MVA T/F @ Tilawani	22-Aug-11	09.30	22-Aug-11	11.00	Attending Hot Spot.
220KV	220/110 KV 200 MVA T/F-II @ Apta	22-Aug-11	12.40	22-Aug-11	15.54	Quarterly Bay Maint.
220KV	Bhusawal-Chalisgaon-I	22-Aug-11	10.02	27-Aug-11	12.08	Replacement of Bus Isolator,Ckt on TBC.
220KV	New Paras TPS - Chikhali - I	22-Aug-11	08.27	22-Aug-11	20.41	Stringing Work of 220KV Akola-Balapur Line Loc.25.
220KV	New Paras TPS - Chikhali - II	22-Aug-11	08.28	22-Aug-11	20.44	Stringing Work of 220KV Akola-Balapur Line Loc.25.
220KV	220 KV Main Bus-I @ Koradi	22-Aug-11	09.00	22-Aug-11	22.27	Repl of 20A Isolator Complete Arm Set in 220KV ICT-II Bay.
220KV	Pedambe-Mahad	23-Aug-11	10.09	23-Aug-11	18.33	R.M.Work.
220KV	Karad-Vita-II	23-Aug-11	10.20	23-Aug-11	16.31	Maintenance work.
220KV	Dhule-Chalisgaon	23-Aug-11	10.11	23-Aug-11	19.20	Isolator replacement work.
220KV	Uran-Kharghar-II	23-Aug-11	10.30	23-Aug-11	17.55	Insulator replacement work.
220KV	Badnera - Deoli (PGCIL)	23-Aug-11	17.35	23-Aug-11	18.10	R-Ph auto recloser operated.
220KV	New Paras TPS-Alola-II	23-Aug-11	14.09	23-Aug-11	19.20	For stringing of 220KV Apatapa-Balapur DC line Loc.no 0/0 to 0/1.
220KV	Akola - Badnera - I	23-Aug-11	14.15	23-Aug-11	19.16	For stringing of 220KV Apatapa-Balapur DC line Loc.no 0/0 to 0/1.
220KV	New Paras TPS - Akola - I	23-Aug-11	14.08	23-Aug-11	19.15	For stringing of 220KV Apatapa-Balapur DC line Loc.no 0/0 to 0/1.
220KV	Chandrapur - Rly TSS - I	23-Aug-11	11.15	23-Aug-11	20.45	CT circular wiring of bay IED of RTU DC Project
220KV	Gadchiroli - Virur	23-Aug-11	14.20	23-Aug-11	21.56	To take Dist.Prot. scheme I/S.
220KV	Abhijeet-Wardha-I	23-Aug-11	15.05	23-Aug-11	15.55	ICT-II outage at Koradi.
220KV	Abhijeet - Wardha ckt - II	23-Aug-11	15.05	23-Aug-11	15.55	ICT-II outage at Koradi.
220KV	Chandrapur - Chandrapur MIDC	23-Aug-11	12.49	24-Aug-11	10.34	CKT on TBC for attending Hot Spot on Main Bus Isolator.
220KV	Halkarni-Amona I	24-Aug-11	12.39	25-Aug-11	13.07	Dist.Protection.
220KV	Bus section - I @ Pawas	24-Aug-11	08.30	24-Aug-11	18.40	C.T and P.T. New erection.
220KV	Malinagar-Temburni	24-Aug-11	16.00	24-Aug-11	18.07	Bay Maint.Work
220KV	Mudshingi-Wathar	24-Aug-11	10.10	24-Aug-11	12.22	Attending hot spot.
220KV	Dhamangaon - Badnera	24-Aug-11	10.28	24-Aug-11	17.55	Isoalator Jaw Replacement.
220KV	Gadchiroli - Virur	24-Aug-11	09.47	24-Aug-11	12.39	Tan Delta Measurement.
220KV	Usmanabad-Barshi	24-Aug-11	10.07	24-Aug-11	13.10	Q.M.Work
220KV	Pusad-Nanded	24-Aug-11	18.53	24-Aug-11	19.04	At Nanded end only.Line A/R optd at Pusad end.
220KV	220/132 KV 100 MVA ICT - I @ Amalner	24-Aug-11	00.55	24-Aug-11	07.00	Main Buchholz Prot Operated.

220KV	Jejuri I-Jejuri II	25-Aug-11	08.19	25-Aug-11	21.13	Isolator retrofitting upgradation.
220KV	Apta-Bombay Dyeing	25-Aug-11	11.07	25-Aug-11	13.14	Hot spot attending.
220KV	Uran - Khargar - I	25-Aug-11	09.48	25-Aug-11	13.23	Removal of jumper of line.
220KV	Karad - Miraj	25-Aug-11	09.32	25-Aug-11	13.46	Wave trap replacement.
220KV	220/132 KV,200MVA ICT-I at Nasik GCR	25-Aug-11	10.14	25-Aug-11	12.50	Maintenance work.
220KV	Khadka-Badli Ckt.II	25-Aug-11	09.14	25-Aug-11	11.29	Measurement of Tan Delta of CT
220KV	Khaparkheda - Kanhan - II	25-Aug-11	09.49		Continued.	Tower Height Raising work
220KV	Badnera--Rly.TSS - I	25-Aug-11	10.38	25-Aug-11	16.07	Q.M.Work
220KV	Kanhan - Bhandara - II	25-Aug-11	09.54		Continued.	Tower Height Raising work
220KV	220 KV Main Bus @ Yavatmal	25-Aug-11	11.38	25-Aug-11	18.00	Bus PT Replacement
220KV	Padgha - Temghar - II	25-Aug-11	11.50		Continued.	To control Padgha ICT Load
220KV	Mahape-Tifil	26-Aug-11	09.47	26-Aug-11	16.53	Testing and Maint.work
220KV	Pedambe - Tambati	26-Aug-11	11.40	26-Aug-11	15.29	Replacement of B Phase WT Jumper
220KV	Pophali-K'gaon	26-Aug-11	16.10	26-Aug-11	17.58	Distance Protection
220KV	220/33KV 50 MVA T/F- I @ Boiser	26-Aug-11	11.21	26-Aug-11	13.23	Red Hot
220KV	Khaparkheda-Kawlewada-I	26-Aug-11	13.07	26-Aug-11	21.03	Relay Retrofitting work
220KV	Chandrapur MIDC - Gadchandur	26-Aug-11	16.07	26-Aug-11	17.07	Distance Protection
220KV	Chandrapur - Warora	26-Aug-11	02.29		Continued.	Over Voltage
220KV	Jambul - Pal	26-Aug-11	07.43	26-Aug-11	18.56	Maint.work
220KV	Kanhan - Umred	27-Aug-11	20.51	27-Aug-11	21.24	Distance Protection
220KV	Borivali-Kalwa	27-Aug-11	08.51	27-Aug-11	14.17	To replace Old Insulator String
220KV	220/132,200MVA Tr.-2 @ A' Nager	27-Aug-11	08.30	27-Aug-11	15.42	To Check fire system of CTR services
220KV	Dhule-Chalisgaon	27-Aug-11	11.34	27-Aug-11	15.30	Jumpering work at Chalisgaon end
220KV	Hinjawadi-I - Hinjawadi-II	27-Aug-11	12.25	27-Aug-11	14.05	B Phase W/T replacement work
220KV	Bhugaon-Wardha	27-Aug-11	09.56	27-Aug-11	12.08	Hot Spot on CT
220KV	Chandrapur MIDC - Gadchandur	27-Aug-11	14.39	27-Aug-11	15.37	Distance Protection
220KV	Chandrapur MIDC - Gadchandur	27-Aug-11	17.43	27-Aug-11	20.06	R Phase C/C Burst
220KV	220/132 KV,200 MVA ICT-II At Chalisgaon	27-Aug-11	16.20	27-Aug-11	17.23	Trip Ckt Faulty Indication appeared
220KV	Umred - Virangana	27-Aug-11	20.51	27-Aug-11	21.32	Bus Bar Prot.Operated
220KV	Main Bus at Umred	27-Aug-11	20.51	27-Aug-11	21.32	Bus Bar Prot.Operated
220KV	Khaparkheda-Kawlewada-I	27-Aug-11	15.00	28-Aug-11	20.14	Taking Distance Scheme in service
220KV	Gadchandur-Virur-I	27-Aug-11	11.20	27-Aug-11	14.05	Replacement of Post Insulator
220KV	Karad-Pophali	28-Aug-11	16.12	28-Aug-11	16.42	Distance Protection.
220KV	Borivali-Boisar	28-Aug-11	09.43	28-Aug-11	13.53	Hot Spot Attending Work.
220KV	220/110KV,200MVA T/F At Ichalkarani.	28-Aug-11	13.12	28-Aug-11	20.30	On OLTC Buchholz.
220KV	Vita - Ghatnandare	28-Aug-11	10.33	28-Aug-11	13.15	Hot Spot Attending Work.
220KV	220/132KV 100MVA ICT-I at Dondaicha	28-Aug-11	14.29	28-Aug-11	15.30	Maintenance Work.
132KV	Bale - Nuldurg	21-Aug-11	16.44	22-Aug-11	17.15	Tripped.
132KV	Beed-Gevrai	24-Aug-11	01.21	24-Aug-11	01.41	Distance Protection.
132KV	Bale - Nuldurg	24-Aug-11	01.00	24-Aug-11	01.18	Distance Protection.

132KV	Bale-Ujani-II	24-Aug-11	01.00	24-Aug-11	01.20	Distance Protection.
132KV	Gadhchiroli-Vayunandana	24-Aug-11	07.50	24-Aug-11	09.36	Tan Delta Measurement.
132KV	Giravali-Gangakhed	24-Aug-11	06.05	24-Aug-11	06.28	Dist.Prot.Operated,Z-II.
132KV	Chalisgaon - Manmad - I	24-Aug-11	11.30	25-Aug-11	20.57	Line Isolator replacement
132KV	Karanja-Mangrulpir	25-Aug-11	12.29	25-Aug-11	15.08	Replacement of CB driving mechanism
132KV	132/22KV 50MVA T/F-II at Walchandnagar	25-Aug-11	07.02	27-Aug-11	18.45	B Phase CT Burst
132KV	Bus Section -I at Boiser	26-Aug-11	10.54	26-Aug-11	13.50	Red Hot
132KV	Amravati - Achalpur	26-Aug-11	05.35	26-Aug-11	06.00	Distance Protection
132KV	Kawalewada-Gondia-I	27-Aug-11	10.12	27-Aug-11	12.42	Replacement of R Phase Disc Insulator
132KV	Kawlewada-Gondia-II	27-Aug-11	10.11	27-Aug-11	13.08	Replacement of R Phase Disc Insulator
132KV	Kawlewada-Gondia-II	27-Aug-11	19.49	27-Aug-11	20.05	Distance Protection
132KV	Main Bus-I at Bhusawal-I	27-Aug-11	13.08		Continued.	Bus and Line Isolator repl.work
110KV	Miraj-Kavathemahakal	28-Aug-11	11.35	28-Aug-11	17.30	Criming Work.
100KV	Kalwa-Nocil II	22-Aug-11	12.18	22-Aug-11	21.04	R Ph. L A Brokendown @ Nocil
100KV	Borivali-Tata-I	28-Aug-11	10.25	28-Aug-11	20.22	RTU SCADA & Separation of D C Source.
100KV	Borivali-Tata-II	28-Aug-11	10.30	28-Aug-11	20.22	RTU SCADA & Separation of D C Source.