

# LINE OUTAGES FOR THE WEEK

FROM 20-Sep-10 TO 26-Sep-10

| Voltage | Name                                | date_trip | time_trip | date_sync | time_sync  | reason                                        |
|---------|-------------------------------------|-----------|-----------|-----------|------------|-----------------------------------------------|
| 400KV   | Main Bus-I At Stage-4 Koyna.        | 12-Aug-10 | 11.50     | 25-Sep-10 | 10.00      | Routine Maintainance Work.                    |
| 400KV   | Akola - Wardha - II                 | 1-Sep-10  | 01.48     | 21-Sep-10 | 17.34      | Over Voltage.                                 |
| 400KV   | Akola - Aurangabad - II             | 4-Sep-10  | 12.29     | 25-Sep-10 | 14.26      | Over Voltage.                                 |
| 400KV   | Kolhapur - Mapusa - I               | 6-Sep-10  | 17.51     | 22-Sep-10 | 14.49      | Over Voltage                                  |
| 400KV   | Karad - Kolhapur - I                | 18-Sep-10 | 22.23     | 21-Sep-10 | 10.00      | Over Voltage.                                 |
| 400KV   | Lonikand- Koyna Stage IV            | 19-Sep-10 | 23.30     | 20-Sep-10 | 08.04      | Over Voltage                                  |
| 400KV   | Karad-Lamboti                       | 19-Sep-10 | 23.36     | 20-Sep-10 | 09.02      | Over Voltage.                                 |
| 400KV   | Dhule-SarSarovar - II               | 19-Sep-10 | 23.14     | 20-Sep-10 | 18.53      | Over Voltage.                                 |
| 400KV   | Newkoyna - Jaigad - I               | 20-Sep-10 | 08.00     | 23-Sep-10 | 13.31      | Coupling of 400KV GIS Stage-II with Stage-I   |
| 400KV   | Chandrapur-Bhadravti - I            | 20-Sep-10 | 11.12     | 20-Sep-10 | 13.24      | Mock Drill                                    |
| 400KV   | Karad-Lamboti                       | 21-Sep-10 | 00.54     | 21-Sep-10 | 09.42      | Over Voltage                                  |
| 400KV   | Karad - Kolhapur - II               | 21-Sep-10 | 10.26     | 22-Sep-10 | 11.37      | LA Replacement , ready for charging           |
| 400KV   | Wardha - Akola - I                  | 21-Sep-10 | 17.45     |           | Continued. | Interchange                                   |
| 400KV   | Karad-Lamboti                       | 21-Sep-10 | 22.44     | 22-Sep-10 | 08.33      | Over Voltage                                  |
| 400KV   | Lonikand- Koyna Stage IV            | 21-Sep-10 | 23.14     | 22-Sep-10 | 08.29      | Over Voltage                                  |
| 400KV   | Karad - Kolhapur - II               | 22-Sep-10 | 18.03     | 23-Sep-10 | 14.28      | Over Voltage.                                 |
| 400KV   | Karad-Lamboti                       | 22-Sep-10 | 21.45     | 23-Sep-10 | 07.35      | Over Voltage.                                 |
| 400KV   | Lonikand- Koyna Stage IV            | 22-Sep-10 | 22.02     | 23-Sep-10 | 08.26      | Over Voltage.                                 |
| 400KV   | Kolhapur - Mapusa - II              | 22-Sep-10 | 22.02     | 23-Sep-10 | 08.45      | Over Voltage.                                 |
| 400KV   | Chandrapur - Parli - II             | 23-Sep-10 | 01.49     | 23-Sep-10 | 07.36      | Over Voltage.                                 |
| 400KV   | Bablsr-Padgha Ckt I                 | 23-Sep-10 | 02.19     | 23-Sep-10 | 06.42      | Over Voltage.                                 |
| 400KV   | Kolhapur - Mapusa - I               | 23-Sep-10 | 09.48     |           | Continued. | C.B.Problem at Kolhapur.                      |
| 400KV   | Karad-Lamboti                       | 23-Sep-10 | 23.58     | 24-Sep-10 | 08.05      | Over Voltage.                                 |
| 400KV   | New Koyna - Karad - I               | 24-Sep-10 | 00.05     |           | Continued. | Taken on TBC, Breaker Problem.                |
| 400KV   | Lonikand- Koyna Stage IV            | 24-Sep-10 | 01.31     | 24-Sep-10 | 08.48      | Over Voltage.                                 |
| 400KV   | Karad - Kolhapur - II               | 24-Sep-10 | 00.01     | 24-Sep-10 | 09.16      | Over Voltage.                                 |
| 400KV   | Padgha - Kharghar                   | 24-Sep-10 | 15.15     | 24-Sep-10 | 17.11      | To attend red hot.                            |
| 400KV   | Main Bus - I @ Bhusawal             | 24-Sep-10 | 10.45     | 24-Sep-10 | 19.36      | Jumpering work.                               |
| 400KV   | 400/220KV 315 MVA ICT-I @ Padgha    | 24-Sep-10 | 09.35     | 24-Sep-10 | 18.33      | Bay maintenance work and hot spot attending.  |
| 400KV   | Dabhol-Nagothane-II                 | 24-Sep-10 | 08.37     | 25-Sep-10 | 09.19      | Replacement of nutbolts.                      |
| 400KV   | Main Bus I at 400KV BBLSR           | 24-Sep-10 | 20.39     | 24-Sep-10 | 21.27      | Bus fault at Bableshwar end at Y-Ph IPS tube. |
| 400KV   | Babaleshwar - Dhule - II            | 24-Sep-10 | 20.39     | 24-Sep-10 | 22.22      | Bus fault at Bableshwar end at Y-Ph IPS tube. |
| 400KV   | Babaleshwar - Bhusawal              | 24-Sep-10 | 20.39     | 25-Sep-10 | 12.36      | Bus fault at Bableshwar end at Y-Ph IPS tube. |
| 400KV   | Bablsr-Padgha Ckt I                 | 24-Sep-10 | 20.39     | 24-Sep-10 | 22.37      | Bus fault at Bableshwar end at Y-Ph IPS tube. |
| 400KV   | 400/220 KV315 MVA ICT-I @ BBLR      | 24-Sep-10 | 20.39     | 24-Sep-10 | 21.50      | Bus fault at Bableshwar end at Y-Ph IPS tube. |
| 400KV   | Karad-Lamboti                       | 24-Sep-10 | 22.40     | 25-Sep-10 | 08.00      | Over Voltage.                                 |
| 400KV   | Karad - Kolhapur - I                | 24-Sep-10 | 22.46     | 25-Sep-10 | 08.52      | Over Voltage.                                 |
| 400KV   | Lonikand- Koyna Stage IV            | 24-Sep-10 | 23.46     | 25-Sep-10 | 10.00      | Over Voltage.                                 |
| 400KV   | 400/132KV 200 MVA ICT- I @ Bhusawal | 24-Sep-10 | 13.17     | 24-Sep-10 | 15.59      | Connecting jumper.(HV side on TBC)            |
| 400KV   | Dabhol-Nagothane - II               | 25-Sep-10 | 09.35     | 25-Sep-10 | 12.26      | CVT fuse fail at Dabhol end.                  |

|       |                                    |           |        |           |            |                                                        |
|-------|------------------------------------|-----------|--------|-----------|------------|--------------------------------------------------------|
| 400KV | Akola - Aurangabad - I             | 25-Sep-10 | 14.21  |           | Continued. | Over Voltage.                                          |
| 400KV | Bablsr-Padgha Ckt I                | 25-Sep-10 | 16.01  | 25-Sep-10 | 16.08      | PDR operated at Padgha end.                            |
| 400KV | Dabhol-Nagothane - II              | 25-Sep-10 | 17.10  | 25-Sep-10 | 18.42      | A/R blockd Main-I,Main-II.                             |
| 400KV | Kalwa-Kharghar                     | 25-Sep-10 | 14.35  | 25-Sep-10 | 14.56      | Attending red hot on B Ph.B bus.                       |
| 400KV | 400/220 KV 315MVA ICT-II @ Karad   | 25-Sep-10 | 14.47  | 25-Sep-10 | 17.17      | Oil top up work                                        |
| 400KV | Karad - Kolhapur - II              | 25-Sep-10 | 22.54  | 26-Sep-10 | 09.26      | Over Voltage,Taken on TBC at Kolhapur end.             |
| 400KV | Karad-Lamboti                      | 25-Sep-10 | 22.33  | 26-Sep-10 | 09.33      | Over Voltage.                                          |
| 400KV | STG IV-New Koyna-II                | 26-Sep-10 | 04.06  | 26-Sep-10 | 10.45      | Over Voltage.                                          |
| 400KV | Stage-IV - Jejuri                  | 26-Sep-10 | 04.06  | 26-Sep-10 | 08.56      | Over Voltage.                                          |
| 400KV | Kalwa-Kharghar                     | 26-Sep-10 | 04.36  | 26-Sep-10 | 11.39      | Due to sparking of wave trap at Kharghar end.          |
| 400KV | Karad - Kolhapur - I               | 26-Sep-10 | 09.44  | 26-Sep-10 | 11.31      | Attending red hot.                                     |
| 400KV | 400/220 KV 600 MVA ICT- I @ Kalwa  | 26-Sep-10 | 07.12  | 27-Sep-10 | 02.07      | Bus bar protection operated.Y Ph.CT burst.             |
| 400KV | Kalwa-Kharghar                     | 26-Sep-10 | 07.12  | 26-Sep-10 | 09.17      | Bus fault at Kalwa.                                    |
| 400KV | Kalwa - Padgha - I                 | 26-Sep-10 | 07.12  | 26-Sep-10 | 15.34      | Bus fault at Kalwa.                                    |
| 400KV | Kalwa - Lonikand                   | 26-Sep-10 | 07.12  | 26-Sep-10 | 08.13      | Bus fault at Kalwa.                                    |
| 400KV | Dabhol-Nagothane - II              | 26-Sep-10 | 14.44  | 26-Sep-10 | 15.48      | B Ph.to Earth.                                         |
| 400KV | 400KV Bus Coupler @ Kalwa          | 26-Sep-10 | 07.12  | 26-Sep-10 | 15.10      | Air pressure pipe burst.                               |
| 400KV | Karad - Kolhapur - I               | 26-Sep-10 | 21.11  |           | Continued. | To attend red hot.Line ready for charging @ 01.29 hrs. |
| 400KV | 400/220 KV 600 MVA ICT- II @ Kalwa | 26-Sep-10 | 22.02  | 27-Sep-10 | 00.52      | Due to red hot.                                        |
| 400KV | Karad-Lamboti                      | 26-Sep-10 | 22.42  |           | Continued. | Over Voltage.                                          |
| 400KV | Lonikand- Koyna Stage IV           | 26-Sep-10 | 23.24  |           | Continued. | Over Voltage.                                          |
| 400KV | Dhule-S'Sarovar I                  | 26-Sep-10 | 23.27. |           | Continued. | Over Voltage.                                          |
| 400KV | Main Bus - II @ Koyna Stg - IV     | 26-Sep-10 | 10.45  |           | Continued. | Maintenance Work.                                      |
| 220KV | 220/6.6 KV Stn Tr - II @ K'Kheda   | 6-Sep-10  | 08.58  | 22-Sep-10 | 10.15      | Annual Maint.of Bay                                    |
| 220KV | Bus section-I At Borivali.         | 19-Sep-10 | 22.34  | 20-Sep-10 | 00.15      | R Ph.jumper bottom palm nut bolt replacement work.     |
| 220KV | Borivali (MSEB)- Borivali (T)      | 19-Sep-10 | 22.23  | 20-Sep-10 | 00.45      | Emergency outage on 220KV M.B.section No.1 At Boriali. |
| 220KV | Borivali-Mulund                    | 19-Sep-10 | 22.23  | 20-Sep-10 | 00.24      | Emergency outage on 220KV M.B.section No.1 At Boriali. |
| 220KV | Borivali-Tarapur                   | 19-Sep-10 | 22.27  | 20-Sep-10 | 00.35      | Emergency outage on 220KV M.B.section No.1 At Boriali. |
| 220KV | Miraj -Ichalkarajini               | 19-Sep-10 | 22.30  | 20-Sep-10 | 19.30      | Distance Protection                                    |
| 220KV | Kalwa - Borivali                   | 20-Sep-10 | 05.55  | 20-Sep-10 | 12.32      | Red Hot work.                                          |
| 220KV | BBLSR-Waluj                        | 20-Sep-10 | 08.00  | 22-Sep-10 | 13.18      | Insulator replacement                                  |
| 220KV | Babaleshwar - Chalisgaon           | 20-Sep-10 | 11.50  | 20-Sep-10 | 15.56      | Distance Protection                                    |
| 220KV | Babaleshwar - Nagar - II           | 20-Sep-10 | 11.59  | 20-Sep-10 | 12.14      | Load Trimming operated                                 |
| 220KV | Babaleshwar - Nagar - I            | 20-Sep-10 | 11.59  | 20-Sep-10 | 16.03      | Load Trimming operated                                 |
| 220KV | Padgha - Boisar ( PGCIL )          | 20-Sep-10 | 10.12  | 20-Sep-10 | 10.32      | Tripped at Bhoisor end                                 |
| 220KV | Badnera - Deoli (PGCIL)            | 20-Sep-10 | 10.03  | 20-Sep-10 | 18.08      | R phase CT replacement work                            |
| 220KV | 220KV A Bus at Kharghar            | 20-Sep-10 | 10.11  | 20-Sep-10 | 19.26      | R.M.Work                                               |
| 220KV | Koradi-Butibori                    | 20-Sep-10 | 00.26  | 20-Sep-10 | 00.44      | Distance Protection                                    |
| 220KV | Khaperkheda - Ambazari - II        | 20-Sep-10 | 09.19  | 20-Sep-10 | 16.32      | Q.M.Work                                               |
| 220KV | Main Bus Section-II at Shendra     | 20-Sep-10 | 10.03  | 20-Sep-10 | 14.54      | R.M.Work                                               |
| 220KV | Vita - Ghatnandre                  | 21-Sep-10 | 08.32  | 21-Sep-10 | 18.07      | Disc Insulator replacement                             |
| 220KV | Taloja - Owenscorning              | 21-Sep-10 | 11.55  | 21-Sep-10 | 16.35      | Q.M.work                                               |
| 220KV | Kandalgaon - Dasturi               | 21-Sep-10 | 12.15  | 21-Sep-10 | 12.43      | Distance Protection                                    |
| 220KV | Lote- Dasturi                      | 21-Sep-10 | 12.15  | 21-Sep-10 | 12.42      | Distance Protection                                    |
| 220KV | Pedambe-Kharepatan                 | 21-Sep-10 | 12.20  | 21-Sep-10 | 12.35      | Distance Protection                                    |

|       |                                          |           |       |           |       |                                                             |
|-------|------------------------------------------|-----------|-------|-----------|-------|-------------------------------------------------------------|
| 220KV | Bhusawal-Chalisgaon-II                   | 21-Sep-10 | 11.35 | 21-Sep-10 | 12.03 | Distance Protection                                         |
| 220KV | Babaleshwar - Ranjangaon                 | 21-Sep-10 | 14.53 | 21-Sep-10 | 15.11 | Distance Protection                                         |
| 220KV | Kandalgaon-Lonand                        | 21-Sep-10 | 13.40 | 21-Sep-10 | 20.28 | Tapping of SONA ALLOYS                                      |
| 220KV | 220/22KV 50 MVA ICT- II @ Mahad          | 21-Sep-10 | 11.17 | 21-Sep-10 | 13.37 | R.M.Work                                                    |
| 220KV | TBC at Bhoisor                           | 21-Sep-10 | 11.30 | 21-Sep-10 | 17.05 | Repl.of Y and B phase CT                                    |
| 220KV | Apta-Nagothane                           | 21-Sep-10 | 10.44 | 21-Sep-10 | 19.31 | Q.M.Work                                                    |
| 220KV | Girwali - Parbhani                       | 21-Sep-10 | 13.40 | 21-Sep-10 | 14.05 | To attend Breaker ON/OFF Switch                             |
| 220KV | Ambazari-Wardha                          | 21-Sep-10 | 19.01 | 22-Sep-10 | 07.15 | To control Koradi ICT Loading                               |
| 220KV | 220/132 KV 150 MVA ICT-I @ Akola.        | 21-Sep-10 | 11.10 | 21-Sep-10 | 13.59 | OLTC BUCHHOLZ Prot.operated                                 |
| 220KV | 220/100KV 200 MVA ICT- I @ Padgha        | 21-Sep-10 | 08.31 | 22-Sep-10 | 19.10 | L V Side Bushing Replacement.                               |
| 220KV | 220/132 KV 200 MVA ICT - V @ Nasik (OCR) | 22-Sep-10 | 14.10 | 22-Sep-10 | 14.55 | Attending Oil Leakage from Radiators.                       |
| 220KV | New Koyna - Pawas                        | 22-Sep-10 | 11.49 | 22-Sep-10 | 12.26 | Distance Protection, B Ph Zone-1.                           |
| 220KV | Kandalgaon - Dasturi                     | 22-Sep-10 | 14.50 | 22-Sep-10 | 15.15 | Tripped @ Kandalgaon End B Ph to Earth.                     |
| 220KV | Lote - Dasturi                           | 22-Sep-10 | 14.50 | 22-Sep-10 | 15.10 | Tripped @ Lote End,B Ph to Earth.                           |
| 220KV | Tarapur - Borivali                       | 22-Sep-10 | 12.43 | 22-Sep-10 | 12.51 | Distance Protection, B Ph to Earth.                         |
| 220KV | 220/132 KV 200 MVA ICT - I @ Kalmeshwar  | 22-Sep-10 | 21.12 | 22-Sep-10 | 21.53 | H V & L V Backup Protection Opeared,Main Bkr Problem.       |
| 220KV | Bombaydyng-Sahara                        | 23-Sep-10 | 08.38 | 23-Sep-10 | 21.00 | Replacement of Insulators and E/W.                          |
| 220KV | Nasik - Airoli - Knowledge Park          | 23-Sep-10 | 09.35 | 23-Sep-10 | 20.23 | Insulator String replacement work.                          |
| 220KV | Bale-Murud                               | 23-Sep-10 | 09.44 | 23-Sep-10 | 18.34 | For PGCIL line Crossing Work.                               |
| 220KV | Bale-Usmanabad                           | 23-Sep-10 | 10.02 | 23-Sep-10 | 18.27 | For PGCIL line Crossing Work.                               |
| 220KV | Phursungi - Parvati                      | 23-Sep-10 | 10.24 | 23-Sep-10 | 12.15 | Taurus Measurement Work.                                    |
| 220KV | Borivali-Kalwa                           | 23-Sep-10 | 11.51 | 23-Sep-10 | 16.57 | Hot Spot.                                                   |
| 220KV | Borivali-Tata Borivali 4                 | 23-Sep-10 | 10.28 | 23-Sep-10 | 17.05 | Hot Spot.                                                   |
| 220KV | 220KV Main Mus at Matardevi              | 23-Sep-10 | 11.10 | 23-Sep-10 | 19.20 | Jumpering Work.                                             |
| 220KV | Mudsungi-Amona                           | 23-Sep-10 | 12.17 | 23-Sep-10 | 12.49 | Amona end.                                                  |
| 220KV | Mudsungi-Amona                           | 23-Sep-10 | 18.00 | 23-Sep-10 | 23.10 | Dist.protection at Ponda                                    |
| 220KV | New Koyna-Pophali-II                     | 23-Sep-10 | 11.40 | 23-Sep-10 | 18.45 | Distance Protection.                                        |
| 220KV | Kandalgaon-Lonand                        | 23-Sep-10 | 13.10 | 23-Sep-10 | 13.45 | Distance Protection.                                        |
| 220KV | Pedambe-Tambati                          | 23-Sep-10 | 15.19 | 23-Sep-10 | 15.55 | Distance Protection.                                        |
| 220KV | New Koyna-Pedambe-II                     | 23-Sep-10 | 17.01 | 23-Sep-10 | 19.07 | Distance Protection.                                        |
| 220KV | 220/132KV 100 MVA ICT- I @ Parbhani      | 23-Sep-10 | 09.36 | 23-Sep-10 | 12.05 | Oil Top Up.                                                 |
| 220KV | Girivali - Parli - III                   | 23-Sep-10 | 09.23 | 24-Sep-10 | 17.42 | Repl.of CT's, erection work completed testing is remaining. |
| 220KV | Aurangabad - Babaleshwar                 | 24-Sep-10 | 08.10 | 24-Sep-10 | 20.03 | Isolator replacement work.                                  |
| 220KV | Nasik-Kalwa-III                          | 24-Sep-10 | 09.19 | 24-Sep-10 | 18.30 | Insulator replacement work.                                 |
| 220KV | Kandalgaon - Pophali                     | 24-Sep-10 | 10.30 | 24-Sep-10 | 19.05 | Insulator replacement work.                                 |
| 220KV | Bhoisor - Borivali                       | 24-Sep-10 | 11.30 | 24-Sep-10 | 13.48 | Hot Spot attending work.                                    |
| 220KV | Talandge - Sawantwadi                    | 24-Sep-10 | 08.38 | 24-Sep-10 | 18.30 | Line fault.                                                 |
| 220KV | 220/33KV 50 MVA T/F- II @ Boiser         | 24-Sep-10 | 15.15 | 24-Sep-10 | 18.20 | R.M.Work                                                    |
| 220KV | Lonikand-Khadki                          | 24-Sep-10 | 14.39 | 24-Sep-10 | 19.57 | Distance Protection.                                        |
| 220KV | Sahara-B'dying                           | 24-Sep-10 | 14.56 | 24-Sep-10 | 16.25 | Distance Protection.                                        |
| 220KV | Apta-Tambati                             | 24-Sep-10 | 14.56 | 24-Sep-10 | 15.25 | Distance Protection.                                        |
| 220KV | Chinchwad - Parvati                      | 24-Sep-10 | 18.56 | 24-Sep-10 | 20.05 | For controlling load of Lnknnd-Bhosari.                     |
| 220KV | Tarapur - Borivali                       | 24-Sep-10 | 14.27 | 24-Sep-10 | 18.40 | To attend hot spot.                                         |
| 220KV | Tarapur - Borivali                       | 24-Sep-10 | 19.08 | 24-Sep-10 | 22.30 | To attend hot spot.                                         |
| 220KV | Babaleshwar - Babaleshwar - II           | 25-Sep-10 | 06.35 | 26-Sep-10 | 00.45 | Replacement of CTs and LAs.                                 |

|       |                                       |           |       |           |            |                                               |
|-------|---------------------------------------|-----------|-------|-----------|------------|-----------------------------------------------|
| 220KV | Pusad-Nanded                          | 25-Sep-10 | 22.41 | 26-Sep-10 | 13.58      | Distance protection.                          |
| 220KV | 220/33 KV 100 MVA ICT- IV @ Aarey     | 25-Sep-10 | 06.17 | 25-Sep-10 | 09.00      | To attend hot spot on R Ph.H.V.bushing.       |
| 220KV | Kalwa-Ghatghar                        | 25-Sep-10 | 08.03 | 25-Sep-10 | 19.10      | Insulator string replacement work.            |
| 220KV | Kandalgaon - Dasturi                  | 25-Sep-10 | 08.26 | 25-Sep-10 | 19.05      | Replacement of insulator string.              |
| 220KV | 220/132KV 200MVA ICT-I @ Raymond      | 25-Sep-10 | 10.17 | 25-Sep-10 | 15.12      | Measurement of tan delta.                     |
| 220KV | BBLSR-Waluj II                        | 25-Sep-10 | 09.20 | 25-Sep-10 | 19.02      | Jumper replacement.                           |
| 220KV | Tarapur - Borivali                    | 25-Sep-10 | 11.20 | 25-Sep-10 | 17.24      | Attending hot spot at Tarapur end.            |
| 220KV | Bus Coupler At Ranjangaon             | 25-Sep-10 | 15.56 | 26-Sep-10 | 21.10      | Overhauling of breaker.                       |
| 220KV | Chinchwad - Parvati                   | 26-Sep-10 | 09.22 | 26-Sep-10 | 10.51      | Earth wire removed.                           |
| 220KV | Nerul-Kharghar                        | 26-Sep-10 | 04.04 | 26-Sep-10 | 10.46      | Distance protection.                          |
| 220KV | Pedambe-Tambati                       | 26-Sep-10 | 09.00 | 26-Sep-10 | 18.50      | Replacement of insulator string.              |
| 220KV | Chinchwad-Theur                       | 26-Sep-10 | 08.26 | 26-Sep-10 | 10.50      | Earth wire snapped.                           |
| 220KV | Talandge - Sawantwadi                 | 26-Sep-10 | 15.09 | 26-Sep-10 | 15.46      | Distance protection.                          |
| 220KV | Kalwa - Borivali                      | 26-Sep-10 | 20.46 | 27-Sep-10 | 01.25      | Due to red hot at ICT-II at Kalwa.            |
| 220KV | Pophali - KDPH                        | 26-Sep-10 | 21.52 |           | Continued. | Distance protection.                          |
| 220KV | NASIK-NAVSARI-II                      | 26-Sep-10 | 16.37 | 26-Sep-10 | 17.27      | Distance protection.                          |
| 132KV | Kawlewada-Gondia-II                   | 20-Sep-10 | 13.45 | 20-Sep-10 | 15.15      | Replacement and testing of O/C and E/F relay  |
| 132KV | Girwali - Latur MIDC                  | 21-Sep-10 | 01.42 | 21-Sep-10 | 11.26      | Distance Protection                           |
| 132KV | Amravati - Achalpur                   | 21-Sep-10 | 05.45 | 21-Sep-10 | 06.15      | Distance Protection                           |
| 132KV | Girwali - Latur MIDC                  | 21-Sep-10 | 12.44 | 21-Sep-10 | 17.48      | Distance Protection                           |
| 132KV | Amravati - Achalpur                   | 22-Sep-10 | 02.17 | 22-Sep-10 | 02.39      | Distance Protection Operated Z-I Bkr Problem. |
| 132KV | Girwali - Latur - I                   | 23-Sep-10 | 13.43 | 24-Sep-10 | 17.01      | Distance protection.                          |
| 132KV | Kanhan-Pardi                          | 23-Sep-10 | 18.19 | 24-Sep-10 | 22.13      | Distance Protection.                          |
| 132KV | Ambazari-Pardi                        | 23-Sep-10 | 18.30 | 24-Sep-10 | 08.28      | Distance Protection.                          |
| 132KV | Ambazari-Kalmeshwar                   | 23-Sep-10 | 18.30 | 23-Sep-10 | 18.56      | O/C Earth Fault.                              |
| 132KV | Chalisgaon - Kannad                   | 23-Sep-10 | 19.05 | 23-Sep-10 | 19.22      | FTR Relay Operated.                           |
| 132KV | Pusad-Umarkhed                        | 23-Sep-10 | 19.22 | 23-Sep-10 | 19.33      | Distance Protection.                          |
| 132KV | Boiser - Viraj                        | 24-Sep-10 | 09.55 | 24-Sep-10 | 11.11      | T jumper replacement work.                    |
| 100KV | Ganeshkhind-Chinchwad                 | 20-Sep-10 | 09.54 | 20-Sep-10 | 10.10      | Fault on 16 MVA T/F I&II                      |
| 100KV | 100/11KV 16 MVA T/F-II at Ganeshkhind | 20-Sep-10 | 09.54 | 20-Sep-10 | 13.35      | Cable Fault                                   |
| 100KV | 100/11KV 16 MVA T/F-I at Ganeshkhind  | 20-Sep-10 | 09.54 | 20-Sep-10 | 10.10      | Fault on T/F-II                               |
| 100KV | Borivali - Borivali- I                | 23-Sep-10 | 06.05 | 23-Sep-10 | 06.29      | O/C and E/F.                                  |
| 100KV | Chinchwad - Talegaon                  | 23-Sep-10 | 12.22 | 23-Sep-10 | 12.33      | Distance Protection.                          |