

LINE OUTAGES FOR THE WEEK

FROM 22-Nov-10 TO 28-Nov-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	400/220 KV 500 MVA ICT-II at Lamboti	10-Oct-10	15.28	22-Nov-10	16:54	Y-Ph Buchholz..
400KV	Akola - Aurangabad - I	22-Oct-10	14.43	28-Nov-10	16.37	Changeover.
400KV	Akola - Wardha - I	11-Nov-10	23.47	28-Nov-10	18.33	Over Voltage.
400KV	Kolhapur-Mapusa-II	20-Nov-10	21.49	24-Nov-10	11:25	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	20-Nov-10	23.02	25-Nov-10	09.16	Over Voltage.
400KV	Dhule-S'Sarovar I	21-Nov-10	22:50	22-Nov-10	08:24	Over Voltage.
400KV	Bhusawal- Aurangabad	21-Nov-10	22:56	22-Nov-10	05:57	Over Voltage.
400KV	Karad - Kolhapur - II	21-Nov-10	23:35	22-Nov-10	10:28	Over Voltage.
400KV	400/220KV,500MVA ICT-III At Kalwa.	22-Nov-10	00:56	23-Nov-10	08.08	Red hot on 29 Bph Isolator taken on TBC.
400KV	400/220KV 315 MVA ICT- II @ Talangade	22-Nov-10	09.56	22-Nov-10	18.17	Q.M.Work
400KV	400/220 KV 315MVA ICT-II @ Karad	22-Nov-10	10.26	22-Nov-10	11.55	Red hot on breaker palm.
400KV	400/220KV 315MVA ICT-II @ BBLSR	22-Nov-10	12.15	22-Nov-10	14.38	Attend hot spot.
400KV	400/220 KV 315 MVA ICT @ Akola	22-Nov-10	14:20	23-Nov-10	09.40	Differential Protection.
400KV	400/220 KV 315 MVA ICT- II @ Chakan	22-Nov-10	16:35	22-Nov-10	17:22	Buchholz relay.
400KV	Karad - Kolhapur - II	22-Nov-10	23.41	23-Nov-10	13.43	Over Voltage
400KV	Bhusawal- Aurangabad	22-Nov-10	22.36	23-Nov-10	07.13	Over Voltage
400KV	Dhule-Sar'Sarovar - I	22-Nov-10	23.46	23-Nov-10	17.48	Over Voltage.
400KV	Chandrapur - Parli - I	22-Nov-10	10.44	22-Nov-10	16.10	Ckt.on TBC. Y ph.PG isolator work.
400KV	Dhule-Sar'Sarovar - I	23-Nov-10	22.31	24-Nov-10	08:57	Over Voltage
400KV	Koradi - Akola	23-Nov-10	02.06	23-Nov-10	05.32	Distance protection.
400KV	Akola - Wardha - II	23-Nov-10	02.47	23-Nov-10	06.18	Over Voltage.
400KV	Karad-Lamboti	23-Nov-10	00.35	23-Nov-10	06.55	Over Voltage.
400KV	400/220 KV 315MVA ICT-II @ Karad	23-Nov-10	10.43	26-Nov-10	19.47	Dismantaling of existing old 220KV CB.
400KV	Karad - Kolhapur - II	23-Nov-10	16.48	23-Nov-10	17.00	Distance protection.
400KV	Bablsr-Aurangabad	24-Nov-10	00.12	24-Nov-10	05.08	Over Voltage
400KV	Lonikand- Koyna Stage IV	24-Nov-10	00.11	24-Nov-10	08:10	Over Voltage
400KV	Karad-Lamboti	24-Nov-10	00.49	24-Nov-10	05.52	Over Voltage.
400KV	Karad-Lamboti	24-Nov-10	08:35	24-Nov-10	18:32	Stringing of E/W.(Location 2 to 10)
400KV	Parli - Lamboti	24-Nov-10	08:36	24-Nov-10	18:10	Stringing of E/W. (Location 2 to 10)
400KV	Khadka-Deepnagar-I	24-Nov-10	14.13	24-Nov-10	17.45	To attend Red Hot on Line Isolator
400KV	C'pur-Parli II	24-Nov-10	10.55	24-Nov-10	16.20	To attend Hot Spot
400KV	400/220 KV 315 MVA ICT-II @ Chandrapur	24-Nov-10	18.22	24-Nov-10	19.53	Lv side on TBC for Isolator work
400KV	Bhusawal- Aurangabad	24-Nov-10	23.43	25-Nov-10	06.03	Over Voltage
400KV	Kolhapur - Mapusa - I	24-Nov-10	22.32		Continued.	Over Voltage
400KV	Lonikand- Koyna Stage IV	25-Nov-10	00.43	25-Nov-10	08.08	Over Voltage
400KV	Dhule-Sar'Sarovar - I	25-Nov-10	01.38		Continued.	Over Voltage
400KV	Karad - Kolhapur - I	25-Nov-10	00.41	25-Nov-10	06.17	Over Voltage
400KV	400/220KV,315 MVA ICT-I At Lonikand.	25-Nov-10	07.36	25-Nov-10	19.23	C.T.replacement work at 220KV side
400KV	Chandrapur - Parli - II	25-Nov-10	09.00	25-Nov-10	17.07	Attending Hot Spot
400KV	Lonikand - Parli - I	25-Nov-10	10.38	25-Nov-10	17.33	Attending Hot Spot (Ckt charged through TBC)
400KV	Karad - Kolhapur - I	25-Nov-10	23.35	26-Nov-10	09.22	Over Voltage
400KV	Bhusawal- Aurangabad	25-Nov-10	23.52	26-Nov-10	05.55	Over Voltage
400KV	Lonikand- Koyna Stage IV	26-Nov-10	01.26	26-Nov-10	08.14	Over Voltage
400KV	Main Bus- II @ Kalwa	26-Nov-10	08.30	26-Nov-10	12.35	Red Hot on M B-II in ICT-III Bay.

400KV	Lonikand- Koyna Stage IV	26-Nov-10	23.38	27-Nov-10	08.28	Over Voltage.
400KV	400/220 KV 315 MVA ICT - II @ Lamboti	26-Nov-10	11.50	26-Nov-10	18.02	Alignment on 29 T Isolator.
400KV	315 MVA ICT-I @ Lonikand	26-Nov-10	10.44	26-Nov-10	13.50	Oil Leakage on 220KV Side B Ph C T.
400KV	Karad - Kolhapur - II	26-Nov-10	21.52	27-Nov-10	11.45	Over Voltage.
400KV	Bhusawal- Aurangabad	26-Nov-10	22.54	27-Nov-10	08.53	Over Voltage.
400KV	400 KV TBC @ Koradi	26-Nov-10	09.25	26-Nov-10	18.02	Quarterly Maintainance Work.
400KV	Parli-Lonikand - II	27-Nov-10	10.15	27-Nov-10	11.55	Attending Hot Spot.
400KV	Karad - Kolhapur - II	27-Nov-10	22.05		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	27-Nov-10	22.17	28-Nov-10	05.56	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	27-Nov-10	23.13		Continued.	Over Voltage.
400KV	Akola - Aurangabad- II	28-Nov-10	16.49		Continued.	Changeover.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	28-Nov-10	06.16	28-Nov-10	10.29	Hot Spot Attending.
400KV	400/220 KV,105 MVA Spare ICT @ Dhule	28-Nov-10	11.56	28-Nov-10	16.20	PRV Indication.
400KV	Bhusawal- Aurangabad	28-Nov-10	23.40	29-Nov-10	04.40	Over Voltage.
400KV	Akola - Wardha - II	28-Nov-10	18.37		Continued.	Change over
220KV	Tifil-Trombay	8-Oct-10	10.18	26-Nov-10	17.40	Erection & Stringing of M/C Towers (Loc.22-40)
220KV	Mudsungi-Amona	14-Nov-10	14.27	23-Nov-10	17.11	Dist.Prot.R Ph - E142.5KM FROM Mudsungi.
220KV	Babaleshwar - Babaleshwar - II	18-Nov-10	09.02	26-Nov-10	17.02	Isolator replacement work, Line on TBC
220KV	Halkarni - Hemres	20-Nov-10	17.20	23-Nov-10	12.40	Distance Protection.
220KV	Raymond-Washala	21-Nov-10	19:35	22-Nov-10	20.58	Dist. Prot.
220KV	Tillari-Amona-II	21-Nov-10	21:25	23-Nov-10	10.25	Dist. Prot.
220KV	Jejuri-Phursungi	22-Nov-10	12.35		Continued.	Overhauling of breaker.
220KV	Boiser-Versova	22-Nov-10	06.50	22-Nov-10	10.00	R.M.Work
220KV	Main Bus @ Ichalkaranji	22-Nov-10	11.45	22-Nov-10	19.00	Jumpering of M.B.isolator of T/F.
220KV	Kalwa-Colourchem	22-Nov-10	09.42	22-Nov-10	16.57	Commissioning of numerical backing relay.
220KV	220/132 KV 150 MVA T/F @ Boiser	22-Nov-10	11.34	22-Nov-10	12.55	Bus isolator and alignment work
220KV	Babaleshwar - Ahemednagar - I	22-Nov-10	14.55	22-Nov-10	15.30	Attend red hot.
220KV	Bus Section-I At Dhamangaon	22-Nov-10	10.25	22-Nov-10	14.25	Replacement of B Ph jumper on M.B.isolator
220KV	Bus Section-II At Dhamangaon	22-Nov-10	15.15	22-Nov-10	17.54	Replacement of R Ph jumper on M.B.isolator.
220KV	Khaperkheda - Wardha.	22-Nov-10	08.02	22-Nov-10	21.39	Laying of E/W from Loc.113 to 125.
220KV	Bus Coupler @ Koradi	22-Nov-10	09.54	22-Nov-10	17.09	Tan delta measurement .
220KV	Warora - Wardha Power - II	22-Nov-10	13.20	22-Nov-10	17.45	For B/B protection scheme
220KV	220/33KV 50 MVA T/F - I @ Yavatmal	22-Nov-10	08.55	22-Nov-10	16.05	Attending oil leakage from top plate.
220KV	Mudsungi-Amona	23-Nov-10	17.14	25-Nov-10	16.10	Distance protection.
220KV	Boisor - Dahanu	23-Nov-10	07.56	23-Nov-10	09.42	Isolator work.
220KV	220/132 KV 200 MVA ICT- II @ Boiser	23-Nov-10	08.40	23-Nov-10	09.50	Isolator maintenance work.
220KV	Mumewadi - Halkarni	23-Nov-10	13.50	23-Nov-10	14.15	Distance protection.
220KV	Halkarni-Hemous	23-Nov-10	13.50	23-Nov-10	14.30	Distance protection.
220KV	Halkarni -Tillary	23-Nov-10	13.50	23-Nov-10	15.00	Distance protection.
220KV	Halkarni -Tillary	23-Nov-10	15.25	23-Nov-10	15.46	Distance protection.
220KV	Momewadi -Halkarni	23-Nov-10	15.25	23-Nov-10	15.38	Distance protection.
220KV	Halkarni-Hemous	23-Nov-10	14.36	23-Nov-10	16.40	Distance protection.
220KV	Trombay Sonkhar	23-Nov-10	17.38	23-Nov-10	18.04	Distance protection.
220KV	Tillary-Amona	23-Nov-10	13.50	23-Nov-10	15.24	Distance protection.
220KV	Tillary-Amona	23-Nov-10	15.24	24-Nov-10	08:32	Tripped
220KV	Ambazari-Amravati	23-Nov-10	10.20	23-Nov-10	15.50	Replacement of disc insulator

220KV	Main Bus-II At 400KV Chandrapur.	23-Nov-10	08.48	24-Nov-10	23.00	Relay Testing and tan delta of 220KV bus coupler CT.
220KV	Khaperkheda-Purti	23-Nov-10	09.56	23-Nov-10	15.23	Replacement of disc insulator.
220KV	Khaperkheda - Koradi	23-Nov-10	09.31	23-Nov-10	18.02	Tan delta measurement of CTs.
220KV	Chalisgaon-BSL-I	23-Nov-10	06.10	23-Nov-10	06.25	Distance protection.
220KV	Kalwa - Tifil	24-Nov-10	11:50	24-Nov-10	15:02	Commissioning of Numerical Relay.
220KV	Kalwa - Borivali	24-Nov-10	10:06	24-Nov-10	12:38	To attend Red Hot.
220KV	Tillari-Amona-II	24-Nov-10	12:50	24-Nov-10	15:30	To avail outage on Mudshingi-Ponda line.
220KV	Borivali-Mulund	24-Nov-10	11:10	24-Nov-10	12:35	Tripped at Mulund end only.
220KV	Bus Cupler at Salset.	24-Nov-10	11:10	24-Nov-10	12:32	Line Loding for Mulund -Borivali
220KV	Pedambe-Kharepatan	24-Nov-10	15:12	24-Nov-10	17:05	Dist. Prot.
220KV	Phinolex-Kharepatan	24-Nov-10	15:12	24-Nov-10	16:20	Back up Prot.
220KV	MUDSHINGI-CHIKODI	24-Nov-10	13:40	25-Nov-10	09.10	Dist. Prot.
220KV	Main Bus-II At 400KV Chandrapur.	24-Nov-10	08.48	24-Nov-10	23.59	REPL,Fully take off assambesly of Bus-II Isolator
220KV	Khaparkheda - Kanhan - I	24-Nov-10	09.49	24-Nov-10	11.01	Removing Broken Earth Wire
220KV	Gadchandur-Virur-I	24-Nov-10	09.15	24-Nov-10	12.06	Q.M.Work
220KV	Butibori TSS -Butibori(MIDC)	24-Nov-10	10.08	24-Nov-10	13.40	REPL,of LA at Butibori TSS
220KV	Aurangabad-Shendra	24-Nov-10	06.40	24-Nov-10	10.01	R phase Jumper broken at Shendra end
220KV	Aurangabad-Jalna-II	24-Nov-10	06.40	24-Nov-10	07.13	R phase Jumper Broken at Shendra end
220KV	Chandrapur - Rly TSS - I	24-Nov-10	08.30	24-Nov-10	16.30	Ckt.on TBC for 29B Bus-II Isolator work
220KV	Kanhan - Bhandara - I	24-Nov-10	09.47	24-Nov-10	11.02	Kanhan-K'Kheda Ckt I&II outage
220KV	Kanhan - Bhandara - II	24-Nov-10	09.47	24-Nov-10	11.02	Kanhan-K'Kheda Ckt I&II outage
220KV	Kalmeshwar-Kaparkheda	24-Nov-10	11.37	25-Nov-10	18.41	To attend Gas Leakage on Main Breaker
220KV	Bhosari-Chinchwad	25-Nov-10	07.02	25-Nov-10	20.08	Conductor replacement work
220KV	Wadkhal-IPCL I	25-Nov-10	09.28	25-Nov-10	18.48	Q.M.Work
220KV	Kalyani-Bhigwan	25-Nov-10	12.30	25-Nov-10	15.25	Decapping Insulator work
220KV	Pusad-Parbhani	25-Nov-10	07.53	25-Nov-10	21.20	Commissioning of WT and CC
220KV	220/66KV 150 MVA ICT- II @ Gadchandur	25-Nov-10	09.35	25-Nov-10	16.31	Testing work
220KV	220/132 KV 150 MVA ICT- I @ Dhule	25-Nov-10	14.40	25-Nov-10	16.40	Repl.of 132KV B phase CT due to heavy oil leakage
220KV	Main Bus at Parbhani	25-Nov-10	09.44	25-Nov-10	15.16	Attending Hot Spot
220KV	Babaleshwar - Babaleshwar - II	26-Nov-10	16.32	26-Nov-10	17.02	Isolator Sparking.
220KV	Wadkhal-IPCL-II	26-Nov-10	09.50	26-Nov-10	17.10	Insulator Replacement.
220KV	Padgha-Wada	26-Nov-10	10.52	26-Nov-10	20.52	Breaker O/H.
220KV	Khaperkheda - Wardha.	26-Nov-10	09.27	26-Nov-10	15.10	E/W Laying Work Bet. Loc.113 to 125.
220KV	220/132KV 100 MVA ICT-I @Padegaon	26-Nov-10	10.20	26-Nov-10	16.43	Q.M.Work of C T,SFRA Test of ICT.
220KV	Gadchandur-Virur-II	26-Nov-10	09.00	26-Nov-10	13.24	Main Bkr Operating Mechanism Work,(Ckt is on TBC)
220KV	Kalmeshwar-Nippon	26-Nov-10	14.37	26-Nov-10	14.53	Tripped @ Nippon Denro end only.
220KV	ONGC-JNPT	27-Nov-10	10.55	27-Nov-10	19.06	CVT Replacement.
220KV	Nerul -Sonkhar	27-Nov-10	07.05	27-Nov-10	09.47	To attend wave-trap jumper.
220KV	Babaleshwar - Babaleshwar - I	27-Nov-10	10.00	27-Nov-10	15.10	Replacement flashover insulator alignment of isolator.
220KV	Kalwa-Mahape	27-Nov-10	15.17		Continued.	Strengining Work of Mumbai System.
220KV	Babaleshwar - Ranjangaon	28-Nov-10	01.55	28-Nov-10	01.59	Distance Protection.
220KV	Babaleshwar - Ranjangaon	28-Nov-10	03.59	28-Nov-10	04.23	Distance Protection.
220KV	Phursungi - Theur	28-Nov-10	03.23	28-Nov-10	05.13	Distance Protection.
220KV	Dahanu-Bhoisor	28-Nov-10	07.35	28-Nov-10	18.37	Bay equipment preventive maintenance.
220KV	220/100 KV125 MVA ICT-III @Trombay	28-Nov-10	09.33	28-Nov-10	20.22	Due to outage of group CB No. 1 & 2 of 110 KV Trombay(T).

220KV	Trombay-Dharavi	28-Nov-10	16.04	28-Nov-10	16.17	Distance protection operated.
220KV	Badnera - Deoli (PGCIL)	28-Nov-10	18.57	28-Nov-10	19.55	Distance protection operated.
220KV	Badnera - Deoli (PGCIL)	28-Nov-10	20.37	28-Nov-10	20.22	Distance protection operated.
132KV	Butibori MIDC-Khapri Cky.	8-Nov-10	10.10	26-Nov-10	17.50	Dist.Prot. Y Ph. and B Ph. B/D declassified.
132KV	Bhandara-Ambhora	23-Nov-10	12.30	23-Nov-10	23.15	Distance protection.
132KV	Waghala - Narsi	25-Nov-10	14.53	25-Nov-10	16.47	Taking of CT in service
132KV	Amravati - Achalpur	26-Nov-10	08.22	26-Nov-10	18.25	Replacement of Disc Insulator.
132KV	Ujani-Umarga	27-Nov-10	13.17	27-Nov-10	18.40	Dist.Prot.
132KV	Ujani - Latur	27-Nov-10	13.00	27-Nov-10	13.10	Dist. Prot. R Ph.
132KV	Harangul - Ujni	27-Nov-10	13.00	27-Nov-10	13.10	Dist.Prot. R Ph. Zone - I.
132KV	Ujni - Killari	27-Nov-10	13.17	27-Nov-10	18.40	Dist.Prot. R & Y Ph. Zone - I.
132KV	Kawlewada-Madgi-I	28-Nov-10	06.21	28-Nov-10	06.37	Distance protection operated.
132KV	Ujani-Umarga	28-Nov-10	13.40	28-Nov-10	19.13	Distance protection operated.
110KV	Salset - Dharavi	27-Nov-10	07.19	27-Nov-10	07.30	B Phase E/F.
100KV	Kalwa-Kalyan	27-Nov-10	14.20	27-Nov-10	17.45	Repair of Damaged Jaw.
100KV	Dharavi - Vikroli	27-Nov-10	07.19	27-Nov-10	07.24	B Phase E/F.
100KV	Chinchwad - Talegaon	28-Nov-10	14.40	28-Nov-10	16.55	Red Hot.