

LINE OUTAGES FOR THE WEEK

FROM 20-Dec-10 TO 26-Dec-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Main Bus - I @ Kolhapur	14-Dec-10	15.02	20-Dec-10	09.47	Isolator Alignment and Testing Work.
400KV	Wardha - Akola - II	15-Dec-10	21.41	20-Dec-10	09.51	Over Voltage.
400KV	Kolhapur - Mapusa - I	18-Dec-10	23.46	22-Dec-10	15.41	Due to SF6 Gas Pressure Alarm
400KV	Dhule - S'Sarovar - II	18-Dec-10	23.09	24-Dec-10	05.55	Over Voltage
400KV	Karad - Kolhapur - I	19-Dec-10	19.30	20-Dec-10	10.49	Over Voltage.
400KV	Bhusawal- Aurangabad	19-Dec-10	22.10	20-Dec-10	05.56	Over Voltage.
400KV	Lonikand- Koyna Stage IV	19-Dec-10	22.34	20-Dec-10	07.44	Over Voltage.
400KV	Karad-Lamboti	19-Dec-10	22.43	20-Dec-10	06.56	Over Voltage.
400KV	Karad - Kolhapur - II	19-Dec-10	22.43	20-Dec-10	06.07	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	19-Dec-10	23.52	20-Dec-10	08.22	Over Voltage.
400KV	Akola - Wardha - I	20-Dec-10	03.05	23-Dec-10	16.14	D.T.Received @ Akola end.Due to high voltage.
400KV	Wardha - Seoni	20-Dec-10	03.05	20-Dec-10	09.23	Over Voltage.
400KV	Dhule - Babhaleshwar - I	20-Dec-10	00.52	20-Dec-10	05.55	Over Voltage.
400KV	400/220 KV 315MVA ICT-II @ Karad	20-Dec-10	09.55	22-Dec-10	18.10	400KV CT repl.and CB dismentling.
400KV	Parli-Lonikand -I	20-Dec-10	10.57		Continued.	Overhauling work.Line on TBC.
400KV	New Koyna - StagelV - I	20-Dec-10	23.47	21-Dec-10	08.14	Over Voltage.
400KV	Karad - Kolhapur - II	20-Dec-10	19.33	21-Dec-10	09.03	Over Voltage.
400KV	Bhusawal- Aurangabad	20-Dec-10	21.03	21-Dec-10	06.07	Over Voltage.
400KV	Karad-Lamboti	20-Dec-10	22.01	21-Dec-10	06.56	Over Voltage.
400KV	Lonikand- Koyna Stage IV	20-Dec-10	23.53	21-Dec-10	06.57	Over Voltage
400KV	50 MVAR 400KV Bus Reactor At 400KV K	20-Dec-10	10.35		Continued.	Oil replacement and filtration of oil.
400KV	Dhule - Babhaleshwar - I	21-Dec-10	01.33	21-Dec-10	05.55	Over Voltage.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	21-Dec-10	10.48	21-Dec-10	15.52	Bay inspection and maintenance work.
400KV	400/220KV 105MVA Spare ICT @ Nagotha	21-Dec-10	09.01	21-Dec-10	18.31	R.M.& Testing work.
400KV	400 KV Main Bus- II @ Khargar	21-Dec-10	09.54	21-Dec-10	19.43	Commissioning of high set relay of Bkr.
400KV	Bus Coupler @ Kharghar	21-Dec-10	09.41	21-Dec-10	18.48	Commissioning of high set relay of Bkr.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	21-Dec-10	09.30	21-Dec-10	10.48	Hot spot, B-Ph clamp of Bkr.(Taken on TBC)
400KV	Bhusawal- Aurangabad	21-Dec-10	21.38	22-Dec-10	06.07	Over Voltage.
400KV	Lonikand- Koyna Stage IV	21-Dec-10	21.55	22-Dec-10	08.03	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	21-Dec-10	21.55	22-Dec-10	08.50	Over Voltage.
400KV	400/220/33KV 500 MVA ICT-I At Kalwa	21-Dec-10	23.20		Continued.	Internal inspection, Gas R-Ph unit.
400KV	Karad - Kolhapur - I	21-Dec-10	23.20	22-Dec-10	08.51	Over Voltage.
400KV	Bus Coupler @ New Koyna	22-Dec-10	12.21	22-Dec-10	13.13	Oil filling in CB.
400KV	Babaleshwar - Bhusawal	22-Dec-10	06.50	22-Dec-10	07.25	CB pole descrepancy main I and II operated.
400KV	New Koyna - Karad - I	22-Dec-10	18.50	25-Dec-10	17.09	Taken on Own breaker problem at N/Koyna end.
400KV	Karad - Kolhapur - II	22-Dec-10	19.22	23-Dec-10	05.49	Over Voltage
400KV	Bhusawal- Aurangabad	22-Dec-10	19.29	23-Dec-10	05.29	Over Voltage
400KV	Kolhapur-Mapusa-II	22-Dec-10	18.05		Continued.	Over Voltage
400KV	Karad-Lamboti	22-Dec-10	11.41		Continued.	Servicing O/H CB at Lamboti end.Line on TBC.
400KV	Karad-Lamboti	22-Dec-10	12.35	22-Dec-10	19.05	Y ph.CT hot spot.
400KV	Lonikand - Jejuri	23-Dec-10	08.17	23-Dec-10	18.47	Maintenance Work.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	23-Dec-10	09.06	23-Dec-10	19.30	Removed of Faulty Oil Pump Motor of B Ph & Oil Topup Work.
400KV	400/220 KV 315 MVA ICT - II @ Lamboti	23-Dec-10	13.54	23-Dec-10	20.06	Oil Top in Y Ph Unit.
400KV	New Koyna - Koyna Stage IV - II	23-Dec-10	19.54	23-Dec-10	20.28	Over Voltage.
400KV	Karad - Kolhapur - I	23-Dec-10	20.01	24-Dec-10	07.24	Over Voltage.
400KV	Bhusawal- Aurangabad	23-Dec-10	22.56	24-Dec-10	05.28	Over Voltage.
400KV	Padgha-Bhoisor (PGCIL)	23-Dec-10	22.42	24-Dec-10	05.50	Attending Red Hot Spot on R Ph C T Jumper.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	23-Dec-10	23.47	24-Dec-10	00.37	Topping up of Oil.
400KV	New Koyna - Koyna Stage IV - II	24-Dec-10	01.31	24-Dec-10	08.38	Over Voltage.
400KV	Lonikand - Jejuri	24-Dec-10	00.14	24-Dec-10	08.47	Over Voltage

400KV	Koradi - Akola	24-Dec-10	05.57	24-Dec-10	20.11	Stringing Activaty of 765 KV Seoni-Wardha Line.
400KV	Koradi - Bhusawal	24-Dec-10	05.59	24-Dec-10	19.42	Stringing Activaty of 765 KV Seoni-Wardha Line.
400KV	Bhusawal- Aurangabad	24-Dec-10	19.38	25-Dec-10	06.15	Over Voltage
400KV	Karad - Kolhapur - II	24-Dec-10	21.43	25-Dec-10	08.12	Over Voltage
400KV	400/220KV 315MVA ICT-II @ Aurangabad.	24-Dec-10	11.06	24-Dec-10	17.00	Attending Oil Leakage of ICT.
400KV	Dhule-Sar'Sarovar - I	24-Dec-10	22.31	26-Dec-10	09.25	Over Voltage.
400KV	Akola - Wardha - II	24-Dec-10	23.44		Continued.	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	25-Dec-10	01.11	25-Dec-10	07.38	Over Voltage.
400KV	Babaleshwar - Dhule - I	25-Dec-10	09.25	26-Dec-10	05.25	Y Ph L A Replacement.
400KV	Main Bus- I @ New Koyna	25-Dec-10	11.01	25-Dec-10	16.28	Jumpering Work of 400 KV Jaigad-II.
400KV	400/220 KV 315MVA ICT-II @ Karad	25-Dec-10	16.28	25-Dec-10	19.34	Attending Red Hot of R Ph C T Stud.
400KV	Karad - Kolhapur - I	25-Dec-10	22.47	26-Dec-10	07.32	Over Voltage.
400KV	Lonikand- Koyna Stage IV	25-Dec-10	00.16	25-Dec-10	07.11	Over Voltage.
400KV	New Koyna - Karad - I	25-Dec-10	09.17	25-Dec-10	11.34	Bus Outage @ New Koyna.
400KV	New Koyna - StageIV - I	25-Dec-10	08.02	25-Dec-10	10.00	Bus Outage @ New Koyna.
400KV	Dhule-Sar'Sarovar - II	25-Dec-10	23.16		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	26-Dec-10	21.40	27-Dec-10	05.22	Over Voltage.
400KV	Lonikand- Koyna Stage IV	26-Dec-10	00.10	26-Dec-10	06.50	Over Voltage.
400KV	Bhusawal- Aurangabad	26-Dec-10	00.57	26-Dec-10	05.41	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	26-Dec-10	01.13	26-Dec-10	08.26	Over Voltage.
400KV	Kalwa - Padgha - II	26-Dec-10	09.02	26-Dec-10	20.06	Replacement of Faulty Disc Insulator.
400KV	Lonikand- Koyna Stage IV	26-Dec-10	22.53		Continued.	Over Voltage.
400KV	Karad - Kolhapur - I	26-Dec-10	23.27		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	26-Dec-10	22.57		Continued.	Over Voltage.
220KV	Pedambe - Tambati	18-Dec-10	08.30	24-Dec-10	18.46	Overhauling of C B.
220KV	Pawas 220KV main Bus.	20-Dec-10	11.12	20-Dec-10	18.43	Jumpering bitween existing MB and New MB.
220KV	Phursungi - Theur	20-Dec-10	02.21	20-Dec-10	02.44	Distance Protection,B Ph - E.
220KV	Pawas-New Koyna	20-Dec-10	11.09	20-Dec-10	18.45	Replacement of insulator.
220KV	Tilawni-Talangade-I	20-Dec-10	11.15	20-Dec-10	18.13	Tan delta CT measurement.
220KV	ONGC-TSS	20-Dec-10	11.20	20-Dec-10	15.25	Repl.of R ph.LA at TSS.
220KV	Uran-ONGC	20-Dec-10	14.40	20-Dec-10	17.46	H/T from ONGC to attend air leakage of compressor.
220KV	Mudshingi-Talandage-II	20-Dec-10	11.10	20-Dec-10	18.07	Testing work.
220KV	Tilwani - Talandge - II	20-Dec-10	11.15	20-Dec-10	18.14	Tan delta CT measurement.
220KV	220/132 KV,200MVA T/F-3 At Tilawani	20-Dec-10	11.15	20-Dec-10	18.40	Tan delta CT measurement.
220KV	Nasik-Navsari-I	20-Dec-10	22.37	20-Dec-10	23.14	R ph.breaker problem At Nasik end.
220KV	Vita - Miraj	21-Dec-10	11.20	21-Dec-10	14.00	Tan delta measurement.
220KV	Vita-Maisal	21-Dec-10	14.40	21-Dec-10	16.20	Tan delta of C.T
220KV	Murud - Girawli.	21-Dec-10	10.58	21-Dec-10	15.40	Q.M.Work
220KV	Apta-Uran-II	21-Dec-10	09.55	21-Dec-10	13.51	Attending Hot Spot.
220KV	Karad - Miraj	21-Dec-10	09.41	21-Dec-10	17.57	Jumpering work.
220KV	New Koyna - Pawas	21-Dec-10	09.20	21-Dec-10	18.20	Replacement of Insulator.
220KV	Abhijeet-Wardha Ckt.	21-Dec-10	10.04	21-Dec-10	13.30	Attending Oil leakage of 220KV Y-Ph CT.
220KV	220/132 KV 100 MVA ICT @ Parli - I	21-Dec-10	09.09	21-Dec-10	17.11	Replacement of L.A.
220KV	220 KV TBC At Warora	21-Dec-10	14.40		Continued.	Bkr.Y-Ph pole mechanical problem.
220KV	220/132 KV 150MVA ICT-II @ Dhule	21-Dec-10	13.34		Continued.	Replacement by 200 MVA ICT UPTO 20.01.11
220KV	Padgha TBC	22-Dec-10	14.00	22-Dec-10	19.16	R ph.CT replacement.
220KV	Miraj-Maisal	22-Dec-10	15.10	22-Dec-10	17.45	Breaker air leakage problem.
220KV	Pawas-Kharepatan	22-Dec-10	09.00	22-Dec-10	18.00	R.M.Work.
220KV	Mhape-Kharghar	22-Dec-10	13.25	22-Dec-10	15.50	CB air leakage.
220KV	220/22 KV,50 MVA T/F-II At Wada.	22-Dec-10	15.05	22-Dec-10	20.40	Differential protection R ph.LA faulty.
220KV	220/132KV,100 MVA ICT-I At Peth	22-Dec-10	08.00		Continued.	Oil replacement (4 days outage.Outage up to 27.12.2010)
220KV	Talangade-Mudshingi-II	22-Dec-10	09.36	22-Dec-10	18.30	Insulator Replacement.
220KV	220/132 KV 200 MVA ICT - III @ Bale	22-Dec-10	10.00	22-Dec-10	16.40	R.M.Work.
220KV	220/132KV 200 MVA ICT- II @ Amravati	22-Dec-10	08.57	23-Dec-10	21.55	Replacement of CT.

220KV	Chandrapur-Gadchandur	22-Dec-10	10.17	22-Dec-10	14.10	Breaker overhaul.Ckt on TBC.
220KV	Chandrapur-Chandrapur MIDC	22-Dec-10	16.40	22-Dec-10	16.40	Attending PDR problem of breaker.Ckt on TBC.
220KV	Kandalgaon - Pirangut	23-Dec-10	07.52	23-Dec-10	18.25	Earthwire Replacement @ Pirangut.
220KV	Uran - HOCL	23-Dec-10	09.55	23-Dec-10	18.38	Outage.
220KV	Kolhapur-Karad-IV	23-Dec-10	09.24	23-Dec-10	12.56	Tand Measurment.
220KV	Phursungi - Jejuri	23-Dec-10	10.45	23-Dec-10	19.56	Insulator Replacement.
220KV	Phursungi - Parvati	23-Dec-10	10.27	23-Dec-10	20.02	Insulator Replacement.
220KV	Pawas-Kharepattan	23-Dec-10	09.14	23-Dec-10	14.43	Replacement of Insulator.
220KV	Chinchwad-Bhosari	23-Dec-10	08.33	23-Dec-10	10.06	Outage.
220KV	Kalwa - Borivali	24-Dec-10	00.14	24-Dec-10	06.17	JICA Work.
220KV	Boiser - Borivali	24-Dec-10	00.18	24-Dec-10	08.30	JICA Work.
220KV	220/100 KV ICT-II @ Borivali.	24-Dec-10	00.14	24-Dec-10	06.25	JICA Work.
220KV	220/100 KV ICT-3 at Borivali	24-Dec-10	00.14		Continued.	Augmentation Work by 200 MVA.
220KV	Bus Section - II @ Borivali	24-Dec-10	00.15	24-Dec-10	06.10	220 KV Bus Section-II Outage & Aug.Work of ICT - III.
220KV	Kalwa - Airoli - Knowledge Park.	24-Dec-10	08.59	24-Dec-10	16.55	B Ph C T Leakage @ Kalwa.
220KV	Apta-Kalwa	24-Dec-10	09.23	24-Dec-10	17.27	Insulator Replacement Work.
220KV	Temghar-Colourchem	24-Dec-10	09.30	24-Dec-10	17.09	Replacement of Jumper.
220KV	Mudshingi-Chikodi	24-Dec-10	10.55	24-Dec-10	18.24	Maint.Work (Ready for Charging).
220KV	220/33 KV 50 MVA T/F @ Borivali	24-Dec-10	07.40	24-Dec-10	07.55	Tripped With 33KV Pawnewadi Feeder.
220KV	220/66 KV 50 MVA ICT @ Yavatmal	24-Dec-10	08.45	24-Dec-10	17.15	Filteration Work.
220KV	Badnera-Rly.TSS - I	24-Dec-10	10.40	24-Dec-10	12.33	For Repl of TTB of TSS Metering Unit by MSEDCL & R. M. Work.
220KV	Badnera - Rly TSS - II	24-Dec-10	12.43	24-Dec-10	14.03	For Repl of TTB of TSS Metering Unit by MSEDCL & R. M. Work.
220KV	Pusad - Yavatmal	24-Dec-10	09.43	24-Dec-10	11.44	To Attend Hot Spot on Line Side Isolator.
220KV	Wardha-RLY TSS I	24-Dec-10	10.56	24-Dec-10	16.36	B Ph C T Oil Leakage.
220KV	Apta-Nagothane	25-Dec-10	09.26	25-Dec-10	18.22	Replacement of Insulator.
220KV	Borivali-Mulund	25-Dec-10	11.30	25-Dec-10	16.44	Changing of C T Ratio.
220KV	Ranjangaon- Fiat-I	25-Dec-10	10.00	25-Dec-10	15.05	Q.M.Work.
220KV	Tambati-Pedambe	25-Dec-10	10.54	25-Dec-10	19.15	Distance Protection.
220KV	Ranjangaon - Fiat - II	25-Dec-10	10.54	25-Dec-10	14.55	Bus Bar Operated.
220KV	Ranjangaon- Fiat-I	25-Dec-10	19.20	26-Dec-10	12.22	With No Indication.(On TBC)
220KV	Ranjangaon - Fiat - II	25-Dec-10	19.20	25-Dec-10	19.27	Trip With No Indication.
220KV	Kandalgaon - Pirangut	26-Dec-10	07.21	26-Dec-10	18.08	Stringing of Earthwire.
220KV	Kandalgaon - Pophali	26-Dec-10	11.20	26-Dec-10	18.00	Replacement of Insulator String.
220KV	Trombay-Salset-II	26-Dec-10	11.38	26-Dec-10	11.42	Work of Providing 3rd Feed to 220KV Dharavi S/S.
220KV	Trombay - Salsett - I	26-Dec-10	11.38	26-Dec-10	23.15	Out for Investigation of fault.
220KV	Bhira - Dharavi - VII	26-Dec-10	11.38	26-Dec-10	12.02	Alongwith Trombay-Salset-I Line.
220KV	Bhira - Dharavi - VIII	26-Dec-10	14.21	26-Dec-10	23.30	Work of 220KV Trombay-Salset-I Line.
132KV	132/22 KV,25 MVA T/F-I At Sanaswadi	22-Dec-10	10.29	22-Dec-10	10.45	O/C,E/F protn.operated
132KV	Theur - Kharadi	22-Dec-10	06.25	22-Dec-10	08.45	Y ph.LA flashover.
132KV	Bhusawal - Nimbhora	22-Dec-10	08.40	22-Dec-10	19.00	Isolator replacemnet and PLCC panel installation.
132KV	Kanhan-Pardi	22-Dec-10	11.02	22-Dec-10	13.39	Attending red hot.
132KV	Kothrud-Phursungi	23-Dec-10	05.33	23-Dec-10	18.01	Tower Erection Work Loc. no 85.
132KV	Yawat - Janai	25-Dec-10	14.45	25-Dec-10	16.00	Distance Protection.
132KV	Yawat - Janai	26-Dec-10	11.52	26-Dec-10	11.57	R Ph to Earth.
110KV	TILWANI--ICHALKARANJI	20-Dec-10	08.00	20-Dec-10	18.40	Line work.
110KV	110/33KV,25 MVA T/F At Sawalaj	22-Dec-10	16.30	22-Dec-10	20.40	Differential protection.
100KV	Chinchwad - Talegaon	23-Dec-10	08.14	23-Dec-10	17.19	Outage.
100KV	Borivali-Tata-I	24-Dec-10	00.15	24-Dec-10	06.39	220 KV Bus Section-II Outage & Aug.Work of ICT - III.
100KV	Borivali-Tata-II	24-Dec-10	00.15	24-Dec-10	06.37	220 KV Bus Section-II Outage & Aug.Work of ICT - III.
100KV	Kalwa-Kalyan	24-Dec-10	08.54	24-Dec-10	16.14	Insulator Replacement Work.