

LINE OUTAGES FOR THE WEEK

FROM 28-May-12 TO 3-Jun-12

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC POLE - II	28-May-12	22.23	29-May-12	02.26	Premansoon Maint. Work @ Padgha.
500KV	HVDC POLE - II	30-May-12	09.40	31-May-12	02.57	Differential Protection B Ph. Padgha End
500KV	HVDC Pole I Padgha	2-Jun-12	21.49	3-Jun-12	04.27	Pre mansoon maintenance work.
400KV	Wardha - Seoni - I	22-May-12	08.59	30-May-12	17.15	Converted to 765 KV.
400KV	Akola - Wardha - I	26-May-12	08.07	29-May-12	10.52	765KV Koradi-Akola stringing work
400KV	Akola - Wardha - II	26-May-12	08.31	29-May-12	11.20	765KV Koradi-Akola stringing work.
400KV	400/220KV 500MVA ICT-III at Bableshtar	26-May-12	15.55	30-May-12	23.18	ICT Taken on Humming from L V Side @ 12.56 Hrs..
400KV	Parly(PG) - Wardha (PG) - I	27-May-12	08.07	29-May-12	12.44	To control load on Wardha-Deoli.
400KV	Parli (PG) - Wardha (PG) - II	27-May-12	08.28	29-May-12	11.02	To control load on Wardha-Deoli.
400KV	Bhusawal- Aurangabad	27-May-12	16.16	28-May-12	07.58	Over Voltage
400KV	Aurangabad-Deepnagar-II	27-May-12	18.18	30-May-12	09.56	Over Voltage.
400KV	Kolhapur - Mapusa - I	27-May-12	17.29	28-May-12	09.11	Over Voltage.
400KV	New Koyna - Karad - I	28-May-12	01.30	28-May-12	08.13	Distance protection.
400KV	Dabhol - New Koyna - I	28-May-12	04.12	28-May-12	19.44	Distance protection.
400KV	Dhule-Sar Sarovar - I	27-May-12	00.13	28-May-12	19.21	Over Voltage.
400KV	Newkoyna - Jaigad - I	28-May-12	08.28	28-May-12	20.45	Replacement of Insulator.
400KV	Karad - Newkoyna - I	28-May-12	13.31	28-May-12	19.37	Replacement of Flashover Disc Insulator String.
400KV	Bhusawal- Aurangabad	28-May-12	19.28	29-May-12	06.39	Over Voltage.
400KV	Jejuri-Koyna STG-IV	29-May-12	00.24	29-May-12	01.00	Distance Protection.
400KV	Lonikand- Koyna Stage IV	29-May-12	01.03	29-May-12	01.43	Distance Protection.
400KV	Jejuri-Koyna STG-IV	29-May-12	01.33	29-May-12	02.23	Distance Protection.
400KV	Newkoyna - Jaigad - I	29-May-12	06.44	29-May-12	13.32	Replacement of Insulator.
400KV	Nagothane-Dabhol-I	29-May-12	08.22	29-May-12	19.20	Cold Line Washing.
400KV	765KV Seoni - Wardha - II	26-May-12	09.30	29-May-12	11.04	765 KV Koradi-Akola Stringing Work.Swapping of 400 KV Sioni-Wardha.
400KV	Karad-Jaigad I	29-May-12	14.05	29-May-12	21.07	Insulator Replacement.
400KV	Koradi-Akola	29-May-12	15.50	29-May-12	18.59	To Attend Heavy Sarking on R Ph. Wave Trap.(Ckt Taken on TBC)
400KV	Padgha - Nagothane - I	29-May-12	15.55	1-Jun-12	19.44	Main Breaker Overhauling Work upto 7/06/12.(Taken on TBC)
400KV	Bhusawal- Aurangabad	29-May-12	17.13	30-May-12	09.50	Over Voltage.
400KV	Koyna IV - Jejuri	30-May-12	00.30	30-May-12	14.32	Distance Protection,Declared Faulty.
400KV	Lonikand- Koyna Stage IV	30-May-12	00.31	30-May-12	09.48	Distance Protection.
400KV	Dhule - S'Sarovar- II	29-May-12	23.18	30-May-12	10.03	Over Voltage.
400KV	Dabhol - New Koyna - I	30-May-12	08.16	30-May-12	18.29	Decapping of Insulator.
400KV	Karad-Jaigad I	30-May-12	08.22	30-May-12	19.40	Insulator Washing.
400KV	Bus Coupler @ Bhusawal	30-May-12	10.25	30-May-12	18.17	Measurment of Tan Delta of C T.
400KV	400/220 KV 315 MVA ICT-I @ Nagothane	30-May-12	10.51	30-May-12	21.15	Diff. Relay Retrofitting.
400KV	Bhusawal- Aurangabad	30-May-12	17.37	31-May-12	07.52	Over Voltage.
400KV	Deepnagar-Aurangabad-I	30-May-12	19.03	31-May-12	15.06	Over Voltage.
400KV	Bhusawal- Aurangabad	3-Jun-12	18.01	4-Jun-12	09:18	Over Voltage.
400KV	Lonikand-Karad	30-May-12	18.32	30-May-12	19.02	Heavy Sparking Karad End.
400KV	Nagothane-Dabhol-I	30-May-12	04.11	30-May-12	04.40	Distance Protection.
400KV	New Koyna - Jaigad - II	31-May-12	02.27	31-May-12	07.58	Distance Protection,Declared Faulty.
400KV	Karad-Jaigad I	31-May-12	02.45	1-Jun-12	11.40	Distance Protection,Declared Faulty.
400KV	Koradi-Bhilai	30-May-12	13.25	30-May-12	19.25	PLCC Work.
400KV	Koyna IV - Jejuri	31-May-12	08.25	31-May-12	19.18	Replaement of insulator.
400KV	New Koyna - Dabhol - II	31-May-12	09.41	31-May-12	16.16	Cold line washing of insulator.
400KV	New Koyna-Jaigad II	31-May-12	13.53	31-May-12	19.54	Insulator decaping attending work.
400KV	Bhusawal- Aurangabad	31-May-12	15.09	1-Jul-12	09.57	Aattend hot spot.Ready for charging at 18.17 hrs.
400KV	Aurangabad-Deepnagar-II	31-May-12	18.41		Continued.	Over Voltage.
400KV	Newkoyna - Jaigad - I	31-May-12	05.20	31-May-12	07.30	Distance protection.
400KV	Dabhol-Nagothane-II	1-Jun-12	07.04	1-Jun-12	10.54	Restranging of E/W.
400KV	Kalwa-Padgha II	1-Jun-12	07.34	1-Jun-12	09.10	Hot spot,29C isolator.
400KV	Lonikand- Koyna Stage IV	1-Jun-12	07.50	1-Jun-12	19.59	Repl.of insulator.
400KV	Akola - Bhusawal	1-Jun-12	08.36	1-Jun-12	22.44	Repl.of insulator.
400KV	400/220KV 500MVA ICT- I at Khaperkheda	1-Jun-12	08.15	1-Jun-12	16.38	Testing of NDR relay.
400KV	Kalwa - Padgha - I	1-Jun-12	09.29	1-Jun-12	16.46	Repair of Y-Ph damaged conductor.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	1-Jun-12	10.15	1-Jun-12	19.38	Testing work.
400KV	Karad-Jaigad II	1-Jun-12	12.28	1-Jun-12	22.48	Repl.of insulator, ready for charging at 20.40Hrs.

400KV	Bhusawal- Aurangabad	1-Jun-12	17.49	2-Jun-12	06.38	Over Voltage.
400KV	Akola - Wardha - II	1-Jun-12	19.21	1-Jun-12	20.48	Distance Protection.
400KV	New Koyna-Jaigad II	2-Jun-12	04.12	2-Jun-12	06.52	Dist.Prot,declared faulty.
400KV	Karad-Jaigad II	2-Jun-12	08.00	2-Jun-12	19.27	Old insulator replacement work.
400KV	Lonikand- Koyna Stage IV	2-Jun-12	08.08	2-Jun-12	19.20	Old insulator replacement work.
400KV	400/220 KV 315 MVA ICT- II @ Dhule	2-Jun-12	09.01		Continued.	Cable termination work.
400KV	Dabhol - NewKoyna - II	2-Jun-12	08.13	2-Jun-12	18.15	Cold line insulator washing.
400KV	Kolhapur - Mapusa - II	2-Jun-12	12.30	4-Jun-12	04.59	Over Voltage.
400KV	Bhusawal- Aurangabad	2-Jun-12	17.49	3-Jun-12	09.57	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	2-Jun-12	17.01	2-Jun-12	20.14	H/T
400KV	Tie Breaker at Akola	2-Jun-12	14.28	2-Jun-12	15.04	To check Bkr unhealthy indication.
400KV	New Koyna-Jaigad II	3-Jun-12	03.44	3-Jun-12	19.22	Distance Protection.
400KV	Newkoyna - Jaigad - I	3-Jun-12	04.30	3-Jun-12	16.47	Distance Protection.
400KV	765 KV Wardha - Seoni -I	30-May-12	17.48		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	3-Jun-12	18.06	3-Jun-12	21.10	Over Voltage.
400KV	Padgha-Bhoisor (PGCIL)	3-Jun-12	21.13	4-Jun-12	00.24	To attend hot spot.
400KV	Dabhol - Nagothane - I	3-Jun-12	08.50	3-Jun-12	18.22	Cold line insulator washing.
220KV	220/132 KV 150 MVA ICT @ Bhandara	28-Dec-11	13.57	2-Jun-12	15.25	Replacement of ICT by 200MVA New ICT Commissioning.
220KV	Hingoli-Parbhani	28-May-12	14.15	28-May-12	22.46	Distance Protection Operated Zone - I.
220KV	220/132 KV 200MVA T/F II at Lonand	28-May-12	12.56	28-May-12	16.13	Testing Work.
220KV	Vankuswade-Malharpath	28-May-12	09.43	28-May-12	19.26	Cold Washing of Disc Insulator.
220KV	Vankushwadi - MIDC Satara - I	28-May-12	09.40	28-May-12	19.29	Cold Washing of Disc Insulator.
220KV	Apta-Kalwa	28-May-12	11.41	30-May-12	16.45	SF-6 Leakage Problem in Breaker (Line Taken on TBC).
220KV	Babaleshwar - Alephata	27-May-12	13.53	30-May-12	23.50	To Control Load of Balsr ICT's (ICT-III Under Outage).
220KV	Lamboti-Bale-I	29-May-12	05.35	29-May-12	07.30	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
220KV	Lamboti-Bale-II	29-May-12	05.35	29-May-12	07.30	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
220KV	220/132 KV 200 MVA ICT - I @ Bale	29-May-12	05.35	29-May-12	08.25	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
220KV	220/132 KV 200 MVA ICT - II @ Bale	29-May-12	05.35	29-May-12	08.26	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
220KV	220/132 KV 200 MVA ICT - III @ Bale	29-May-12	05.35	29-May-12	14.22	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
220KV	Nagothane-IPCL	29-May-12	09.17	29-May-12	22.17	Maintenance Work.
220KV	Kalwa-Trombay	29-May-12	08.25	29-May-12	11.09	Connection of Jumpers Bet. C T & 29C Isolator.
220KV	Peth-Nigde	29-May-12	09.17	29-May-12	13.00	R.M.Work.
220KV	Pawas-Kharepatan	29-May-12	10.25	29-May-12	10.50	B Phase O/C,E/F.
220KV	Nasik-Navsari-I	29-May-12	11.22	29-May-12	14.35	Tree Cutting.
220KV	Bus Section @ Vankuswadi	29-May-12	09.18	29-May-12	19.25	Cold Washing of Bus Equipment.
220KV	Tuljapur - Murud	29-May-12	18.56	29-May-12	21.33	Distance Protection Operated Z-I B Ph.
220KV	Aurangabad-Padegaon CKT-II	29-May-12	14.50	29-May-12	18.21	Ckt on TBC FOR CRM.
220KV	Aurangabad - Bhenda	29-May-12	09.41	29-May-12	14.39	For CRM of Bkr. (Ckt is on TBC)
220KV	220/132 KV 200 MVA ICT-I @ Harangul	29-May-12	09.53	29-May-12	18.30	Quarterly Maintainance Work.
220KV	Pophali - KDPH	30-May-12	00.32	30-May-12	01.05	Distance Protection.
220KV	M'Peth -Vankuswade	30-May-12	01.28	30-May-12	15.27	Distance Protection,Declared Faulty.
220KV	Pawas-Kharepatan	30-May-12	06.02	30-May-12	06.25	Distance Protection,Y Ph E/F.
220KV	Bale-Usmanabad	30-May-12	05.27	2-Jun-12	15.51	Erection of Towers.
220KV	Vankuswadi-KDPH	30-May-12	01.18	30-May-12	15.30	Distance Protection.
220KV	Bhigwan-Kurkum	30-May-12	08.10	31-May-12	11.15	Taken on TBC @ Bhigwan.
220KV	Bhenda-Waluj	30-May-12	08.13	30-May-12	12.59	Decapping of Insulator.
220KV	Phursungi - Theur	30-May-12	14.52	31-May-12	08.00	To Control Lonikand ICT Loading.
220KV	Boiser - Tarapur	30-May-12	16.53	30-May-12	17.10	Distance Protection.
220KV	Pawas-Kharepatan	31-May-12	04.05	31-May-12	04.18	Distance Protection.
220KV	Khaparkheda-Ambazari - I	30-May-12	08.46	30-May-12	11.32	Erection of Aux.Isolator.
220KV	Aurangabad - Padegaon - I.	30-May-12	10.15	30-May-12	16.01	Measurment of Contact Ressistance.(Ckt is on TBC).
220KV	Hingoli-Pusad	30-May-12	19.25	30-May-12	21.11	B Ph. C T Clamp Replacement Work.
220KV	Mudshingi - Talandage - I	31-May-12	07.32	31-May-12	17.32	Replacement of insulator.
220KV	Bombay Dyeing - Sahara	31-May-12	09.20	31-May-12	13.10	Maintenance work.
220KV	220/132 KV,200 MVA ICT-I at Kurkumbh	31-May-12	08.00	31-May-12	14.30	Overhauling of OLTC diverter switch.
220KV	Babaleshwar - Ranjangaon	31-May-12	12.15	31-May-12	19.12	Testing work.
220KV	220/132 KV 200 MVA ICT - II @ Bale	31-May-12	14.39	31-May-12	15.56	Relay testing work.
220KV	Tarapur - Boiser	31-May-12	10.59	31-May-12	16.05	Line maintenance work.

220KV	220/132 KV 100 MVA ICT @ Gadchiroli	31-May-12	06.53	31-May-12	10.05	Measurement of tan delta of CT.
220KV	Girwali - Parbhani	31-May-12	06.45	31-May-12	15.09	Replacement of guy piece at Loc.295.
220KV	220/22 KV,40 MVA T/F-I at SICOM	31-May-12	20.29	31-May-12	21.02	To attend LV side R ph.open clamp.
220KV	Kalwa-Colourchem	1-Jun-12	10.57	1-Jun-12	19.20	Maint.of 220KV Bus Sec.Isolator and PT Isolator.
220KV	Mudshingi-Talangade - I	1-Jun-12	07.15	1-Jun-12	18.55	Repl.of insulator.
220KV	220/33 KV 100 MVA - II @ Aarey	1-Jun-12	06.07	1-Jun-12	08.39	Premansoon Maint.work.
220KV	220KV Creekside Bus @ Kalwa	1-Jun-12	06.20	1-Jun-12	15.30	Repl.of all 3 twin core jumpers near interconnecting.
220KV	220/100KV 200 MVA ICT- II @ Kolshet	1-Jun-12	08.04	1-Jun-12	12.48	R.M.Work
220KV	Babaleshwar - Ranjangaon	1-Jun-12	08.21	1-Jun-12	19.50	Restranging of E/W.
220KV	Nivali-Pawas	1-Jun-12	10.22	1-Jun-12	12.11	Hot Spot.
220KV	Raymond-Washala	1-Jun-12	09.12	1-Jun-12	15.23	Testing work.
220KV	Padgha-Vasai	1-Jun-12	10.27	1-Jun-12	18.21	Testing work.
220KV	Chalisgaon - Malegaon	1-Jun-12	10.53	1-Jun-12	16.38	Insulator replacement.
220KV	Mahape - Siemens	1-Jun-12	09.15	1-Jun-12	18.23	Water proffing work at Siemens.
220KV	220/100 KV 200 MVA ICT- I @ Kolshet	1-Jun-12	13.26	1-Jun-12	18.30	R.M.Work
220KV	Bale - Lamboti I	1-Jun-12	16.43	1-Jun-12	21.43	Hot Spot.
220KV	Pedambe - Tambati	1-Jun-12	11.53	1-Jun-12	21.08	Distance Protection.
220KV	Wardha - Deoli (PGCIL)	1-Jun-12	19.21	1-Jun-12	21.01	Distance Protection.
220KV	Badnera - Deoli (PGCIL)	1-Jun-12	19.21	1-Jun-12	20.45	Distance Protection.
220KV	220/132 KV 100MVA ICT I at Pusad	1-Jun-12	15.45	1-Jun-12	18.16	Tan delta measurement of CT.
220KV	220/33 KV 100 MVA T/F @ Walve	1-Jun-12	15.45	1-Jun-12	18.16	Connecting jumpers of Y-Ph isolator.
220KV	220 KV Bus-I @ Trombay	1-Jun-12	23.18	2-Jun-12	01.49	Charging 220 KV Chembur I&II cables for soak test.
220KV	Karad-Pophali	2-Jun-12	00.40	2-Jun-12	07.36	Dist.protection.
220KV	BBLSR-A'Nagar II	2-Jun-12	07.03	2-Jun-12	10.36	Q.M.Work
220KV	Talangade-Mudshingi	2-Jun-12	08.17	2-Jun-12	20.27	Replacement of old insulator string.
220KV	Lonand - Jejuri	2-Jun-12	10.32	2-Jun-12	13.55	Replacement of 220 KV LA.
220KV	Hinjawadi-I - Hinjawadi-II	2-Jun-12	10.03	2-Jun-12	17.45	R.M.Work
220KV	Loniland-Kathapur	2-Jun-12	10.03	2-Jun-12	13.33	Hot spot attending work.
220KV	Vankuswade-Malharpath	2-Jun-12	09.07	3-Jun-12	03.00	Maint.work.
220KV	220/132KV 100 MVA ICT @ Bhenda	2-Jun-12	09.10	2-Jun-12	17.00	Q.M.Work
220KV	P'pur-Malinagar	2-Jun-12	12.24	2-Jun-12	12.34	Distance protection.
220KV	Bale - Lamboti I	2-Jun-12	16.23	2-Jun-12	20.20	Atetending hot spot on CT.
220KV	Alephata-Kathapur	2-Jun-12	13.50	2-Jun-12	17.02	Attending hot spot on CT clamp.
220KV	220/132,200MVA Tr.-2 @ A' Nager	2-Jun-12	11.12	2-Jun-12	13.23	Q.M.Work
220KV	Tuljapur - Murud	2-Jun-12	12.31	2-Jun-12	15.51	Maint & testing work.(Ckt.on TBC)
220KV	Parly - Harangool - I	3-Jun-12	09.24	3-Jun-12	15.06	To attend hot spot.
220KV	Bus Section - I @ Pophali	3-Jun-12	06.15	3-Jun-12	17.20	Q.M.Work
220KV	Kharghar-Nerul	3-Jun-12	09.09	3-Jun-12	19.13	Attending hot spot.
220KV	Ghodbandar - Bhoisor (MSETCL)	3-Jun-12	11.10	3-Jun-12	13.47	Pre mansoon maint.work.
220KV	220/16.5 KV,315 MVA ,GT-I Bay at Paras U-3	3-Jun-12	09.30	3-Jun-12	23.10	For replacement of 29 D isolator.
220KV	220/33 KV 100 MVA T/F - I at Aarey	3-Jun-12	07.18	3-Jun-12	17.55	Replacement of NGT.
220KV	Boiser-Boiser(PGCIL)-I	3-Jun-12	07.58	3-Jun-12	10.53	Pre mansoon maint.work.
132KV	Jangamwadi - Kandhar	28-May-12	18.27	28-May-12	19.30	Distance Protection Operated Zone - I.
132KV	Waghala- Jangamwadi	28-May-12	18.27	28-May-12	18.39	Distance Protection Operated Zone - I.
132KV	Bale - Nuldurg	29-May-12	05.35	29-May-12	08.30	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
132KV	Bale-Degaon I	29-May-12	05.35	29-May-12	08.30	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
132KV	Bale-Degaon II	29-May-12	05.35	29-May-12	08.30	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
132KV	Bale-Akkalkot	29-May-12	05.35	29-May-12	08.30	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
132KV	Bale - Umarga	29-May-12	05.35	29-May-12	08.32	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
132KV	Bale - Mohal	29-May-12	05.35	29-May-12	08.32	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.
132KV	Bale - Chinchalkati	29-May-12	05.35	29-May-12	08.32	132KV Naldurg Bus Side Jumper Open @ 220KV Bale S/S.