

LINE OUTAGES FOR THE WEEK

FROM 27-Jun-11 TO 3-Jul-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Karad - Kolhapur - II	20-Jun-11	13.38	30-Jun-11	14.00	Over Voltage.
400KV	Akola - Wardha - I	22-Jun-11	02.15	2-Jul-11	08.10	Over Voltage.
400KV	Bhusawal- Aurangabad	25-Jun-11	20.27	27-Jun-11	09.00	Over Voltage.
400KV	Dhule-S'Sarovar I	25-Jun-11	21.46	28-Jun-11	09.10	Over Voltage.
400KV	Kolhapur - Mapusa - I	26-Jun-11	21.35	27-Jun-11	10.19	Over Voltage.
400KV	Lonikand- Koyna Stage IV	26-Jun-11	21.40	27-Jun-11	07.22	Over Voltage.
400KV	Bhusawal- Aurangabad	27-Jun-11	20.22	28-Jun-11	06.09	Over Voltage.
400KV	New Koyna-Jaigad II	27-Jun-11	11.52	27-Jun-11	12.07	Corona ring of B Bus isolator damaged.Charged on 'A'Bus.
400KV	Lonikand- Koyna Stage IV	27-Jun-11	22.30	28-Jun-11	07.04	Over Voltage.
400KV	Kolhapur - Mapusa - II	27-Jun-11	22.35	28-Jun-11	16.04	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	27-Jun-11	10.25	27-Jun-11	20.55	CVT testing work.
400KV	400/6.9KV 80 MVA Stn T/F at Deepnagar.	27-Jun-11	17.55	27-Jun-11	20.10	REF protection operated.
400KV	Dhule - S'Sarovar- II	28-Jun-11	09.20	29-Jun-11	08.13	CVT Testing,ready for charging at 19.05 Hrs,
400KV	Kolhapur - Mapusa - I	28-Jun-11	21.56	29-Jun-11	09.12	Over Voltage.
400KV	Bhusawal- Aurangabad	28-Jun-11	21.08	29-Jun-11	08.10	Over Voltage.
400KV	Lonikand- Koyna Stage IV	28-Jun-11	22.32	29-Jun-11	6.50	Over voltage
400KV	Dhule-Sar'Sarovar - I	29-Jun-11	22.01	30-Jun-11	04.59	Over Voltage
400KV	Lonikand- Koyna Stage IV	29-Jun-11	21.42	30-Jun-11	08.30	Over Voltage
400KV	Kolhapur-Mapusa-II	29-Jun-11	22.34	30-Jun-11	10.17	Over Voltage
400KV	Main Bus-II At New Koyna	29-Jun-11	09.10	29-Jun-11	18.37	Replacement of R and B Phase Conductor
400KV	Bhusawal- Aurangabad	29-Jun-11	20.55	30-Jun-11	07.27	Over Voltage
400KV	Main Bus- II @ New Koyna	30-Jun-11	07.56	30-Jun-11	14.09	Replacement of R & B Ph.Conductor of 400KV Dabhol-I.
400KV	Main Bus- I @ New Koyna	30-Jun-11	16.42	30-Jun-11	22.48	Alignment of B Bus(Near 400KV KaradI&II)
400KV	New Koyna - Jaigad - II	30-Jun-11	16.41	30-Jun-11	23.07	Bus Outage on New Koyna.
400KV	Karad - Kolhapur - I	30-Jun-11	21.34	1-Jul-11	10:07	Over Voltage.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	30-Jun-11	16.20	30-Jun-11	20.36	Taken on TBC forAttending Hot Spot.
400KV	Bhusawal- Aurangabad	30-Jun-11	22.15	1-Jul-11	05.25	Over Voltage
400KV	Kolhapur - Mapusa - I	1-Jul-11	00.24	1-Jul-11	10:16	Over Voltage
400KV	Dhule - S'Sarovar- II	1-Jul-11	00.42	2-Jul-11	07.21	Tried to charge, tripped on Distance Protection (Declared Faulty)
400KV	Dhule-Sar'Sarovar - I	1-Jul-11	04.21	2-Jul-11	10.44	Distance Protection(Declared Faulty)
400KV	Bhusawal- Aurangabad	1-Jul-11	19:47	2-Jul-11	05.51	Over Voltage.
400KV	Kolhapur - Mapusa - II	1-Jul-11	21:25	2-Jul-11	10.05	Over Voltage.
400KV	Chandrapur - Parli - III	1-Jul-11	06:41	1-Jul-11	18:34	Rectification work of diverted section.
400KV	Bhusawal- Aurangabad	1-Jul-11	09:04	1-Jul-11	17:36	Replacement of isolator with earth blade.
400KV	400/220KV,500MVA ICT-III At Kalwa.	1-Jul-11	15:44	1-Jul-11	19:40	Installation of Rainguard.
400KV	400/220 KV 315 MVA ICT- I @ Dhule	1-Jul-11	09:18	1-Jul-11	19:46	P.I. Tandelta measurment.
400KV	Bablsr-Padgha Ckt I	1-Jul-11	13:16	1-Jul-11	16:15	Line Maintenance Work.
400KV	Padgha - Babalshwar - II	1-Jul-11	17:19	1-Jul-11	19:39	Singnature analysis work.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	1-Jul-11	09:15	1-Jul-11	15:15	Installation of Rainguard.
400KV	Stage-IV - Jejuri	2-Jul-11	04:28	2-Jul-11	19:10	Distance Protection.(Declared Faulty)
400KV	Dabhol - New Koyna - I	2-Jul-11	15.38	2-Jul-11	15.58	SF 6 Gas Filling.
400KV	Bhusawal- Aurangabad	2-Jul-11	20.40	3-Jul-11	05.49	Over Voltage.
400KV	Kolhapur - Mapusa - I	2-Jul-11	17.57	4-Jul-11	11.30	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	2-Jul-11	22.23		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	3-Jul-11	00.19	3-Jul-11	09.30	Over Voltage.
400KV	Chandrapur - Parli - II	3-Jul-11	09.54	3-Jul-11	19.18	Rectification Work of Divorted Section.
400KV	Karad - Kolhapur - I	3-Jul-11	17.22	4-Jul-11	09.18	Over Voltage.

400KV	Bhusawal- Aurangabad	3-Jul-11	18.38	4-Jul-11	07.15	Over Voltage.
400KV	Bhusawal- Aurangabad	3-Jul-11	05.49	3-Jul-11	19.18	Isolator Replacement Work(Ckt is on TBC)
220KV	220/110KV 200MVA ICT-II at Mudshingi	10-Apr-11	18.10	4-Jul-11	14.20	Diff.Prot.Defective B Phase LA replaced.
220KV	Bale-Usmanabad	11-Jun-11	16.01	1-Jul-11	10:50	To Control Parly ICT Loading.
220KV	220/132KV 200MVA ICT-II at Lonand	16-Jun-11	08.47	29-Jun-11	15.00	Red Hot Spot(Kept on Huming since 16.06.2011)
220KV	Murud-Bale	19-Jun-11	15.33	1-Jul-11	10:50	At Bale end,To control Parli ICT loading.
220KV	Gangapur - Valve - I	26-Jun-11	06.00	27-Jun-11	02.04	At Loc.18 string clamp broken.
220KV	Tilawani-Miraj	27-Jun-11	10.06	27-Jun-11	14.54	Q.M.Work
220KV	Karad-Mudsingi-IV	27-Jun-11	10.03	27-Jun-11	12.47	Q.M.Work
220KV	Talagade-Ichalkaranji I	27-Jun-11	11.07	27-Jun-11	11.24	To avail outage on Bus-I
220KV	Talagade-Ichalkaranji -II	27-Jun-11	11.11	27-Jun-11	12.07	Distance protection.
220KV	220/33KV 50 MVA T/F- I @ Jalna	27-Jun-11	09.06	27-Jun-11	18.55	Q.M.Work
220KV	M.B.Section-II at Akola	27-Jun-11	13.45	27-Jun-11	18.08	Jumpering work.
220KV	Main Bus - I at Kolhapur.	27-Jun-11	11:47	1-Jul-11	15:20	Sawantwadi I New Bay erection work.
220KV	Apta-Uran-III	28-Jun-11	09.41	28-Jun-11	13.40	Replacement of earth wire.
220KV	Apta-Uran-IV	28-Jun-11	10.04	28-Jun-11	13.26	Replacement of earth wire.
220KV	Bus Coupler at 400KV Kalwa	28-Jun-11	10.00	28-Jun-11	17.55	To attend hot spot.
220KV	Vita - Ghatnandre	28-Jun-11	10.13	28-Jun-11	15.50	To attend hot spot.
220KV	Main Bus @ Vita	28-Jun-11	11.30	28-Jun-11	15.40	Q.M.Work.
220KV	Vita-Karad-I	28-Jun-11	11.30	28-Jun-11	15.40	Due to Bus Outage.
220KV	Vita - Karad II	28-Jun-11	11.30	28-Jun-11	15.43	Due to Bus Outage.
220KV	Vita - Pandharpur	28-Jun-11	11.18	28-Jun-11	15.47	Due to Bus Outage.
220KV	Vita-Maisal	28-Jun-11	11.19	28-Jun-11	15.47	Due to Bus Outage.
220KV	220/33 KV 50 MVA T/F- I @ Vita	28-Jun-11	11.20	28-Jun-11	15.49	Due to Bus Outage.
220KV	220/33 KV 50 MVA T/F II @ Vita	28-Jun-11	11.20	28-Jun-11	15.50	Due to Bus Outage.
220KV	Vita - Miraj	28-Jun-11	11.20	28-Jun-11	15.47	Due to Bus Outage.
220KV	Padgha-Jambhul-I	28-Jun-11	16.12	28-Jun-11	16.54	Distance protection.
220KV	Padgha-Jambhul II	28-Jun-11	16.12	28-Jun-11	16.52	Distance protection.
220KV	220 KV Main Bus-II @ Ambazari	28-Jun-11	11.00	28-Jun-11	22.19	Jumpering of newly erected isolator of 220KV Amvt.Ckt.
220KV	Koradi-Ambazari-I	28-Jun-11	10.23	2-Jul-11	17.58	Transfer of the control panel from existing control panels.
220KV	Dondaicha - Sahada	28-Jun-11	17.55	28-Jun-11	23.25	To attend R ph.WT jumper.
220KV	Bableshtar - Alephata	29-Jun-11	01.57	29-Jun-11	02.39	Distance protection.
220KV	220/132 KV 200 MVA ICT - III @ Bale	29-Jun-11	12.05	29-Jun-11	16.30	Replacement of LV side CT
220KV	Karad - Miraj	29-Jun-11	11.34	29-Jun-11	12.00	SCADA Work
220KV	Karad-Vita-II	29-Jun-11	12.06	29-Jun-11	12.21	SCADA Work
220KV	Mahape-Tifil	29-Jun-11	10.22	29-Jun-11	13.45	Tree Cutting
220KV	Chandrapur - Chandrapur MIDC	29-Jun-11	10.42	29-Jun-11	15.17	Q.M.Work
220KV	220/132KV 100MVA ICT at Butibori	29-Jun-11	20.02	29-Jun-11	21.25	Backup Protection operated
220KV	Koradi-Butibori	29-Jun-11	20.02	29-Jun-11	21.09	Distance Protection
220KV	Butibori TSS -Butibori(MIDC)	29-Jun-11	20.02	30-Jun-11	10.09	Distance Protection(B phase CC Burst)
220KV	220KV Bus Coupler at Abhijeet	29-Jun-11	20.02	29-Jun-11	21.03	Tripped on O/C, E/F
220KV	220KV Bus Section-I Breaker at Abhijeet	29-Jun-11	20.02	30-Jun-11	21.30	Tripped on O/C E/F
220KV	Lonikand -Theur - II	30-Jun-11	08.15	30-Jun-11	13.58	Tan Delta & Measurement of I R Value.
220KV	Babaleshtar - Alephata	30-Jun-11	09.00	1-Jul-11	07:52	Line Maintenance Work.(Charged from BBLSR end)
220KV	220/22 KV, 50 MVA T/F-II @ Kalwa	30-Jun-11	12.20	30-Jun-11	13.40	Maintenance Work.
220KV	Bhosari-Telco	30-Jun-11	11.40	30-Jun-11	18.40	Due to Outage on Bus Section @ Telco.
220KV	Kandalgaon - Pophali	30-Jun-11	12.10	30-Jun-11	12.43	Distance Protection

220KV	Pedambe-Newkoyna	30-Jun-11	13.02	30-Jun-11	21.02	Bus Bar Protection Operated.
220KV	Babaleshwar - Ranjangaon	30-Jun-11	14.37	30-Jun-11	17.12	Y Ph.C T Oil Leakage.
220KV	Bus Section - I @ Telco	30-Jun-11	11.40	30-Jun-11	18.30	Replacement of Bus Isolator,Bus Side Jumper.
220KV	Kalmeshwar - Pandurna	30-Jun-11	10.19	30-Jun-11	14.16	To attend Hot Spot
220KV	Ambazari-Amravati	30-Jun-11	13.35	30-Jun-11	16.55	Connecting and crimping of T point jumpers
220KV	Khaparkheda-Ambazari - I	30-Jun-11	11.08	30-Jun-11	13.08	Connecting & Crimping of T point jumpers
220KV	Vita - Ghatnandre	1-Jul-11	02.33	1-Jul-11	08:44	Distance protection
220KV	220/100KV 200 MVA ICT- I @ Padgha	1-Jul-11	09:14	1-Jul-11	17:08	Bay maint. work.
220KV	Apta - Kalwa - II	1-Jul-11	09:59	1-Jul-11	16:42	Repairing of Conductor.
220KV	Temghar-Colourchem	1-Jul-11	10:47	2-Jul-11	00:47	For taking A/R realy.
220KV	Pedambe-Newkoyna	1-Jul-11	10:10	1-Jul-11	13:46	W.T. Replacement work.
220KV	Babaleshwar - Bhenda	1-Jul-11	10:05		Continued.	Tower Shifting work.
220KV	Nasik - Airoli - Knowledge Park	1-Jul-11	10:52	1-Jul-11	14:29	Maintenance work.
220KV	Kalwa-Mulund II	1-Jul-11	14:08	1-Jul-11	17:58	Testing of Realy.
220KV	220/132 KV 200 MVA ICT - II @ Malegaon	1-Jul-11	14:40	1-Jul-11	15:50	Isolator Maintenance work.
220KV	Kalwa - Airoli - Knowledge Park.	1-Jul-11	11:23	1-Jul-11	14:36	Maintenance Work.
220KV	Dondaicha - Sahada	1-Jul-11	07:05	1-Jul-11	07:40	Backup Protection Operated O/C and E/F.
220KV	Bale-Murud	2-Jul-11	06:00		Continued.	To Control Parli ICT Loading.
220KV	Bale-Osmanbad	2-Jul-11	06:00		Continued.	To Control Parli ICT Loading.
220KV	Babaleshwar - Babaleshwar - I	2-Jul-11	09.07	2-Jul-11	20.10	Replacement of Isolator.
220KV	Babaleshwar - Nagar - I	2-Jul-11	10.15	2-Jul-11	18.27	Taurus Testing.
220KV	Uran-Apta-II	2-Jul-11	10.18	2-Jul-11	15.03	Bay Maint.,Hot Spot Attending.
220KV	Jejuri-Jejuri-II	2-Jul-11	10.50	2-Jul-11	12.25	Attending Hot Spot.
220KV	220/132 KV 200 MVA ICT - II @ Raymand	2-Jul-11	11.32	2-Jul-11	16.35	Bay Maint.Work.
220KV	Jejuri (New) - Parvati	2-Jul-11	08.14	2-Jul-11	19.22	Hand Tripped.
220KV	220 KV Bus Coupler @ New Koyna	2-Jul-11	14.38	2-Jul-11	15.16	Trip.
220KV	N.Koyna-Phinolex	2-Jul-11	14.38	2-Jul-11	15.21	B Ph.Earth Fault.
220KV	Phursungi - Theur	2-Jul-11	19.30		Continued.	To Control Loading.
220KV	Badnera-Amravati	2-Jul-11	11.10	2-Jul-11	14.17	Replacement of LMU & R.M.Work.
220KV	Hingoli-Parbhani	2-Jul-11	14.20	2-Jul-11	18.30	To Attend WT Jumpering Work.
220KV	220/132 KV 200 MVA ICT - I @ Parbhani	2-Jul-11	09.17	2-Jul-11	12.35	Replacement of H V Side Bushing Clamp.
220KV	Urse - General Motors	3-Jul-11	08.14	3-Jul-11	16.45	To Attend Sparking @ Wavetrap @ G.M.End.
220KV	Boisor-Versova	3-Jul-11	09.53	3-Jul-11	13.25	Replacement of Shifted Vibration Damper.
220KV	Jejuri-Phursungi	3-Jul-11	13.04	3-Jul-11	14.53	Replacement of Faulty Insulator String.
220KV	Hingoli-Pusad	3-Jul-11	09.57	3-Jul-11	21.03	To Control Wrd-Ytl Ckt Loading.
220KV	Khapakheda - Koulawada - II	3-Jul-11	16.30	3-Jul-11	16.49	Distance Protection Operated Z-I B Ph.
220KV	Chandrapur - Warora	3-Jul-11	21.47		Continued.	To Control Wrr-Wrd & Wrr-Hgkat Loading.
132KV	Amravati - Akola	28-Jun-11	09.11	28-Jun-11	12.38	Replacement of damaged jumper.
132KV	Ujani-Umarga	28-Jun-11	07.00	28-Jun-11	18.20	Tower erection work at Loc.NO.40-41.
132KV	Chinchwad-Chakan	30-Jun-11	10.00	30-Jun-11	14.03	Bus Isolator Alignment.
132KV	Boiser - Palghar - I	30-Jun-11	11.41	30-Jun-11	14.04	Testing Work.
132KV	Akola - Paras - I	30-Jun-11	20.30	30-Jun-11	20.45	Distance Protection
132KV	Akola-Paras	2-Jul-11	05.05	2-Jul-11	05.12	D/P,Z-I,B Ph-E.
100KV	Kalwa - Salsette - II	28-Jun-11	22.14	29-Jun-11	02.57	Tree fall on conductor at Loc.24 and 25.
100KV	Nerul- Ambarnath	29-Jun-11	10.30	29-Jun-11	19.20	LILo WORK.
100KV	Nerul-Bhivpuri	29-Jun-11	10.30	29-Jun-11	19.05	LILo WORK.