

LINE OUTAGES FOR THE WEEK

FROM 29-Aug-11 TO 4-Sep-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Karad - Kolhapur - I	23-Aug-11	04.45	29-Aug-11	16.19	Tripped Alongwith All Elements of Bus-I .
400KV	Karad - Solapur (PGCIL)	25-Aug-11	21.39	3-Sep-11	08.51	Over Voltage
400KV	Dhule-Khandwa-II	25-Aug-11	23.34	30-Aug-11	10.15	Over Voltage.
400KV	Bhusawal- Aurangabad	28-Aug-11	16.03	30-Aug-11	09.25	Over Voltage.
400KV	Lonikand- Koyna Stage IV	28-Aug-11	22.53	29-Aug-11	08.45	Over Voltage.
400KV	Akola - Bhusawal	29-Aug-11	03.29	29-Aug-11	08.31	Over Voltage.
400KV	Akola-Koradi	29-Aug-11	03.33	29-Aug-11	05.59	Over Voltage.
400KV	New Koyna-Karad-II	29-Aug-11	09.18	29-Aug-11	19.17	Replacement of Defective C V T.(B Ph.)
400KV	New Koyna - StageIV - I	29-Aug-11	17.19	29-Aug-11	19.25	SF 6 Gas Filling Work.
400KV	Karad-Kolhapur-II	29-Aug-11	16.20		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	29-Aug-11	21.52	30-Aug-11	08.33	Over Voltage.
400KV	Akola - Bhusawal	29-Aug-11	22.14	30-Aug-11	07.17	Over Voltage.
400KV	400/11.5 KV 90 MVA Station T/F-IV @ Cha	29-Aug-11	17.37	1-Sep-11	15.55	B Ph. L A Burst.
400KV	400/11.5KV 90 MVA STN T/F- V @ 400 KV	29-Aug-11	17.56	29-Aug-11	18.50	Tripped on Earth Fault.
400KV	400/220 KV 315 MVA ICT @ Akola	29-Aug-11	07.06	29-Aug-11	11.09	Stringing Work of 220KV Apatapa-Balapur D C Line.
400KV	Chandrapur - Parli - III	29-Aug-11	23.15	30-Aug-11	06.42	Over Voltage.
400KV	Kalwa-Kharghar	30-Aug-11	08.36	30-Aug-11	13.39	To attend hot spot.
400KV	Padgha-Bhoisor (PGCIL)	30-Aug-11	12.52	30-Aug-11	16.28	Replacement of LMV of CVT's at Padgha.
400KV	Bhusawal- Aurangabad	30-Aug-11	20.21	3-Sep-11	08.30	Over Voltage.
400KV	Lonikand- Koyna Stage IV	30-Aug-11	23.00	31-Aug-11	08.09	Over Voltage.
400KV	Dhule-Khandwa-II	31-Aug-11	00.37	2-Sep-11	11.18	Over Voltage.
400KV	Padgha - Kharghar	31-Aug-11	09.56	31-Aug-11	12.30	Red hot attended.(Taken on TBC)
400KV	Chandrapur - Khaparkheda	31-Aug-11	10.28	31-Aug-11	15.23	Taurs kit Testing work.
400KV	Koyna IV - Jejuri	31-Aug-11	21.26	2-Sep-11	10.02	Distance protection.
400KV	Lonikand- Koyna Stage IV	31-Aug-11	14.15	31-Aug-11	14.55	Distance protection.
400KV	Akola - Bhusawal	31-Aug-11	22.50	1-Sep-11	08.55	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	1-Sep-11	03.05	2-Sep-11	11.08	Over Voltage.
400KV	Akola - Bhusawal	1-Sep-11	21.52		Continued.	Over Voltage.
400KV	C'pur-Parli II	1-Sep-11	15.00	2-Sep-11	06.23	Over Voltage.
400KV	Lamboti - Solapur (PGCIL)	1-Sep-11	22.19	3-Sep-11	09.06	Over Voltage.
400KV	Karad - Kolhapur - I	2-Sep-11	02.20	2-Sep-11	09.19	Over Voltage
400KV	Kalwa - Lonikand	2-Sep-11	10.59	2-Sep-11	16.34	For attending hot spot.
400KV	Padgha -Tarapur - I	2-Sep-11	09.04	2-Sep-11	19.17	Bay maint.work.
400KV	Dhule-Khandwa-II	2-Sep-11	23.58	3-Sep-11	07.51	Over Voltage.
400KV	Lonikand- Koyna Stage IV	2-Sep-11	23.25	3-Sep-11	09.44	Over voltage
400KV	Karad - Kolhapur - I	3-Sep-11	04.03	3-Sep-11	09.51	Over Voltage.
400KV	Karad - Solapur (PGCIL)	3-Sep-11	09.06		Continued.	Over voltage.
400KV	Solapur - Solapur (PG)	3-Sep-11	10.37		Continued.	Over voltage.
400KV	400/220 KV 315 MVA ICT- I @ Parly.	3-Sep-11	09.14	3-Sep-11	12.43	Attending hot spot on'A'Phase C.T.
400KV	Chandrapur - Parli - III	3-Sep-11	21.46		Continued.	Over voltage.
400KV	Dhule-Khandwa-II	3-Sep-11	16.27		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	3-Sep-11	13.32		Continued.	Over Voltage
400KV	Koradi - Akola	4-Sep-11	00.34	4-Sep-11	07.58	Over Voltage
400KV	Koyna IV - Jejuri	4-Sep-11	01.07	4-Sep-11	10.21	Over Voltage
400KV	Dhule-S'Sarovar I	4-Sep-11	04.20		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	4-Sep-11	22.55		Continued.	Over Voltage
220KV	220/132KV,100 MVA ICT-III at Girwali.	21-Jun-11	10.44	31-Aug-11	16.30	Augmentation of ICT by new 200 MVA ICT.upto 10.09.2011.

220KV	Khaparkheda - Kanhan - II	25-Aug-11	09.49	3-Sep-11	19.52	Tower Height Raising work
220KV	Kanhan - Bhandara - II	25-Aug-11	09.54	3-Sep-11	19.58	Tower Height Raising work
220KV	Chandrapur - Warora	26-Aug-11	02.29	30-Aug-11	08.52	Over Voltage
220KV	Babaleshwar - Nagar - I	29-Aug-11	04.29	29-Aug-11	04.46	Tripped.
220KV	Dahanu-Bhoisor	29-Aug-11	06.31	29-Aug-11	07.30	Attending Moisture Drain Valve Leakage of Dahanu Breaker.
220KV	220/100KV 200MVA ICT-IV at Kalwa	29-Aug-11	13.07	29-Aug-11	14.45	Insulator Jumper Replacement Work.
220KV	Main Bus Section- I @ Pedambe	29-Aug-11	13.17	29-Aug-11	18.20	Replacement of B Ph. Main Bus Conductor of Mahad Line.
220KV	Trombay-Mulund	29-Aug-11	18.18	29-Aug-11	20.28	V T Fuse Problem.
220KV	Trombay - Tata Tie - I	29-Aug-11	19.08	29-Aug-11	20.33	V T Fuse Problem.
220KV	Jejuri-Phursungi	29-Aug-11	08.46	29-Aug-11	10.26	Distance Protection.
220KV	Nerul -Sonkhar	29-Aug-11	18.49	29-Aug-11	22.47	Y Ph. C T Jumper Broken @ Sonkhar End.
220KV	Halkarni-Amona I	29-Aug-11	11.44	1-Sep-11	04.16	Retrofitting of Distance Protection Scheme.
220KV	New Paras TPS - Akola - I	29-Aug-11	11.25	29-Aug-11	16.53	Stringing of 220KV Apatapa-Balapur D C Line.
220KV	New Paras TPS-Alola-II	29-Aug-11	07.04	29-Aug-11	16.48	Stringing of 220KV Apatapa-Balapur D C Line.
220KV	Badnera - Akola - I	29-Aug-11	11.37	29-Aug-11	16.44	Stringing of 220KV Apatapa-Balapur D C Line.
220KV	Khaparkheda - Koulawada - II	29-Aug-11	11.20	30-Aug-11	19.50	Retrofitting of Distance Scheme.
220KV	Aurangabad-Shendra	29-Aug-11	08.30	29-Aug-11	10.09	To Attend Hot Spot on R Ph. W T.
220KV	220/33 KV 25 MVA T/F - I @ Dhule	29-Aug-11	16.01	29-Aug-11	16.34	Tripped on PDR.
220KV	220/33 KV 25 MVA T/F - II @ Dhule	29-Aug-11	16.01	29-Aug-11	17.43	Due to D C Supply Fail.
220KV	Vita-Maisal	29-Aug-11	22.30	30-Aug-11	10.58	Distance Protection Y Ph. Z-I.
220KV	Jejuri-Phursungi	30-Aug-11	09.00	30-Aug-11	11.30	Line maint.work.
220KV	220/132KV,200MVA T/F-I at Lonand	30-Aug-11	09.05	30-Aug-11	13.10	Q.M.Work
220KV	Malegaon-Satana	30-Aug-11	11.59	30-Aug-11	15.45	To attend hot spot.
220KV	Virur - Gadchiroli	30-Aug-11	11.27	30-Aug-11	11.42	D/P,Z-2,R-E fault.
220KV	220/132KV 200 MVA ICT I at Chalisgaon	30-Aug-11	16.44	30-Aug-11	19.09	Isolator replacement work.
220KV	Chandrapur-Wani	30-Aug-11	09.08	30-Aug-11	14.07	Measurement of Tan Delta of CT.
220KV	Warora-Wardha	30-Aug-11	11.05	30-Aug-11	13.40	Attending hot spot.
220KV	Uran - HOCL	31-Aug-11	10.21	31-Aug-11	16.40	Attended hot spot.
220KV	Borivali-Mulund	31-Aug-11	10.40	31-Aug-11	13.02	Attended Hot Spot.
220KV	Tarapur - Borivali	31-Aug-11	08.55	31-Aug-11	09.23	Distance protection.
220KV	220/132 KV,200 MVA ICT-II At Chalisgaon	31-Aug-11	23.24	1-Sep-11	22.35	Diff.Prot.Operated.
220KV	Halkarni-Amona I	1-Sep-11	04.35	1-Sep-11	14.55	Distance protection.
220KV	Chinchwad-Urse	1-Sep-11	06.04	1-Sep-11	06.49	E/F.
220KV	Pophali-K'gaon	1-Sep-11	15.35	1-Sep-11	15.45	Distance protection.
220KV	Khaperkheda - Wardha.	1-Sep-11	20.42	3-Sep-11	08.27	To control Koradi ICT loading.
220KV	Ambazari - Abhijeet	1-Sep-11	20.48	3-Sep-11	12.07	To control Koradi ICT loading.
220KV	220KV Main Bus at Virur	1-Sep-11	20.00	1-Sep-11	20.32	Bus Bar Prot.Operated.
220KV	220/132KV 100 MVA ICT @ Virur	1-Sep-11	20.00	1-Sep-11	20.40	Bus Bar Prot.Operated.
220KV	Virur - Gadchiroli	1-Sep-11	20.00	1-Sep-11	20.34	Bus Bar Prot.Operated.
220KV	Gadchandur-Virur-I	1-Sep-11	20.00	1-Sep-11	20.32	Bus Bar Prot.Operated.
220KV	220KV Main Bus at Virur	1-Sep-11	17.24	1-Sep-11	18.00	Bus Bar Prot.Operated.
220KV	Virur - Railway TSS-II	1-Sep-11	17.24	1-Sep-11	23.30	Bus Bar Prot.Operated.
220KV	Virur - Railway TSS -I	1-Sep-11	17.24	1-Sep-11	20.32	Bus Bar Prot.Operated.
220KV	Virur - Gadchiroli	1-Sep-11	17.24	1-Sep-11	18.00	Bus Bar Prot.Operated.
220KV	Gadchandur-Virur-I	1-Sep-11	17.24	1-Sep-11	18.00	Bus Bar Prot.Operated.
220KV	Virur - Gadchiroli	1-Sep-11	13.51	1-Sep-11	14.06	Dist.Prot.Opetd.
220KV	220/33 KV 25 MVA T/F - I @ Dhule	1-Sep-11	01.00	1-Sep-11	01.40	LV Back up Prot.Operated.

220KV	220/33 KV 25 MVA T/F - II @ Dhule	1-Sep-11	01.00	1-Sep-11	04.36	LV Back up Prot.Operated.
220KV	220/132KV 100MVA ICT-II at Virur	1-Sep-11	00.00	1-Sep-11	18.15	Bus Bar Prot.Operated.
220KV	220/132KV 100MVA ICT-II at Virur	1-Sep-11	20.00	1-Sep-11	20.40	Bus Bar Prot.Operated.
220KV	Chandrapur - Warora	2-Sep-11	03.18	2-Sep-11	12.47	Dist.Prot.Operated
220KV	Trombay Sonkhar	2-Sep-11	07.15	2-Sep-11	11.18	Jumper replacement work.
220KV	Padgha-Kamba	2-Sep-11	10.40	2-Sep-11	18.05	Replacement of flashover insulator.
220KV	Chalisgaon - Malegaon	2-Sep-11	08.56		Continued.	Replacement of line and Transfer bus isolator.
220KV	Apta-Uran-IV	2-Sep-11	10.11	2-Sep-11	17.40	R.M.and hot spot attending work.
220KV	Padgha-Jambhul-I	2-Sep-11	11.31	2-Sep-11	16.09	Repairing work of damaged conductor.
220KV	Padgha - Boisar (PGCIL)	2-Sep-11	09.35	2-Sep-11	17.25	Replacement of flashover insulator.
220KV	220/132 KV,100MVA ICT-II At Padegaon.	2-Sep-11	12.53	2-Sep-11	16.30	Q.M.Work
220KV	Chandrapur - Warora	2-Sep-11	12.47	5-Sep-11	00.05	To control WRR-WRD Hinganghat loading.
220KV	Bhugaon-Wardha	2-Sep-11	18.15	3-Sep-11	06.41	To control 220KV Wardha-Deoli loading.
220KV	Badnera-Akola Ckt.I	2-Sep-11	18.32	3-Sep-11	08.31	To control 220KV Wardha-Deoli loading.
220KV	Babaleshwar - Nagar - I	3-Sep-11	00.49	3-Sep-11	01.36	Dist.Protection.
220KV	220/132KV 200MVA ICT-VI at Nasik GCR	3-Sep-11	09.00	3-Sep-11	15.19	SFRA Tan delta testing work.
220KV	220/132 KV 200 MVA ICT - II @ Malegaon	3-Sep-11	11.37	3-Sep-11	18.15	Conductor replacement work.
220KV	Babaleshwar - Nagar - I	3-Sep-11	10.30	3-Sep-11	18.30	Replacement of faulty insulator.
220KV	PADGHA-BOISER (PGCIL)	3-Sep-11	19.27	4-Sep-11	01.17	Distance protection.
220KV	Nasik - Ghatghar	4-Sep-11	09.45	4-Sep-11	17.39	Replacement of String Insulator
220KV	Babaleshwar - Bhenda	4-Sep-11	12.00	4-Sep-11	14.00	ICT-III commissioning work
220KV	Borivali-Tata Borivali 4	4-Sep-11	10.34	4-Sep-11	14.00	Red Hot on B&C phase vertical droffer
220KV	Nasik-Navsari-I	4-Sep-11	06.58	4-Sep-11	07.41	Distance Protection
220KV	Nasik-Navsari -II	4-Sep-11	06.58	4-Sep-11	07.46	Distance Protection
220KV	Badnera - Akola - I	4-Sep-11	09.05	4-Sep-11	12.06	To attend Hot Spot on R Phase Isolator(Ckt is on TBC)
220KV	Dhule-Chalisgaon	4-Sep-11	10.05		Continued.	Bus side Isolator replacement work(Ckt charged Through TBC)
132KV	Kawlewada-Gondia-II	30-Aug-11	19.55	30-Aug-11	21.52	R-Ph to E,Z-1.
132KV	Kawlewada-Madgi-I	30-Aug-11	19.55	31-Aug-11	06.55	B-Ph C.C.Burst.
132KV	Kawlewada-Madgi II	30-Aug-11	19.55	30-Aug-11	20.42	D/P,Z-1,R-Ph
132KV	Kanhan - Bhandara	31-Aug-11	16.02	31-Aug-11	16.14	Backup prot.operated,O/C & E/F R-Ph.
132KV	Bhandara - Madgi -I	31-Aug-11	16.02	31-Aug-11	16.42	B-Ph CT burst at Madgi-II.
132KV	Bhandara - Madgi - II	31-Aug-11	16.02	31-Aug-11	16.41	B-Ph CT burst at Madgi-II.
132KV	Madgi-Kawlewada-I	31-Aug-11	16.02	31-Aug-11	16.25	B-Ph CT burst at Madgi-II.
132KV	Madgi-Kawlewada-II	31-Aug-11	16.02	1-Sep-11	22.00	B-Ph CT burst at Madgi-II.
132KV	Daund-Shrigonda	31-Aug-11	04.05	31-Aug-11	04.20	Distance protection.
132KV	Virur-Ashti	1-Sep-11	20.00	1-Sep-11	20.47	Bus Bar Prot.Operated.
132KV	Virur-Ashti	1-Sep-11	17.24	1-Sep-11	18.30	Bus Bar Prot.Operated.
132KV	Bhandara-Ambhora	1-Sep-11	13.46	1-Sep-11	13.53	Dist.Prot.Opetd.
132KV	Parli-Talegaon	1-Sep-11	11.45	1-Sep-11	12.00	Dist.Prot.Opetd.
132KV	Paras-Akola-I	1-Sep-11	01.35	1-Sep-11	01.55	Dist.Prot.Opetd.

132KV	132/11 KV 16 MVA T/F @ Kalmeshwar	1-Sep-11	03.20	1-Sep-11	10.40	PRV Operated.
132KV	BBLSR - Newasa	2-Sep-11	10.30	2-Sep-11	13.45	Replacement of insulator.
132KV	Paras-Patur	2-Sep-11	13.24	2-Sep-11	13.49	Distance protection .
132KV	Georai-Mahakala	2-Sep-11	15.15	2-Sep-11	16.45	Back up protection operated.
132KV	Pusad - Umarkhed	3-Sep-11	19.48	3-Sep-11	20.01	Distance protection.
132KV	IOL MIDC-Boiser-I	3-Sep-11	20.30	3-Sep-11	22.43	Y Phase jumper repair.
132KV	Paras - Warwat Bakal	3-Sep-11	17.01	4-Sep-11	11.23	Distance Protection
132KV	Dhule-Nardhane	3-Sep-11	17.04	4-Sep-11	03.53	Distance Protection
132KV	Pusad-Jambazar	3-Sep-11	22.36	3-Sep-11	22.48	Distance Protection
132KV	Dondaicha - Nandurbar	4-Sep-11	04.10	4-Sep-11	18.10	Distance Protection
100KV	Kalwa - Salshet - I	31-Aug-11	16.02	31-Aug-11	16.25	B-Ph wave trap sparking.
100KV	Kalwa-Kalyan	31-Aug-11	14.08	31-Aug-11	14.19	Dist.Prot.Operated.
100KV	Kalwa - Salshet - I	31-Aug-11	14.08	31-Aug-11	14.58	Dist.Prot.Operated.
100KV	Kalwa-Washi	1-Sep-11	06.50	1-Sep-11	08.55	Red Hot.
100KV	Pal-Taloja	3-Sep-11	21.21	3-Sep-11	02.35	Jumper opened at Taloja end.