

LINE OUTAGES FOR THE WEEK

FROM 27-Sep-10 TO 3-Oct-10

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	Wardha - Akola - I	21-Sep-10	17.45	8-Oct-10	17.53	Interchange
400KV	Kolhapur - Mapusa - I	23-Sep-10	09.48	28-Sep-10	11.17	C.B.Problem at Kolhapur.
400KV	Akola - Aurangabad - I	25-Sep-10	14.21	2-Oct-10	13.49	Over Voltage.
400KV	400/220 KV 600 MVA ICT- I @ Kalwa	26-Sep-10	07.12	27-Sep-10	02.07	Bus bar protection operated.Y Ph.CT burst.
400KV	Karad - Kolhapur - I	26-Sep-10	21.11	27-Sep-10	07.54	To attend red hot.Line ready for charging @ 01.29 hrs.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	26-Sep-10	22.02	27-Sep-10	00.52	Due to red hot.
400KV	Karad-Lamboti	26-Sep-10	22.42	27-Sep-10	08.39	Over Voltage.
400KV	Lonikand- Koyna Stage IV	26-Sep-10	23.24	27-Sep-10	09.11	Over Voltage.
400KV	Dhule-S'Sarovar I	26-Sep-10	23.27.	30-Sep-10	08.35	Over Voltage.
400KV	Bhusawal- Aurangabad	26-Sep-10	14.33	1-Oct-10	09.56	Over Voltage.
400KV	Karad - Kolhapur - II	27-Sep-10	04.02	2-Oct-10	14.49	Over Voltage.
400KV	Dabhol - Nagothane - I	27-Sep-10	10.14	28-Sep-10	06.56	To attend sparking near B phase wave trap at Dabhol end
400KV	Main Bus-II @ Kolhapur	27-Sep-10	13.08	28-Sep-10	11.14	Replacement of R phase pentograph
400KV	Dabhol-Nagothane - II	27-Sep-10	15.19	27-Sep-10	16.03	Distance Protection
400KV	Dabhol-Nagothane - II	27-Sep-10	20.13	27-Sep-10	20.54	Distance Protection
400KV	400/220 KV 315 MVA ICT- I @ Parly.	27-Sep-10	17.35	28-Sep-10	13.33	Differential Protection operated.
400KV	Karad-Lamboti	27-Sep-10	22.46	28-Sep-10	08.36	Over Voltage
400KV	Lonikand- Koyna Stage IV	28-Sep-10	00.22	28-Sep-10	08.50	Over Voltage
400KV	Chandrapur - Parli - II	28-Sep-10	00.20	28-Sep-10	06.03	Over Voltage
400KV	Dabhol-Nagothane - II	28-Sep-10	11.39	28-Sep-10	20.01	Attending Red Hot at Dabhol end
400KV	400/220 KV 315MVA ICT- II @ Kolhapur	28-Sep-10	12.11	28-Sep-10	17.57	Breaker Maint.work
400KV	Karad-Lamboti	28-Sep-10	22.00	1-Oct-10	09.02	Over Voltage
400KV	Kolhapur - Mapusa - II	28-Sep-10	11.30	29-Sep-10	19.46	Over Voltage.
400KV	Lonikand- Koyna Stage IV	29-Sep-10	00.48	29-Sep-10	07.58	Over Voltage
400KV	Padgha - Kalwa - I	29-Sep-10	21.36	30-Sep-10	00.30	Distance Protection, R Ph - Earth.
400KV	New Koyna - Dabhol - II	29-Sep-10	08.25	29-Sep-10	17.30	Insulator String Replacement,Loc.No-7.
400KV	400/220 KV 315 MVA ICT - II @ Koradi.	29-Sep-10	12.40	29-Sep-10	18.53	Taken on TBC Main Bkr N-2 Gas Accumulator Replacement.
400KV	Khadka - Deepnagar - II	29-Sep-10	20.53		Continued.	DT Received @ Khadka.
400KV	400/220 KV 315 MVA ICT - II @ Lamboti	29-Sep-10	10.56	29-Sep-10	16.59	L V Side 29 a Isolator Alighment Work.
400KV	Kolhapur - Mapusa - I	29-Sep-10	20.52	30-Sep-10	10.14	Over Voltage.
400KV	Chandrapur - Parli - II	30-Sep-10	00.15	30-Sep-10	05.46	Over Voltage.
400KV	Lonikand- Koyna Stage IV	30-Sep-10	00.18	30-Sep-10	08.46	Over Voltage.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	30-Sep-10	09.14	1-Oct-10	05.12	Taken on TBC, Due to Hot Spot.
400KV	400/220 KV 315 MVA ICT- II @ Kharghar	30-Sep-10	11.01	30-Sep-10	11.21	B Bus Isolator R Ph Sparking Work.
400KV	Kolhapur-Mapusa-II	30-Sep-10	22.50	1-Oct-10	11.14	Over Voltage.
400KV	Lonikand- Koyna Stage IV	1-Oct-10	00.09	1-Oct-10	08.35	Over Voltage.
400KV	Chandrapur - Parli - II	1-Oct-10	00.58	1-Oct-10	05.28	Over Voltage.
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	1-Oct-10	05.12	1-Oct-10	07.50	To Attended Hot Spot on Y Ph IPS Tube Clamp of 29 C Isolator.
400KV	Padgha - Tarapur - I	1-Oct-10	09.34	1-Oct-10	18.30	Bay maintenance work.
400KV	Akola - Aurangabad- II	1-Oct-10	10.45	3-Oct-10	05.30	New line crossing work.
400KV	Karad-Lamboti	1-Oct-10	20.54	2-Oct-10	08.38	Over Voltage.
400KV	Kolhapur-Mapusa-II	1-Oct-10	22.14	4-Oct-10	10.30	Over Voltage.
400KV	Lonikand- Koyna Stage IV	1-Oct-10	23.11	2-Oct-10	09.05	Over Voltage.
400KV	C'pur-Parli II	1-Oct-10	23.44	2-Oct-10	08.21	Over Voltage.
400KV	Bhusawal- Aurangabad	2-Oct-10	13.52	3-Oct-10	05.07	New line crossing work.

400KV	Main Bus I at 400KV BBLSR	2-Oct-10	09.44	2-Oct-10	13.04	Dhule-II, Y-Ph PG Isolator IPS tube fitting.
400KV	Karad - Kolhapur - I	2-Oct-10	23.12	7-Oct-10	09.00	Over Voltage.
400KV	Karad-Lamboti	2-Oct-10	23.30	3-Oct-10	08.44	Over Voltage.
400KV	Lonikand- Koyna Stage IV	2-Oct-10	23.47	3-Oct-10	09.09	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	3-Oct-10	00.01	3-Oct-10	05.49	Over Voltage.
400KV	Koradi - Bhusawal	3-Oct-10	05.09	3-Oct-10	18.00	New line crossing work.
400KV	Akola - Bhusawal	3-Oct-10	05.34	3-Oct-10	17.35	New line crossing work.
400KV	Dhule-Sar'Sarovar - I	3-Oct-10	13.44	4-Oct-10	08.24	For Dhule ICT loading.
400KV	Bhusawal- Aurangabad	3-Oct-10	18.02	11-Oct-10	09.01	Over Voltage.
400KV	Karad-Lamboti	3-Oct-10	20.08	4-Oct-10	11.38	Over Voltage.
400KV	Akola - Aurangabad- II	3-Oct-10	17.38	22-Oct-10	14.43	Over Voltage.
220KV	Kalwa - Borivali	26-Sep-10	20.46	27-Sep-10	01.25	Due to red hot at ICT-II at Kalwa.
220KV	Pophali - KDPH	26-Sep-10	21.52	27-Sep-10	18.05	Distance protection.
220KV	Mahad-Nagothane	27-Sep-10	08.19	27-Sep-10	18.36	Insulator String replacement
220KV	Apta-Uran-IV	27-Sep-10	17.35	27-Sep-10	20.44	Bus Fault
220KV	Bombay Dyeing - Sahara	27-Sep-10	05.45	27-Sep-10	07.42	Distance Protection
220KV	Padgha-Jambhul-I	27-Sep-10	09.28	27-Sep-10	11.10	Distance Protection
220KV	Trombay-Kalwa	27-Sep-10	14.12	27-Sep-10	14.29	Distance Protection
220KV	Apta-Uran-II	27-Sep-10	17.35	27-Sep-10	18.29	Bus Fault
220KV	Aurangabad-Jalna-II	27-Sep-10	06.47	27-Sep-10	17.58	Conductor and E/W string for old Jalna I&II
220KV	Khaperkheda - Wardha.	27-Sep-10	18.26	28-Sep-10	16.43	To control Koradi ICT loading
220KV	Ambazari-Wardha	27-Sep-10	18.40	28-Sep-10	07.21	To control Koradi ICT Loading
220KV	Main Bus at Jalna	27-Sep-10	06.59	27-Sep-10	18.15	Jumpering of Main Bus Isolator for Chikhali I&II
220KV	Apta-Uran-I	27-Sep-10	17.35	27-Sep-10	18.30	Bus Fault
220KV	Apta-Bombay Dyeing	27-Sep-10	17.35	27-Sep-10	19.40	Bus Fault
220KV	Apta-Nagothane	27-Sep-10	17.35	27-Sep-10	18.10	Bus Fault
220KV	Apta-Kalwa	27-Sep-10	17.35	27-Sep-10	21.47	Bus Fault
220KV	Apta - Tambati	27-Sep-10	17.35	27-Sep-10	18.35	Bus Fault
220KV	Trombay - Tifil	27-Sep-10	17.40	27-Sep-10	19.10	Distance Protection
220KV	Pedambe - Tambati	27-Sep-10	19.18	27-Sep-10	19.58	Distance Protection
220KV	220/100 KV,200 MVA ICT-I @ Apta	27-Sep-10	17.35	27-Sep-10	18.34	Bus Fault
220KV	220/100 KV 200 MVA ICT- IV @ Apta	27-Sep-10	17.35	27-Sep-10	18.13	Bus Fault
220KV	220/22KV 30MVA ICT-I at Apta	27-Sep-10	17.35	27-Sep-10	18.15	Bus Fault
220KV	220/22KV 20MVA ICT-II at Apta	27-Sep-10	17.35	27-Sep-10	18.25	Bus Fault
220KV	Kalwa-Colourchem	27-Sep-10	17.25	27-Sep-10	18.47	Distance Protection
220KV	Apta - Taloja	27-Sep-10	23.58	28-Sep-10	00.15	Numerical relay problem
220KV	Main Bus Section-I at Apta	27-Sep-10	17.35	27-Sep-10	18.10	Bus Fault
220KV	Main Bus Section-II at Apta	27-Sep-10	17.35	27-Sep-10	18.10	Bus Fault
220KV	Aurangabad-Shendra	27-Sep-10	06.10	27-Sep-10	17.22	Conductor and E/W String for old Jalna I&II
220KV	220/100 KV 200 MVA ICT - IV @ Padgha.	27-Sep-10	11.00	29-Sep-10	10.09	Replacement of L V Bushing.
220KV	Main breaker of Chalisgaon-Malegaon Ckt.	27-Sep-10	11.07	15-Oct-10	10.40	Main breaker replacement.Ckt.is on TBC.
220KV	Mahad-Nagothane	28-Sep-10	08.22	28-Sep-10	18.25	Insulator String replacement work
220KV	Apta-Uran-IV	28-Sep-10	09.12	28-Sep-10	18.21	Replacement of P.T.and R.M.work
220KV	Main Bus @ Vita	28-Sep-10	09.30	28-Sep-10	18.45	Attending Red Hot and R.M.work
220KV	220 KV Main Bus @ Ogalewadi	28-Sep-10	10.45	28-Sep-10	13.45	For connecting Jumper of new T/F
220KV	220/132KV 100MVA ICT at Satara MIDC	28-Sep-10	09.50	28-Sep-10	12.40	Inspection of CTR System
220KV	220/110KV 100MVA T/F-III at Miraj	28-Sep-10	12.35	28-Sep-10	13.30	Q.M.work
220KV	NewKoyna - Pawas	28-Sep-10	21.44	28-Sep-10	22.30	Distance Protection
220KV	220/132 KV 50 MVA T/F @ Peth	28-Sep-10	09.10	28-Sep-10	14.15	R.M.Work
220KV	Pophali - Pedambe	28-Sep-10	10.17	28-Sep-10	11.40	Distance Protection

220KV	Halkarni -Tillary	28-Sep-10	12.22	28-Sep-10	13.25	Distance Protection
220KV	Tillary-Amona	28-Sep-10	12.22	28-Sep-10	15.35	Distance Protection
220KV	Pophali - Kandalgaon - I	28-Sep-10	14.38	29-Sep-10	17.45	Distance Protection
220KV	Bus Coupler @ Uran	29-Sep-10	07.54	29-Sep-10	18.40	Replacement of C T Under LES.
220KV	Apta - Tambati	29-Sep-10	10.34	29-Sep-10	17.55	Attending Hot Spot.
220KV	Main Bus- I @ Lamboti	29-Sep-10	10.56	29-Sep-10	16.58	29 A Isolator Alighment Work.
220KV	Ghatghar-Jindal	29-Sep-10	15.36	29-Sep-10	17.53	To Attend Red Hot @ Y Ph Line Side Isolator.
220KV	Ghatghar-Jindal	29-Sep-10	13.55	29-Sep-10	14.36	Distance Protection.
220KV	Kalwa-C'chem	29-Sep-10	17.33	29-Sep-10	17.54	Distance Protection.
220KV	N.Koyna-Phinolex	29-Sep-10	20.36	29-Sep-10	22.13	Distance Protection.
220KV	C'pur-Sicom-II	29-Sep-10	12.02	29-Sep-10	15.13	Quarterly Maintainance.
220KV	Khaperkheda - Koradi	29-Sep-10	08.56	29-Sep-10	15.18	To Attend Red Hot on B Ph C B Pad.
220KV	Valve-Jamde	29-Sep-10	15.08	29-Sep-10	16.25	Distance Protection Operated Zone-I.
220KV	Aurangabad-Padegaon CKT-II	29-Sep-10	15.28	30-Sep-10	01.15	Distance Protection Operated @ Loc. No.239 R Ph Jumper Open.
220KV	Parly - New Parly TPS - I	29-Sep-10	17.18	29-Sep-10	18.03	Distance Protection Operated Zone-I.
220KV	220/132 KV 200 MVA ICT - III @ Bale	29-Sep-10	10.30	29-Sep-10	13.45	R. M. Work.
220KV	220/132 KV 150 MVA ICT - IV @ Bale	29-Sep-10	13.57	29-Sep-10	17.40	R.M.Work,Tand Measurment.
220KV	Pedambe-Mahad	29-Sep-10	22.50	29-Sep-10	23.43	Distance Protection R Ph - Earth.
220KV	Main Bus Section @ Lonand	30-Sep-10	09.00	30-Sep-10	09.30	Kandalgaon Feeder Isolator Jumper Replacement.
220KV	Kalwa-Colourchem	30-Sep-10	10.38	30-Sep-10	13.50	Taken on TBC, Due to Hot Spot.
220KV	Nasik-Raymond	30-Sep-10	10.58	30-Sep-10	12.37	Attending Hot Spot.
220KV	Borivali-Boisar	30-Sep-10	11.05	30-Sep-10	13.30	Attending Hot Spot @ Loc.139.
220KV	Padgha-Kamba	30-Sep-10	18.56	30-Sep-10	19.00	Bkr. Trip @ Kamba End.
220KV	220/132 KV 200 MVA ICT - I @ Kalmeshwar	30-Sep-10	10.58	30-Sep-10	18.30	Backup Protection Operated.
220KV	Padgha-Jambhul	1-Oct-10	09.13	1-Oct-10	18.50	Bay maintenance work.
220KV	Kalwa - Khargar	1-Oct-10	08.25	3-Oct-10	07.37	Interchanging of lines at 220 KV Kalwa S/stn.Up to 31/10/2010.
220KV	Apta-Kalwa	1-Oct-10	08.06	3-Oct-10	07.31	Interchanging of lines at 220 KV Kalwa S/stn.Up to 31/10/2010
220KV	Bale - Lamboti I	1-Oct-10	10.15	1-Oct-10	12.52	Jumper replacement.
220KV	220/132KV,200MVA ICT-I at Malegaon	1-Oct-10	10.30	1-Oct-10	14.20	Maintenance work.
220KV	Aurangabad - Babaleshwar	1-Oct-10	11.15	1-Oct-10	17.21	Isolator maint.work
220KV	Butibori - Wardha	1-Oct-10	12.38	1-Oct-10	16.45	LILO arrangment for Abhijit power.
220KV	Karad-Pedambe	1-Oct-10	12.48	1-Oct-10	13.15	Distance Protection.
220KV	Tillary - Halkarni	1-Oct-10	12.30	1-Oct-10	14.26	Distance Protection.
220KV	Tillary-Amona	1-Oct-10	12.30	1-Oct-10	14.32	Distance Protection.
220KV	220/132 200 MVA ICT - I @ Harangul	1-Oct-10	14.30	1-Oct-10	18.10	OSR replacement work.
220KV	220/132KV 200 MVA ICT- III @ Padegaon	1-Oct-10	10.30	1-Oct-10	15.00	Q.M.Work
220KV	220/132 KV 100 MVA ICT @ Parli - I	1-Oct-10	11.26	5-Oct-10	11.33	Replacement of isolator.
220KV	Bhusawal-Chalisgaon-I	1-Oct-10	14.25	1-Oct-10	14.58	Distance Protection.
220KV	Bombay Dyeing - Sahara	2-Oct-10	07.32	2-Oct-10	19.40	Replacement of E/W.
220KV	Pedambe - Karad	2-Oct-10	09.38	2-Oct-10	11.55	Replacement of jumper.
220KV	Babaleshwar - Babaleshwar - II	2-Oct-10	10.44	2-Oct-10	18.28	Alignment of isolator.
220KV	Bus sectionlizer @ Kalwa	2-Oct-10	12.26	2-Oct-10	13.16	Replacement of B-Ph isolator jaw.
220KV	Apta-Bombay Dyeing	2-Oct-10	11.25	2-Oct-10	14.00	Distance Protection.
220KV	Bus Section - II @ Apta.	2-Oct-10	11.25	2-Oct-10	11.45	LBB Operated.
220KV	Apta-HOC	2-Oct-10	11.25	2-Oct-10	11.55	LBB Operated.
220KV	Apta-Tambati	2-Oct-10	11.25	2-Oct-10	11.50	LBB Operated.
220KV	Apta-Uran-II	2-Oct-10	11.25	2-Oct-10	11.47	LBB Operated.
220KV	220/100 KV 200 MVA ICT- IV @ Apta	2-Oct-10	11.25	2-Oct-10	12.23	LBB Operated.
220KV	Kalwa - Salshet - III	2-Oct-10	16.16	3-Oct-10	21.21	Isolator replacement.
220KV	220/132 KV 100MVA T/F II at Ogalewadi	2-Oct-10	00.01	2-Oct-10	13.20	Commissioning of new X'mer.

220KV	M.B.I at Abhijeet	2-Oct-10	17.15	2-Oct-10	19.13	Emergency outage for Testing work by MSSEDCL.
220KV	M.B.II at Abhijeet	2-Oct-10	17.15	2-Oct-10	19.13	Emergency outage for Testing work by MSSEDCL.
220KV	220/132 KV 100 MVA ICT @ Bhandara	2-Oct-10	17.28	4-Oct-10	16.58	L.V.Bkr.replacement work.
220KV	Chalisgaon-BSL-I	2-Oct-10	14.41	2-Oct-10	16.29	Replacement of faulty distance relay.
220KV	Kalwa-I 220KV Bus Road Side	3-Oct-10	07.29	3-Oct-10	07.46	Phasing out work.
220KV	Bombay Dyeing - Sahara	3-Oct-10	07.48	3-Oct-10	19.55	Replacement of earth wire and cut point insulator.
220KV	Phinolex-Kharepatan	3-Oct-10	19.37	3-Oct-10	20.40	Distance protection.
220KV	220/132KV200 MVA ICT-III @Phursungi	3-Oct-10	09.09	3-Oct-10	18.03	Tan delta and rectification work.
220KV	Pedambe-Kharepatan	3-Oct-10	19.37	4-Oct-10	17.40	Distance protection.
220KV	220/132 KV 250 MVA ICT at Ambazari	3-Oct-10	06.00	6-Oct-10	14.13	Oil filtration of ICT.
132KV	Dondaicha - Sahada	26-Sep-10	11.40	27-Sep-10	23.25	To control line loading
132KV	Mansar-Pench	27-Sep-10	18.30	27-Sep-10	19.00	Distance Protection
132KV	Boiser - MIDC	27-Sep-10	12.45	27-Sep-10	16.17	Distance Protection
132KV	Kanhan - Bhandara	27-Sep-10	12.30	2-Oct-10	17.00	Main Breaker replacement
132KV	132 KV Main Bus at Jalna	27-Sep-10	06.10	27-Sep-10	13.50	Jumpering of Main Bus Isolator for Chikhali I&II
132KV	Kawlewada-Kachewani RLY - I	27-Sep-10	08.26	27-Sep-10	08.35	Distance Protection
132KV	Dondaicha - Sahada	28-Sep-10	11.00	28-Sep-10	16.25	Attending Hot Spot
132KV	Paras-Akot	28-Sep-10	14.02	28-Sep-10	15.05	Directional E/F
132KV	Harangul-Chakur	29-Sep-10	03.55	29-Sep-10	04.15	Distance Protection.
132KV	Bhandara-Tekepar	30-Sep-10	05.59	30-Sep-10	06.22	Trip.
132KV	Kardha - Tekepar	30-Sep-10	05.59	30-Sep-10	07.54	Backup Protection Operated.
132KV	Kalmeshwar-Saoner	30-Sep-10	10.58	30-Sep-10	12.07	Distance Protection Operated.
132KV	Boiser - Viraj	1-Oct-10	08.46	1-Oct-10	15.25	Replacement of C.T.
132KV	Dondaicha - Sahada	1-Oct-10	10.30	1-Oct-10	14.30	Distance Protection.
110KV	Pedambe-- Ratnagiri	29-Sep-10	20.35	30-Sep-10	13.28	Distance Protection..Declared Faulty.
100KV	Kalwa-Standard	27-Sep-10	17.46	27-Sep-10	18.26	Distance Protection
100KV	Kandalgaon - Mhasale	28-Sep-10	03.30	28-Sep-10	09.35	Conductor broken at Mhasale
100KV	Kalwa-Standard	30-Sep-10	06.45	30-Sep-10	08.17	Flashover @ Loc. 4A.
100KV	Kandalgaon-Roha-I	30-Sep-10	17.30	30-Sep-10	18.25	Distance Protection.
100KV	Kandalgaon-Roha-II	30-Sep-10	17.30	30-Sep-10	18.10	Distance Protection.