

LINE OUTAGES FOR THE WEEK

FROM 28-Nov-11 TO 4-Dec-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
500KV	HVDC Pole-I	29-Nov-11	06.37	29-Nov-11	08.48	DC Line protection operated
500KV	HVDC Pole-I	29-Nov-11	09.39	29-Nov-11	14.41	DC Line Protection operated
500KV	HVDC POLE I -CHDPR	1-Dec-11	22.35	2-Dec-11	00.44	Oil Topup in pole-I Y phase OLTC convertor T/F
400KV	Parli (PG) - Wardha (PG) - II	24-Nov-11	17.49	28-Nov-11	16.37	Over Voltage.
400KV	Karad-Kolhapur-II	26-Nov-11	16.35	28-Nov-11	14.16	Over Voltage
400KV	C'pur-Parli II	27-Nov-11	16.15	28-Nov-11	07.36	CVT replacement at Parli.
400KV	Bhusawal- Aurangabad	27-Nov-11	20.48	28-Nov-11	06.44	Over Voltage.
400KV	Kolhapur-Mapusa-II	27-Nov-11	16.23	28-Nov-11	09.33	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	27-Nov-11	16.31	28-Nov-11	14.10	Tripped on Over Voltage.
400KV	Karad - Kolhapur - I	28-Nov-11	16.49	29-Nov-11	10.37	Over Voltage
400KV	Akola - Aurangabad - I	28-Nov-11	11.38	28-Nov-11	17.10	Shifting from M.B.I to M.B.-II
400KV	Main Bus- I @ Aurangabad	28-Nov-11	12.11	28-Nov-11	19.13	Extension of M.B.-I to New Bhusawal Bay
400KV	Parli (PG) - Wardha (PG) - II	28-Nov-11	16.55		Continued.	Isolator Problem
400KV	Dhule-Sar'Sarovar - II	28-Nov-11	16.53	29-Nov-11	08.06	Over Voltage
400KV	Kolhapur - Mapusa - I	28-Nov-11	22.01	29-Nov-11	09.05	Over Voltage
400KV	Dhule-S'Sarovar I	29-Nov-11	08.16	30-Nov-11	09.06	Over Voltage
400KV	400/220KV 315MVA ICT-II @ New Koyna	29-Nov-11	08.00	30-Nov-11	17.50	Taken on TBC for replacing faulty cable.
400KV	400/220 KV 315 MVA ICT- I @ Parly.	29-Nov-11	09.50	29-Nov-11	12.20	Taken on TBC to attend hot spot.
400KV	Karad - Kolhapur - II	29-Nov-11	16.20	30-Nov-11	09.04	H/T For O/V
400KV	400/220KV 500MVA ICT- I at Khaperkheda	29-Nov-11	17.37	29-Nov-11	17.38	First time Charged from HV side
400KV	Dhule-S'Sarovar I	30-Nov-11	17.00		Continued.	B Ph.main C B Pole Burst at Dhule end.
400KV	Dhule-Khandwa-II	30-Nov-11	17.00	30-Nov-11	17.42	Bus Fault @ 400 KV Dhule.
400KV	400/220 KV 315 MVA ICT- I @ Dhule	30-Nov-11	17.00	30-Nov-11	17.40	Bus Fault @ 400 KV Dhule.
400KV	400/220 KV 315 MVA ICT- II @ Dhule	30-Nov-11	17.00	30-Nov-11	17.40	Bus Fault @ 400 KV Dhule.
400KV	Dhule - Babaleshwar - II	30-Nov-11	17.00	30-Nov-11	17.48	Bus Fault @ 400 KV Dhule.
400KV	Main Bus- I @ Dhule	30-Nov-11	17.00	30-Nov-11	17.39	Bus Fault @ 400 KV Dhule.
400KV	Dhule-Sar'Sarovar - II	30-Nov-11	17.00	1-Dec-11	00.33	Bus Fault @ 400 KV Dhule.
400KV	Koradi-Bhilai	30-Nov-11	12.39	30-Nov-11	13.44	RTU Commisioning Work,Online Work.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	1-Dec-11	00.10	1-Dec-11	20.35	33 KV B Ph. Bushing Replacement.
400KV	Lonikand - Parli - I	1-Dec-11	07.20	1-Dec-11	18.47	Replacement of Faulty Disc Insulator
400KV	Main Bus- I @ New Koyna	1-Dec-11	11.12	2-Dec-11	12.36	For attending problem of R phase A Isolator of Karad-II line
400KV	Padgha -Tarapur - I	1-Dec-11	08.32	2-Dec-11	05.26	Emergency Outage at Tarapur end
400KV	Karad - Kolhapur - I	2-Dec-11	02.45	2-Dec-11	09.55	Over Voltage
400KV	Chandrapur - Parli - III	2-Dec-11	09.32	2-Dec-11	15.23	Attending Hot Spot.
400KV	400/220 KV 315 MVA ICT-III @ Padgha	2-Dec-11	10.40	2-Dec-11	18.38	Maintenance of line C-Bus section.
400KV	Karad-Jaigad I	2-Dec-11	1500	2-Dec-11	1520	New Ckt.charged.
400KV	Kolhapur - Mapusa - I	2-Dec-11	16.12		Continued.	Over Voltage.
400KV	Karad - Kolhapur - II	2-Dec-11	17.06	3-Dec-11	06.50	Over Voltage.
400KV	Bhusawal- Aurangabad	2-Dec-11	21.01	3-Dec-11	06.50	Over Voltage.
400KV	Bhusawal- Aurangabad	2-Dec-11	10.18	2-Dec-11	10.26	D.T.Received
400KV	Bableshtar-Aurangabad	2-Dec-11	10.34	2-Dec-11	10.52	D.T.Received
400KV	400/220KV 315MVA ICT-II @ BBLSR	3-Dec-11	08.46	3-Dec-11	18.16	For N2 injection fire prot.system commissioning work.
400KV	400/220 KV 315 MVA ICT- I @ Dhule	3-Dec-11	12.02	3-Dec-11	15.10	Repl.of jumper Y-Ph.
400KV	Bhusawal- Aurangabad	3-Dec-11	21.36	4-Dec-11	07.20	Over Voltage.
400KV	Karad - Kolhapur - I	4-Dec-11	16.19		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	4-Dec-11	22.17		Continued.	Over Voltage.
220KV	Kalwa-Mulund II	12-Nov-11	09.43	28-Nov-11	17.38	Replacement of breaker isolator .Line taken on TBC
220KV	Girivali - Parli - III	23-Nov-11	10.13	28-Nov-11	17.05	Replacement of Main-I & Main-II Isolator Under LES.

220KV	Borivali-Mulund	27-Nov-11	08.08	29-Nov-11	14.30	For erection of 220KV LA on LILO Tower.
220KV	Halkarni-Amona I	27-Nov-11	16.36	28-Nov-11	14.45	Distance protection.Declared faulty.
220KV	Tillary-Amona	28-Nov-11	15.34	28-Nov-11	16.16	LBA Operated
220KV	Main Bus Section - II @ Pedambe	28-Nov-11	09.38	28-Nov-11	16.55	To attend Red Hot Spot
220KV	Pedambe - Tambati	28-Nov-11	08.50	28-Nov-11	18.40	Bus Section-II outage at Pedambe
220KV	Pedambe - Karad	28-Nov-11	09.11	28-Nov-11	17.23	Bus Section-II outage at Pedambe
220KV	Pedambe - Pophali - II	28-Nov-11	09.28	28-Nov-11	18.10	Bus Section-II outage at Pedambe
220KV	Pedambe - Oni	28-Nov-11	09.15	28-Nov-11	17.30	Bus Section-II outage at Pedambe
220KV	Bus section - I at Tambati	28-Nov-11	09.15	28-Nov-11	18.20	Maint.work
220KV	Lote - Dasturi	28-Nov-11	10.47	28-Nov-11	17.40	Maint.work
220KV	Badnera-Akola-II	28-Nov-11	16.23	28-Nov-11	16.44	A/R Lockout (Tripped at Akola end only)
220KV	Main Bus-I at Koradi.	28-Nov-11	11.19		Continued.	Replacement of 29A Bus-I isolator of various feeders under LES.
220KV	Karad-Wathar	29-Nov-11	12.16	29-Nov-11	14.54	Taurus Measurement work
220KV	Pedambe-Mahad	29-Nov-11	10.20	29-Nov-11	15.55	Bus Section-II outage at Mahad
220KV	Bus section- II @ Mahad	29-Nov-11	10.35	29-Nov-11	17.11	Retrofitting of relay
220KV	Malegaon - Satana - I	29-Nov-11	12.17	29-Nov-11	13.48	Red Hot work
220KV	Nasik-Navsari-I	29-Nov-11	08.17	29-Nov-11	17.30	Conductor repair work at Navsari
220KV	Chinchwad-Parvati	29-Nov-11	21.32	29-Nov-11	22.59	Hot Spot
220KV	220/132 KV 100 MVA ICT @ Bhandara	29-Nov-11	12.41		Continued.	Breaker Overhaul
220KV	Koradi-Ambazari-I	29-Nov-11	16.34		Continued.	Isolator replacement work(Ckt is on TBC)
220KV	Usmanabad-Barshi	30-Nov-11	05.36	30-Nov-11	17.55	LILO Work for New 220KV Paranda S/S.
220KV	Kalwa-Trombay	30-Nov-11	09.20		Continued.	Replacement of Breaker (Taken on TBC upto 14/12/2011).
220KV	Kalwa - Ghatghar	30-Nov-11	11.30	30-Nov-11	21.27	Relay Testing Work.
220KV	Uran-Kharghar-II	30-Nov-11	09.15	30-Nov-11	18.04	R.M.Work.
220KV	Main Bus- II @ Lamboti	30-Nov-11	10.19	30-Nov-11	13.55	Hot Spot Attending.
220KV	Malinagar-Temburni	30-Nov-11	12.15	30-Nov-11	16.15	Q.M.Work.
220KV	Bombay Dyeing - Sahara	30-Nov-11	09.25	30-Nov-11	12.20	B Ph.P T Burst @ Sahara S/S.
220KV	Sahara-Urse	30-Nov-11	09.25	30-Nov-11	10.23	B Ph.P T Burst @ Sahara S/S.
220KV	220/132 KV 100 MVA ICT @ Bhandara	30-Nov-11	15.37	30-Nov-11	17.43	Breaker Overhaul.
220KV	Koradi-Ambazari-I	30-Nov-11	16.34	30-Nov-11	17.18	220KV Main Bus-I Isolator Replacement Work (Ckt is on TBC).
220KV	Khaperkheda-Purti	30-Nov-11	07.30	30-Nov-11	20.49	Stringing of 220KV Butibori-I TO Butibori-III(New) EHV Line.
220KV	Koradi - Ambazari - II	30-Nov-11	17.28	1-Dec-11	18.07	29A Isolator Replacement Work (For 3 Day's Ckt on TBC).
220KV	Wardha-RLY TSS I	30-Nov-11	10.34	30-Nov-11	13.50	Attending Hot Spot on Y Ph.C T & other Maint.Work.
220KV	Dhule - Dondaicha	30-Nov-11	17.03	30-Nov-11	17.52	Bus Bar Protection Operated.
220KV	Dhule - Amalner	30-Nov-11	17.03	30-Nov-11	17.50	Bus Bar Protection Operated.
220KV	Dhule - Malegaon	30-Nov-11	17.03	30-Nov-11	17.45	Bus Bar Protection Operated.
220KV	Dhule - Dhule - I	30-Nov-11	17.03	30-Nov-11	17.52	To Dhule-SSNL-I Breaker B Ph.Pole Burst @ 400KV Dhule S/S.
220KV	Dondaicha - Jamde - I	30-Nov-11	17.03	30-Nov-11	17.57	To Dhule-SSNL-I Breaker B Ph.Pole Burst @ 400KV Dhule S/S.
220KV	Dondaicha - Jamde - II.	30-Nov-11	17.03	30-Nov-11	17.58	To Dhule-SSNL-I Breaker B Ph.Pole Burst @ 400KV Dhule S/S.
220KV	Valve-Jamde	30-Nov-11	17.03	30-Nov-11	17.59	To Dhule-SSNL-I Breaker B Ph.Pole Burst @ 400KV Dhule S/S.
220KV	Dhule - Dhule - II	30-Nov-11	17.03	30-Nov-11	17.52	To Dhule-SSNL-I Breaker B Ph.Pole Burst @ 400KV Dhule S/S.
220KV	BombayDyeing - Sahara	1-Dec-11	07.40	2-Dec-11	18.55	Diversion work at M/S Adlab Entertainment
220KV	Babaleshwar - Alephata	1-Dec-11	08.56	1-Dec-11	16.51	Replacement of Faulty Disc Insulator
220KV	220KV Bus (creek side) at Kalwa	1-Dec-11	17.14	1-Dec-11	17.44	Bus Fault at 220KV Kalwa S/stn.
220KV	220KV Bus (creek side) at Kalwa	1-Dec-11	18.17	1-Dec-11	18.22	Bus Fault at 220KV Kalwa S/stn.
220KV	Inter Connector @ Kalwa	1-Dec-11	17.14	1-Dec-11	17.43	Bus Fault at 220KV Kalwa S/stn.
220KV	Inter Connector @ Kalwa	1-Dec-11	18.17	1-Dec-11	18.23	Bus Fault at 220KV Kalwa S/stn.
220KV	Kalwa - Airoli - Knowledge Park.	1-Dec-11	17.14	1-Dec-11	17.44	Bus Fault at 220KV Kalwa S/stn.
220KV	Airoli-Knowledge park-Nasik	1-Dec-11	18.17	1-Dec-11	18.22	Bus Fault at 220KV Kalwa S/stn.

220KV	Apta-Kalwa	1-Dec-11	17.14	1-Dec-11	17.48	Bus Fault at 220KV Kalwa S/stn.
220KV	220/100KV 200MVA ICT-II at Kalwa	1-Dec-11	17.14	1-Dec-11	17.32	Bus Fault at 220KV Kalwa S/stn.(Charged through TBC)
220KV	220/100KV 200MVA ICT-II at Kalwa	1-Dec-11	18.17	1-Dec-11	18.27	Bus Fault at 220KV Kalwa S/stn.(Charged through TBC)
220KV	220/100KV 200MVA ICT-I at Kalwa	1-Dec-11	17.14	1-Dec-11	17.44	Bus Fault at 220KV Kalwa S/stn.
220KV	220/100KV 200MVA ICT-I at Kalwa	1-Dec-11	18.17	1-Dec-11	18.25	Bus Fault at 220KV Kalwa S/stn.
220KV	220/22 KV 50 MVA T/F - I @ Kalwa	1-Dec-11	17.14	1-Dec-11	17.46	Bus Fault at 220KV Kalwa S/stn.
220KV	220/22 KV 50 MVA T/F - I @ Kalwa	1-Dec-11	18.17	1-Dec-11	18.24	Bus Fault at 220KV Kalwa S/stn.
220KV	Bus Section at Kalwa	1-Dec-11	18.17	1-Dec-11	18.27	Bus Fault at 220KV Kalwa S/stn.
220KV	Kanhan - Bhandara - I	1-Dec-11	15.50	3-Dec-11	11.38	Main Breaker O/H work(Ckt on TBC)
220KV	220/132KV 150MVA T/F VII at Chinchwad	1-Dec-11	10.00	1-Dec-11	18.43	R.M.Work
220KV	Kalwa-Temghar	2-Dec-11	05.40	2-Dec-11	20.25	Repl.of conductor by twin conductor.
220KV	Kalwa I-Taloja	2-Dec-11	05.48	2-Dec-11	20.12	Repl.of conductor by twin conductor.
220KV	Kalwa-Roadside Bus	2-Dec-11	06.43	2-Dec-11	19.35	Repl.of conductor by twin conductor.
220KV	220/132 KV 200 MVA T/F - I @ Boiser	2-Dec-11	09.05	2-Dec-11	17.39	Tan delta of HV,LV bushings.
220KV	Kolshet - Kamba	2-Dec-11	09.59	2-Dec-11	16.45	C.T.leakage attending work.
220KV	220/132KV 200MVA ICT-I at Malegaon	2-Dec-11	10.58	2-Dec-11	16.58	Attending OLTC oil leakage.
220KV	Anandnagar-Jambul	2-Dec-11	10.09	2-Dec-11	17.30	To take auto recloser into service.
220KV	Bus Section at Niwaliphata	2-Dec-11	13.40	2-Dec-11	15.27	Main Bus Isolator alignement.
220KV	Bombay Dyeing - Sahara	2-Dec-11	19.15	2-Dec-11	19.45	Pole discrapancy.
220KV	Girwali - Parly - II	2-Dec-11	10.32	2-Dec-11	15.11	Repl.of new main II isolator blade and jumper.
220KV	Kalwa - Khargar	2-Dec-11	03.47	3-Dec-11	18.37	Multi Ckt.conversion.
220KV	Nerul-Kharghar	3-Dec-11	09.33	3-Dec-11	10.54	Tree cutting work.
220KV	Pedambe-Newkoyna	3-Dec-11	08.44	3-Dec-11	11.58	Jumper replacement.
220KV	220/110,200 MVA T/F-I at Miraj	3-Dec-11	09.25	3-Dec-11	14.10	Retrofitting of O/C,E/F relay.
220KV	Chalisgaon-Bhusawal	3-Dec-11	10.23	3-Dec-11	13.51	Repl.of disc insulator Y-Ph.
220KV	220/100 KV,200 MVA ICT-I @ Apta	3-Dec-11	11.12	3-Dec-11	17.47	Tan delta test measurement.
220KV	Miraj-Maisal	3-Dec-11	10.21	3-Dec-11	13.58	Repl.of insulator strings.
220KV	220/100KV 200 MVA ICT- III @ Padgha	3-Dec-11	11.12	3-Dec-11	13.19	Oil leakage from CTR pipe.
220KV	Vita-Maisal	3-Dec-11	14.04	3-Dec-11	16.31	Repl.of faulty insulator string.
220KV	Vita-Maisal	3-Dec-11	16.48	4-Dec-11	17.10	Distance Protection.
220KV	Uran-Kharghar-I	3-Dec-11	17.05	3-Dec-11	17.43	Distance Protection.
220KV	Uran-Kharghar-II	3-Dec-11	17.05	3-Dec-11	17.43	Distance Protection.
220KV	Kharghar-Nerul	3-Dec-11	17.05	3-Dec-11	17.43	Distance Protection.
220KV	Miraj-Maisal	3-Dec-11	21.50	4-Dec-11	13.11	Distance Protection.
220KV	Bhandara - Rly TSS - I	3-Dec-11	12.05	3-Dec-11	16.02	Overhauling of C.B and Tan delta measurement of C.T. and C.C.
220KV	Khaparkheda-Kawlewada-II	3-Dec-11	10.12	3-Dec-11	16.30	To attend hot spot.
220KV	Kalmeshwar - Rly TSS - I	3-Dec-11	12.35	3-Dec-11	17.18	E/F.
220KV	220/132 KV,200MVA ICT-I at Nasik GCR	3-Dec-11	09.40	3-Dec-11	12.10	Attending hot spot on R-Ph bushing.
220KV	Bhandara - Rly TSS - I	3-Dec-11	16.02	4-Dec-11	16.50	Main breker overhaul work.
220KV	220/100KV 200MVA ICT-III at Trombay	4-Dec-11	10.04	4-Dec-11	19.59	To attend oil leakage.
220KV	220/100KV,200MVA ICT-I at Borivali.	4-Dec-11	12.10	4-Dec-11	16.00	Tan delta ,CRM and Timing of CB.
220KV	Bhoisor - Bhoisor PGCIL-II	4-Dec-11	13.30	4-Dec-11	18.00	Removal of cross jumpering and shifting of line to original work.
220KV	Padgha - Boisar (PGCIL)	4-Dec-11	07.40	4-Dec-11	13.12	Removal of cross jumpering and shifting of line to original work.
220KV	Bhoisor-Bhoisor(PGCIL)-I	4-Dec-11	07.42	4-Dec-11	12.41	Removal of cross jumpering and shifting of line to original work.
220KV	Trombay - Salsett - I	4-Dec-11	05.50	4-Dec-11	19.14	Diversion in Godrej complex.
220KV	Borivali - Salset - I	4-Dec-11	15.40	4-Dec-11	17.58	Diversion in Godrej complex.
220KV	220/100KV 200 MVA ICT III at Borivali	4-Dec-11	16.30	4-Dec-11	18.30	Tan delta of CT. & R.M.Works.
220KV	Vita-Maisal	4-Dec-11	17.15		Continued.	Fault at Loc.No.61 R-Ph cut point conductor snapped.
132KV	Hingna-Mankapur-I	29-Nov-11	08.10		Continued.	Replacement of Conductor

132KV	Chinchwad-Chakan	1-Dec-11	10.45	1-Dec-11	18.31	To attend Hot Spot
132KV	Ambazari-Arvi	1-Dec-11	08.42	1-Dec-11	08.50	Distance Protection
132KV	Paras - Warwat Bakal	2-Dec-11	09.54	2-Dec-11	13.04	132 KV Paras-Akola I outage.
132KV	Boiser - Palghar - I	4-Dec-11	09.09	4-Dec-11	12.55	Removal of cross jumpering and shifting of line to original work.
132KV	Bhatghar-Shirwal	4-Dec-11	16.55		Continued.	Loc.No.1 R-Ph conductor snapped near Bhatghar.
100KV	Kalwa-Washi	1-Dec-11	17.30	1-Dec-11	18.00	To control load on Kalyan and Salsett line
100KV	Borivali - Borivali- I	4-Dec-11	07.44	4-Dec-11	20.22	For Commissioning work of new 220KV MSETCL-TATA line.
100KV	Borivali-Borivali-II	4-Dec-11	07.28	4-Dec-11	20.24	For Commissioning work of new 220KV MSETCL-TATA line.