

LINE OUTAGES FOR THE WEEK

FROM 27-Dec-10 TO 2-Jan-11

Voltage	Name	date_trip	time_trip	date_sync	time_sync	reason
400KV	50 MVAR 400KV Bus Reactor At 400KV Kd	20-Dec-10	10.35	29-Dec-10	19.51	Oil replacement and filtration of oil.
400KV	400/220/33KV,500 MVA ICT-I At Kalwa	21-Dec-10	23.20	28-Dec-10	22.24	Charged from HV Side kept on humming at 21:15hrs on 27/12/2010
400KV	Kolhapur-Mapusa-II	22-Dec-10	18.05	30-Dec-10	11.51	Over Voltage
400KV	Dhule-Sar'Sarovar - II	25-Dec-10	23.16	27-Dec-10	08.36	Over Voltage.
400KV	Bhusawal- Aurangabad	26-Dec-10	21.40	27-Dec-10	05.22	Over Voltage.
400KV	Lonikand- Koyna Stage IV	26-Dec-10	22.53	27-Dec-10	07.32	Over Voltage.
400KV	Karad - Kolhapur - I	26-Dec-10	23.27	27-Dec-10	10.22	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	26-Dec-10	22.57	29-Dec-10	10.44	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	27-Dec-10	00.34	27-Dec-10	08.12	Over Voltage
400KV	Padgha - Nagothane - I	27-Dec-10	18.18	28-Dec-10	11.34	Distance Protection.
400KV	Main Bkr of ICT-I (HV Side) at 400KV Lamb	27-Dec-10	10.25	27-Dec-10	16.30	Breaker Overhauling.
400KV	Bhusawal- Aurangabad	27-Dec-10	21.50	28-Dec-10	06.18	Over Voltage.
400KV	Karad - Kolhapur - II	27-Dec-10	22.10	28-Dec-10	08.18	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	27-Dec-10	22.52	28-Dec-10	07.32	Over Voltage.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	28-Dec-10	09.21		Continued.	Filtration of oil.
400KV	Koradi-Satpur	28-Dec-10	10.27	28-Dec-10	16.05	For taking protn.trial of new breaker at Koradi end.
400KV	Karad - Kolhapur - I	28-Dec-10	21.59	29-Dec-10	08.05	Over Voltage.
400KV	Bhusawal- Aurangabad	28-Dec-10	21.13	29-Dec-10	04.14	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	28-Dec-10	23.32	29-Dec-10	07.47	Over Voltage.
400KV	Lonikand- Koyna Stage IV	28-Dec-10	23.38	29-Dec-10	06.52	Over Voltage.
400KV	400/220 KV 500 MVA ICT - I @ Lamboti	29-Dec-10	09.00	29-Dec-10	10.16	Change tap position from 8 to 11.
400KV	Dhule-Sar'Sarovar - II	29-Dec-10	10.46	31-Dec-10	08.01	'Y'ph.CVT testing work.
400KV	400/220 KV,500 MVA ICT-II At Lamboti.	29-Dec-10	10.14	29-Dec-10	11.11	Change tap position 8 to 11.
400KV	Karad - Kolhapur - I	29-Dec-10	20.22	30-Dec-10	07.58	Over Voltage.
400KV	Bhusawal- Aurangabad	29-Dec-10	20.25	30-Dec-10	05.32	Over Voltage.
400KV	New Koyna - Koyna Stage IV - II	29-Dec-10	22.23	30-Dec-10	05.42	Over Voltage.
400KV	Lonikand- Koyna Stage IV	29-Dec-10	22.26	30-Dec-10	07.30	Over Voltage.
400KV	Karad-Lamboti	30-Dec-10	00.28	30-Dec-10	05.42	Over Voltage.
400KV	Lonikand - Chakan	30-Dec-10	09.05	30-Dec-10	17.55	To attend Oil Leakage
400KV	Kolhapur - Mapusa - I	30-Dec-10	22.48		Continued.	Over Voltage
400KV	Karad - Kolhapur - II	30-Dec-10	21.40	31-Dec-10	07.58	Over Voltage
400KV	Lonikand- Koyna Stage IV	30-Dec-10	22.08	31-Dec-10	07.44	Over Voltage
400KV	New Koyna - Koyna Stage IV - II	30-Dec-10	22.10	31-Dec-10	07.52	Over Voltage
400KV	400/220 KV 315 MVA ICT- III @ Lonikand.	30-Dec-10	12.00	30-Dec-10	15.27	To attend Red Hot on 220KV B phase CT
400KV	400 KV TBC @ Lonikand	30-Dec-10	14.08	30-Dec-10	17.21	CT Leakage
400KV	Dhule-Sar'Sarovar - I	30-Dec-10	23.57	1-Jan-11	07.32	Over Voltage
400KV	Bhusawal- Aurangabad	30-Dec-10	21.20	31-Dec-10	05.40	Over Voltage
400KV	Karad-Lamboti	30-Dec-10	23.19	31-Dec-10	05.47	Over Voltage
400KV	Main Bus- II @ Kalwa	31-Dec-10	08.16	31-Dec-10	11.05	To connect new spare ICT to Main Bus-II
400KV	New Koyna - Koyna Stage IV - II	31-Dec-10	08.24	31-Dec-10	14.14	Isolator maint.work
400KV	400/220 KV 315 MVA ICT-III @ Padgha	31-Dec-10	08.38	31-Dec-10	18.45	Bay Maint.work
400KV	400/220 KV 500 MVA ICT-II at Lamboti	31-Dec-10	12.13	31-Dec-10	15.12	To attend oil leakage of Y phase ICT
400KV	Bhusawal- Aurangabad	31-Dec-10	22.14	1-Jan-11	06.02	Over Voltage
400KV	Dhule - S'Sarovar- II	31-Dec-10	23.30	2-Jan-11	05.55	Over Voltage
400KV	Lonikand- Koyna Stage IV	31-Dec-10	23.59	1-Jan-11	06.43	Over Voltage
400KV	Karad - Kolhapur - I	31-Dec-10	22.27	1-Jan-11	08.15	Over Voltage
400KV	Babaleshwar - Bhusawal	1-Jan-11	07.40	1-Jan-11	20.24	Replacement of Disc Insulator string
400KV	400/220KV,500MVA ICT-III At Kalwa.	1-Jan-11	12.08	2-Jan-11	12.54	To attend Gas Leakage of Breaker(Taken on TBC from LV side)
400KV	Karad - Kolhapur - II	1-Jan-11	22.18	2-Jan-11	07.21	Over Voltage
400KV	Lonikand- Koyna Stage IV	1-Jan-11	23.30	2-Jan-11	06.40	Over Voltage

400KV	Dhule-Sar'Sarovar - I	1-Jan-11	22.37		Continued.	Over Voltage
400KV	Bhusawal- Aurangabad	1-Jan-11	20.30	2-Jan-11	05.39	Over Voltage
400KV	Karad-Lamboti	2-Jan-11	00.31	2-Jan-11	04.23	Over Voltage
400KV	Karad - Kolhapur - I	2-Jan-11	22.19		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	2-Jan-11	23.45		Continued.	Over Voltage.
400KV	Dhule-Sar'Sarovar - II	2-Jan-11	23.17		Continued.	Over Voltage.
400KV	400/220 KV 300 MVA ICT-I @ Koradi	2-Jan-11	09.21	2-Jan-11	18.25	Replacement of Oil in R Ph Unit.
220KV	220/33 KV 100 MVA ICT IV at Jamde	1-Dec-10	12.42	31-Dec-10	24.00	T/F Declared as Failed.
220KV	220/100 KV ICT-3 at Borivali	24-Dec-10	00.14	31-Dec-10	17.57	Augmentation Work by 200 MVA.(Charged at 17:40hrs on 30/12/2010)
220KV	220/132 KV 100 MVA ICT- II @ Kanhan	26-Dec-10	15.38	27-Dec-10	15.16	HV side on TBC for Main Bkr.Compressor prob.
220KV	Borivali-Tarapur	27-Dec-10	00.38	27-Dec-10	03.56	Bus Outage.
220KV	Borivali-Mulund	27-Dec-10	00.40	27-Dec-10	03.50	Bus Outage.
220KV	Borivali-Tata Borivali 4	27-Dec-10	00.33	27-Dec-10	04.02	Bus Outage.
220KV	Mahad-Nagothane	27-Dec-10	08.50	27-Dec-10	19.23	Replacement of faulty disc insulator.
220KV	ONGC-TSS	27-Dec-10	10.55	27-Dec-10	16.20	Replacement of B-Ph CT oil leakage.
220KV	Versova-Arey-II	27-Dec-10	09.33	27-Dec-10	16.56	Annual maintenance work.
220KV	220 KV Main Bus @ Tilwani	27-Dec-10	10.25	27-Dec-10	14.35	220 KV isolator alignment work.
220KV	220/132 KV.200MVA T/F-3 At Tilawani	27-Dec-10	14.45	27-Dec-10	17.50	Attending oil leakage.
220KV	220 KV B Bus with Coupler at Kharghar	27-Dec-10	09.50	27-Dec-10	21.33	Servicing and Overhauling of isolator, R.M.Work of Bus.
220KV	220/66 KV 50 MVA T/F - I @ Warora	27-Dec-10	06.25	27-Dec-10	15.53	Diff.Protection operated.
220KV	Miraj-Karad	27-Dec-10	13.20	27-Dec-10	15.15	Due to TBC isolator problem.
220KV	Kalwa-Padgha I	28-Dec-10	08.30	28-Dec-10	16.43	CT Jumper replacement.
220KV	Kandalgaon - ONGC	28-Dec-10	08.25	1-Jan-11	04.30	Lowering of 6 Nos.of conductor at Loc.413 restringing work.
220KV	Kandalgaon - Topworth	28-Dec-10	09.00	30-Dec-10	2007	Lowering of 6 Nos.of conductor at Loc.413 restringing work.
220KV	Main Bus @ Miraj	28-Dec-10	09.00	28-Dec-10	18.17	Red Hot at B ph.bus isolator.
220KV	Main Bus-II At 220 KV BBLSR	28-Dec-10	12.46		Continued.	PT replacement under LES
220KV	Kharghar-Topworth	28-Dec-10	09.55	28-Dec-10	15.18	Bunching of this line with 220 KV ONGC-K'gaon.
220KV	Kolhapur - Peth	28-Dec-10	12.50	28-Dec-10	14.35	Crimping of Jumper.
220KV	Nasik-Navsari-I	28-Dec-10	09.02	28-Dec-10	18.20	Red Hot at Loc.182 R ph.
220KV	Miraj-Karad	28-Dec-10	10.00	28-Dec-10	19.49	For M.B. outage at Miraj.
220KV	Miraj -Ichalkarajni	28-Dec-10	09.00	28-Dec-10	18.22	For M.B. outage at Miraj.
220KV	Mahsal - Miraz	28-Dec-10	09.00	28-Dec-10	18.25	For M.B. outage at Miraj.
220KV	Babaleshwar - Bhenda	28-Dec-10	10.12	28-Dec-10	15.34	For making 220 KV TBC free for operation of load transfer.
220KV	Chandrapur MIDC - Gadchandur	28-Dec-10	10.30	28-Dec-10	13.07	Main breaker work.Ckt was I/S through TBC.
220KV	220/132 KV 200 MVA ICT-I @ Harangul	28-Dec-10	10.20	28-Dec-10	13.00	Q.M.Work.
220KV	220/132 KV 150 MVA ICT- I @ Dhule	29-Dec-10	05.18	29-Dec-10	05.45	Back up protection.
220KV	Vita - Lamboti	29-Dec-10	08.44	29-Dec-10	16.25	Ckt.Bkr.Overhauling.
220KV	NASIK-NAVSARI-II	29-Dec-10	09.14	29-Dec-10	18.26	Maintenance work at Navsari
220KV	Main Bus - I @ Varsova	29-Dec-10	09.25	29-Dec-10	17.56	Annual maintenance.
220KV	Lamboti-Bale-I	29-Dec-10	11.28	29-Dec-10	17.20	Annual maintenance work.
220KV	Lamboti-Bale-II	29-Dec-10	11.28	29-Dec-10	17.21	Annual maintenance work.
220KV	220KV Versova-GIS Main Bus with TBC.	29-Dec-10	09.25	29-Dec-10	18.18	Annual maintenance.
220KV	Karad-Vita-II	29-Dec-10	10.56	29-Dec-10	14.28	Isolator work.
220KV	Babaleshwar - Bhenda	29-Dec-10	11.20	29-Dec-10	19.22	Replacement of PT under LES.
220KV	Main Bus - I @ Kurkumbh	29-Dec-10	10.30	29-Dec-10	16.25	Q.M.Work.
220KV	Jeur-Kurkumbh	29-Dec-10	12.22	29-Dec-10	16.25	Q.M.Work.
220KV	Main Bus @ Bale	29-Dec-10	11.28	29-Dec-10	17.20	Annual maintenance.
220KV	Dombivali-Jambul	29-Dec-10	12.04	29-Dec-10	15.01	Heavy sparking on B ph.CB.
220KV	Karad-Wathar	29-Dec-10	15.28	29-Dec-10	15.33	Change of Bus II to I.
220KV	Karad-Oglewadi-I	29-Dec-10	15.48	29-Dec-10	15.56	Change of Bus II to I.
220KV	Pusad -Parbhani	29-Dec-10	00.17	29-Dec-10	08.19	To control Chdpr-Warora L/L.
220KV	Bhandara - Rly TSS - II	29-Dec-10	11.40	29-Dec-10	16.20	Testing work.
220KV	Murud-Bale	29-Dec-10	12.05	29-Dec-10	14.55	Q.M.Work.
220KV	Nerul -Sonkhar	29-Dec-10	22.15	30-Dec-10	21.20	H/T from Sonkhar end due to distance prot & back-up relay failure.

220KV	Pedambe-Kharepatan	30-Dec-10	08.40	30-Dec-10	17.43	Maint.work
220KV	Main Bus - I @ Varsova	30-Dec-10	09.34	30-Dec-10	20.01	Maint.work
220KV	220/100KV 100MVA ICT-IV at C'wad	30-Dec-10	10.00	30-Dec-10	17.15	Testing work
220KV	Century Enka - Bhosari	30-Dec-10	10.05	30-Dec-10	20.05	Maint.Work
220KV	Malinagar-Temburni	30-Dec-10	13.00	30-Dec-10	14.40	Testing work
220KV	Dahanu-Ghodbandar-II	30-Dec-10	11.05	30-Dec-10	13.16	Distance Protection
220KV	Pusad-Parbhani	30-Dec-10	18.31	31-Dec-10	05.59	To control C'Pur-Warora line Load
220KV	GIS Main Bus with TBC at Versova	30-Dec-10	09.10	30-Dec-10	20.01	Annual Maint.
220KV	Nasik - Airoli - Knowledge Park	31-Dec-10	08.33	31-Dec-10	18.24	Replacement of Insulator
220KV	Trombay - Tifil	31-Dec-10	10.38	31-Dec-10	12.02	Insulator replacement work
220KV	Khargar-Topworth	31-Dec-10	10.06	31-Dec-10	14.23	Removal of Bunching arrangement
220KV	Wardha--Dhamangaon	31-Dec-10	19.24	2-Jan-11	14.59	Main Ckt.BKR Compressor Belt Prob.(Ckt on TBC)
220KV	220/132 KV 150 MVA ICT-I @ Akola.	31-Dec-10	02.53	31-Dec-10	04.46	Insulator string repl.work
220KV	Wardha--Dhamangaon	31-Dec-10	16.48	31-Dec-10	17.18	Distance Protection
220KV	Dhamangaon - Badnera	31-Dec-10	16.48	31-Dec-10	17.09	Distance Protection
220KV	Kalwa - Ghatghar	1-Jan-11	08.53	1-Jan-11	19.13	Insulator String replacement
220KV	Parly - Harangool - I	1-Jan-11	06.10	1-Jan-11	06.45	Distance Protection
220KV	Pirangut - Kandalgaon	2-Jan-11	09.20	2-Jan-11	15.31	Replacement of W/T & C C Replacement @ Kandalgaon.
220KV	Trombay-Salset-II	2-Jan-11	07.00	2-Jan-11	16.52	To Provide 3rd Feed to Dharavi S/S.
220KV	Dharavi - Trombay - 5	2-Jan-11	07.00	2-Jan-11	14.52	To Provide 3rd Feed to Dharavi S/S.
220KV	Trombay-Kalwa	2-Jan-11	17.10	2-Jan-11	17.19	Crossing for Container.
220KV	Trombay-Mulund	2-Jan-11	17.08	2-Jan-11	17.18	Crossing for Container.
220KV	Nasik-Navsari-I	2-Jan-11	14.02	2-Jan-11	14.25	Pole Discripancy.
220KV	Taps 1,2--Taps 3&4 Tie Line	2-Jan-11	09.03	2-Jan-11	14.28	Bus Outage Works.
220KV	220/132 KV 100 MVA ICT- II @ Bhusawal	2-Jan-11	08.58		Continued.	Replacement of 100 MVA By 200 MVA ICT(Upto 23.01.2011).
132KV	Rly TSS - Akola - II	27-Dec-10	14.43	1-Jan-11	17.20	Main BKR.O/H work
132KV	Paras - Akot	28-Dec-10	10.00	28-Dec-10	14.00	To attend R ph.CT oil leakage.
132KV	Butibori MIDC-Khapri Cky.	28-Dec-10	10.29	28-Dec-10	16.08	Opening of old jumpers and charging of new bay.
132KV	Chalisgaon - Kannad	28-Dec-10	11.10	28-Dec-10	11.30	Tripped.
132KV	Chalisgaon - Dhule	29-Dec-10	04.15	30-Dec-10	13.10	Cond.snapped at Loc.no.40.
132KV	Main Bus at Bale	29-Dec-10	11.28	29-Dec-10	17.25	Annual maintenance work.
132KV	Theur - Kharadi	30-Dec-10	10.52	30-Dec-10	16.02	LA replacement work
132KV	Muktainagar-Bodwad	30-Dec-10	09.05	30-Dec-10	20.10	Breaker replacement
132KV	Butibori-MIDC Khapri	30-Dec-10	12.20	30-Dec-10	20.15	For attending B/DN.work of Khapri-Butibori ckt-II
132KV	Dhule-Dondaicha - I	30-Dec-10	13.25		Continued.	Replacement of Line Isolator
132KV	Paras-Malkapur	30-Dec-10	22.25	31-Dec-10	04.58	To control Akola ICT Load
132KV	Dhule - Dhule - I	31-Dec-10	10.48	31-Dec-10	13.40	To attend sparking in Line Isolator
132KV	Paras - Akot	31-Dec-10	02.46	31-Dec-10	05.00	To control Akola ICT Load
132KV	Bus Section-II at Dhule	1-Jan-11	09.23	1-Jan-11	18.45	Twin Conductoring work of LV side of Newly 200MVA ICT
132KV	Buldana-Motala	2-Jan-11	09.45	2-Jan-11	16.18	To Chikali ICT Loading.
132KV	Amravati - Akola	2-Jan-11	17.25	2-Jan-11	17.47	Distance Protection Operated Zone-I.
110KV	TILWANI--ICHALKARANJJI	27-Dec-10	08.30	27-Dec-10	18.15	Balance stringing work of Tilawani terminal.
100KV	Kalwa - Salshet - I	12-Dec-10	16.30	31-Dec-10	09.35	Hand Tripped,From Kalwa End.
100KV	Chinchwad - Talegaon	30-Dec-10	08.05	30-Dec-10	17.42	R.M.Work
100KV	Kalwa - Salsette - II	31-Dec-10	09.45	31-Dec-10	18.10	Repl.of Y phase Bus side Isolator
100KV	Bus Section Breaker at Kalwa	31-Dec-10	09.45	31-Dec-10	17.37	Repl.of Y phase Bus side Isolator
100KV	Kalwa - Salshet - I	31-Dec-10	18.12		Continued.	H/T from Kalwa end