

MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO.LTD.

MAHARASHTRA STATE LOAD DESPATCH CENTRE, KALWA

Coincident Peak Demand in MW for period 7-Mar-2011 to 13-Mar-2011

Sr. No.	Date	Time	Maharashtra State	MSEDCL	TPCL Mumbai	GOA
1	7- 3-2011	16:30	15433	12825	2608	308
2	8- 3-2011	13: 0	15720	12935	2785	297
3	9- 3-2011	12: 0	15228	12594	2634	302
4	10-3-2011	12: 0	15238	12712	2526	291
5	11-3-2011	15: 0	15185	12551	2634	272
6	12-3-2011	17:30	15467	13233	2234	294
7	13-3-2011	13: 0	14693	12874	1819	228

- 1. Half Hourly average values of Catered Demand.**
- 2. Calculated on the basis of Ex-Bus power and Exchanges.**