

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 29/Feb/2016 to 06/Mar/2016**

**Supply Position During Morning Peak (MW)**

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |            |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW         | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 29/02/2016     | 12 Hrs | 5146        | 830        | 426        | 6402        | 5021                   | 60         | 5527        | 163        | -1309        | 15864                 | 5                  | 15869                    | 1115        | 514          | 18802            | 18807                   | 49.97        |
| 01/03/2016     | 12 Hrs | 4567        | 351        | 424        | 5342        | 5363                   | 374        | 5459        | 154        | -1344        | 15348                 | 4                  | 15352                    | 1109        | 513          | 18314            | 18318                   | 49.95        |
| 02/03/2016     | 12 Hrs | 4545        | 246        | 291        | 5082        | 5478                   | 96         | 5835        | 178        | -1441        | 15228                 | 4                  | 15232                    | 1087        | 509          | 18265            | 18269                   | 49.97        |
| 03/03/2016     | 12 Hrs | 4202        | 751        | 426        | 5379        | 5698                   | 39         | 5250        | 168        | -1372        | 15162                 | 4                  | 15166                    | 1127        | 514          | 18175            | 18179                   | 49.91        |
| 04/03/2016     | 10 Hrs | 3873        | 294        | 436        | 4603        | 5354                   | 365        | 5009        | 95         | -1471        | 13955                 | 4                  | 13959                    | 803         | 404          | 16633            | 16637                   | 49.96        |
| 05/03/2016     | 11 Hrs | 4372        | 601        | 454        | 5427        | 5500                   | 74         | 5557        | 165        | -1163        | 15560                 | 4                  | 15564                    | 1053        | 516          | 18292            | 18296                   | 49.95        |
| 06/03/2016     | 10 Hrs | 4729        | 233        | 453        | 5415        | 4951                   | 132        | 5740        | 123        | -580         | 15781                 | 4                  | 15785                    | 906         | 518          | 17785            | 17789                   | 49.96        |
| <b>Maximum</b> |        | <b>5146</b> | <b>830</b> | <b>454</b> | <b>6402</b> | <b>5698</b>            | <b>374</b> | <b>5835</b> | <b>178</b> | <b>-580</b>  | <b>15864</b>          | <b>5</b>           | <b>15869</b>             | <b>1127</b> | <b>518</b>   | <b>18802</b>     | <b>18807</b>            | <b>49.97</b> |
| <b>Minimum</b> |        | <b>3873</b> | <b>233</b> | <b>291</b> | <b>4603</b> | <b>4951</b>            | <b>39</b>  | <b>5009</b> | <b>95</b>  | <b>-1471</b> | <b>13955</b>          | <b>4</b>           | <b>13959</b>             | <b>803</b>  | <b>404</b>   | <b>16633</b>     | <b>16637</b>            | <b>49.91</b> |
| <b>Average</b> |        | <b>4491</b> | <b>472</b> | <b>416</b> | <b>5379</b> | <b>5338</b>            | <b>163</b> | <b>5482</b> | <b>149</b> | <b>-1240</b> | <b>15271</b>          | <b>4</b>           | <b>15275</b>             | <b>1029</b> | <b>498</b>   | <b>18038</b>     | <b>18042</b>            | <b>49.95</b> |

**Supply Position During Day Peak (MW)**

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |            |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW         | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 29/02/2016     | 14 Hrs | 5117        | 282        | 425        | 5824        | 5298                   | 30         | 5493        | 159        | -1350        | 15454                 | 4                  | 15458                    | 929         | 517          | 18250            | 18254                   | 49.99        |
| 01/03/2016     | 13 Hrs | 4527        | 225        | 431        | 5183        | 5314                   | 302        | 5439        | 179        | -1319        | 15098                 | 4                  | 15102                    | 1103        | 517          | 18037            | 18041                   | 49.96        |
| 02/03/2016     | 14 Hrs | 4467        | 116        | 280        | 4863        | 5932                   | 23         | 5672        | 137        | -1398        | 15229                 | 4                  | 15233                    | 1005        | 518          | 18150            | 18154                   | 49.96        |
| 03/03/2016     | 13 Hrs | 4236        | 694        | 420        | 5350        | 5315                   | 24         | 5437        | 193        | -1418        | 14901                 | 4                  | 14905                    | 1068        | 518          | 17905            | 17909                   | 49.98        |
| 04/03/2016     | 16 Hrs | 3833        | 624        | 408        | 4865        | 5056                   | 135        | 4578        | 121        | -1312        | 13443                 | 4                  | 13447                    | 1063        | 405          | 16223            | 16227                   | 49.91        |
| 05/03/2016     | 13 Hrs | 4255        | 414        | 427        | 5096        | 5322                   | 27         | 5644        | 195        | -1216        | 15068                 | 4                  | 15072                    | 1030        | 515          | 17829            | 17833                   | 49.99        |
| 06/03/2016     | 16 Hrs | 4309        | 95         | 433        | 4837        | 4791                   | 252        | 5532        | 111        | -598         | 14925                 | 5                  | 14930                    | 871         | 518          | 16912            | 16917                   | 49.99        |
| <b>Maximum</b> |        | <b>5117</b> | <b>694</b> | <b>433</b> | <b>5824</b> | <b>5932</b>            | <b>302</b> | <b>5672</b> | <b>195</b> | <b>-598</b>  | <b>15454</b>          | <b>5</b>           | <b>15458</b>             | <b>1103</b> | <b>518</b>   | <b>18250</b>     | <b>18254</b>            | <b>49.99</b> |
| <b>Minimum</b> |        | <b>3833</b> | <b>95</b>  | <b>280</b> | <b>4837</b> | <b>4791</b>            | <b>23</b>  | <b>4578</b> | <b>111</b> | <b>-1418</b> | <b>13443</b>          | <b>4</b>           | <b>13447</b>             | <b>871</b>  | <b>405</b>   | <b>16223</b>     | <b>16227</b>            | <b>49.91</b> |
| <b>Average</b> |        | <b>4392</b> | <b>350</b> | <b>403</b> | <b>5145</b> | <b>5290</b>            | <b>113</b> | <b>5399</b> | <b>156</b> | <b>-1230</b> | <b>14874</b>          | <b>4</b>           | <b>14878</b>             | <b>1010</b> | <b>501</b>   | <b>17615</b>     | <b>17619</b>            | <b>49.97</b> |

## Supply Position During Evening Peak (MW)

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |          |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 29/02/2016     | 20 Hrs | 4754        | 124         | 445        | 5323        | 4450                   | 107        | 5506        | 0        | -1453        | 13933                 | 4                  | 13937                    | 783         | 468          | 16637            | 16641                   | 49.98        |
| 01/03/2016     | 20 Hrs | 4424        | 304         | 435        | 5163        | 4707                   | 513        | 5316        | 0        | -1485        | 14214                 | 5                  | 14219                    | 863         | 403          | 16965            | 16970                   | 49.96        |
| 02/03/2016     | 20 Hrs | 4390        | 109         | 363        | 4862        | 4854                   | 340        | 5431        | 0        | -1301        | 14186                 | 4                  | 14190                    | 1006        | 517          | 17010            | 17014                   | 49.94        |
| 03/03/2016     | 20 Hrs | 3826        | 1161        | 282        | 5269        | 5285                   | 181        | 5044        | 0        | -1223        | 14556                 | 4                  | 14560                    | 1078        | 519          | 17376            | 17380                   | 49.99        |
| 04/03/2016     | 20 Hrs | 3882        | 585         | 457        | 4924        | 5227                   | 268        | 5030        | 0        | -1505        | 13944                 | 4                  | 13948                    | 819         | 401          | 16669            | 16673                   | 49.98        |
| 05/03/2016     | 20 Hrs | 4076        | 609         | 459        | 5144        | 4674                   | 449        | 5706        | 0        | -1062        | 14911                 | 5                  | 14916                    | 1029        | 517          | 17519            | 17524                   | 50.01        |
| 06/03/2016     | 20 Hrs | 3766        | 416         | 445        | 4627        | 5124                   | 773        | 5141        | 0        | -1039        | 14626                 | 5                  | 14631                    | 731         | 403          | 16799            | 16804                   | 49.99        |
| <b>Maximum</b> |        | <b>4754</b> | <b>1161</b> | <b>459</b> | <b>5323</b> | <b>5285</b>            | <b>773</b> | <b>5706</b> | <b>0</b> | <b>-1039</b> | <b>14911</b>          | <b>5</b>           | <b>14916</b>             | <b>1078</b> | <b>519</b>   | <b>17519</b>     | <b>17524</b>            | <b>50.01</b> |
| <b>Minimum</b> |        | <b>3766</b> | <b>109</b>  | <b>282</b> | <b>4627</b> | <b>4450</b>            | <b>107</b> | <b>5030</b> | <b>0</b> | <b>-1505</b> | <b>13933</b>          | <b>4</b>           | <b>13937</b>             | <b>731</b>  | <b>401</b>   | <b>16637</b>     | <b>16641</b>            | <b>49.94</b> |
| <b>Average</b> |        | <b>4160</b> | <b>473</b>  | <b>412</b> | <b>5045</b> | <b>4903</b>            | <b>376</b> | <b>5311</b> | <b>0</b> | <b>-1295</b> | <b>14339</b>          | <b>4</b>           | <b>14343</b>             | <b>901</b>  | <b>461</b>   | <b>16996</b>     | <b>17001</b>            | <b>49.98</b> |

## Supply Position During Night Off Peak (MW)

| Date           | Time  | MSGENCO     |            |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR    | TPCL Exch.  | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.  | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|-------|-------------|------------|------------|-------------|------------------------|------------|-------------|----------|-------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
|                |       | THM         | HYDRO      | GAS        | Total       |                        |            |             |          |             |                       |                    |                          |            |              |                  |                         |              |
|                |       | MW          | MW         | MW         | MW          | MW                     | MW         | MW          | MW       | MW          | MW                    | MW                 | MW                       | MW         | MW           | MW               | MW                      | Hzs          |
| 29/02/2016     | 4 Hrs | 4325        | 126        | 455        | 4906        | 3112                   | 325        | 4831        | 0        | -648        | 12526                 | 5                  | 12531                    | 496        | 403          | 14073            | 14078                   | 49.97        |
| 01/03/2016     | 4 Hrs | 4336        | 104        | 456        | 4896        | 2843                   | 470        | 4809        | 0        | -690        | 12328                 | 4                  | 12332                    | 497        | 404          | 13919            | 13923                   | 49.95        |
| 02/03/2016     | 5 Hrs | 4026        | 121        | 452        | 4599        | 3314                   | 488        | 4806        | 0        | -812        | 12395                 | 4                  | 12399                    | 496        | 404          | 14107            | 14111                   | 49.99        |
| 03/03/2016     | 4 Hrs | 3805        | 127        | 426        | 4358        | 3714                   | 248        | 4574        | 0        | -686        | 12208                 | 4                  | 12212                    | 652        | 403          | 13949            | 13953                   | 49.94        |
| 04/03/2016     | 5 Hrs | 3998        | 141        | 449        | 4588        | 4155                   | 126        | 4630        | 0        | -805        | 12694                 | 4                  | 12698                    | 560        | 404          | 14463            | 14467                   | 49.89        |
| 05/03/2016     | 3 Hrs | 3842        | 112        | 463        | 4417        | 3795                   | 207        | 4899        | 0        | -912        | 12406                 | 4                  | 12410                    | 465        | 403          | 14186            | 14190                   | 49.97        |
| 06/03/2016     | 4 Hrs | 3868        | 118        | 478        | 4464        | 4106                   | 496        | 4762        | 0        | -648        | 13180                 | 4                  | 13184                    | 666        | 404          | 14898            | 14902                   | 49.96        |
| <b>Maximum</b> |       | <b>4336</b> | <b>141</b> | <b>478</b> | <b>4906</b> | <b>4155</b>            | <b>496</b> | <b>4899</b> | <b>0</b> | <b>-648</b> | <b>13180</b>          | <b>5</b>           | <b>13184</b>             | <b>666</b> | <b>404</b>   | <b>14898</b>     | <b>14902</b>            | <b>49.99</b> |
| <b>Minimum</b> |       | <b>3805</b> | <b>104</b> | <b>426</b> | <b>4358</b> | <b>2843</b>            | <b>126</b> | <b>4574</b> | <b>0</b> | <b>-912</b> | <b>12208</b>          | <b>4</b>           | <b>12212</b>             | <b>465</b> | <b>403</b>   | <b>13919</b>     | <b>13923</b>            | <b>49.89</b> |
| <b>Average</b> |       | <b>4029</b> | <b>121</b> | <b>454</b> | <b>4604</b> | <b>3577</b>            | <b>337</b> | <b>4759</b> | <b>0</b> | <b>-743</b> | <b>12534</b>          | <b>4</b>           | <b>12538</b>             | <b>547</b> | <b>404</b>   | <b>14228</b>     | <b>14232</b>            | <b>49.95</b> |

## Details of Supply Position (MUs)

| Date           | MSGENCO        |               |               |                | Pench (MS)   | Central Sector Receipt | Central Sector Share | WIND           | CPP            | SOLAR        | TPCL Gen.     | R-INFRA Gen.  | TPCL Exch.     | Energy Requirement |               |                |
|----------------|----------------|---------------|---------------|----------------|--------------|------------------------|----------------------|----------------|----------------|--------------|---------------|---------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS           | Total          |              |                        |                      |                |                |              |               |               |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus           | Mus            | Mus          | Mus                    | Mus                  | Mus            | Mus            | Mus          | Mus           | Mus           | Mus            | Mus                | Mus           | Mus            |
| 29/02/2016     | 113.853        | 5.617         | 10.661        | 130.131        | 0.096        | 104.602                | 109.697              | 4.439          | 126.021        | 1.087        | 17.795        | 11.090        | -27.115        | 339.160            | 56.000        | 395.160        |
| 01/03/2016     | 108.207        | 4.332         | 10.577        | 123.116        | 0.062        | 105.504                | 109.773              | 9.020          | 123.848        | 0.965        | 17.701        | 10.574        | -28.836        | 333.617            | 57.111        | 390.728        |
| 02/03/2016     | 102.974        | 3.955         | 9.242         | 116.171        | 0.096        | 111.059                | 114.348              | 7.413          | 127.365        | 1.063        | 18.138        | 11.126        | -29.725        | 333.346            | 58.989        | 392.335        |
| 03/03/2016     | 95.996         | 10.694        | 10.188        | 116.878        | 0.137        | 116.534                | 116.136              | 5.522          | 120.714        | 1.117        | 20.236        | 11.551        | -27.631        | 333.130            | 59.418        | 392.548        |
| 04/03/2016     | 94.667         | 6.097         | 10.552        | 111.316        | 0.060        | 114.762                | 116.555              | 6.212          | 116.014        | 1.268        | 16.911        | 9.972         | -30.898        | 318.674            | 57.781        | 376.455        |
| 05/03/2016     | 98.679         | 6.557         | 10.910        | 116.146        | 0.027        | 113.602                | 112.783              | 5.731          | 129.115        | 1.221        | 19.182        | 11.337        | -24.849        | 340.966            | 55.368        | 396.334        |
| 06/03/2016     | 92.768         | 4.672         | 10.990        | 108.430        | 0.057        | 107.950                | 106.435              | 9.827          | 126.425        | 1.282        | 18.328        | 10.789        | -18.156        | 335.758            | 47.273        | 383.031        |
| <b>Maximum</b> | <b>113.853</b> | <b>10.694</b> | <b>10.990</b> | <b>130.131</b> | <b>0.137</b> | <b>116.534</b>         | <b>116.555</b>       | <b>113.853</b> | <b>129.115</b> | <b>1.282</b> | <b>20.236</b> | <b>11.551</b> | <b>-18.156</b> | <b>340.966</b>     | <b>59.418</b> | <b>396.334</b> |
| <b>Minimum</b> | <b>92.768</b>  | <b>3.955</b>  | <b>9.242</b>  | <b>108.430</b> | <b>0.027</b> | <b>104.602</b>         | <b>106.435</b>       | <b>92.768</b>  | <b>116.014</b> | <b>0.965</b> | <b>16.911</b> | <b>9.972</b>  | <b>-30.898</b> | <b>318.674</b>     | <b>47.273</b> | <b>376.455</b> |
| <b>Average</b> | <b>101.021</b> | <b>5.989</b>  | <b>10.446</b> | <b>117.455</b> | <b>0.076</b> | <b>110.573</b>         | <b>112.247</b>       | <b>101.021</b> | <b>124.215</b> | <b>1.143</b> | <b>18.327</b> | <b>10.920</b> | <b>-26.744</b> | <b>333.522</b>     | <b>55.991</b> | <b>389.513</b> |

## Details of Koyna Water Consumption (in TMC)

---

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 29/02/2016 | 0.072       | 2.312         | 31.392  |
| 01/03/2016 | 0.075       | 0.075         | 31.317  |
| 02/03/2016 | 0.056       | 0.131         | 31.261  |
| 03/03/2016 | 0.184       | 0.315         | 31.077  |
| 04/03/2016 | 0.089       | 0.404         | 30.988  |
| 05/03/2016 | 0.110       | 0.514         | 30.878  |
| 06/03/2016 | 0.083       | 0.597         | 30.795  |

**State Load Despatch Center,Airoli (MSETCL)**  
**Central Sector Share/Drawal from 29/Feb/2016 to 06/Mar/2016**

| Date         | DAY      | Central Sector Share |         | Total Interstate Bilateral Purchase |         | Total Share    |         | Total Drawal   |         | Overdrawal(+) / UnderDrawal(-) |         |
|--------------|----------|----------------------|---------|-------------------------------------|---------|----------------|---------|----------------|---------|--------------------------------|---------|
|              |          | MUs                  | Avg. MW | MUs                                 | Avg. MW | MUs            | Avg. MW | MUs            | Avg. MW | MUs                            | Avg. MW |
|              |          | <b>1</b>             |         | <b>2</b>                            |         | <b>1+2=3</b>   |         | <b>4</b>       |         | <b>3-4=5</b>                   |         |
| 29/02/2016   | MONDAY   | 93.341               | 4554    | 16.356                              | 681     | 109.697        | 4571    | 104.602        | 4358    | -5.095                         | -212    |
| 01/03/2016   | TUESDAY  | 93.668               | 4558    | 16.105                              | 671     | 109.773        | 4574    | 105.504        | 4396    | -4.269                         | -178    |
| 02/03/2016   | WEDNESDA | 91.924               | 4742    | 22.424                              | 934     | 114.348        | 4764    | 111.059        | 4627    | -3.289                         | -137    |
| 03/03/2016   | THURSDAY | 95.222               | 4818    | 20.914                              | 871     | 116.136        | 4839    | 116.534        | 4856    | 0.398                          | 17      |
| 04/03/2016   | FRIDAY   | 94.312               | 4834    | 22.243                              | 927     | 116.555        | 4856    | 114.762        | 4782    | -1.793                         | -75     |
| 05/03/2016   | SATURDAY | 97.245               | 4684    | 15.538                              | 647     | 112.783        | 4699    | 113.602        | 4733    | 0.819                          | 34      |
| 06/03/2016   | SUNDAY   | 89.747               | 4418    | 16.688                              | 695     | 106.435        | 4435    | 107.950        | 4498    | 1.515                          | 63      |
| <b>Total</b> |          | <b>655.457</b>       |         | <b>130.270</b>                      |         | <b>785.727</b> |         | <b>774.013</b> |         | <b>-11.714</b>                 |         |

| GENERATING UNITS OUTAGES FOR THE WEEK FROM 29/02/2016 TO 06/03/2016 |                    |          |              |              |             |            |                                                                          |
|---------------------------------------------------------------------|--------------------|----------|--------------|--------------|-------------|------------|--------------------------------------------------------------------------|
| Generator                                                           | Generating Unit    | Capacity | Tripped Date | Tripped Time | Synch. Date | Synch Time | Reason                                                                   |
| PLANNED OUTAGES                                                     |                    |          |              |              |             |            |                                                                          |
| IPP                                                                 | Tata Trombay 6     | 500MW    | 15/Jul/2015  | 17.08        |             | Continued. | Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016) |
| Cent_Sect                                                           | Tarapur 2          | 160MW    | 10/Sep/2015  | 12.55        |             | Continued. | Refuelling work                                                          |
| MSPGCL                                                              | Koyna Unit 10      | 80MW     | 29/Dec/2015  | 08:00        |             | Continued. | Annual Overhaul                                                          |
| FORCED OUTAGES                                                      |                    |          |              |              |             |            |                                                                          |
| RGPPL                                                               | Dabhol Dabhol 1B   | 230MW    | 28/May/2013  | 22:02        |             | Continued. | Gas Shortage.                                                            |
| RGPPL                                                               | Dabhol Dabhol 3A   | 230MW    | 06/Jun/2013  | 08.28        |             | Continued. | Gas Shortage                                                             |
| RGPPL                                                               | Dabhol Dabhol 1X   | 230MW    | 27/Jun/2013  | 21.46        |             | Continued. | Gas Shortage                                                             |
| RGPPL                                                               | Dabhol Dabhol 1A   | 230MW    | 27/Jun/2013  | 21.47        |             | Continued. | Gas Shortage                                                             |
| IPP                                                                 | Dhariwal           | 300MW    | 28/May/2014  | 02.27        |             | Continued. | No schedule                                                              |
| MSPGCL                                                              | Chandrapur Unit 1  | 210MW    | 28/Aug/2014  | 07:15        |             | Continued. | Economic Shutdown.                                                       |
| MSPGCL                                                              | Koradi Unit 6      | 210MW    | 20/Mar/2015  | 01.02        |             | Continued. | Economic shutdown                                                        |
| MSPGCL                                                              | Parli Unit 3       | 210MW    | 14/Jun/2015  | 12.58        |             | Continued. | Water Shortage                                                           |
| MSPGCL                                                              | Parli Unit 6       | 250MW    | 25/Jun/2015  | 15.03        |             | Continued. | Water Shortage                                                           |
| MSPGCL                                                              | Parli Unit 4       | 210MW    | 05/Jul/2015  | 18.45        |             | Continued. | Water Shortage                                                           |
| MSPGCL                                                              | Parli Unit 5       | 210MW    | 06/Jul/2015  | 14.55        |             | Continued. | Water Shortage.                                                          |
| MSPGCL                                                              | Parli Unit 7       | 250MW    | 08/Jul/2015  | 12.08        |             | Continued. | Water Shortage                                                           |
| MSPGCL                                                              | Chandrapur Unit-8  | 500MW    | 10/Nov/2015  | 12.10        |             | Continued. | Drum level low                                                           |
| RGPPL                                                               | Dabhol 3B          | 230MW    | 07/Jan/2016  | 17:51        |             | Continued. | Change Over.                                                             |
| MSPGCL                                                              | Chandrapur Unit 2  | 210MW    | 12/Jan/2016  | 04.47        |             | Continued. | Boiler Tube Leakage                                                      |
| MSPGCL                                                              | Uran Unit 5        | 108MW    | 19/Jan/2016  | 14.34        | 01/Mar/2016 | 12.36      | Overhauling                                                              |
| RGPPL                                                               | Dabhol 3X          | 230MW    | 03/Feb/2016  | 15:36        |             | Continued. | Change Over                                                              |
| IPP                                                                 | Trombay 8          | 250MW    | 07/Feb/2016  | 17.40        | 02/Mar/2016 | 20.57      | Boiler Maintenance Work,Bearing Inspection.                              |
| MSPGCL                                                              | Ghatghar Unit-2    | 125MW    | 09/Feb/2016  | 18.00        |             | Continued. | Oil filtration work.                                                     |
| MSPGCL                                                              | Bhusawal Unit 4    | 500MW    | 14/Feb/2016  | 12.10        |             | Continued. | Zero Schedule Given by MSEDCL.                                           |
| MSPGCL                                                              | Ghatghar Unit-1    | 125MW    | 15/Feb/2016  | 00.00        |             | Continued. | Attending Water valve Leakage.                                           |
| IPP                                                                 | WPCL U-1           | 135MW    | 16/Feb/2016  | 17.09        |             | Continued. | Change Over , No Schedule                                                |
| MSPGCL                                                              | Bhusawal Unit 2    | 210MW    | 16/Feb/2016  | 04.53        | 16/Feb/2016 | 13.33      | Switch Board Supply Tripped.                                             |
| IPP                                                                 | RPL(AMT) U-3       | 270MW    | 16/Feb/2016  | 01.17        |             | Continued. | Due to Zero Schedule Given by MSEDCL.                                    |
| IPP                                                                 | RPL(AMT) U-2       | 270MW    | 16/Feb/2016  | 01.14        |             | Continued. | Due to Zero Schedule Given by MSEDCL.                                    |
| MSPGCL                                                              | Koradi Unit 5      | 200MW    | 18/Feb/2016  | 11.21        |             | Continued. | MSEDCL Zero Shedule.                                                     |
| IPP                                                                 | WPCL U-3           | 135MW    | 23/Feb/2016  | 07.28        | 29/Feb/2016 | 17.45      | Botom Ash Conveyer belt problem.                                         |
| MSPGCL                                                              | Paras Unit 4       | 250MW    | 28/Feb/2016  | 11.53        | 01/Mar/2016 | 09.40      | Furnace Pressure High                                                    |
| IPP                                                                 | WPCL U-2           | 135MW    | 29/Feb/2016  | 21.46        |             | Continued. | Change over against Unit III                                             |
| MSPGCL                                                              | Koradi Unit 7      | 210MW    | 01/Mar/2016  | 23.55        |             | Continued. | Zero Schedule Given by MSEDCL.                                           |
| MSPGCL                                                              | Bhusawal Unit 2    | 210MW    | 01/Mar/2016  | 10.13        | 06/Mar/2016 | 00.00      | Boiler Tube Leakage                                                      |
| MSPGCL                                                              | Paras Unit 3       | 250MW    | 01/Mar/2016  | 22.09        | 03/Mar/2016 | 18.57      | Boiler Tube Leakage                                                      |
| MSPGCL                                                              | Uran Unit 5        | 108MW    | 01/Mar/2016  | 13.09        | 04/Mar/2016 | 18.43      | Gas Pressure Low.                                                        |
| MSPGCL                                                              | Bhusawal Unit 3    | 210MW    | 02/Mar/2016  | 11.28        | 02/Mar/2016 | 15.56      | Due to Hot Spot on R, Y ph CT                                            |
| MSPGCL                                                              | Nasik Unit 4       | 210MW    | 02/Mar/2016  | 16.33        | 02/Mar/2016 | 18.35      | Tripped on Jerk of 220kb nashik BBLR -II ckt.                            |
| MSPGCL                                                              | Uran Unit A0       | 120MW    | 02/Mar/2016  | 09.23        | 02/Mar/2016 | 20.18      | Filter Replacement.                                                      |
| MSPGCL                                                              | Uran Unit 6        | 108MW    | 02/Mar/2016  | 09.31        | 02/Mar/2016 | 15.06      | Filter Replacemnt.                                                       |
| IPP                                                                 | JSW (J) U3         | 300MW    | 02/Mar/2016  | 13.45        | 05/Mar/2016 | 10.11      | Cooling Water Leakage.                                                   |
| MSPGCL                                                              | Paras Unit 4       | 250MW    | 02/Mar/2016  | 22.50        |             | Continued. | Air heater problem                                                       |
| MSPGCL                                                              | Paras Unit 3       | 250MW    | 03/Mar/2016  | 19.33        | 03/Mar/2016 | 22.14      | Drum level high                                                          |
| IPP                                                                 | WPCL U-4           | 135MW    | 03/Mar/2016  | 00.01        |             | Continued. | ESP BACK FILTER MAINTENANCE. WORK.                                       |
| IPP                                                                 | Trombay 8          | 250MW    | 03/Mar/2016  | 20.25        | 05/Mar/2016 | 07.07      | main steam line leakage                                                  |
| MSPGCL                                                              | Uran Unit 8        | 108MW    | 04/Mar/2016  | 22.55        |             | Continued. | Gas shortage                                                             |
| MSPGCL                                                              | Khaparkheda Unit 3 | 210MW    | 04/Mar/2016  | 05.10        | 05/Mar/2016 | 07.22      | Boiler Tube Leakage                                                      |
| MSPGCL                                                              | Chandrapur Unit 6  | 500MW    | 05/Mar/2016  | 10.15        |             | Continued. | Turbine bearing Vabration high                                           |
| MSPGCL                                                              | Bhusawal Unit 3    | 210MW    | 06/Mar/2016  | 11.11        |             | Continued. | Boiler Tube Leakage                                                      |

**LINE OUTAGES FOR THE WEEK FROM 29/03/2016 TO 06/03/2016**

| Voltage | Name of Line                    | Tripping Date | Tripping Time | Synch Date  | Synch Time | Reason                                                                                                              |
|---------|---------------------------------|---------------|---------------|-------------|------------|---------------------------------------------------------------------------------------------------------------------|
| 500 KV  | Chandrapur - Padghe HvdC Pole 2 | 06/Mar/2016   | 20.00         | 06/Mar/2016 | 21.00      | Sparking on capacitive Bank at Padghe end                                                                           |
| 400 KV  | Akola II - Taplitanda ckt-II    | 31/Dec/2015   | 18.16         |             | Continued. | Change over(outage taken on 2/3/2016 at 10.34hrs for commissioning of 765KV Ektuni S/Stn)                           |
| 400 KV  | Babhaleshwar-Taplitanda ckt-II  | 11/Feb/2016   | 18.40         |             | Continued. | CHANGE OVER                                                                                                         |
| 400 KV  | Bhusawal-Aurangabad             | 26/Feb/2016   | 17.08         |             | Continued. | Over Voltage                                                                                                        |
| 400 KV  | Dhule SarSarovar I              | 27/Feb/2016   | 17.12         | 29/Feb/2016 | 06.16      | Over Voltage                                                                                                        |
| 400 KV  | karad -kolhapur-I               | 28/Feb/2016   | 16.08         | 29/Feb/2016 | 09.25      | Over Voltage                                                                                                        |
| 400 KV  | Karad - Jaigad - II             | 28/Feb/2016   | 16.31         | 29/Feb/2016 | 09.27      | Over Voltage                                                                                                        |
| 400 KV  | Kolhapur Solapur(PG) I          | 28/Feb/2016   | 16.43         | 29/Feb/2016 | 07.15      | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 29/Feb/2016   | 07.08         | 29/Feb/2016 | 15.05      | Insulator Replacement Work                                                                                          |
| 400 KV  | Main Bus-I @ Koradi III         | 29/Feb/2016   | 08.16         | 29/Feb/2016 | 19.22      | P.M.Work.                                                                                                           |
| 400 KV  | karad -kolhapur-I               | 29/Feb/2016   | 16.08         | 29/Feb/2016 | 09.25      | Over Voltage                                                                                                        |
| 400 KV  | karad -kolhapur-II              | 29/Feb/2016   | 16.13         | 01/Mar/2016 | 09.35      | Over Voltage                                                                                                        |
| 400 KV  | Karad-Jaigad - I                | 29/Feb/2016   | 16.16         | 29/Feb/2016 | 18.42      | Over Voltage                                                                                                        |
| 400 KV  | Dhule SarSarovar I              | 29/Feb/2016   | 17.16         | 01/Mar/2016 | 09.18      | Over Voltage                                                                                                        |
| 400 KV  | Kolhapur Solapur (PG) II        | 29/Feb/2016   | 18.07         | 01/Mar/2016 | 07.51      | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 01/Mar/2016   | 07.50         | 01/Mar/2016 | 16.51      | Replacement of Insulator String.                                                                                    |
| 400 KV  | Chandrapur - Khaperkheda        | 01/Mar/2016   | 11.45         | 02/Mar/2016 | 08.54      | To Attend Hot Spot(RFC @ 19.27 Hrs).                                                                                |
| 400 KV  | Dhule SarSarovar I              | 01/Mar/2016   | 17.10         | 02/Mar/2016 | 09.47      | Over Voltage                                                                                                        |
| 400 KV  | Karad - Jaigad - II             | 01/Mar/2016   | 17.51         | 02/Mar/2016 | 09.59      | Over Voltage                                                                                                        |
| 400 KV  | Kolhapur Solapur(PG) I          | 01/Mar/2016   | 20.31         | 02/Mar/2016 | 07.29      | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 01/Mar/2016   | 20.39         | 02/Mar/2016 | 09.12      | Over Voltage                                                                                                        |
| 400 KV  | Main Bus-II @ Koradi III        | 02/Mar/2016   | 09.03         | 02/Mar/2016 | 18.49      | Annual Maintenance Work                                                                                             |
| 400 KV  | Chandrapur - Khaperkheda        | 02/Mar/2016   | 09.34         | 02/Mar/2016 | 18.58      | Distance Protection                                                                                                 |
| 400 KV  | Khadka- Deepnagar Ckt 1         | 02/Mar/2016   | 09.40         | 02/Mar/2016 | 16.55      | Testing Work                                                                                                        |
| 400 KV  | Padghe - Nagothane - I          | 02/Mar/2016   | 09.53         | 03/Mar/2016 | 09.33      | Faulty String Replacement Work.                                                                                     |
| 400 KV  | Karad-Jaigad - I                | 02/Mar/2016   | 16.34         |             | Continued. | Over Voltage                                                                                                        |
| 400 KV  | Girwali- Lonikand 2             | 02/Mar/2016   | 16.51         | 02/Mar/2016 | 19.21      | Distance Protection                                                                                                 |
| 400 KV  | Dhule SarSarovar I              | 02/Mar/2016   | 17.18         | 03/Mar/2016 | 07.43      | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 02/Mar/2016   | 18.17         | 02/Mar/2016 | 19.32      | Over Voltage                                                                                                        |
| 400 KV  | Kolhapur Solapur(PG) I          | 02/Mar/2016   | 18.20         | 03/Mar/2016 | 08.05      | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 02/Mar/2016   | 23.58         | 03/Mar/2016 | 06.22      | Over Voltage                                                                                                        |
| 400 KV  | Chakan Talegaon(Pg)             | 03/Mar/2016   | 07.24         | 03/Mar/2016 | 19.03      | conductor stringing work                                                                                            |
| 400 KV  | Akola Wardha II                 | 03/Mar/2016   | 09.30         | 03/Mar/2016 | 18.30      | Insulator Replacement Work                                                                                          |
| 400 KV  | Padghe - Nagothane - II         | 03/Mar/2016   | 09.50         | 04/Mar/2016 | 09.49      | Maintenance Work RFC at 20.30 hrs                                                                                   |
| 400 KV  | N.Koyna-Karad -Ckt I            | 03/Mar/2016   | 12.08         | 05/Mar/2016 | 09.59      | Attend hot spot(RFC 14.45/3-3-16)                                                                                   |
| 400 KV  | Dhule SarSarovar I              | 03/Mar/2016   | 13.47         | 04/Mar/2016 | 10.03      | Over Voltage                                                                                                        |
| 400 KV  | karad -kolhapur-I               | 03/Mar/2016   | 16.32         | 05/Mar/2016 | 10.03      | Over Voltage                                                                                                        |
| 400 KV  | Dhule - Bableshevar - II        | 03/Mar/2016   | 17.15         | 03/Mar/2016 | 17.39      | Distance Protection                                                                                                 |
| 400 KV  | Kolhapur Solapur(PG) I          | 03/Mar/2016   | 18.07         | 04/Mar/2016 | 07.18      | Over Voltage                                                                                                        |
| 400 KV  | Akola Wardha I                  | 04/Mar/2016   | 09.47         | 04/Mar/2016 | 14.03      | Insulator Replacement Work                                                                                          |
| 400 KV  | Kalwa - Talegaon(PG)            | 04/Mar/2016   | 10.41         | 04/Mar/2016 | 20.35      | insulator string decapped at kalwa                                                                                  |
| 400 KV  | Padghe - Talegaon (PG)          | 04/Mar/2016   | 11.50         | 05/Mar/2016 | 10.09      | Distance Protection                                                                                                 |
| 400 KV  | Akola Wardha II                 | 04/Mar/2016   | 15.12         | 04/Mar/2016 | 18.25      | insulator string replace                                                                                            |
| 400 KV  | Dhule SarSarovar I              | 04/Mar/2016   | 16.14         | 05/Mar/2016 | 07.08      | Over Voltage                                                                                                        |
| 400 KV  | Kolhapur Solapur(PG) I          | 04/Mar/2016   | 17.09         | 05/Mar/2016 | 06.59      | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 04/Mar/2016   | 18.11         | 05/Mar/2016 | 09.21      | Over Voltage                                                                                                        |
| 400 KV  | New Koyna -Koyna Stage IV-I     | 05/Mar/2016   | 09.44         | 05/Mar/2016 | 14.44      | Routine Maintenance Work                                                                                            |
| 400 KV  | Dhule SarSarovar II             | 05/Mar/2016   | 10.30         | 05/Mar/2016 | 19.00      | Rejoining of Earth Wire                                                                                             |
| 400 KV  | Babhaleshwar - Padghe-I         | 05/Mar/2016   | 10.56         | 05/Mar/2016 | 21.32      | Insulator Replacement Work                                                                                          |
| 400 KV  | Akola Wardha II                 | 05/Mar/2016   | 13.27         | 05/Mar/2016 | 21.37      | Distance Protection                                                                                                 |
| 400 KV  | karad -kolhapur-II              | 05/Mar/2016   | 16.36         |             | Continued. | Over Voltage                                                                                                        |
| 400 KV  | Kolhapur Solapur (PG) II        | 05/Mar/2016   | 17.45         | 06/Mar/2016 | 06.57      | Over Voltage                                                                                                        |
| 400 KV  | Dhule SarSarovar I              | 05/Mar/2016   | 19.05         |             | Continued. | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 05/Mar/2016   | 21.54         | 06/Mar/2016 | 09.32      | Over Voltage                                                                                                        |
| 400 KV  | Babhaleshwar - Padghe-II        | 06/Mar/2016   | 08.16         | 06/Mar/2016 | 23.00      | Insulator Replacement Work                                                                                          |
| 400 KV  | Kolhapur Solapur(PG) I          | 06/Mar/2016   | 16.52         | 07/Mar/2016 | 06.01      | Over Voltage                                                                                                        |
| 400 KV  | Lonikand I - Koyna stage-IV     | 06/Mar/2016   | 17.41         |             | Continued. | Over Voltage                                                                                                        |
| 400 KV  | Padghe - Talegaon (PG)          | 06/Mar/2016   | 23.07         |             | Continued. | To attend Hot Spot                                                                                                  |
| 220 KV  | Chandrapur GCR - Warora - I     | 05/Apr/2015   | 09.13         |             | Continued. | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| 220 KV  | Chandrapur GCR - Wani           | 05/Apr/2015   | 09.15         |             | Continued. | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| 220 KV  | Kalwa - Borivali                | 10/Jan/2016   | 09:15         |             | Continued. | Tower Erection Work.                                                                                                |
| 220 KV  | GIS Bhandup - Borivali          | 11/Jan/2016   | 07.42         |             | Continued. | Tower Erection Work.                                                                                                |
| 220 KV  | Padghe - Vasai                  | 24/Jan/2016   | 08.32         |             | Continued. | For Formation of Temp. Padghe-Borivali (Charge upto 51/1).                                                          |
| 220 KV  | Bableshevar- Alephata           | 03/Feb/2016   | 06.28         |             | Continued. | controlling bblsr ICT Overloading                                                                                   |
| 220 KV  | Bableshevar- Ranjangaon         | 03/Feb/2016   | 07.12         |             | Continued. | controlling bblsr ICT Overloading                                                                                   |
| 220 KV  | Hingoli- Girawali               | 14/Feb/2016   | 12.37         |             | Continued. | To Improve Voltage @ Hingoli.                                                                                       |
| 220 KV  | Chinchwad-Hinjewadi I           | 28/Feb/2016   | 20.04         | 29/Feb/2016 | 05.04      | For Chinchwad Outage.                                                                                               |
| 220 KV  | Chakan-Chinchwad                | 28/Feb/2016   | 20.18         | 29/Feb/2016 | 04.58      | Erection of Narrow Base M/C Tower.                                                                                  |
| 220 KV  | Telco- Chinchwad                | 28/Feb/2016   | 20.20         | 29/Feb/2016 | 05.01      | Erection of Narrow Base M/C Tower.                                                                                  |

| Voltage | Name of Line                       | Tripping Date | Tripping Time | Synch Date  | Synch Time | Reason                                                 |
|---------|------------------------------------|---------------|---------------|-------------|------------|--------------------------------------------------------|
| 220 KV  | Flagship-Nandedcity                | 29/Feb/2016   | 05.13         | 29/Feb/2016 | 20.24      | For Chinchwad Outage.                                  |
| 220 KV  | Nagothane - Spcl                   | 29/Feb/2016   | 08.32         | 29/Feb/2016 | 14.35      | Distance Protection                                    |
| 220 KV  | Raymond - Washala                  | 29/Feb/2016   | 09.15         | 29/Feb/2016 | 18.20      | Insulator Replacement Work                             |
| 220 KV  | New Koyna - Loteparshuram          | 29/Feb/2016   | 09.50         | 29/Feb/2016 | 14.32      | To attend Hot Spot                                     |
| 220 KV  | Khadka-Chalisingaon-1              | 29/Feb/2016   | 10.08         |             | Continued. | For Diversion of CKT Which Submerges in Waghur Dam.    |
| 220 KV  | Khadka-Chalisingaon-2              | 29/Feb/2016   | 10.14         |             | Continued. | For Diversion of CKT Which Submerges in Waghur Dam.    |
| 220 KV  | Pirangut - Hinjewadi I             | 29/Feb/2016   | 11.38         | 02/Mar/2016 | 10.15      | Taken on TBC of Breaker Overhauling.                   |
| 220 KV  | Magar Patta City- Serum            | 29/Feb/2016   | 13.04         | 29/Feb/2016 | 12.43      | On TBC for Main Breaker Ocer Hauling.                  |
| 220 KV  | Abhijeet-Wardha-Ii                 | 29/Feb/2016   | 17.42         | 29/Feb/2016 | 18.56      | Distance Protection                                    |
| 220 KV  | Warora - Wardha                    | 29/Feb/2016   | 20.52         | 01/Mar/2016 | 04.52      | Distance Protection                                    |
| 220 KV  | Chinchwad- Parvati                 | 01/Mar/2016   | 11.17         | 01/Mar/2016 | 12.47      | Diagnostic Testing Line Ideally Charged from C'Wad End |
| 220 KV  | Butibori - VIPL Ckt I              | 01/Mar/2016   | 12.17         | 01/Mar/2016 | 18.04      | Y Phase CT Replacement Work.                           |
| 220 KV  | Badnera Tss-Ii                     | 01/Mar/2016   | 15.05         | 01/Mar/2016 | 17.45      | Diagnostic Testing of CT & Routine Maintenance Work.   |
| 220 KV  | Nasik Navsari I                    | 01/Mar/2016   | 18.32         | 01/Mar/2016 | 19.04      | Distance Protection                                    |
| 220 KV  | Chinchwad-Hinjewadi I              | 01/Mar/2016   | 20.25         | 02/Mar/2016 | 05.51      | For Chinchwad Outage.                                  |
| 220 KV  | Chakan-Chinchwad                   | 01/Mar/2016   | 20.30         | 02/Mar/2016 | 05.37      | Erection of Narrow Base M/C Tower.                     |
| 220 KV  | Telco- Chinchwad                   | 01/Mar/2016   | 20.37         | 02/Mar/2016 | 04.57      | Erection of Narrow Base M/C Tower.                     |
| 220 KV  | Pusad - Hingoli                    | 01/Mar/2016   | 20.56         | 01/Mar/2016 | 21.45      | Backup Protection Operated O/C & E/F.                  |
| 220 KV  | Flagship-Nandedcity                | 02/Mar/2016   | 05.47         | 02/Mar/2016 | 20.23      | For Chinchwad Outage.                                  |
| 220 KV  | satara MIDC- Malharpath            | 02/Mar/2016   | 09.53         | 01/Mar/2016 | 14.07      | CB,CT Testing.                                         |
| 220 KV  | Eklahara(Gcr)(Nasik)- Bableshwar 2 | 02/Mar/2016   | 16.33         | 02/Mar/2016 | 17.57      | Distance Protection                                    |
| 220 KV  | Karad(400kv) -Mudshingi Ckt 2-Tak  | 02/Mar/2016   | 18.53         | 02/Mar/2016 | 19.40      | Distance Protection                                    |
| 220 KV  | Kharepatan -Pawas Line             | 02/Mar/2016   | 19.45         | 02/Mar/2016 | 22.45      | Y Ph Bus PT Burst.                                     |
| 220 KV  | Oni Kharepatan Line                | 02/Mar/2016   | 19.45         | 02/Mar/2016 | 21.22      | Y Ph Bus PT Burst.                                     |
| 220 KV  | Karad - Vita Ckt- I                | 02/Mar/2016   | 20.14         | 03/Mar/2016 | 14.00      | Distance Protection                                    |
| 220 KV  | Chakan-Chinchwad                   | 02/Mar/2016   | 20.58         | 03/Mar/2016 | 05.22      | Erection of Narrow Base M/C Tower.                     |
| 220 KV  | Chinchwad-Hinjewadi I              | 02/Mar/2016   | 21.08         | 03/Mar/2016 | 05.32      | Over Voltage                                           |
| 220 KV  | Telco- Chinchwad                   | 02/Mar/2016   | 21.10         | 03/Mar/2016 | 05.24      | Erection of Narrow Base M/C Tower.                     |
| 220 KV  | Chinchwad-Hinjewadi I              | 03/Mar/2016   | 07.08         | 03/Mar/2016 | 20.25      | H/T for Talegaon chakan line                           |
| 220 KV  | Kharepatan -Pawas Line             | 03/Mar/2016   | 09.05         | 03/Mar/2016 | 14.55      | insulator cleaning                                     |
| 220 KV  | Wadkhal - NDIL-III                 | 03/Mar/2016   | 10.40         | 03/Mar/2016 | 19.30      | safety purpose                                         |
| 220 KV  | Eklahara(Gcr)(Nasik)- Bableshwar 2 | 03/Mar/2016   | 11.24         | 03/Mar/2016 | 12.18      | Distance Protection                                    |
| 220 KV  | Dahanu-Viraj                       | 03/Mar/2016   | 21.51         | 04/Mar/2016 | 00.24      | Distance Protection                                    |
| 220 KV  | Bhigwan-Baramat lagro              | 04/Mar/2016   | 08.00         | 04/Mar/2016 | 19.07      | Stringng work at GANTRY                                |
| 220 KV  | Niwali - Pawas Line                | 04/Mar/2016   | 09.55         | 04/Mar/2016 | 16.40      | Insulator Cleaning work                                |
| 220 KV  | Padghe - Kamba                     | 04/Mar/2016   | 09.56         | 04/Mar/2016 | 17.27      | jumpering work of bus isolator                         |
| 220 KV  | Pigasus-Hinjewadi-II               | 04/Mar/2016   | 10.00         |             | Continued. | Overhauling of CB.on TBC                               |
| 220 KV  | Kharghar Trombay                   | 04/Mar/2016   | 10.50         | 04/Mar/2016 | 11.01      | Distance Protection                                    |
| 220 KV  | Talandage - Chikodi                | 04/Mar/2016   | 12.41         | 04/Mar/2016 | 14.17      | Isolator maintenance work                              |
| 220 KV  | Wadkhal - IpcI 2                   | 04/Mar/2016   | 16.45         | 05/Mar/2016 | 19.49      | conductor stringing work                               |
| 220 KV  | Nanded - Parli Ext. Ckt II         | 05/Mar/2016   | 07.41         | 05/Mar/2016 | 17.17      | Re-orientation work                                    |
| 220 KV  | Koradi-Butibori Rly Tss            | 05/Mar/2016   | 09.38         | 05/Mar/2016 | 17.30      | Tan Delta Measurment of CTs                            |
| 220 KV  | Vsni-512 Khadki                    | 05/Mar/2016   | 10.00         | 05/Mar/2016 | 14.14      | Testing Work                                           |
| 220 KV  | Mudshingi Chikodi                  | 05/Mar/2016   | 10.21         | 05/Mar/2016 | 12.16      | Attending Hot Spot                                     |
| 220 KV  | 512 Khadki- Century Enka           | 05/Mar/2016   | 14.24         | 05/Mar/2016 | 17.44      | Testing Work                                           |
| 220 KV  | Karad(400kv) -Mudshingi Ckt 2-Tak  | 05/Mar/2016   | 14.55         | 05/Mar/2016 | 15.14      | Distance Protection                                    |
| 220 KV  | Talandage(kolh'r)- Sawantwadi II   | 05/Mar/2016   | 16.24         | 05/Mar/2016 | 16.33      | Distance Protection                                    |
| 220 KV  | Hinganghat - Bhugaon               | 05/Mar/2016   | 18.28         | 05/Mar/2016 | 18.46      | Distance Protection                                    |
| 220 KV  | Chakan-Chinchwad                   | 05/Mar/2016   | 21.09         | 06/Mar/2016 | 05.32      | Erection of Narrow Base M/C Tower                      |
| 220 KV  | Telco- Chinchwad                   | 05/Mar/2016   | 21.10         | 06/Mar/2016 | 05.33      | Erection of Narrow Base M/C Tower                      |
| 220 KV  | Nanded - Parli Ext. Ckt I          | 06/Mar/2016   | 08.35         | 06/Mar/2016 | 17.18      | Re-orientation work                                    |
| 220 KV  | Dahanu Ghodbunder Line 2           | 06/Mar/2016   | 08.47         | 06/Mar/2016 | 17.41      | Replacement of CT Junction Box                         |
| 220 KV  | Chakan (400kv)-Bridgestone         | 06/Mar/2016   | 09.19         | 06/Mar/2016 | 16.50      | For removing Bunching arrangement                      |
| 220 KV  | Talegaon (Ambi)-General Motors     | 06/Mar/2016   | 09.30         | 06/Mar/2016 | 13.10      | Annual Maintenance Work                                |
| 220 KV  | Salsette Borivli 1                 | 06/Mar/2016   | 10.25         | 06/Mar/2016 | 19.44      | Testing Work                                           |
| 220 KV  | Pophali - Nerale                   | 06/Mar/2016   | 15.10         | 06/Mar/2016 | 15.30      | Distance Protection                                    |
| 220 KV  | Badnera - Deoli (PG)               | 06/Mar/2016   | 17.56         | 06/Mar/2016 | 18.29      | Distance Protection                                    |
| 220 KV  | Hinganghat - Hinganghat Rly TSS-2  | 06/Mar/2016   | 19.41         |             | Continued. | O/C, E/F(Trial taken 20.29 Hrs but failed)             |
| 220 KV  | Chakan-Chinchwad                   | 06/Mar/2016   | 20.12         | 07/Mar/2016 | 05.24      | Erection of Narrow Base M/C Tower                      |
| 220 KV  | Telco- Chinchwad                   | 06/Mar/2016   | 20.15         | 07/Mar/2016 | 05.26      | Erection of Narrow Base M/C Tower                      |
| 220 KV  | Nanded-Ghatodi                     | 06/Mar/2016   | 22.11         | 06/Mar/2016 | 22.27      | Distance Protection                                    |
| 132 KV  | Theur-Purander                     | 03/Mar/2016   | 08.55         | 03/Mar/2016 | 14.20      | Annual Maintenance Work                                |
| 132 KV  | Amravati-Lalkhedi                  | 03/Mar/2016   | 19.22         | 03/Mar/2016 | 19.50      | Buccholz Protection Optd                               |
| 132 KV  | Hinganghat-Ismt-Ckt1               | 06/Mar/2016   | 19.41         | 06/Mar/2016 | 20.45      | Directional O/C E/F operated                           |