

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 27/Feb/2017 to 05/Mar/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/02/2017	12 Hrs	5756	1211	407	7374	7480	373	3896	187	-1085	18225	0	18225	1391	499	21200	21200	49.89
28/02/2017	12 Hrs	6222	992	413	7627	7500	323	4152	181	-1102	18681	0	18681	1384	495	21662	21662	49.97
01/03/2017	12 Hrs	6024	1243	401	7668	7523	99	4248	184	-1153	18569	0	18569	1371	487	21580	21580	49.95
02/03/2017	12 Hrs	6053	1232	424	7709	7557	152	4091	189	-1119	18579	0	18579	1385	490	21573	21573	49.95
03/03/2017	12 Hrs	5878	1178	423	7479	7511	147	4245	182	-1103	18461	0	18461	1387	507	21458	21458	49.93
04/03/2017	12 Hrs	5688	878	415	6981	7604	44	4474	189	-923	18369	0	18369	1344	494	21130	21130	49.93
05/03/2017	12 Hrs	5723	796	439	6958	7266	62	4585	196	-664	18403	0	18403	996	504	20567	20567	49.95
Maximum		6222	1243	439	7709	7604	373	4585	196	-664	18681	0	18681	1391	507	21662	21662	49.97
Minimum		5688	796	401	6958	7266	44	3896	181	-1153	18225	0	18225	996	487	20567	20567	49.89
Average		5906	1076	417	7399	7492	171	4242	187	-1021	18470	0	18470	1323	497	21310	21310	49.94

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/02/2017	13 Hrs	5768	1304	412	7484	7680	353	3607	201	-1076	18249	0	18249	1384	505	21214	21214	49.92
28/02/2017	13 Hrs	6192	723	405	7320	7724	349	4140	200	-1128	18605	0	18605	1348	501	21582	21582	49.98
01/03/2017	13 Hrs	6043	1220	417	7680	7601	67	4260	185	-1117	18676	0	18676	1372	496	21661	21661	49.91
02/03/2017	13 Hrs	6120	1178	426	7724	7541	70	4071	182	-1096	18492	0	18492	1387	499	21474	21474	49.95
03/03/2017	13 Hrs	5905	819	428	7152	7644	99	4222	191	-1108	18200	0	18200	1335	509	21152	21152	49.99
04/03/2017	13 Hrs	5697	885	419	7001	7707	63	4484	198	-949	18504	0	18504	1308	501	21262	21262	49.92
05/03/2017	13 Hrs	5709	775	419	6903	6945	114	4580	191	-655	18078	0	18078	996	509	20238	20238	49.97
Maximum		6192	1304	428	7724	7724	353	4580	201	-655	18676	0	18676	1387	509	21661	21661	49.99
Minimum		5697	723	405	6903	6945	63	3607	182	-1128	18078	0	18078	996	496	20238	20238	49.91
Average		5919	986	418	7323	7549	159	4195	193	-1018	18401	0	18401	1304	503	21226	21226	49.95

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/02/2017	20 Hrs	6069	386	429	6884	5947	225	4161	0	-1227	15990	0	15990	1099	386	18702	18702	49.99
28/02/2017	20 Hrs	6180	462	440	7082	5992	135	4187	0	-1062	16334	0	16334	1201	505	19102	19102	49.99
01/03/2017	20 Hrs	5738	595	435	6768	6318	312	4196	0	-1197	16397	0	16397	1108	504	19206	19206	49.97
02/03/2017	20 Hrs	5996	348	445	6789	6315	338	4103	0	-1149	16396	0	16396	1226	386	19157	19157	50.00
03/03/2017	20 Hrs	5175	342	431	5948	6819	515	4309	0	-1335	16256	0	16256	1020	387	18998	18998	50.00
04/03/2017	20 Hrs	5116	480	434	6030	6686	468	4519	0	-1208	16495	0	16495	966	387	19056	19056	49.98
05/03/2017	20 Hrs	4492	950	428	5870	6337	508	4009	0	-1085	15639	0	15639	696	387	17807	17807	49.99
Maximum		6180	950	445	7082	6819	515	4519	0	-1062	16495	0	16495	1226	505	19206	19206	50.00
Minimum		4492	342	428	5870	5947	135	4009	0	-1335	15639	0	15639	696	386	17807	17807	49.97
Average		5538	509	435	6482	6345	357	4212	0	-1180	16215	0	16215	1045	420	18861	18861	49.99

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/02/2017	3 Hrs	5040	128	450	5618	5302	337	4154	0	-645	14766	0	14766	693	387	16491	16491	49.97
28/02/2017	4 Hrs	5427	136	450	6013	5408	444	4107	0	-597	15375	0	15375	697	388	17057	17057	49.98
01/03/2017	3 Hrs	5980	135	443	6558	5077	233	4224	0	-711	15381	0	15381	710	388	17190	17190	49.99
02/03/2017	4 Hrs	5677	127	451	6255	5369	197	4221	0	-657	15385	0	15385	708	387	17137	17137	49.98
03/03/2017	3 Hrs	5403	126	440	5969	5592	216	4184	0	-718	15243	0	15243	689	388	17038	17038	49.97
04/03/2017	3 Hrs	5082	139	442	5663	6002	274	4201	0	-668	15472	0	15472	696	387	17223	17223	49.98
05/03/2017	23 Hrs	4526	489	445	5460	6565	191	3716	0	-983	14949	0	14949	696	387	17015	17015	49.94
Maximum		5980	489	451	6558	6565	444	4224	0	-597	15472	0	15472	710	388	17223	17223	49.99
Minimum		4526	126	440	5460	5077	191	3716	0	-983	14766	0	14766	689	387	16491	16491	49.94
Average		5305	183	446	5934	5616	270	4115	0	-711	15225	0	15225	698	387	17022	17022	49.97

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
27/02/2017	136.659	13.085	10.467	160.211	0.132	154.341	156.419	6.974	98.093	1.422	24.267	10.616	-22.757	398.284	57.640	455.924
28/02/2017	144.281	12.011	10.376	166.668	0.142	153.222	153.393	5.595	99.952	1.387	24.962	11.096	-22.420	404.404	58.478	462.882
01/03/2017	139.887	17.941	10.452	168.280	0.110	152.990	155.443	4.906	101.521	1.345	24.428	10.946	-24.035	405.007	59.414	464.421
02/03/2017	141.165	16.163	10.470	167.798	0.164	155.442	158.316	5.472	99.472	1.301	24.724	10.622	-23.703	405.782	59.049	464.831
03/03/2017	134.678	11.491	10.501	156.670	0.193	160.368	163.255	6.262	100.663	1.319	23.799	10.556	-24.170	401.112	58.525	459.637
04/03/2017	129.087	10.558	10.558	150.203	0.167	162.252	163.882	6.070	106.507	1.393	23.336	10.273	-21.365	405.060	54.964	460.024
05/03/2017	123.717	10.733	10.522	144.972	0.074	153.669	156.364	7.146	106.063	1.391	19.641	10.432	-17.274	395.967	47.347	443.314
Maximum	144.281	17.941	10.558	168.280	0.193	162.252	163.882	144.281	106.507	1.422	24.962	11.096	-17.274	405.782	59.414	464.831
Minimum	123.717	10.558	10.376	144.972	0.074	152.990	153.393	123.717	98.093	1.301	19.641	10.273	-24.170	395.967	47.347	443.314
Average	135.639	13.140	10.478	159.257	0.140	156.041	158.153	135.639	101.753	1.365	23.594	10.649	-22.246	402.231	56.488	458.719

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
27/02/2017	0.175	5.228	17.932
28/02/2017	0.154	5.382	17.778
01/03/2017	0.283	0.283	17.495
02/03/2017	0.242	0.525	17.253
03/03/2017	0.133	0.658	17.120
04/03/2017	0.105	0.763	17.015
05/03/2017	0.111	0.874	16.904

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 27/Feb/2017 to 05/Mar/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
27/02/2017	MONDAY	117.795	6479	38.624	1609	156.419	6517	154.341	6431	-2.078	-87
28/02/2017	TUESDAY	116.742	6355	36.651	1527	153.393	6391	153.222	6384	-0.171	-7
01/03/2017	WEDNESDA	119.874	6441	35.569	1482	155.443	6477	152.990	6375	-2.453	-102
02/03/2017	THURSDAY	122.125	6560	36.191	1508	158.316	6596	155.442	6477	-2.874	-120
03/03/2017	FRIDAY	123.906	6763	39.349	1640	163.255	6802	160.368	6682	-2.887	-120
04/03/2017	SATURDAY	123.935	6788	39.947	1664	163.882	6828	162.252	6760	-1.630	-68
05/03/2017	SUNDAY	125.112	6484	31.252	1302	156.364	6515	153.669	6403	-2.695	-112
Total		849.490		257.582		1107.072		1092.284		-14.788	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 27/02/2017 TO 05/03/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Paras Unit 3	250MW	25/Oct/2016	08.54		Continued.	Stator Fault, continued under AOH.26/10/2016 00.00hrs
MSPGCL	Chandrapur Unit 7	500MW	25/Jan/2017	19.32		Continued.	Capital Overhaul
MSPGCL	Koyna Unit 7	80MW	10/Feb/2017	11.20		Continued.	Maintenance Work.
FORCED OUTAGES							
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	RPL(AMT) U-5	270MW	15/Nov/2016	20.00		Continued.	Zero schedule
IPP	RPL(AMT) U-4	270MW	16/Nov/2016	21.03		Continued.	Zero Schedule By MSEDCL.
IPP	RPL(AMT) U-2	270MW	16/Nov/2016	22.36		Continued.	Zero Schedule By MSEDCL.
IPP	JSW (J) U1	300MW	16/Nov/2016	14.38	03/Mar/2017	13.40	Due To CW Duct Leakage.
IPP	RPL(AMT) U-1	270MW	17/Nov/2016	17.23		Continued.	Zero Schedule.
MSPGCL	Parli Unit 8	250MW	18/Nov/2016	16.23		Continued.	w/dn for balance work.
IPP	JSW (J) U2	300MW	01/Dec/2016	00.00		Continued.	No Schedule.
IPP	VIPL U-1	300MW	03/Jan/2017	00.45		Continued.	Turbine bearing temprature high.
MSPGCL	Koradi Unit 10	660MW	07/Feb/2017	00.10		Continued.	Work Of PG Test.
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
MSPGCL	Koradi Unit 7	210MW	15/Feb/2017	14.18		Continued.	Zero Schedule by MSEDCL
MSPGCL	Nasik Unit 5	210MW	24/Feb/2017	14.30		Continued.	Zero Schedule.
MSPGCL	Chandrapur Unit 6	500MW	25/Feb/2017	11.48	27/Feb/2017	12.02	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 8	500MW	27/Feb/2017	12.24	05/Mar/2017	10.19	Boiler Tube Leakage
MSPGCL	Khaparkheda Unit 2	210MW	28/Feb/2017	22.51	02/Mar/2017	10.51	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 9	500MW	01/Mar/2017	14.31	01/Mar/2017	17.55	Low furnace pressure
IPP	SWPGL U-3	135MW	01/Mar/2017	16.51	04/Mar/2017	12.00	Flame Failure
IPP	Trombay 7A	120MW	01/Mar/2017	16.45	01/Mar/2017	20.56	EHC TRANSMITTER FAULTY.
IPP	Trombay 7B	60MW	01/Mar/2017	16.45	01/Mar/2017	22.49	EHC TRANSMITTER FAULTY.
MSPGCL	Khaparkheda Unit 1	210MW	02/Mar/2017	13.08		Continued.	zero schedule.
MSPGCL	Ghatghar Unit-1	125MW	02/Mar/2017	21.45	04/Mar/2017	01.30	C W Booster Pump Damage.
MSPGCL	Bhusawal Unit 3	210MW	03/Mar/2017	06.42		Continued.	zero schedule
MSPGCL	Chandrapur Unit 4	210MW	04/Mar/2017	05.23		Continued.	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 9	500MW	05/Mar/2017	15.17		Continued.	Low furnace pressure

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 27/02/2017 TO 05/03/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Main Bus - II @ Kalwa	24/Feb/2017	08.55	02/Mar/2017	18.16	Conductor Replacement Work.
400 KV	Dabhol Nagothane II	25/Feb/2017	14.44	27/Feb/2017	16.11	Distance Protection
400 KV	Karad -kolhapur-II	26/Feb/2017	17.07	27/Feb/2017	09.20	Over Voltage
400 KV	Dhule Sar'Sarovar II	26/Feb/2017	18.06	27/Feb/2017	06.53	Over Voltage
400 KV	Bhusawal-Aurangabad	26/Feb/2017	18.15	27/Feb/2017	06.50	Over Voltage
400 KV	Padghe - Kalwa- I	27/Feb/2017	07.14	28/Feb/2017	16.01	Conductor Replacement Work.
400 KV	Chandrapur2-Parali 2 ckt1	27/Feb/2017	08.29	27/Feb/2017	08.52	Checking Outage Feasibility.
400 KV	Dhule Khandwa I	27/Feb/2017	09.13	27/Feb/2017	16.35	Taken On Tbc For Main Breaker Work.
400 KV	New Koyna - Koyna Stage IV-II	27/Feb/2017	10.05	27/Feb/2017	14.32	Taken On TBC For Testing Work.
400 KV	Karad -kolhapur-I	27/Feb/2017	16.37	28/Feb/2017	07.24	Over Voltage
400 KV	Karad - Jaigad - II	27/Feb/2017	18.04	28/Feb/2017	07.51	Over Voltage
400 KV	Dhule Sar'Sarovar II	27/Feb/2017	19.34	28/Feb/2017	06.02	Over Voltage
400 KV	Bhusawal-Aurangabad	27/Feb/2017	19.58	28/Feb/2017	05.55	Over Voltage
400 KV	Akola-Nandgaonpeth (RPL)	28/Feb/2017	08.44	28/Feb/2017	09.17	TRIPPED ON DP.
400 KV	Nagothane - Dabhol-II	28/Feb/2017	13.26	03/Mar/2017	14.36	DP TRIP.
400 KV	Dhule Sar'Sarovar II	28/Feb/2017	18.41	01/Mar/2017	05.28	Over Voltage
400 KV	Bhusawal-Aurangabad	28/Feb/2017	19.45	01/Mar/2017	06.42	Over Voltage
400 KV	Kalwa - Talegaon(PG)	01/Mar/2017	06.58	02/Mar/2017	16.18	taken on tbc for conductor replacement.
400 KV	Kalwa - Kharghar	01/Mar/2017	07.21	01/Mar/2017	20.11	400kv b bus old conductor replacement work.
400 KV	Chandrapur2-Parali 2 ckt1	01/Mar/2017	08.39	01/Mar/2017	18.04	for making lilo arrangement at nanded substation.
400 KV	Dhule Sar'Sarovar I	01/Mar/2017	08.42	02/Mar/2017	06.46	Relay Testing Work.RFC 18.18HRS
400 KV	N.Koyna-Karad -Ckt I	01/Mar/2017	09.24	01/Mar/2017	17.22	taken on tbc for breaker diagnostic testing.
400 KV	Dhule(MS)- Dhule(BDTCL) -1	01/Mar/2017	11.22	01/Mar/2017	15.44	Line Maintenance work
400 KV	Karad -kolhapur-II	01/Mar/2017	16.41	02/Mar/2017	06.47	Over Voltage
400 KV	Bhusawal-Aurangabad	01/Mar/2017	18.23	02/Mar/2017	06.24	Over Voltage
400 KV	Chandrapur2-Parali 2 ckt1	02/Mar/2017	08.06	02/Mar/2017	18.18	LILo work at Nanded
400 KV	Padghe - Kalwa-II	02/Mar/2017	20.23	02/Mar/2017	20.27	Heavy sparking on Isolator
400 KV	Bhusawal-Aurangabad	02/Mar/2017	21.24	03/Mar/2017	06.55	Over Voltage
400 KV	Dhule Sar'Sarovar II	02/Mar/2017	21.27	03/Mar/2017	06.31	Over Voltage
400 KV	Dhule Sar'Sarovar II	03/Mar/2017	09.04	04/Mar/2017	08.58	Maintenance by WRLLDC.
400 KV	Bhusawal-Aurangabad	03/Mar/2017	18.12	04/Mar/2017	06.14	Over Voltage
400 KV	Dhule(MS)- Dhule(BDTCL) -II	04/Mar/2017	10.02	04/Mar/2017	19.13	Bay Maintenance.
400 KV	Chandrapur-II - Nanded	04/Mar/2017	11.31	04/Mar/2017	17.52	Earthwire Suspension Clamp Replacement.
400 KV	Ektuni-Taptitanda II	04/Mar/2017	14.42	04/Mar/2017	21.24	Isolator Maintenance.
400 KV	Dhule Sar'Sarovar I	04/Mar/2017	18.19	05/Mar/2017	06.54	Over Voltage
400 KV	Bhusawal-Aurangabad	04/Mar/2017	18.30	05/Mar/2017	06.48	Over Voltage
400 KV	Ektuni-Bablesghwar ckt I	05/Mar/2017	09.38	05/Mar/2017	20.28	For stringing work of 765KV D/c Aurangabad -padgha line code 470.
400 KV	Ektuni-Bablesghwar ckt II	05/Mar/2017	09.52	05/Mar/2017	20.32	For stringing work of 765KV D/c Aurangabad -padgha line code 470.
400 KV	Karad -kolhapur-II	05/Mar/2017	17.13	06/Mar/2017	06.47	Over Voltage
400 KV	Jaigad-Karad Ckt-I	05/Mar/2017	17.15	06/Mar/2017	06.48	Over Voltage
400 KV	Dhule Sar'Sarovar I	05/Mar/2017	18.36	06/Mar/2017	06.51	Over Voltage
400 KV	Bhusawal-Aurangabad	05/Mar/2017	20.57	06/Mar/2017	06.46	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Pophli Pedhmbe Line- 2	13/Feb/2017	03.40	05/Mar/2017	16.10	Distance Protection at pedhmbe end
220 KV	Trombay MSETCL Tie 2	22/Feb/2017	09.24		Continued.	protection panel replacement work.
220 KV	Mahalakshmi Amona	27/Feb/2017	07.11	27/Feb/2017	09.11	Distance Protection
220 KV	Karad(400kv) - Wathar	27/Feb/2017	09.43	27/Feb/2017	17.25	Bus Section 1 Outage.
220 KV	Talandge(400kv)- Ichalkaranji 1	27/Feb/2017	10.05	27/Feb/2017	19.25	Annual Maintenance Work
220 KV	Talandge(400kv)- Ichalkaranji 2	27/Feb/2017	10.05	27/Feb/2017	17.58	Annual Maintenance Work
220 KV	Kalwa - Mulund 1	27/Feb/2017	10.24	27/Feb/2017	14.03	Safety Purpose For Work On Kharghar Borivali line.
220 KV	Nerle - Dasgaon	27/Feb/2017	10.56	27/Feb/2017	18.32	Testing Work
220 KV	New Koyna - Loteparshuram	27/Feb/2017	11.53	27/Feb/2017	19.27	Replacement Of Distance Relay.
220 KV	Nagothane - Posco	27/Feb/2017	16.18	27/Feb/2017	17.25	Line Signature Analysis.
220 KV	Kandalgaon - Bhira	27/Feb/2017	17.45	27/Feb/2017	19.08	Line Signature Analysis.
220 KV	Karad - Dasgaon	28/Feb/2017	10.16	28/Feb/2017	18.09	Routine Maintenance Work
220 KV	Vilebagad-PGPL	28/Feb/2017	11.11	28/Feb/2017	13.15	Testing Work
220 KV	Kalwa - Borivali	01/Mar/2017	06.24	01/Mar/2017	08.45	Attending Hot Spot
220 KV	Mahad-Kandalgaon	01/Mar/2017	10.36	01/Mar/2017	13.01	line signature analysis test.
220 KV	Bhugaon- Wardha	01/Mar/2017	11.08	01/Mar/2017	20.06	Relay Testing Work.
220 KV	Mulund - GIS Bhandup	01/Mar/2017	12.25	01/Mar/2017	13.25	TRIPPED ON DP.
220 KV	Mahad - Pedambe	01/Mar/2017	13.45	01/Mar/2017	15.20	line signature analysis test.
220 KV	Miraj - Mhaishal	01/Mar/2017	13.58	01/Mar/2017	15.00	beem errection work.
220 KV	Khaparkheda-Ambazari-I	01/Mar/2017	14.19	01/Mar/2017	15.58	N/T SWITCH REPLACEMENT.
220 KV	Pedambe-Nerle	01/Mar/2017	14.28	01/Mar/2017	15.35	tripped on dp.
220 KV	Koradi II - Kandlewada	01/Mar/2017	14.50	01/Mar/2017	17.13	Attending Hot Spot
220 KV	Miraj - Mhaishal	01/Mar/2017	19.41	02/Mar/2017	06.55	Distance Protection
220 KV	Apta - Tambati	02/Mar/2017	07.57	02/Mar/2017	11.00	Testing Work
220 KV	Jejuri-Phursungi 2	02/Mar/2017	09.30	02/Mar/2017	19.38	Half yearly maintenance work
220 KV	512 Khadki- Century Enka	02/Mar/2017	10.00	02/Mar/2017	18.23	Line Maintenance work
220 KV	Chinchwad-Hinjewadi I	02/Mar/2017	10.01	02/Mar/2017	20.30	H/T for Telco outage
220 KV	Bhosari 2 - Telco	02/Mar/2017	10.14	02/Mar/2017	20.03	To attend Air Leakage
220 KV	220KV Sawangi- Bhokardan	02/Mar/2017	13.25	02/Mar/2017	18.33	Distance Protection
220 KV	Phulambri-Bhokardan	02/Mar/2017	13.25	02/Mar/2017	18.53	Distance Protection
220 KV	Jambhul - Anandnagar	03/Mar/2017	06.10	03/Mar/2017	17.15	Routine Maintenance Work
220 KV	sawangi-Phulambri	03/Mar/2017	08.05	03/Mar/2017	10.45	Distance Protection

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Apta - Taloja	03/Mar/2017	08.41	03/Mar/2017	13.15	Diagnostic Testing Work.
220 KV	Uran - Kharghar I	03/Mar/2017	09.05	03/Mar/2017	17.23	Taken on TBC for Diagnostic Testing of C B.
220 KV	sawangi-Phulambri	03/Mar/2017	11.10	03/Mar/2017	20.06	For Padegaon-Sawangi Outage.
220 KV	ACCIL - Apta	03/Mar/2017	11.23	03/Mar/2017	14.55	Line Signature Analysis Test.
220 KV	220KV Sawangi- Bhokardan	03/Mar/2017	11.25	03/Mar/2017	19.58	For Padegaon-Sawangi Outage.
220 KV	Padegaon-Sawangi	03/Mar/2017	11.36	03/Mar/2017	19.38	Diagnostic Testing Work.
220 KV	Wadkhal - Ndil3	03/Mar/2017	12.15	03/Mar/2017	14.00	Emergency H/T for Sparking @ NDIL.