

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.
Maharashtra State Load Despatch Centre, Kalwa

To,
DSS CONTROL ROOM,
Head Office Mumbai.

No. 682/05.05.14

Sub: Report of the Power System position for the period 28-Apr-14 To 4-May-14

Date	Monday 28-Apr-14	Tuesday 29-Apr-14	Wednesday 30-Apr-14	Thursday 1-May-14	Friday 2-May-14	Saturday 3-May-14	Sunday 4-May-14
On Line Capacity (MW)							
MSPGCL THM	5657	5352	5782	5869	5520	5338	5410
MSPGCL HY	1409	1411	1420	1420	1417	1407	1407
MSPGCL GAS	460	460	460	460	610	630	460
MSPGCL TOTAL	7526	7223	7662	7749	7547	7375	7277
Cent. Sect.(incl. RGPPL)	5821	6512	6202	5803	5365	5666	5509
MSPGCL + CS	13347	13735	13864	13552	12912	13041	12786
TPCL	1627	1627	1627	1627	1627	1627	1627
REL	500	500	500	500	500	500	500
TPCL + REL	2127	2127	2127	2127	2127	2127	2127
CPP	2388	3393	3440	3234	3416	3321	3456
STATE OLC	17862	19255	19431	18913	18455	18489	18369
Morning Peak Demand (MW)	12 Hrs	12 Hrs	12 Hrs	12 Hrs	12 Hrs	13 Hrs	12 Hrs
MSPGCL THM	5528	5407	5569	5308	5506	5820	5343
MSPGCL HY	2418	1598	1050	289	930	773	609
MSPGCL GAS	432	429	430	429	590	479	439
MSPGCL TOTAL	8378	7434	7049	6026	7026	7072	6391
Cent. Sect.(incl. RGPPL)	6052	6435	6193	5560	5566	5773	5951
Wind	130	112	178	204	186	180	38
CPP	2777	3168	3442	3319	3422	3694	3451
TPCL Asst	-1323	-1366	-1322	-1147	-1402	-1339	-934
MSEDCL Catered	16163	15948	15675	14106	14936	15518	15040
Load Shedding (LS)	1164	914	828	255	745	993	795
MSEDCL Demand(Incl LS)	17327	16862	16503	14361	15681	16511	15835
TPCL + REL Dem.	3207	3274	3193	2366	3148	2945	2216
State Demand (Incl LS)	20534	20136	19696	16727	18829	19456	18051
Sys. Freq. (Hz)	49.93	49.79	49.96	49.95	50.02	49.98	50
Evening Peak Demand (MW)	14 Hrs	14 Hrs	15 Hrs	16 Hrs	16 Hrs	16 Hrs	16 Hrs
MSPGCL THM	5866	5524	5902	5489	5501	5243	5484
MSPGCL HY	1930	1371	906	296	829	816	723
MSPGCL GAS	433	432	427	583	529	450	429
MSPGCL TOTAL	8229	7327	7235	6368	6859	6509	6636
Cent. Sect.(incl. RGPPL)	6080	6511	6418	5255	5658	6336	5800
Wind	205	180	462	229	396	717	371
CPP	2774	2955	2879	3320	3466	3620	3442
TPCL Asst	-1280	-1202	-1276	-1188	-1397	-1344	-947
MSEDCL Catered	16142	15932	15836	14074	15073	15984	15400
Load Shedding (LS)	1033	935	681	143	546	466	512
MSEDCL Demand(Incl LS)	17175	16867	16517	14217	15619	16450	15912
TPCL + REL Dem.	3188	3157	3148	2418	3146	2829	2244
State Demand (Incl LS)	20363	20024	19665	16635	18765	19279	18156
Sys. Freq. (Hz)	49.88	49.77	49.73	50.04	49.94	49.94	49.98

Chief Engineer
MSLDC, Kalwa

SLDC,KALWA
MSPGCL WEEKLY FORCED & PLANNED UNIT OUTAGES

WEEK	28-Apr-14	TO	4-May-14
------	-----------	----	----------

A) (UNITWISE PLANNED/FORCED OUTAGE POSITION @ 05:30 HRS. OF THE DAY OF (MSPGCL THERMAL UNITS ONLY)

Sr.No	Date	28-Apr-2014		29-Apr-2014		30-Apr-2014		1-May-2014		2-May-2014		3-May-2014		4-May-2014	
	Day	MONDAY		TUESDAY		WEDNESDAY		THURSDAY		FRIDAY		SATURDAY		SUNDAY	
	Outage Type	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED
1	NASIK	*	4	*	4	*	*	*	*	*	*	*	*	*	*
2	KORADI	5	*	5	*	5	*	5	*	5	*	5	*	5	*
3	KHAPERKHEDA	3	*	3	*	3	*	3	*	3	*	3	*	*	*
4	PARALI	3	4	3	4	3	4	3	4	3	4	3	4	3	4
5	CHANDRAPUR	*	*	*	*	*	*	*	*	*	*	*	*	*	*
6	BHUSAVAL	*	*	*	*	*	*	*	*	*	*	*	*	*	*
7	PARAS	*	*	*	*	*	*	*	*	*	*	*	4	*	4

REMARKS:-
 1)THIS INFORMATION TO BE VERIFIED FROM CGM.(GEN.WORKS) MSPGCL,H.O. MUMBAI REPORT BEFORE SUBMITTING TO THE CABINET COMMITTEE
 2) URAN GTPS UNITS ARE KEPT SHUT OR ON STAND BY MODE DUE TO GAS SHORTAGE.
 3) Koradi U-1 to 4, Paras U-2, Parli U-1,2, Bhusawal U-1 and Nasik 1,2 are withdrawn being a vintage units.

B) WEEKLY CENTRAL SECTOR SHARE/DRAWL(IN MUs)

DATE	DAY	CENT.SECT. SHARE		TOTAL INTER STATE BILATERAL PURCHASE		TOTAL SHARE		TOTAL DRAWL		OVERDRAWL(+) UNDREDRAWL(-)	
		MUs	AVG. MW	MUs	AVG. MW	MUs	AVG. MW	MUs	AVG. MW	MUs	AVG. MW
		1		2		1+2=3		4		3-4=5	
28-Apr-2014	MONDAY	109.724	4572	16.668	695	126.392	5266	131.466	5478	5.074	211
29-Apr-2014	TUESDAY	109.241	4552	30.276	1262	139.517	5813	140.641	5860	1.124	47
30-Apr-2014	WEDNESDAY	110.726	4614	24.435	1018	135.161	5632	137.565	5732	2.404	100
1-May-2014	THURSDAY	101.532	4231	15.099	629	116.631	4860	118.552	4940	1.921	80
2-May-2014	FRIDAY	102.017	4251	11.770	490	113.787	4741	117.834	4910	4.047	169
3-May-2014	SATURDAY	104.173	4341	15.725	655	119.898	4996	123.278	5137	3.380	141
4-May-2014	SUNDAY	100.313	4180	19.802	825	120.115	5005	122.152	5090	2.037	85
	TOTAL	737.726		133.775		871.501		891.488		19.987	

Details of Koyna Water Consumption (In TMC)

DATE	For the Day	For the Month	Balance
28-Apr-14	0.674	13.203	-7.755
29-Apr-14	0.332	13.535	-8.087
30-Apr-14	0.194	13.729	-8.281
1-May-14	0.068	0.068	-8.349
2-May-14	0.176	0.244	-8.525
3-May-14	0.188	0.432	-8.713
4-May-14	0.073	0.505	-8.786

Supply Position During Evening Peak (MW)

Date	Time	MSEDCL Generation				NO. 401 / 18.03.2014	WIND	CPP	TPCL Exch	MSEDCL Catered Demand	Load Shedding (LS).	MSEDCL Demand (Incl LS)	TPCL Gen.	REL Gen.	State demand met	State Demand (Incl LS)	Freq.
		Thermal	Hydro	Gas	Total												
		MW	MW	MW	MW												
28-Apr-14	14	5866	1930	433	8229	6080	205	2774	-1280	16142	1033	17175	1388	520	19330	20363	49.88
29-Apr-14	14	5524	1371	432	7327	6511	180	2955	-1202	15932	935	16867	1434	521	19089	20024	49.77
30-Apr-14	15	5902	906	427	7235	6418	462	2879	-1276	15836	681	16517	1353	519	18984	19665	49.73
1-May-14	16	5489	296	583	6368	5255	229	3320	-1188	14074	143	14217	815	415	16492	16635	50.04
2-May-14	16	5501	829	529	6859	5658	396	3466	-1397	15073	546	15619	1229	520	18219	18765	49.94
3-May-14	16	5243	816	450	6509	6336	717	3620	-1344	15984	466	16450	965	520	18813	19279	49.94
4-May-14	16	5484	723	429	6636	5800	371	3442	-947	15400	512	15912	778	519	17644	18156	49.98
Maximum		5902	1930	583	8229	6511	717	3620	-947	16142	1033	17175	1434	521	19330	20363	50.04
Minimum		5243	296	427	6368	5255	180	2774	-1397	14074	143	14217	778	415	16492	16635	49.73
Average		5573	982	469	7023	6008	366	3208	-1233	15492	617	16108	1137	505	18367	18984	49.90

Supply Position During Morning Peak (MW)

Date	Time	MSEDCL Generation				Central Sector Receipt	WIND	CPP	TPCL Exch	MSEDCL Catered Demand	Load Shedding (LS).	MSEDCL Demand (Incl LS)	TPCL Gen.	REL Gen.	State demand met	State Demand (Incl LS)	Freq.
		Thermal	Hydro	Gas	Total												
		MW	MW	MW	MW												
28-Apr-14	12	5528	2418	432	8378	6052	130	2777	-1323	16163	1164	17327	1367	517	19370	20534	49.93
29-Apr-14	12	5407	1598	429	7434	6435	112	3168	-1366	15948	914	16862	1390	518	19222	20136	49.79
30-Apr-14	12	5569	1050	430	7049	6193	178	3442	-1322	15675	828	16503	1353	518	18868	19696	49.96
1-May-14	12	5308	289	429	6026	5560	204	3319	-1147	14106	255	14361	795	424	16472	16727	49.95
2-May-14	12	5506	930	590	7026	5566	186	3422	-1402	14936	745	15681	1227	519	18084	18829	50.02
3-May-14	13	5820	773	479	7072	5773	180	3694	-1339	15518	993	16511	1085	521	18463	19456	49.98
4-May-14	12	5343	609	439	6391	5951	38	3451	-934	15040	795	15835	764	518	17256	18051	50.00
Maximum		5820	2418	590	8378	6435	204	3694	-934	16163	1164	17327	1390	521	19370	20534	50.02
Minimum		5308	289	429	6026	5560	38	2777	-1402	14106	255	14361	764	424	16472	16727	49.79
Average		5497	1095	461	7054	5933	147	3325	-1262	15341	813	16154	1140	505	18248	19061	49.95

Details of Supply Position (MUs)

Date	MSEDCL Generation					Central Sector Receipt	Central Sector Share	WIND	CPP	TPCL Gen	R-Infra Gen	TPCL Exch	Energy Requirement		
	Thermal	Hydro	Gas	Pench(MS)	Total								MSEDCL	MUMBAI	State
28-Apr-14	129.287	34.451	10.363	0.226	174.327	131.466	126.392	9.310	68.330	26.372	12.457	-25.471	359.048	64.298	423.346
29-Apr-14	128.200	19.398	10.643	0.652	158.893	140.641	139.517	8.963	76.273	25.768	12.461	-26.576	359.188	64.804	423.992
30-Apr-14	133.719	14.011	10.587	0.161	158.478	137.565	135.161	10.266	73.374	25.307	12.459	-26.465	354.193	64.230	418.423
1-May-14	128.895	7.303	12.097	0.115	148.410	118.552	116.631	9.957	74.944	18.926	11.102	-24.299	328.568	54.327	382.895
2-May-14	128.858	13.051	13.349	0.000	155.258	117.834	113.787	11.540	81.982	22.786	12.300	-27.804	339.790	62.890	402.680
3-May-14	127.055	12.961	11.913	0.237	152.166	123.278	119.898	10.441	84.140	21.567	12.477	-25.523	345.522	59.568	405.090
4-May-14	128.127	8.124	10.422	0.153	146.826	122.152	120.115	7.264	81.522	18.955	12.298	-20.638	338.122	51.892	390.014
Maximum	133.719	34.451	13.349	0.652	174.327	140.641	139.517	11.540	84.140	26.372	12.477	-20.638	359.188	64.804	423.992
Minimum	127.055	7.303	10.363	0.000	146.826	117.834	113.787	7.264	68.330	18.926	11.102	-27.804	328.568	51.892	382.895
Average	129.163	15.614	11.339	0.221	156.337	127.355	124.500	9.677	77.224	22.812	12.222	-25.254	346.347	60.287	406.634

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.
 Maharashtra State Load Despatch Centre, Kalwa
Information for Weekly Cabinet Meeting

For the Week **28-Apr-14** to **4-May-14**

Demand Supply Summary

	Morning Peak (MW)	Evening Peak (MW)
Average Peak Demand	16154	16108
Average Peak Supply	15341	15492
Average Load Relief (LS)	813	617

Average Supply Summary

	Morning Peak (MW)	Evening Peak (MW)	Mus
Thermal	5497	5573	129.16
Gas	461	469	11.34
Hydro	1095	982	15.61
CS Drawal (Total)	5933	6008	127.36
TPCL	-1262	-1233	-25.25

Koyna Water position

	Water in TMC Feet
Average Water Used Per Day	0.244
Balance Left	-8.786
Balance Left Last Year Same Week	5.647

MSPGCL Unit Outage Position

Date	MSPGCL (in MW)		
	Planned	Forced	Total
28-Apr-14	620	420	1040
29-Apr-14	620	420	1040
30-Apr-14	620	210	830
1-May-14	620	210	830
2-May-14	620	210	830
3-May-14	620	460	1080
4-May-14	410	460	870

Distressed Load Shedding

Maxm. No. of Hours in a day	0
Number of Days	0

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 28-Apr-14 TO 4-May-14

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Parli	Unit 3	210	13-Feb-13	23.50		Continued.	Water Shortage
Khaparkheda	Unit 3	210	1-Apr-14	05.14	3-May-14	19.08	A.O.H.
Koradi	Unit 5	200	10-Apr-14	19.21		Continued.	Coal conservation
CPP	JSW (J) U3	300	14-Apr-14	23.51	29-Apr-14	02.30	Annual Shutdown.

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	1B	230	28-May-13	22.02		Continued.	Gas shortage.
Dabhol	2A	230	6-Jun-13	09.10		Continued.	Gas Shortage
Dabhol	3A	230	6-Jun-13	08.28		Continued.	Gas Shortage
Dabhol	1A	230	27-Jun-13	21.47		Continued.	Gas Shortage
Dabhol	1X	290	27-Jun-13	21.46		Continued.	Gas Shortage
Dabhol	2X	290	15-Jul-13	15.09		Continued.	Gas Shortage
Dabhol	2B	230	8-Aug-13	15.03		Continued.	Gas Shortage
Dabhol	3X	290	29-Dec-13	05.47		Continued.	Gas Shortage
Dabhol	3B	230	29-Dec-13	06.14		Continued.	Gas Shortage
Tata	Trombay 8	250	9-Jan-14	22.54		Continued.	Emergency H/T, Fire at turbine track.
CPP	WPCL U-1	135	30-Jan-14	12.45		Continued.	turbine vibration
CPP	WPCL U-2	135	18-Feb-14	00.02		Continued.	Ash Conveying problem
CPP	INDIABULLS	270	20-Feb-14	19.43	28-Apr-14	17.41	BFP and Turbine Problem of U-2
CPP	JSW (J) U2	300	28-Feb-14	17.52		Continued.	No Schedule.
CPP	WPCL U-3	135	1-Apr-14	00.07	30-Apr-14	21.41	No Schedule
CPP	WPCL U-4	135	3-Apr-14	00.01		Continued.	No Schedule
CPP	Adani U-4	660	14-Apr-14	04:35	28-Apr-14	06.24	Withdrawn
Uran	Unit 5	108	16-Apr-14	03.31	1-May-14	12.28	Gas Shortage.
CPP	INDIABULLS	270	19-Apr-14	19.50		Continued.	Coal Shortage of U-1
Parli	Unit 4	210	25-Apr-14	17.52		Continued.	Flame Failure.
CPP	Adani U-3	660	26-Apr-14	00.33	1-May-14	06.37	Boiler Tube Leakage.
Nasik	Unit 4	210	27-Apr-14	11.15	29-Apr-14	21.12	Boiler Tube Leakage.
Koyna	Unit 9	80	28-Apr-14	22.25	29-Apr-14	05.25	R.M.Work
Koyna	ST-IV 1	250	29-Apr-14	12.15	30-Apr-14	04.00	Butterfly valve problem
Koyna	ST - IV 4	250	29-Apr-14	12.05	29-Apr-14	19.10	Governor safety valve problem
CPP	INDIABULLS	270	29-Apr-14	09.34		Continued.	PA Fan Problem of U-2
CPP	Adani U1	660	30-Apr-14	12.11		Continued.	BTL.
Koyna	Unit 6	75	1-May-14	22.15	2-May-14	02.40	Preventive Maint.work
Uran	Unit 5	108	2-May-14	02.31	2-May-14	03.52	Damper Discrepancy
Paras	Unit 4	250	2-May-14	17.36	4-May-14	23.14	Boiler Tube Leakage
Khaparkheda	Unit 3	210	3-May-14	19.40	3-May-14	21.23	UAT Tripping
Parli	Unit 5	210	4-May-14	0.45	4-May-14	5.14	Id fan problem
Uran	Unit 8	108	4-May-14	12.53		Continued.	Gas shortage
Chandrapur	Unit 5	500	5-May-14	00.40		Continued.	CEP Pump Tripped.
Koradi	Unit 7	210	5-May-14	05.05		Continued.	ID Fan Bearing Temp.High.
Chandrapur	Unit 3	210	5-May-14	06.10		Continued.	GCR Building Caught Fire.
Hydro	GhatgharU2	125	5-May-14	03.00		Continued.	Speed Not Raised.

LINE OUTAGES FOR THE WEEK

FROM 28-Apr-14 TO 4-May-14

Voltage	Name	date_trip	time_trip	date_sync	time_sync	Reason
500KV	765/400KV 1500MVA ICT at Tiroda	15-Apr-14	00.25	28-Apr-14	05.14	H/T.
500KV	HVDC POLE I - CHDPPR	29-Apr-14	04.12	29-Apr-14	09.44	Testing and Trouble shooting of Pole-I valve control system
500KV	HVDC Pole-I	1-May-14	03.44	1-May-14	18.34	Replacement of Faulty MCB Fans.
500KV	HVDC Pole II Padgha	2-May-14	15.09	2-May-14	16.51	Pole Control Standby System Redundancy Failed
500KV	765 KV (Akola 2) 240 MVAR bus reactor	3-May-14	9.19	3-May-14	17.27	over voltage
400KV	A'bad-Talegaon PG-1	25-Apr-14	17.45	28-Apr-14	04.05	For Akola-A'bad 1 & 2 Outage.
400KV	Talegaon PG- Aurangabad - II	25-Apr-14	18.11	28-Apr-14	12.57	For Akola-A'bad 1 & 2 Outage.
400KV	Akola - Aurangabad - I	25-Apr-14	18.35	28-Apr-14	01.36	Tube,Line Isolator & Twin to Quad Conversion of Conductor of Ckt.
400KV	Akola-Aurangabad--II	25-Apr-14	18.57	28-Apr-14	00.28	Tube,Line Isolator & Twin to Quad Conversion of Conductor of Ckt.Ckt Making LILO @ 400KV A'bad(PG) S/S.
400KV	Deepnagar-Aurangabad-I	26-Apr-14	09.02	28-Apr-14	07.47	To Control L/L of Akola-Bhusawal.
400KV	Karad - Kolhapur - II	27-Apr-14	16.35	28-Apr-14	07.09	Over Voltage.
400KV	Kolhapur - Mapusa - I	27-Apr-14	16.37	28-Apr-14	09.19	Over Voltage
400KV	Kolhapur - Mapusa - I	28-Apr-14	16.37	29-Apr-14	09.06	Over Voltage
400KV	Aurangabad (M) 400KV Aurangabad (PG) - I	28-Apr-14	00.47	28-Apr-14	00.48	Ckt Charged by Making LILO @ 400KV A'bad (PG) S/S.
400KV	Aurangabad (PG) - 400KV Akola - I	28-Apr-14	01.35	28-Apr-14	01.36	Ckt Charged by Making LILO @ 400KV A'bad (PG) S/S.
400KV	Aurangabad (PG) - 400KV Akola - II	28-Apr-14	00.27	28-Apr-14	00.28	Ckt Charged by Making LILO @ 400KV A'bad(PG) S/S.
400KV	Karad-Jaigad I	28-Apr-14	02.08	28-Apr-14	07.12	Over Voltage
400KV	Karad - Kolhapur - II	28-Apr-14	17.06	29-Apr-14	07.14	Over Voltage
400KV	Dabhol - New Koyna - I	28-Apr-14	12.26		Continued.	Cold washing of Insulator, RFC 19.53Hrs
400KV	Karad - Solapur (PGCIL)	28-Apr-14	13.50	29-Apr-14	10.46	Replacement of CVT at Karad
400KV	400/220 KV 500 MVA ICT-I @ Deepnagar	28-Apr-14	08.33	28-Apr-14	15.00	Q.M.Work
400KV	400/220 KV,500MVA ICT-II at Deepnagar.	28-Apr-14	16.57	28-Apr-14	18.46	To attend False Indication CTR Pannel
400KV	Kolhapur-Mapusa-II	29-Apr-14	17.14	30-Apr-14	07.39	Over Voltage
400KV	Karad - Kolhapur - II	29-Apr-14	16.30	30-Apr-14	06.20	Over Voltage
400KV	Karad-Jaigad I	29-Apr-14	16.32	30-Apr-14	06.29	Over Voltage
400KV	400/220 KV 500 MVA ICT-II at Lamboti	30-Apr-14	11.06	30-Apr-14	15.34	OLTC conservetor oil top up & Tan Delta Measurement.
400KV	Karad-Kolhapur-II	30-Apr-14	16.14	1-May-14	09.29	Over Voltage.
400KV	Karad-Jaigad I	30-Apr-14	16.38	1-May-14	10.08	Over Voltage.
400KV	Karad-Lonikand	30-Apr-14	07.20	30-Apr-14	22.58	Due To Sparking On Cvt jumper Ready For Charging.
400KV	Bhusawal- Aurangabad	30-Apr-14	18.32	2-May-14	07.45	Over Voltage.
400KV	Kolhapur - Mapusa - I	30-Apr-14	16.45	1-May-14	08.28	Over Voltage.
400KV	Lonikand - Jejuri	30-Apr-14	00.26	1-May-14	04.17	CVT Replacement.
400KV	400/220 KV 500 MVA ICT-I @ Jejuri	30-Apr-14	00.17	1-May-14	03.45	Hot spot
400KV	Dhule-Sar'Sarovar - I	1-May-14	02.43	1-May-14	09.04	Over Voltage.
400KV	Kolhapur - Mapusa - II	1-May-14	16.39	2-May-14	09.10	Over Voltage
400KV	Dhule-Sar'Sarovar - I	1-May-14	18.14	2-May-14	08.47	Over Voltage
400KV	Dabhol-Nagothane - II	1-May-14	17.05	3-May-14	11.02	Over Voltage
400KV	Kalwa - Talegaon (PGCIL)	1-May-14	14.35	1-May-14	20.52	Testing work
400KV	Karad - Kolhapur - I	1-May-14	16.34	2-May-14	07.28	Over Voltage.
400KV	Karad-Jaigad I	1-May-14	17.08	2-May-14	07.56	Over Voltage.
400KV	Karad-Kolhapur-II	1-May-14	17.59	2-May-14	07.36	Over Voltage.
400KV	Kolhapur - Mapusa - I	2-May-14	17.10	3-May-14	7.21	Over Voltage
400KV	Karad - Kolhapur - II	2-May-14	16.46	3-May-14	7.09	Over Voltage
400KV	Karad-Jaigad I	2-May-14	16.48	3-May-14	7.11	Over Voltage
400KV	Bhusawal- Aurangabad	2-May-14	17.28	3-May-14	7.16	Over Voltage
400KV	400/220KV 315 MVA ICT-I @ Padgha	2-May-14	10.47	2-May-14	18.32	Checking of SF6 Gas
400KV	Jejuri-403 CB	3-May-14	10.45	3-May-14	15.45	maint.work
400KV	400/220 KV,500MVA ICT - III at Parly	3-May-14	13.40	4-May-14	10.03	R phase jumper broken connected to bus
400KV	Karad - Kolhapur - II	3-May-14	16.09	4-May-14	07.15	over voltage
400KV	Karad-Jaigad I	3-May-14	16.32	3-May-14	19.05	over voltage
400KV	Bhusawal- Aurangabad	3-May-14	17.15	4-May-14	08.48	over voltage
400KV	Lonikand - Jejuri	3-May-14	15.50	3-May-14	18.37	B phase cvt jumper heavy sparking observed,heavy rain & wind at loni
400KV	Kolhapur - Mapusa - II	3-May-14	16.41	4-May-14	09.55	over voltage
400KV	Dhule - Babhaleshwar - I	3-May-14	9.53	3-May-14	9.53	A/R oprated z-1,b-ph to n,ls/n distance 144km at bblr end
400KV	Karad-Jaigad II	3-May-14	17.15	4-May-14	07.10	distance protection
400KV	400/220 KV 600 MVA ICT- II @ Kalwa	4-May-14	06.34	4-May-14	15.55	To Attend Hot Spot.
400KV	Karad-Kolhapur-II	4-May-14	16.04		Continued.	Over Voltage.
400KV	Karad-Jaigad I	4-May-14	16.06		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	4-May-14	17.45		Continued.	Over Voltage.
400KV	Bus Reactor @ Kolhapur	4-May-14	10.27	4-May-14	16.38	Hand Tripped.
400KV	Bus reactor @ Dhule	4-May-14	10.29		Continued.	Hand Tripped.
400KV	Bus Reactor @ 765KV Akola	4-May-14	10.30	4-May-14	17.21	Hand Tripped.
400KV	Kolhapur - Mapusa - I	4-May-14	16.41		Continued.	Over Voltage.
220KV	Aurangabad-Jalna-I	25-Apr-14	18.25	28-Apr-14	01.14	In View of Outage on 400KV Akola-A'bad - I & II.
220KV	Aurangabad-Jalna-II	25-Apr-14	18.25	28-Apr-14	01.14	In View of Outage on 400KV Akola-A'bad - I & II.
220KV	Usmanabad-Parli	27-Apr-14	22.33	28-Apr-14	00.55	R Phase CT Oil Leakage.
220KV	Chikhali - Jalna - I	28-Apr-14	01.14		Continued.	To Control O/L of 220KV Paras-ChiKhli
220KV	Chikhali - Jalna - II	28-Apr-14	01.14		Continued.	To control O/L of 220KV Paras-Chikhli

220KV	Mudshingi-Wathar	28-Apr-14	09.05	28-Apr-14	18.17	Insulator cleaning work
220KV	Kalyani-Bhigwan	28-Apr-14	10.30	28-Apr-14	18.30	Stringing of 765KV Solapur pune PG Line
220KV	Main Bus - II Talangde	28-Apr-14	11.05	28-Apr-14	19.17	Hot Spot
220KV	Karad-Vita-II	28-Apr-14	15.16	28-Apr-14	16.10	Distance Protection
220KV	Parli-Usmanabad	29-Apr-14	10.05	29-Apr-14	15.03	CT replacement
220KV	Halkarni - Momewadi -I	29-Apr-14	09.36	29-Apr-14	18.38	Fixing of Vibration Dampers
220KV	Akola - Badnera - I	29-Apr-14	08.00	29-Apr-14	21.20	Stringing work of Akola-Indiabulls D/C Line
220KV	Akola - Badnera - II	29-Apr-14	08.00	29-Apr-14	20.25	Stringing work of Akola-Indiabulls D/C Line
220KV	Kanhan - Bhandara - II	29-Apr-14	08.10	29-Apr-14	15.33	Conversion of SSN to DSN
220KV	Halkarni-Mahalaxmi	30-Apr-14	08.46	30-Apr-14	17.38	For Fixing of Vibration Dampers.
220KV	Lamboti - Pandharpur	30-Apr-14	08.38	30-Apr-14	19.32	Strinning Of 765kv PGCIL Line Over crossing.
220KV	Vita - Lamboti	30-Apr-14	09.03	30-Apr-14	21.01	Strinning Of 765kv PGCIL Line Over Crossing.
220KV	P'pur-Malinagar	30-Apr-14	08.40	30-Apr-14	21.15	Strinning Of 765kv PGCIL Line Over Crossing.
220KV	New Parly - Beed - I	30-Apr-14	11.03	30-Apr-14	13.45	Replacement Of R Phase.
220KV	Koradi-Butibori	30-Apr-14	10.35		Continued.	O/H Of C.B.
220KV	220/132KV 100 MVA ICT II at Pusad	30-Apr-14	07.03	30-Apr-14	17.23	Tan Delta & CRM Measurement and Bay Main Work.
220KV	Nerul -Sonkhar	1-May-14	07.05	1-May-14	09.02	Hot Spot
220KV	Vita - Lamboti	1-May-14	18.19	1-May-14	19.42	Maintenance Work.
220KV	Wardha - Yawatmal	1-May-14	08.04	1-May-14	19.15	Stringing work of 765KV Raipur wardha Ckt By Powergrid
220KV	Pusad - Bhugaon	1-May-14	08.04	1-May-14	19.15	Stringing work of 765KV Raipur wardha Ckt By Powergrid
220KV	Halkarni-Mahalaxmi	1-May-14	08.50	1-May-14	18.52	For Fixing Of Vibration Dampers.
220KV	Uran - JNPT	1-May-14	06.10	2-May-14	16.40	Reorientation Of Uran-JNPT to ERECT one Tower.
220KV	ONGC-JNPT	1-May-14	06.00	2-May-14	16.40	Reorientation of Uran-ONGC-JNPT to Erect one tower.
220KV	Pedambe - Pophali - II	1-May-14	06.50	1-May-14	14.35	CT Replacement.
220KV	Lamboti - Pandharpur	1-May-14	14.16	1-May-14	14.32	Distance Protection.
220KV	Nagothane - SPCL	1-May-14	21.12	1-May-14	23.55	Distance Protection(Charged bypassing SPCL)
220KV	Bale-Usmanabad	1-May-14	07.58	2-May-14	19.53	Outage on Bhugaon-Pusad & Wardha-Yawatmal.
220KV	Bale - Tuljapur	1-May-14	07.58	2-May-14	19.33	Outage on Bhugaon-Pusad & Wardha-Yawatmal.
220KV	Girawli-Parli-III	1-May-14	21.25	1-May-14	21.50	Distance Protection
220KV	Girwali - Parly - IV	1-May-14	21.25	2-May-14	04.29	Distance Protection
220KV	Mahalakshmi - Amona	2-May-14	11.08	2-May-14	19.16	Fixing of Vibration Damper
220KV	Bhugaon-Pusad	2-May-14	19.21	2-May-14	19.44	Distance Protection
220KV	Main Bus Section- I @ Pedambe	2-May-14	08.30	2-May-14	09.25	Y Phase CT Oil Leakage
220KV	Temghar-Colourchem	2-May-14	08.57	2-May-14	10.05	R Phase CT Leakage
220KV	Nivali-Pawas	2-May-14	09.32	2-May-14	17.41	Insulator Cleaning
220KV	Padgha-Jambhul-I	2-May-14	09.28	2-May-14	19.45	Q.M.Work
220KV	220/132 KV 150 MVA T/F @ Boiser	2-May-14	09.05	2-May-14	11.45	Oil Leakage
220KV	Nerul-Kharghar	3-May-14	6.10	3-May-14	9.12	Attending hot spot on y phase line
220KV	Nivali-Pawas	3-May-14	9.24	3-May-14	17.08	Insulator cleaning work
220KV	Miraj -Ichalkarajni	3-May-14	9.12	3-May-14	12.42	hot spot on r ph at wave trap bottom side
220KV	Trombay Sonkhar	3-May-14	11.45	3-May-14	15.34	for jumper replacement work
220KV	Chinchwad-Parvati	3-May-14	15.41	3-May-14	16.40	distance protection
220KV	Karad - Sadawaghapur - II	3-May-14	16.46		Continued.	distance protection
220KV	Karad-Wathar	3-May-14	17.18	3-May-14	17.57	distance protection
220KV	Karad - Dasgaon	3-May-14	17.25	3-May-14	17.52	distance protection
220KV	Apta-Kalwa	4-May-14	06.30	4-May-14	12.30	For Stringing of OPGW Cable @ L.N.-681B-684B.
220KV	Kalwa I-Taloja	4-May-14	06.33	4-May-14	12.28	For Stringing of OPGW Cable @ L.N.-681B-684B.
220KV	Kalwa- salsett 6	4-May-14	08.35	4-May-14	12.45	P.M.Work.
220KV	Boiser PGCIL-Boiser II	4-May-14	06.46	4-May-14	09.30	Red Hot Spot.
132KV	Bhusawal - Nimbhora	28-Apr-14	13.27	28-Apr-14	13.56	Distance Protection
132KV	Kawlewada-Madgi-I	30-Apr-14	07.21	30-Apr-14	17.55	Overhead crossing of 765kv.
132KV	Kawlewada-Madgi II	30-Apr-14	07.22	30-Apr-14	17.56	Overhead Crossing Of 765kv.
132KV	Pathardi - Raimoha	30-Apr-14	11.57	30-Apr-14	13.30	Quarterly Maintainance work.
132KV	Durgowada - Daryapur	30-Apr-14	09.03	30-Apr-14	16.57	Stringing Bet.
132KV	Pathardi - Raimoha	30-Apr-14	16.43	30-Apr-14	17.08	Distance protection Operated Y B Phase.
132KV	Buldana-Motala	30-Apr-14	07.22	30-Apr-14	07.37	Distance Protection operated Zone 1 y phase.
132KV	Kallamb - Bhoom	30-Apr-14	23.45	1-May-14	00.02	Distance Protection
132KV	Ambazari-Pardi	1-May-14	09.57	1-May-14	12.49	Distance Protection
132KV	Pusad - Gunj	2-May-14	19.22	2-May-14	19.42	Load Trimming operated
132KV	Jalna - Rajur 1	4-May-14	06.27	4-May-14	06.34	Over Current,Earthfault.
132KV	Kawlewada-Madgi-I	4-May-14	19.41	4-May-14	20.35	Distance Protection Operated Z-2.
132KV	Bhokardan-Rajur	4-May-14	05.57	4-May-14	19.35	Distance Protection Operated Z-I.R-E Fault.
132KV	Girwali - Gangakhed	4-May-14	20.18	4-May-14	20.35	Distance Protection Operated Z-I.
110KV	Kalwa-Kalyan	29-Apr-14	07.32	29-Apr-14	08.09	Over Current
110KV	Kalwa-Kalyan	29-Apr-14	17.22	29-Apr-14	17.40	Distance Protection
110KV	Kalwa-Kalyan-Salsette - I	29-Apr-14	07.32	29-Apr-14	08.05	Over Current