

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 30/May/2022 to 05/Jun/2022

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
30-05-2022	12 Hrs	7162	1692	136	8990	8659	671	5295	1350	-2216	22326	0	22326	860	435	26260	26260	50.01
31-05-2022	12 Hrs	6954	1978	123	9054	9012	492	5005	1305	-2231	22223	0	22223	828	418	26114	26114	49.98
01-06-2022	12 Hrs	6957	566	124	7646	8561	546	5433	1255	-2290	20719	0	20719	760	446	24647	24647	50.01
02-06-2022	12 Hrs	6887	584	125	7596	8225	837	5899	1291	-2180	21230	0	21230	844	460	25152	25152	50.04
03-06-2022	12 Hrs	6532	944	125	7601	7945	1007	4907	1401	-1711	20722	0	20722	1257	497	24615	24615	49.89
04-06-2022	12 Hrs	7339	345	123	7807	8105	644	5563	1312	-2025	20989	0	20989	781	454	24666	24666	49.99
05-06-2022	12 Hrs	7347	392	134	7874	7942	565	5645	1347	-1491	21483	0	21483	662	485	24520	24520	49.93
Maximum		7347	1978	136	9054	9012	1007	5899	1401	-1491	22326	0	22326	1257	497	26260	26260	50.04
Minimum		6532	345	123	7596	7942	492	4907	1255	-2290	20719	0	20719	662	418	24520	24520	49.89
Average		7025	929	127	8081	8350	680	5392	1323	-2021	21385	0	21385	856	456	25139	25139	49.98

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
30-05-2022	15 Hrs	7212	1326	136	8674	9167	1040	5294	1186	-2179	22767	0	22767	880	468	26708	26708	49.91
31-05-2022	15 Hrs	6894	1678	133	8706	9666	596	5027	1045	-2123	22510	0	22510	916	464	26420	26420	49.96
01-06-2022	15 Hrs	6646	1012	134	7792	9112	495	5527	1154	-2136	21508	0	21508	833	478	25390	25390	49.94
02-06-2022	16 Hrs	7178	786	135	8099	8054	700	6228	870	-2145	21380	0	21380	897	465	25313	25313	49.79
03-06-2022	15 Hrs	7262	1064	124	8450	8099	1082	5411	1036	-1943	21711	0	21711	1008	495	25581	25581	49.94
04-06-2022	16 Hrs	7485	1383	124	8992	8036	707	5754	905	-1979	21986	0	21986	883	457	25734	25734	49.95
05-06-2022	15 Hrs	7243	384	124	7750	8522	680	5794	1075	-1563	21878	0	21878	679	490	24990	24990	49.97
Maximum		7485	1678	136	8992	9666	1082	6228	1186	-1563	22767	0	22767	1008	495	26708	26708	49.97
Minimum		6646	384	124	7750	8036	495	5027	870	-2179	21380	0	21380	679	457	24990	24990	49.79
Average		7131	1090	130	8352	8665	757	5576	1039	-2010	21963	0	21963	871	474	25734	25734	49.92

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
30-05-2022	20 Hrs	7357	1068	137	8562	6325	1923	5569	0	-1536	20420	0	20420	1022	478	23880	23880	49.88
31-05-2022	20 Hrs	6909	1034	81	8024	6397	2292	4731	0	-1556	19472	0	19472	1088	478	23010	23010	50.02
01-06-2022	20 Hrs	6668	990	134	7792	6848	1175	6108	0	-1515	19969	0	19969	1087	500	23510	23510	49.91
02-06-2022	20 Hrs	7271	396	136	7803	6234	1856	6159	0	-1467	20148	0	20148	1138	497	23687	23687	49.96
03-06-2022	20 Hrs	7442	762	137	8341	6146	1712	6084	0	-1457	20387	0	20387	1151	493	23927	23927	49.94
04-06-2022	21 Hrs	7564	1517	128	9209	6248	849	6094	0	-1402	20565	0	20565	1087	494	23981	23981	49.91
05-06-2022	21 Hrs	7261	386	125	7772	5511	1437	5987	0	-1180	19151	0	19151	1064	496	22268	22268	50.01
Maximum		7564	1517	137	9209	6848	2292	6159	0	-1180	20565	0	20565	1151	500	23981	23981	50.02
Minimum		6668	386	81	7772	5511	849	4731	0	-1556	19151	0	19151	1022	478	22268	22268	49.88
Average		7210	879	125	8215	6244	1606	5819	0	-1445	20016	0	20016	1091	491	23466	23466	49.95

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
30-05-2022	8 Hrs	7354	900	126	8380	6961	1126	5234	346	-1383	20264	0	20264	662	496	23204	23204	50.02
31-05-2022	23 Hrs	7158	1900	127	9184	6365	939	5338	0	-1510	19906	0	19906	1023	497	23346	23346	49.94
01-06-2022	5 Hrs	7091	312	128	7530	6963	1321	5197	0	-1307	19373	0	19373	650	501	22162	22162	50.01
02-06-2022	8 Hrs	6552	329	129	7010	7216	1410	5727	291	-1667	19616	0	19616	446	455	22555	22555	50.02
03-06-2022	5 Hrs	7231	464	137	7832	6442	1568	5884	0	-1173	20212	0	20212	699	501	22926	22926	49.90
04-06-2022	4 Hrs	7361	387	126	7874	6458	1411	6046	0	-1137	20356	0	20356	945	431	23165	23165	49.95
05-06-2022	23 Hrs	7397	624	126	8148	6217	867	5964	0	-1273	19530	0	19530	1120	493	22809	22809	49.97
Maximum		7397	1900	137	9184	7216	1568	6046	346	-1137	20356	0	20356	1120	501	23346	23346	50.02
Minimum		6552	312	126	7010	6217	867	5197	0	-1667	19373	0	19373	446	431	22162	22162	49.90
Average		7163	702	128	7994	6660	1235	5627	91	-1350	19894	0	19894	792	482	22881	22881	49.97

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
30-05-2022	175.565	35.488	3.164	214.217	0.096	170.173	171.494	33.101	127.209	10.516	20.590	11.587	-40.261	505.594	72.438	587.393
31-05-2022	165.727	40.225	2.837	208.789	0.252	186.341	186.666	31.238	118.651	9.509	19.439	11.360	-42.301	502.821	73.100	585.327
01-06-2022	163.678	14.221	3.133	181.032	0.261	183.786	187.308	23.899	132.150	9.313	20.062	11.580	-41.133	479.444	72.775	561.822
02-06-2022	166.205	9.855	3.137	179.197	0.163	174.199	177.162	32.642	142.818	9.885	20.426	11.446	-41.054	488.104	72.926	570.613
03-06-2022	171.294	17.355	3.154	191.803	0.384	164.900	169.001	33.443	135.514	9.891	25.920	11.806	-34.379	491.504	72.106	573.278
04-06-2022	177.967	18.258	3.152	199.377	0.529	170.510	173.636	24.571	142.412	10.175	21.658	10.783	-37.670	499.937	70.111	579.486
05-06-2022	173.519	18.359	3.149	195.027	0.397	165.139	168.925	24.149	138.296	10.097	20.406	11.490	-31.469	492.304	63.365	564.604
Maximum	177.967	40.225	3.164	214.217	0.529	186.341	187.308	177.967	142.818	10.516	25.920	11.806	-31.469	505.594	73.100	587.393
Minimum	163.678	9.855	2.837	179.197	0.096	164.900	168.925	163.678	118.651	9.313	19.439	10.783	-42.301	479.444	63.365	561.822
Average	170.565	21.966	3.104	195.635	0.297	173.578	176.313	170.565	133.864	9.912	21.214	11.436	-38.324	494.244	70.974	574.646

Details of Koyna Water Consumption (in TMC)			
Date	For the Day	For the Month	Balance
30-05-2022	0.000	0.000	0.000
31-05-2022	0.000	0.000	0.000
01-06-2022	0.159	0.159	67.341
02-06-2022	0.101	0.260	67.240
03-06-2022	0.255	0.515	66.985
04-06-2022	0.278	0.793	66.707
05-06-2022	0.272	1.065	66.435

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 30/May/2022 to 05/Jun/2022

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+)/	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
30-05-2022	MONDAY	82.757	7057	88.737	3697	171.494	7146	170.173	7091	-1.321	-55
31-05-2022	TUESDAY	93.158	7684	93.508	3896	186.666	7778	186.341	7764	-0.325	-14
01-06-2022	WEDNESDAY	99.718	7717	87.590	3650	187.308	7804	183.786	7658	-3.522	-147
02-06-2022	THURSDAY	85.153	7290	92.009	3834	177.162	7382	174.199	7258	-2.963	-123
03-06-2022	FRIDAY	74.949	6948	94.052	3919	169.001	7042	164.900	6871	-4.101	-171
04-06-2022	SATURDAY	85.045	7146	88.591	3691	173.636	7235	170.510	7105	-3.126	-130
05-06-2022	SUNDAY	86.427	6956	82.498	3437	168.925	7039	165.139	6881	-3.786	-158
Total		607.208		626.984		1234.192		1215.048		-19.144	

Generator Unit Outages/Trippings from 30.05.2022 to 05.06.2022						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
Khaparkheda Unit 4	05-06-2022	00:07		Continued.	Annual Overhaul	PLANNED
SWPGPL U-1	16-02-2016	17.09		Continued.	No PPA.	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
IEPL Unit 1	28-08-2018	21.26		Continued.	No PPA	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Uran Unit 7	25-05-2020	12.51		Continued.	Turbine Blade Failure	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
JSW (J) U1	16-03-2022	23:16		Continued.	Turbine Vibration	FORCED
Ghatghar Unit-1	20-04-2022	00:35		Continued.	Stator Earth Fault	FORCED
RPL(AMT) U-1	11-05-2022	21:00	30-05-2022	00:00	Coal Shortage	FORCED
Uran Unit 8	13-05-2022	01:34	06-06-2022	17:07	excitation fault (unit out due to gas shortage)	FORCED
Uran Unit B0	13-05-2022	01:34	11-06-2022	17:36	excitation fault (unit out due to gas shortage)	FORCED
RPL(AMT) U-3	24-05-2022	02:23	31-05-2022	05:45	Flame Failure	FORCED
Adani U-3	27-05-2022	16:13	01-06-2022	03:11	APH-A HOT PA BELOW LEAKAGE.	FORCED
Nasik Unit 3	29-05-2022	19:00	31-05-2022	07:40	Boiler Tube Leakage	FORCED
Trombay 7A	29-05-2022	05:26	02-06-2022	15:00	Gas shortage	FORCED
Trombay 7B	29-05-2022	04:57	05-06-2022	22:22	Gas shortage	FORCED
Uran Unit 6	29-05-2022	00:32	06-06-2022	20:44	Gas shortage	FORCED
RPL(AMT) U-5	30-05-2022	23:20	01-06-2022	16:30	CW LINE BELWO LEKAGE.	FORCED
Bhusawal Unit 5	30-05-2022	23:55	02-06-2022	08:19	Boiler Tube Leakage	FORCED
RPL(AMT) U-4	31-05-2022	01:15	13-06-2022	17:41	Ash Conveyer problem.(Coal shortage From	FORCED
Nasik Unit 4	31-05-2022	15:00	04-06-2022	12:09	ID Fan Problem	FORCED
Uran Unit 5	31-05-2022	16:59	31-05-2022	17:43	JERK IN GAS PRESSURE	FORCED
Uran Unit A0	31-05-2022	16:59	31-05-2022	19:49	JERK IN GAS PRESSURE	FORCED
Chandrapur Unit 3	01-06-2022	13:54	02-06-2022	11:38	Withdrawn	FORCED
Paras Unit 4	01-06-2022	14:32	02-06-2022	05:20	CLINKER FORMATION. Synchronised now	FORCED
Nasik Unit 5	02-06-2022	03:30	02-06-2022	08:26	Loss of fuel	FORCED
Trombay 7A	03-06-2022	03:45	03-06-2022	06:09	Gas shortage	FORCED
RPL(AMT) U-3	04-06-2022	12:00	04-06-2022	15:21	CEP Recirculation valve leakage.	FORCED
Trombay 7A	04-06-2022	03:15	05-06-2022	17:48	Gas shortage	FORCED
SWPGPL U-3	04-06-2022	01:00	06-06-2022	02:36	Boiler Bottom Ash System problem	FORCED
AEML Unit 2	04-06-2022	00:02	04-06-2022	02:38	Generator Elect. Fault	FORCED
Khaparkheda Unit 3	05-06-2022	01:07	05-06-2022	03:57	Furnace Pressure High	FORCED

Transmission Line Outages/Trippings from 30.05.2022 to 05.06.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KORADI III - AKOLA II Ckt - 1	02-06-2022	17:32	02-06-2022	19:47	In tower No. 446 (C+0) the Clevis Eye is open	EO	765 KV
CHANDRAPUR - PADGHE HVDC POLE	05-06-2022	03:21	05-06-2022	06:46	Premonsoon Work	EO	500 KV
400/220/33 KV 315 MVA ICT - 1 @ D	28-05-2022	09:54	30-05-2022	20:25	Work of Overhauling of OLTC of 315 MVA I	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ LO	29-05-2022	17:25	30-05-2022	02:23	For pre-monsoon maintenance activities ar	PO	400 KV
LAMBOTI - SOLAPUR (PG)	30-05-2022	13:48	30-05-2022	19:20	Powergrid Annual Maintenance work	HT	400 KV
400/220/33 KV 315MVA ICT - 1 @ BA	30-05-2022	19:34	30-05-2022	23:52	Attending Red Hot Spot on Y phase LV Bush	EO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT	30-05-2022	15:15	08-06-2022	10:09	H/T for Load Management i.e. to avoid the	HT	400 KV
CHANDRAPUR - KHAPERKHEDA	31-05-2022	06:33	31-05-2022	19:20	Replacement of 04 no.s of Faulty disc insul	EO	400 KV
400/220/33KV ICT - 167 MVA SPARE	31-05-2022	10:55	31-05-2022	16:15	Routine Testing & Premonsoon activities	PO	400 KV
DHULE - - BABLESHWAR - I	31-05-2022	09:25	31-05-2022	18:15	LBB relay testing work; Bay maintenance w	PO	400 KV
125MVAr BUS REACTOR @ WARORA	01-06-2022	08:40	01-06-2022	18:44	Premonsoon Maintenance work. Routine n	PO	400 KV
400/220 KV 3X200 MVA ICT - 2 @ KA	01-06-2022	05:07	01-06-2022	14:33	Premonsoon Maintenance work & oil top u	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ CH	01-06-2022	08:59	01-06-2022	20:19	1) Premonsoon maintenance work. 2) Measurement of bushing tandelta 3) Maintenance and alignments of PG-1 and PG-2 Isolators.	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ D	01-06-2022	17:04	01-06-2022	19:38	Annual Maint & testing work	PO	400 KV
JAIGAD - KARAD CKT - 1	01-06-2022	09:01	01-06-2022	20:25	Coldline washing work	PO	400 KV
NEW KOYNA - DABHOL CKT - 1	01-06-2022	08:46	01-06-2022	17:58	Cold washing work, Diagnostic testing & R	PO	400 KV
BABHALESHWAR - PADGHE CKT- 1	02-06-2022	01:56	02-06-2022	06:51	A] HVDC TL O&M Sub-Division, Junnar:- 1. For Replacement of Flashover Y-phase Insulator String at Location No. 863. 2. Cleaning of dust contaminated insulator string from location no.862 to 865 in Naneghat Area.	EO	400 KV
NAGOTHANE - DABHOL CKT - 2	02-06-2022	10:04	03-06-2022	18:54	Lightning Arrestor replacement	PO	400 KV
400/220KV 315MVA ICT - 3 @ CHAKA	02-06-2022	12:24	02-06-2022	19:59	For Overhauling of Bus C 89 C Rph, Y ph, B	PO	400 KV
JAIGAD - KARAD CKT - 2	02-06-2022	08:58	02-06-2022	20:32	Coldline washing work	PO	400 KV
KALWA - TALEGAON (PG)	03-06-2022	04:19	03-06-2022	14:23	DP	T	400 KV
KARAD - LONIKAND I	03-06-2022	22:54	04-06-2022	03:16	H/T for load management	HT	400 KV
400/220/33 KV 315 MVA ICT - 2 @ CH	03-06-2022	15:04	03-06-2022	21:12	1) Premonsoon maintenance work. 2) Measurement of bushing tandelta 3) Maintenance and alignments of PG-1 and PG-2 Isolators.	PO	400 KV
BABHALESHWAR - RPL(NSK) CKT - 1	03-06-2022	09:14	04-06-2022	16:34	Due to Twin Monopole Cross-Arm jointing	PO	400 KV
BABHALESHWAR - RPL(NSK) CKT - 2	03-06-2022	09:15	04-06-2022	16:40	Due to Twin Monopole Cross-Arm jointing	PO	400 KV
KHARGHAR - TALEGAON (PG)	03-06-2022	23:05	04-06-2022	03:16	Emergency outage for disc replacement	HT	400 KV
KHARGHAR - TALEGAON (PG)	03-06-2022	05:09	03-06-2022	07:55	DP	T	400 KV
NAGOTHANE - DABHOL CKT - 2	04-06-2022	12:57	04-06-2022	20:27	Lightning Arrestor replacement	PO	400 KV
400KV 125 MVAR BUS REACTOR@40	04-06-2022	08:43	04-06-2022	19:55	FOR MAINTENANCE OF PG ISOLATOR OF 4	PO	400 KV
AKOLA - KHADKA (BHUSAWAL)	04-06-2022	06:10	04-06-2022	18:24	String replacement work will be carried out on 400 kV Akola- Khadka (Bhusawal) line. Also work of tightening of Spacers cum Vibration Dampers, providing of corona ring & arcing horn will be carried out.	PO	400 KV
KHARGHAR - TALEGAON (PG)	04-06-2022	23:05	04-06-2022	03:16	Replacement of Flash overed insulator strin	EO	400 KV
KHARGHAR - TALEGAON (PG)	04-06-2022	22:26	05-06-2022	02:21	Cold washing of insulator string rom loc no	EO	400 KV
KARAD - LONIKAND I	05-06-2022	22:56	06-06-2022	06:56	For Load Management	HT	400 KV
PADGHE - KALWA CKT - 2	05-06-2022	19:57	05-06-2022	22:16	Hot Spot Attending work at loc. no. 1012 Y	EO	400 KV
400KV KORADI-BHILAI (Koradi end)	05-06-2022	08:51	05-06-2022	19:40	work at PG end	HT	400 KV
LONIKAND I -JEJURI	05-06-2022	17:41	05-06-2022	21:17	Replacement of R phase L.A due to high LC	EO	400 KV
220/132KV 100MVA ICT 1 @ SATARA	25-05-2022	10:38	30-05-2022	14:21	Transformer painting work	PO	220 KV
KANDALGAON - ONGC PANVEL	30-05-2022	12:30	30-05-2022	14:09	DP	T	220 KV
PADGHE - JAMBHUL 2	30-05-2022	11:17	30-05-2022	21:28	For checking SF6 Gas leakage from mechan	PO	220 KV
PANDHARPUR - MALINAGAR	30-05-2022	16:20	30-05-2022	21:04	Outage is required for For changing / repla	PO	220 KV
220/100 KV 100 MVA ICT 1 @ TAMB	30-05-2022	09:32	30-05-2022	13:58	Premonsoon maintenance work and CT sed	PO	220 KV
220/100 KV 100 MVA ICT 2 @ TAMB	30-05-2022	14:27	30-05-2022	17:55	Premonsoon maintenance work and CT sed	PO	220 KV
220/110 KV 100 MVA PTR 1 @ BIDRI	30-05-2022	09:25	30-05-2022	18:20	For Tan delta testing & quaterly mainten	PO	220 KV

Transmission Line Outages/Trippings from 30.05.2022 to 05.06.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132KV 100MVA PTR 1 @ KHARE	30-05-2022	08:23	30-05-2022	14:51	For quarterly maintenance work of GEC ICT	PO	220 KV
220/132KV 100MVA PTR 2 @ KHARE	30-05-2022	14:59	30-05-2022	17:40	For quarterly maintenance work of Vijai ICT	PO	220 KV
220/22KV 50 MVA PTR - 3 @ AKP	30-05-2022	17:20	30-05-2022	23:19	TRIPPED DUE TO DIFFERENTIAL RELAY OPE	T	220 KV
220/33KV 50MVA PTR 3 @ WATHAR	30-05-2022	09:50	30-05-2022	18:00	Premonsoon Maintainance works. Diagnost	PO	220 KV
220/33kv 125 MVA TF 5 @ AAREY	30-05-2022	09:19	30-05-2022	17:49	Annual and Premonsoon maintenance of T	PO	220 KV
220/33kv 125 MVA TF 5 @ VERSOVA	30-05-2022	19:25	31-05-2022	07:44	Tripped on differential protection	T	220 KV
TBC @ AAREY	30-05-2022	09:37	30-05-2022	18:19	For safety purpose while working on 125 M	PO	220 KV
220/33 KV 50 MVA PTR NO 3 @ ALEP	31-05-2022	11:10	31-05-2022	14:49	For Diagnostic testing work & general mai	PO	220 KV
APTA - BOMBAY DYEING	31-05-2022	06:04	31-05-2022	07:01	CT secondary rusted box replacement work	PO	220 KV
APTA - KALWA	31-05-2022	04:11	31-05-2022	05:59	CT secondary rusted box replacement work	PO	220 KV
APTA - TAMBATI	31-05-2022	07:09	31-05-2022	10:03	CT secondary rusted box replacement work	PO	220 KV
KALWA - COLOURCHEM	31-05-2022	06:06	31-05-2022	08:26	Y ph LA replacement work due to high LCM	EO	220 KV
MAGAR PATTI CITY- SERUM	31-05-2022	13:07	31-05-2022	17:27	Replacement of non priority string, declare	EO	220 KV
NAGOTHANE - ACCIL	31-05-2022	11:10	31-05-2022	19:38	Outage tree cutting work at various locatio	PO	220 KV
PANDHARPUR - MALINAGAR	31-05-2022	16:18	31-05-2022	21:14	Outage is required for For changing / repla	PO	220 KV
132 KV KANHAN (220 KV) - PENCH CK	31-05-2022	12:21	31-05-2022	15:55	Tripped on Distance Protection.	T	220 KV
220/100 KV 200 MVA ICT 4 @ KALWA	31-05-2022	10:35	01-06-2022	14:33	220/100kv, 200 MVA ICT 4, Demonstratio	PO	220 KV
220/22 KV 50 MVA PTR 1 @ MAHAD	31-05-2022	09:44	31-05-2022	10:23	Pre monsoon maintenance work (Plastic w	PO	220 KV
220/22 KV 50 MVA PTR 3 @ MAHAD	31-05-2022	11:20	31-05-2022	12:09	Premonsoon maintenance work (Plastic wr	PO	220 KV
220/33 KV, 50MVA, PTR NO 2 @ ALE	31-05-2022	14:57	31-05-2022	20:03	For Diagnostic testing work & general mai	PO	220 KV
BORIVALI - BOISAR II LINE	31-05-2022	11:27	31-05-2022	18:04	Due to LTS operated on 220 KV Boisar Bois	T	220 KV
TBC @ AAREY	31-05-2022	10:07	31-05-2022	17:00	ANNUAL MAINTENANCE OF TBC	PO	220 KV
CHALISGAON - BABHALESHWAR	01-06-2022	07:41	01-06-2022	17:19	Replacement of damaged earthwire at T.L	PO	220 KV
KALWA - COLOURCHEM	01-06-2022	22:09	02-06-2022	06:00	To carry out retrofitting of Relays at 220KV	PO	220 KV
LOTEPARSHURAM- DASTURI LINE	01-06-2022	04:37	01-06-2022	14:40	TRIPPED ON DP and Rains reported with he	T	220 KV
MALINAGAR - TEMBHURNI	01-06-2022	14:01	01-06-2022	16:50	Outage is required For removing Bunching	PO	220 KV
PADGHE - WADA	01-06-2022	06:27	01-06-2022	08:34	For attending Hot spot at Loc no.85 (70 deg	EO	220 KV
TEMBHURNI - JEUR	01-06-2022	17:21	01-06-2022	21:10	Outage is required For Bunching work on 2	PO	220 KV
220/100 KV 200 MVA ICT 1	01-06-2022	09:42	01-06-2022	14:40	Pre-monsoon Activities of 100MVA, 220/10	PO	220 KV
220/132KV 100MVA PTR 2 @ KHARE	01-06-2022	08:10	01-06-2022	16:19	For replacement of MOG.	PO	220 KV
BUS SECTION BAY @ VSNL	01-06-2022	09:43	01-06-2022	14:26	Replacement of new 220kv Rph CT	PO	220 KV
BUS SECTION BREAKER-3 @ TROMBA	01-06-2022	21:51	01-06-2022	22:04	For raising SF6 gas pressure, breaker open	EO	220 KV
DAHANU - GHODBUNDER CKT - 1	01-06-2022	16:40	01-06-2022	18:56	Attending Hotspot (Temp. @ 62 deg) on R-	EO	220 KV
VITTAL SUGAR CO GEN (VSSK) -KARKA	01-06-2022	13:45	01-06-2022	20:50	Outage is required For removing Bunching	PO	220 KV
APTA - TAMBATI	02-06-2022	05:56	02-06-2022	09:25	CT secondary rusted box repairing work by	PO	220 KV
BAPGAON - KALWA	02-06-2022	09:14	02-06-2022	16:27	Replacement of PID faulty insulator replace	PO	220 KV
GHODBUNDER - GORAI	02-06-2022	08:20	02-06-2022	12:49	To attend Hot spot observed on Yph LA Cor	EO	220 KV
TALOJA II - OCIL 1	02-06-2022	07:56	02-06-2022	19:40	Isolator maintenance & Cleaning of switchg	PO	220 KV
220/100 KV 200 MVA ICT 3 @ TROM	02-06-2022	12:13	02-06-2022	17:17	Premonsoon maintenance activity.	PO	220 KV
220/132 KV 100 MVA ICT - 1 @KALW	02-06-2022	11:55	02-06-2022	14:14	For OLTC work by NOUS technologist	PO	220 KV
220/22 KV 50 MVA PTR 1 @ LONIKAN	02-06-2022	09:26	02-06-2022	16:23	Pre-mansoon activities, Half yearly DT and	PO	220 KV
220/33-22 KV 100 MVA PTR 2	02-06-2022	10:47	02-06-2022	19:08	For diagnostic and relay testing of T/F No. 2	PO	220 KV
220/33kv 125 MVA TF 1 @ BORIVALI	02-06-2022	08:58	02-06-2022	18:04	ANNUAL & PREMONSOON MAINTENANCE	PO	220 KV
KHADKI- CENTURY ENKA	02-06-2022	10:17	02-06-2022	17:29	Due to high Tan delta values of CT replacer	PO	220 KV
LAMBOTI - KARKAMB	02-06-2022	16:12	02-06-2022	21:43	Outage is required for 1) For changing / replacement of faulty string at loc no. 19, 44, 45, 47, 52, 85, 86, 87, 88, 89, 90, 91, 92, 94, 96, 97, 99. 2) Disc cleaning work from loc 24 to 75 (Pandharpur - Karkamb section)	PO	220 KV
MAHAD-KALAMBANI(TSS)	02-06-2022	10:50	02-06-2022	19:15	Outage tree cutting at various location and	PO	220 KV
NANDED CITY-FLAGSHIP	02-06-2022	09:20	02-06-2022	17:32	1. Half yearly maintenance and CT painting work. 2. At location no 35 (CP), Disc insulator replacement work and hot spot attending work by LMSDn.	PO	220 KV
NANDED CITY-FLAGSHIP	02-06-2022	09:20	02-06-2022	17:32	Half yearly maint. work and fixing of bird g	PO	220 KV
PHALTAN MIDC - SWARAJ CO GEN	02-06-2022	09:20	02-06-2022	14:10	For tan delta testing work, Q.M and relay t	PO	220 KV
TBC @ AAREY	02-06-2022	13:35	02-06-2022	15:55	Air Leakage is observed in the pipeline due	EO	220 KV
TROMBAY DHARAVI - 6	02-06-2022	03:48	02-06-2022	03:36	For R/M of line and transfer bus GOD	PO	220 KV
TROMBAY MSETCL TIE - 2	02-06-2022	03:53	02-06-2022	07:01	Attending hotspot	PO	220 KV
TROMBAY SALSETTE LINE-2	02-06-2022	07:05	02-06-2022	08:01	Emergency tree trimming work in span 51-5	PO	220 KV
EKLAHARE (OCR) - PADGHE	03-06-2022	16:24	03-06-2022	22:30	Replacement of broken Y phase DTN string	EO	220 KV

Transmission Line Outages/Trippings from 30.05.2022 to 05.06.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAHAPE - TFIPL	03-06-2022	14:54	03-06-2022	16:50	At TFIPL S/stn :- Line Y-PH CT is observed w	EO	220 KV
ONI KHAREPATAN LINE	03-06-2022	12:36	03-06-2022	15:40	For inspection of SF6 gas leakage from B-ph pole of ABB make CB by external agency. This CB have Sf6 gas leakage problem & required frequent topping up of gas.	EO	220 KV
TALOJA II - OCIL 2	03-06-2022	14:15	03-06-2022	20:53	Isolator maintenance & Cleaning of switchg	PO	220 KV
220/132 KV 150 MVA ICT @ BOISAR	03-06-2022	14:55	03-06-2022	18:37	Pre Monsoon Maintenance, Diagnostic wor	PO	220 KV
220/22 KV 50 MVA PTR 5 @ TEMGH	03-06-2022	10:33	03-06-2022	17:10	For premonsoon work	PO	220 KV
220/22 KV 50 MVA PTR 2 @ KALWA	03-06-2022	16:40	03-06-2022	18:20	Rejumping of broken Jumper on incomer	EO	220 KV
220/22 KV 50 MVA PTR 4 @ KAMBA	03-06-2022	08:25	03-06-2022	12:05	Pre-monsoon activity, bay maintenance an	PO	220 KV
220/22-22 KV 100 MVA PTR 3 @ PAL	03-06-2022	09:12	03-06-2022	17:17	1)Attending oil pump gauge problem 2)Pre-monsoon Maintenance work. 3)Earth pit resistance measurement work.	PO	220 KV
220/22-22 KV 50 MVA PTR 1 @ KAM	03-06-2022	12:30	03-06-2022	16:43	Pre-monsoon activity, bay maintenance an	PO	220 KV
220/33 KV 50 MVA PTR 3 @ SONKAR	03-06-2022	08:40	03-06-2022	10:50	Plastic paper wrapping to PRV,Buchlloz Rel	PO	220 KV
220/33kv 125 MVA TF 1 @ SAKI (AEN	03-06-2022	09:39	03-06-2022	19:03	Annual and Premonsoon maintenance of T	PO	220 KV
220/33kv 125 MVA TF 2 @ BORIVALI	03-06-2022	09:21	03-06-2022	14:42	ANNUAL & PREMONSOON MAINTENANCE	PO	220 KV
BUS COUPLER @ URAN	03-06-2022	16:20	03-06-2022	18:24	For attending Faulty Trip Circuit 2 of the 22	PO	220 KV
VITA WAIPHALE	03-06-2022	10:28	03-06-2022	13:18	checking healthiness and trials of AR of Wa	PO	220 KV
BOMBAY DYEING - SAHARA	04-06-2022	14:41	04-06-2022	19:15	1) Replacement of F/O string R-ph loc-102	EO	220 KV
GHODBUNDER - GORAI	04-06-2022	09:43	04-06-2022	14:47	Checking and Refilling of CB compressor oil	PO	220 KV
KANDALGAON - KOYNA (POPHALI)	04-06-2022	06:33	04-06-2022	11:18	For replacement of damaged tower at loc r	PO	220 KV
220/100 KV 100MVA NO 4 @ CHINCH	04-06-2022	10:25	04-06-2022	18:52	Premonsoon & half yearly Maint.work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ SATAN	04-06-2022	10:33	04-06-2022	17:15	For OLTC overhauling work.	PO	220 KV
220/22 KV 50 MVA PTR 3 @ COLOUR	04-06-2022	08:30	04-06-2022	10:57	For pre monsoon maintenance work includ	PO	220 KV
220/22-22 KV 100 MVA PTR 1 @ COL	04-06-2022	12:05	04-06-2022	17:28	For premonsoon maintenance work includ	PO	220 KV
220/33 KV 50 MVA PTR 1 @ SONKAR	04-06-2022	07:58	04-06-2022	09:49	Plastic paper wrapping to PRV, Buchlloz re	PO	220 KV
220/33 KV 50 MVA PTR 2 @ SONKAR	04-06-2022	09:53	04-06-2022	11:13	Plastic paper wrapping to PRV, Buchlloz re	PO	220 KV
220/33-22 KV 50 MVA PTR 4 @ NERU	04-06-2022	08:23	04-06-2022	11:50	for replacement of R phase LA on EHV Side	PO	220 KV
220/33kv 125 MVA TF 1 @ CHEMBUR	04-06-2022	10:37	04-06-2022	16:27	Annual and Premonsoon maintenance of T	PO	220 KV
220/33kv 125 MVA TF 1 @ GOREGAD	04-06-2022	10:26	04-06-2022	20:31	Annual Maintenance & Premonsoon Maint	PO	220 KV
CHAKAN-BHOSARI 1	04-06-2022	21:59	05-06-2022	00:41	R-ph CC abnormal sound & hotspot at Bhos	HT	220 KV
KARAD - DASGAON	04-06-2022	10:45	04-06-2022	17:28	Insulator cleaning & jumper tightening	PO	220 KV
LONIDEOKAR TAP ON WALCHANDNA	04-06-2022	15:10	04-06-2022	20:05	REPLACEMENT OF FLASHOVER STRING AT	PO	220 KV
AAREY - AEML SAKI CKT - 2	05-06-2022	14:22	05-06-2022	17:50	Covering of damaged Sheath of 220 kV Cab	EO	220 KV
KALWA - TFIPL	05-06-2022	07:00	05-06-2022	12:38	Outage required for safety purpose for rem	PO	220 KV
LOTEPARSHURAM- DASTURI LINE	05-06-2022	06:10	05-06-2022	11:50	For replacement of damaged tower at loc r	PO	220 KV
220/100 KV 100 MVA ICT 1 @ VASAI-	05-06-2022	09:25	05-06-2022	11:26	Plastic wrapping of auxiliaries of ICT-1 & 2	PO	220 KV
220/100 KV 100 MVA ICT 2 @ VASAI	05-06-2022	11:38	05-06-2022	12:44	Plastic wrapping of auxiliaries of ICT-1 & 2	PO	220 KV
220/110/33KV 250 MVA ICT-4 @ MA	05-06-2022	10:02	05-06-2022	16:59	R/M AND PROTECTION TESTING	PO	220 KV
220/22 KV 80 MVA PTR 2 @ NALASO	05-06-2022	13:30	05-06-2022	20:09	Pre monsoon maintenance and LV Bushing	PO	220 KV
220/22-22 KV 50 MVA PTR 2 @ COLO	05-06-2022	07:15	05-06-2022	13:30	For premonsoon maintenance work includ	PO	220 KV
BABLESHWAR- BABLESHWAR(400KV)	05-06-2022	17:16	05-06-2022	20:35	TRIPPED ON DISTANCE PROTECTION	T	220 KV
CHAKAN-BHOSARI 1	05-06-2022	10:47	05-06-2022	18:36	Double Jumping Work at location no 25 t	PO	220 KV
EKLAHARE (OCR) - NAVASARI CKT - 2	05-06-2022	01:21	05-06-2022	02:17	Distance Protection	T	220 KV
KHARGHAR - BORIVALI CKT - 1	05-06-2022	07:08	05-06-2022	14:56	The work of removing of jumpers for makin	PO	220 KV
TROMBAY - ANTOP HILL CKT - 1	05-06-2022	09:41	05-06-2022	20:05	For CVT testing	PO	220 KV
220/22 KV 50 MVA PTR 1 @ VASAI	06-06-2022	06:25	05-06-2022	08:58	Polythene Wrapping of PTR-1 auxiliaries.	PO	220 KV