

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 05/Jun/2023 to 11/Jun/2023

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05-06-2023	12 Hrs	5471	165	202	5838	9880	983	4528	2262	-2556	20433	0	20433	762	436	24689	24689	50.06
06-06-2023	12 Hrs	5931	794	201	6926	10031	528	5807	2224	-2534	22496	0	22496	699	499	26714	26714	49.99
07-06-2023	12 Hrs	6242	801	200	7243	9916	596	5760	2272	-2421	22880	0	22880	809	494	27090	27090	49.98
08-06-2023	12 Hrs	7042	210	195	7447	9845	708	5736	2238	-2451	23019	0	23019	797	496	27267	27267	49.97
09-06-2023	12 Hrs	7272	145	187	7604	10098	738	5018	2162	-2543	22585	0	22585	780	496	26896	26896	50.00
10-06-2023	12 Hrs	7230	148	177	7556	9526	1544	4719	2129	-2331	22643	0	22643	685	477	26636	26636	49.95
11-06-2023	12 Hrs	6362	187	177	6726	9051	1606	4580	1954	-2002	21450	0	21450	528	298	24743	24743	49.95
Maximum		7272	801	202	7604	10098	1606	5807	2272	-2002	23019	0	23019	809	499	27267	27267	50.06
Minimum		5471	145	177	5838	9051	528	4528	1954	-2556	20433	0	20433	528	298	24689	24689	49.95
Average		6507	350	191	7049	9764	958	5164	2177	-2405	22215	0	22215	723	457	26291	26291	49.99

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05-06-2023	16 Hrs	5575	862	193	6630	10248	1027	5817	1295	-2499	22038	0	22038	931	497	26446	26446	50.02
06-06-2023	16 Hrs	6294	1322	194	7810	9912	492	6221	1281	-2377	22850	570	23420	1050	501	27268	27838	49.94
07-06-2023	16 Hrs	7173	671	198	8042	10093	768	6157	1231	-2301	23500	0	23500	1078	501	27870	27870	50.02
08-06-2023	16 Hrs	7321	114	196	7631	9533	838	6382	1339	-2405	22843	865	23708	1067	498	27288	28153	50.03
09-06-2023	16 Hrs	7281	147	176	7604	9945	985	6207	1423	-2451	23233	344	23577	1158	499	27821	28165	50.03
10-06-2023	16 Hrs	7272	124	176	7572	9760	1618	6116	1103	-2330	23400	0	23400	852	459	27480	27480	50.03
11-06-2023	16 Hrs	6872	129	177	7178	9121	1881	5063	1087	-2071	21805	0	21805	619	410	25359	25359	49.97
Maximum		7321	1322	198	8042	10248	1881	6382	1423	-2071	23500	865	23708	1158	501	27870	28165	50.03
Minimum		5575	114	176	6630	9121	492	5063	1087	-2499	21805	0	21805	619	410	25359	25359	49.94
Average		6827	481	187	7495	9802	1087	5995	1251	-2348	22810	254	23064	965	481	27076	27330	50.01

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05-06-2023	21 Hrs	5645	1759	209	7613	8053	1594	6306	0	-1703	21386	0	21386	1259	328	25153	25153	49.99
06-06-2023	21 Hrs	6261	1432	207	7900	8521	1703	6311	0	-1830	22134	0	22134	1194	310	25940	25940	50.03
07-06-2023	20 Hrs	7246	435	201	7882	8561	1614	6265	0	-1873	21966	0	21966	1020	455	25797	25797	50.11
08-06-2023	22 Hrs	7262	200	210	7672	7936	1433	6469	0	-1732	21303	477	21780	1146	498	25154	25631	49.93
09-06-2023	20 Hrs	7375	241	185	7801	8306	1948	6140	0	-1992	21705	0	21705	1029	420	25644	25644	50.08
10-06-2023	20 Hrs	7040	270	181	7490	8392	2206	5481	0	-2109	20982	0	20982	801	299	24670	24670	49.97
11-06-2023	22 Hrs	6965	364	193	7522	7909	1060	6505	0	-1799	20752	0	20752	755	299	24050	24050	49.97
Maximum		7375	1759	210	7900	8561	2206	6505	0	-1703	22134	477	22134	1259	498	25940	25940	50.11
Minimum		5645	200	181	7490	7909	1060	5481	0	-2109	20752	0	20752	755	299	24050	24050	49.93
Average		6828	672	198	7697	8240	1651	6211	0	-1863	21461	68	21529	1029	373	25201	25269	50.01

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05-06-2023	8 Hrs	5496	281	229	6006	8790	995	4888	669	-1824	19081	0	19081	576	303	22227	22227	50.06
06-06-2023	4 Hrs	5629	1630	226	7486	8095	1724	6060	0	-1819	21189	0	21189	629	287	24280	24280	49.95
07-06-2023	8 Hrs	6780	473	223	7476	9015	1119	6043	609	-1835	21955	0	21955	599	313	25174	25174	50.05
08-06-2023	8 Hrs	7266	259	218	7743	8819	1196	5782	656	-1788	21951	0	21951	608	359	25163	25163	50.06
09-06-2023	8 Hrs	7152	278	208	7638	8926	1258	5560	597	-1703	21813	0	21813	760	335	25074	25074	50.03
10-06-2023	23 Hrs	7116	214	193	7522	7651	1556	6482	0	-1701	21052	0	21052	1110	432	24754	24754	49.98
11-06-2023	8 Hrs	7152	303	196	7651	8974	374	5365	534	-1646	20806	0	20806	549	350	23797	23797	50.03
Maximum		7266	1630	229	7743	9015	1724	6482	669	-1646	21955	0	21955	1110	432	25174	25174	50.06
Minimum		5496	214	193	6006	7651	374	4888	0	-1835	19081	0	19081	549	287	22227	22227	49.95
Average		6656	491	213	7360	8610	1175	5740	438	-1759	21121	0	21121	690	340	24353	24353	50.02

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
05-06-2023	134.261	18.113	5.118	157.492	0.126	215.496	215.245	27.349	133.390	16.869	20.661	8.483	-49.584	490.275	78.728	579.740
06-06-2023	143.477	27.935	5.091	176.503	0.063	221.325	218.188	29.646	145.003	16.249	20.936	8.852	-49.804	527.981	79.592	618.514
07-06-2023	162.602	13.842	5.066	181.510	0.067	221.189	220.960	31.311	144.755	16.416	20.796	10.719	-47.441	536.810	78.956	626.696
08-06-2023	174.085	5.737	4.958	184.780	0.107	214.075	210.873	30.854	145.003	16.461	22.113	11.166	-47.023	533.330	80.302	624.452
09-06-2023	174.215	6.144	4.669	185.028	0.110	216.126	215.998	34.400	141.060	16.651	22.242	10.742	-48.698	533.663	81.682	626.249
10-06-2023	170.993	5.078	4.472	180.543	0.058	212.677	213.713	39.371	136.510	15.669	19.603	9.950	-47.313	526.849	76.866	614.323
11-06-2023	165.023	5.854	4.516	175.393	0.049	208.707	210.720	26.355	133.934	14.912	16.716	9.392	-42.265	506.611	68.373	585.409
Maximum	174.215	27.935	5.118	185.028	0.126	221.325	220.960	174.215	145.003	16.869	22.242	11.166	-42.265	536.810	81.682	626.696
Minimum	134.261	5.078	4.472	157.492	0.049	208.707	210.720	134.261	133.390	14.912	16.716	8.483	-49.804	490.275	68.373	579.740
Average	160.665	11.815	4.841	177.321	0.083	215.657	215.100	160.665	139.951	16.175	20.438	9.901	-47.447	522.217	77.786	610.769

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
05-06-2023	0.349	2.595	64.905
06-06-2023	0.555	3.150	64.350
07-06-2023	0.231	3.382	64.118
08-06-2023	0.062	3.444	64.056
09-06-2023	0.062	3.506	63.994
10-06-2023	0.037	3.542	63.958
11-06-2023	0.047	3.589	63.911

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 05/Jun/2023 to 11/Jun/2023

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
05-06-2023	MONDAY	87.924	8841	127.321	5305	215.245	8969	215.496	8979	0.252	10
06-06-2023	TUESDAY	91.627	8965	126.561	5273	218.188	9091	221.325	9222	3.137	131
07-06-2023	WEDNESDAY	91.632	9077	129.328	5389	220.960	9207	221.189	9216	0.229	10
08-06-2023	THURSDAY	91.572	8667	119.301	4971	210.873	8786	214.075	8920	3.202	133
09-06-2023	FRIDAY	94.195	8878	121.803	5075	215.998	9000	216.126	9005	0.128	5
10-06-2023	SATURDAY	81.729	8773	131.984	5499	213.713	8905	212.677	8862	-1.036	-43
11-06-2023	SUNDAY	91.625	8661	119.095	4962	210.720	8780	208.707	8696	-2.013	-84
Total		630.304		875.393		1505.697		1509.596		3.899	

Generator Unit Outages/Trippings from 05.06.2023 to 11.06.2023						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	4:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Ghatghar Unit-1	20-04-2022	0:35		Continued.	Stator Earth Fault	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	12-11-2022	13:23		Continued.	Major overhauled.	FORCED
Chandrapur Unit 5	22-05-2023	19:00		Continued.	Stator Earth Fault	FORCED
IEPL Unit 1	24-05-2023	20:10	08-06-2023	9:19	Clinker formation in furnace	FORCED
Koradi Unit 8	29-05-2023	5:36	06-06-2023	9:11	Boiler Tube Leakage	FORCED
Koradi Unit 9	30-05-2023	0:08	07-06-2023	11:03	Boiler Tube Leakage	FORCED
Uran Unit 6	01-06-2023	19:57	13-07-2023	19:34	No Schedule	FORCED
Chandrapur Unit 3	03-06-2023	7:48	05-06-2023	18:50	Boiler Tube Leakage	FORCED
Nasik Unit 3	04-06-2023	2:10	06-06-2023	3:05	Boiler Tube Leakage	FORCED
Chandrapur Unit 6	05-06-2023	1:55	07-06-2023	5:18	Boiler Tube Leakage	FORCED
Bhusawal Unit 3	05-06-2023	15:40	08-06-2023	21:35	Boiler Tube Leakage	FORCED
Koyna STG-IV Unit-1	05-06-2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4 & 5.	FORCED
Khaparkheda Unit 4	05-06-2023	16:40	05-06-2023	18:54	Low furnace pressure	FORCED
Parli Unit 6	06-06-2023	3:45	06-06-2023	7:26	Furnace Pressure High	FORCED
Koyna STG-IV Unit-4	06-06-2023	14:20	08-06-2023	3:25	GOP Problem	FORCED
Bhusawal Unit 4	07-06-2023	10:42	07-06-2023	13:14	Boiler Tube Leakage	FORCED
Koyna STG-IV Unit-2	07-06-2023	15:30	12-07-2023	18:00	Due to water shortage.	FORCED

Koyna STG-IV Unit-3	07-06-2023	15:30	11-07-2023	15:35	Due to water shortage.	FORCED
Koyna STG-IV Unit-4	08-06-2023	10:45	11-07-2023	15:35	Water Shortage	FORCED
Nasik Unit 3	08-06-2023	11:40	04-07-2023	16:35	Tolling Agreement with IEPL synchronised at 9:19 Hrs	FORCED
Parli Unit 6	10-06-2023	12:04	10-06-2023	14:17	Furnace Pressure High	FORCED
Parli Unit 6	10-06-2023	21:36	11-06-2023	6:16	Drum Level low	FORCED
Paras Unit 4	11-06-2023	13:46	15-06-2023	13:17	Boiler Tube Leakage	FORCED
Chandrapur Unit 4	11-06-2023	18:51	14-06-2023	18:30	SUSPECTED BTL AT AB-4 ELEVATION	FORCED

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
DABHOL - NEW KOYNA CKT - 2	22-05-2023	13:26	06-06-2023	22:18	Dismantling of existing tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor.	PO	400 KV
400/6.9KV 63MVA STN T/F 1 @ NANDGAONPETH	01-06-2023	6:09	06-06-2023	18:11	ST-1 transformer oil leakage arresting, maintenance , diagnostic testing, Metering CT and CVT testing and ST1 transformer protection relay testing work. ST-1transformer painting work	PO	400 KV
LONIKAND I - TALEGAON (PGCIL)	04-06-2023	14:32	05-06-2023	2:32	Y-Phase wave trap burst at Lonikand, heavy storm.	T	400 KV
AURANGABAD(MS) - PUNE (GIS)	04-06-2023	23:37	11-06-2023	14:58	HT for load management	HT	400 KV
DHULE - SSNNL CKT - 1	04-06-2023	10:11	05-06-2023	2:42	Distance Protection	T	400 KV
DHULE - SSNNL CKT - 2	04-06-2023	22:36	05-06-2023	2:18	While ground patrolling carried out, at loc no. 278 to 280 Snapping of earth wire observed so please give permission for emergency outage on 400 KV Dhule-SSNNL-2 line & 400kV Dhule SSNL 1 line is already in Breakdown & work s already progressed on 400kV Dhule SSNL 1 line for stringing of earth wire (LOC No.267 to 268).	EO	400 KV
BUS REACTOR (125 MVar) @ LAMBOTI	05-06-2023	9:48	05-06-2023	18:01	Routine Testing and Pre-monsoon activities.	PO	400 KV
CHANDRAPUR - KHAPERKHEDA	05-06-2023	13:24	05-06-2023	17:51	To attend the problem of low air pressure alarm of 400kV CGL make Circuit Breaker.	EO	400 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400 KV KARAD - SOLAPUR (PG) LR	05-06-2023	10:58	14-06-2023	16:07	Overhauling of 400 kV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	05-06-2023	16:30	06-06-2023	21:49	for attending hot-spot observed at Y ph,D isolator jaw & B-ph,A-bus isolator ,T-jump side jaw at 400 kV Talandge	EO	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	05-06-2023	19:04	05-06-2023	22:08	Tripped on Distance Protection.	T	400 KV
LONIKAND - JEJURI CKT - 1	05-06-2023	5:02	05-06-2023	6:49	Emergency outage is required on 400kV Lonikand 1 -Jejuri Ckt 1 Line to attend CVT clamp broken jump work at Lonikand 1 end.	EO	400 KV
LONIKAND - JEJURI CKT - 2	05-06-2023	7:01	05-06-2023	8:23	Emergency outage is required on 400kV Lonikand 1 -Jejuri Ckt 1 Line to attend CVT clamp broken jump work at Lonikand 1 end.	EO	400 KV
LONIKAND I - KOYNA STAGE-IV	05-06-2023	15:12	05-06-2023	23:28	Hot Spot Attending work at Loc No 01 & PID Faulty String Replacment work at Loc No 186	EO	400 KV
LONIKAND I - KOYNA STAGE-IV	05-06-2023	3:09	05-06-2023	4:45	Emergency outage is required on 400kV Lonikand 1 -Stage 4 Line to attend CVT clamp broken jump work	EO	400 KV
MAIN BAY (406) OF STG-4 @ JEJURI	05-06-2023	9:48	05-06-2023	14:51	For attending hot spot at 406 bay Rph CT Stud clamp	EO	400 KV
PARLI - KARJAT CKT - 1	05-06-2023	2:56	05-06-2023	6:33	For replacement of PID faulty insulator string at loc no 221 Yph	EO	400 KV
KORADI - KHAPERKHEDA CKT - 1	06-06-2023	14:33	06-06-2023	15:42	Tripped on Distance Protection.	T	400 KV
KORADI - KHAPERKHEDA CKT - 2	06-06-2023	14:33	06-06-2023	15:51	Tripped on Distance Protection.	T	400 KV
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	06-06-2023	9:32	06-06-2023	15:35	HV ISOLATOR OVERHAULING WORK BY SHIFTING HV CB ON 400 KV TBC	PO	400 KV
400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	06-06-2023	11:59	06-06-2023	13:54	Premonsoon Maintenance Work	PO	400 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400KV TIE BAY 402 STN TF 1 AND AKOLA2 CKT 1 @ NANDGAONPETH	06-06-2023	6:18	06-06-2023	18:11	Hand tripped for breaker trials of STN TF-1	HT	400 KV
500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	06-06-2023	12:55	06-06-2023	16:09	On dtd. 06.06.2023, general switchyard inspection was carried during inspection it was found that one of the twin conductor jumpers from 400/220/33KV Y-ph Line CT snapped and now the same snapped conductor is to be re-connected. Image of the same is attached in mail. For snapped jumper connection of 400/220/33KV ICT-1 Y-ph Line CT	EO	400 KV
DHULE - SSNNL CKT - 1	06-06-2023	8:54	06-06-2023	22:56	Under MTAMC Project work, Main-II Dist Protn relay replacement work	PO	400 KV
LONIKAND I - KOYNA STAGE-IV	06-06-2023	21:04	10-06-2023	2:36	Tripped on distance protection	T	400 KV
MAIN BAY (404) OF SOLAPUR PG @ ALKUD	06-06-2023	12:49	06-06-2023	13:38	Diagnostic testing & Maintenance work	PO	400 KV
MAIN BAY 401 OF STN T/F 1 @ NANDGAONPETH	06-06-2023	6:18	06-06-2023	18:11	Hand tripped for breaker trials of STN TF-1	HT	400 KV
PADGHE (GIS) PG - KUDUS CKT - 2	06-06-2023	10:51	06-06-2023	20:06	CVT replacement in 400 kV Padghe-Kudus ckt-2 at MSETCL Kudus.	PO	400 KV
TIE BAY - 405 OF SOLAPUR PG @ ALKUD	06-06-2023	11:19	06-06-2023	12:42	Diagnostic testing & Maintenance work	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	07-06-2023	11:25	07-06-2023	15:19	Pre-Monsoon maintenaance	PO	400 KV
CHANDRAPUR-PARLI CKT-3	08-06-2023	16:02	08-06-2023	22:50	Tripped on Distance Protection.	T	400 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PADGHE - NAGOTHANE CKT - 2	08-06-2023	13:08	13-06-2023	18:37	Work of shifting/height raising of various EHV (220/110KV) transmission lines infringing in Samruddhi crossing . 1) Erection of 5 no. of Monopple 2) Stringing of 6.nos. of spans between location nos. 310-313	PO	400 KV
400/220 KV 500MVA ICT - 4 @ KALWA	08-06-2023	5:31	08-06-2023	6:54	For pre-monsoon maintenance work (e.g- for polythin paper wrapping work)	PO	400 KV
DHULE - DHULE(BDTCL) CKT - 1	08-06-2023	9:49	08-06-2023	10:30	DT received from BDTCL Dhule end	T	400 KV
LONIKAND - JEJURI CKT - 2	08-06-2023	17:04	08-06-2023	21:46	Tripped on Distance Protection.	T	400 KV
400/220 KV 500MVA ICT - 4 @ KALWA	09-06-2023	11:01	09-06-2023	20:35	For attending red hot spot on 29A isolator B-Ph 220KV Bus side by hot line unit.	EO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ PARLI	09-06-2023	10:37	09-06-2023	14:40	(1) IV breaker testing work. (2) Bay maintenance work.	PO	400 KV
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	09-06-2023	11:04	09-06-2023	16:52	Diagnostic testing & routine maintenance work	PO	400 KV
DHULE - SSNNL CKT - 2	09-06-2023	9:07	09-06-2023	19:55	Under MTAMC Project work, Main-II Dist Protn relay replacement work	PO	400 KV
MAIN BAY (401) OF GT 9 @ 400KV CHANDRAPUR SWITCHING S/S	09-06-2023	11:59	09-06-2023	15:24	Diagnostic testing and allied bay maintenance work	PO	400 KV
MAIN BAY (415) OF PADGHE PG CKT - 1 @ KUDUS	09-06-2023	18:34	09-06-2023	20:40	Tie bay 414 of Padghe PG ckt 1 outage was under progress for CT replacement , during testing of CT of said bay due to maloperation DT send to other end.	T	400 KV
TIE BAY (414) OF PADGHE PG CKT - 1 @ KUDUS	09-06-2023	11:01	10-06-2023	19:12	CT Replacement Work	PO	400 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KORADI - KHADKA	10-06-2023	8:34	10-06-2023	20:00	For replacement of R and B phase CVT old jump replacement work and routine bay maintenance works etc.	PO	400 KV
WARORA - IEPL	10-06-2023	14:12	10-06-2023	16:30	Tripped on distance protection	T	400 KV
400/220/33 KV 315 MVA ICT - 1 @ PARLI	10-06-2023	16:05	10-06-2023	18:35	220KV BUS SECTION -1 DEAD.	T	400 KV
TBC @ PARLI	10-06-2023	10:01	10-06-2023	12:47	Bay Maintenance Work is to be carried out.	PO	400 KV
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	11-06-2023	3:55	11-06-2023	6:18	Pre monsoon Maintenance work	PO	400 KV
400/220 KV 3X200 MVA ICT - 2 @ KALWA	11-06-2023	6:56	11-06-2023	8:50	Premonsoon work ,polythene wrapping on PRV,Buchhloz, & OSR.	PO	400 KV
DHULE - SSNNL CKT - 1	11-06-2023	11:20	11-06-2023	14:09	TRIPPED ON OVER VOLTAGE	T	400 KV
DHULE - SSNNL CKT - 2	11-06-2023	11:20	11-06-2023	13:41	Tripped from Dhule end only	T	400 KV
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	02-06-2023	10:10	07-06-2023	15:23	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.	HT	220 KV
SAHARA-URSE	04-06-2023	21:12	05-06-2023	6:19	CB overhauling work of 220kv Sahara-Urse line bay.	EO	220 KV
ALEPHATA-PARGAON(KATHAPUR)	05-06-2023	8:10	05-06-2023	19:34	H/T for load Management.	HT	220 KV
GHODBUNDER - GORAI	05-06-2023	0:39	05-06-2023	6:11	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.	PO	220 KV
KALMESHWAR-PANDHURNA	05-06-2023	9:01	05-06-2023	22:36	Work at Pandhurna end.	PO	220 KV
TALANDAGE - FIVE STAR MIDC 1	05-06-2023	15:20	05-06-2023	19:19	Distance and Back up relay testing work	PO	220 KV
WARORA - WARORA RLY TSS 1	05-06-2023	9:13	05-06-2023	12:13	Replacement of broken disc insulators on pilot string at loc no.4A.	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV CHALISGAON - KHADKA CKT - 1	05-06-2023	11:22	05-06-2023	12:56	Removing of broken earth wire at loc no.26 which is observed during drone patrolling.	PO	220 KV
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	05-06-2023	11:45	05-06-2023	18:15	HV R & B Ph bushing replacement work	PO	220 KV
220/132-110KV 100MVA PTR 2 @ WATHAR	05-06-2023	9:40	05-06-2023	16:17	Quarterly maint work	PO	220 KV
MAIN BUS @ NIWALI	05-06-2023	10:45	05-06-2023	18:58	Routine maintenance work.	PO	220 KV
NERUL - SEAWOOD CABLE CKT - 2	05-06-2023	11:24	05-06-2023	14:29	Maintenance work by Railways	PO	220 KV
TALANDAGE - FIVE STAR MIDC 2	05-06-2023	10:33	05-06-2023	15:04	for dignostic testing and quarterly maintenance work	PO	220 KV
VERSOVA - GHODBUNDER	05-06-2023	0:30	05-06-2023	6:06	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.	PO	220 KV
GHATODI-NANDED	06-06-2023	10:32	06-06-2023	18:37	Restranging of Loose OPGW Earth wire	PO	220 KV
GHODBUNDER - GORAI	06-06-2023	23:51	06-06-2023	6:26	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.	PO	220 KV
HINGANGHAT - BHUGAON	06-06-2023	7:09	06-06-2023	9:30	Testing work	PO	220 KV
MIRAJ - ICHALKARANJI	06-06-2023	12:21	06-06-2023	17:38	Balance dismantling work of tower at loc No.29A	EO	220 KV
MUMEWADI -HALKARNI 2 LINE	06-06-2023	9:01	06-06-2023	17:41	Insulator cleaning work	PO	220 KV
OSMANABAD - SOLAPUR (BALE)	06-06-2023	21:21	06-06-2023	22:47	Y phase LA Tilted		220 KV
PUSAD - HINGOLI	06-06-2023	10:33	06-06-2023	17:51	Restranging of Loose OPGW earthwire	PO	220 KV
220 KV CHANDRAPUR - 2-BALLARSHAH CKT	06-06-2023	7:07	06-06-2023	11:56	Routine Maintenance work	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/100 KV 100 MVA ICT 1 @ TAMBATI	06-06-2023	14:15	06-06-2023	16:45	Faulty jumper replacement work by agency & Hot spot attending work.	PO	220 KV
220/100 KV 100 MVA ICT 2 @ TAMBATI	06-06-2023	8:23	06-06-2023	13:30	Faulty jumper replacement work by agency & Hot spot attending work.	PO	220 KV
220/33KV 25MVA PTR 2 @ PAWAS	06-06-2023	10:00	06-06-2023	16:27	For Pre-monsoon Maintenance activities of 220/33kv 25MVA T/F II & 33kv Main Bus with 33kv Equipments; Replacement Bph HVCT.	PO	220 KV
ALKUD - VITA	06-06-2023	18:08	06-06-2023	21:57	Jump Replacement work at Loc No.61 Y ph	EO	220 KV
BHAVEGHAR - ROMA	06-06-2023	10:12	06-06-2023	16:40	EHV breaker OH work at 220KV Bhaveghar Sub Station by shifting the line on TBC.	EO	220 KV
DAHANU - GHODBUNDER CKT - 1	06-06-2023	10:00	06-06-2023	11:30	Premonsoon maintenance of Circuit Breaker.	PO	220 KV
DAHANU - GHODBUNDER CKT - 2	06-06-2023	11:52	06-06-2023	14:27	Premonsoon maintenance of Circuit Breaker	PO	220 KV
GHODBUNDER - MSETCL BOISAR	06-06-2023	22:55	07-06-2023	17:53	Tripped on distance protection	T	220 KV
KHARGHAR - KHANDESHWAR CKT - 1	06-06-2023	10:06	06-06-2023	20:09	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.	PO	220 KV
KHARGHAR - KHANDESHWAR CKT - 2	06-06-2023	10:18	06-06-2023	20:16	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.	PO	220 KV
MALEGAON (ZODGA) - BALAPUR CKT 2	06-06-2023	12:54	06-06-2023	16:36	Repairing of 132KV CKT Breaker limit switch	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
VERSOVA - GHODBUNDER	06-06-2023	23:38	06-06-2023	6:17	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.	PO	220 KV
COLOURCHEM - TEMGHAR	07-06-2023	10:18	07-06-2023	11:14	sparking on wave trap observed , so Handtripped at colourchem end	HT	220 KV
COLOURCHEM - TEMGHAR	07-06-2023	12:55	07-06-2023	13:10	For 220KV Temghar line CB hot spot attending work. And Bus T palm hot spot attending work on R-phase with help of Hot Line Team.	EO	220 KV
GHODBUNDER - GORAI	07-06-2023	11:01	07-06-2023	12:44	Premonsoon maintenance of Circuit Breaker	PO	220 KV
KALMESHWAR-PANDHURNA	07-06-2023	10:43	07-06-2023	16:49	Routine Maint. Work	PO	220 KV
MAHALAXMI - AMONA	07-06-2023	14:09	07-06-2023	15:14	Outage required to M/s. Gadre Marine Export Pvt Ltd to transport the Turbine under 220KV D/C line ie 220KV Tilari-Amona & 220KV Mahalaxmi-Amona at location No. 342-343	EO	220 KV
OSMANABAD - BARSHI	07-06-2023	9:28	07-06-2023	14:34	Outage is required for Quarterly Maintenance	PO	220 KV
TALOJA II - OCIL 1	07-06-2023	8:40	07-06-2023	18:20	220kv OCIL-01 Bay Maintenance OCIL end	PO	220 KV
TILLARI - AMONA LINE	07-06-2023	9:52	07-06-2023	19:15	Maintenance work	PO	220 KV
200 MVA 220/132 KV ICT 1 @ GIRWALI	07-06-2023	9:06	07-06-2023	13:13	Pre-moon maintenance work.	PO	220 KV
200 MVA 220/132 KV ICT 3 @ GIRWALI	07-06-2023	14:03	07-06-2023	16:07	Pre-moon maintenance work.	PO	220 KV
220 / 110 / 22kv 250MVA ICT 1 @ BORIVALI (TATA)	07-06-2023	9:18	07-06-2023	11:57	R/M & Testing	PO	220 KV
220 KV BUS COUPLER @ BUTIBORI	07-06-2023	13:35	07-06-2023	16:48	Replacing overcurrent earth fault relay.	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/100 KV 200 MVA ICT 2 @ PAL-DOMBIVALI	07-06-2023	10:15	07-06-2023	16:05	Plastic paper wrapping & RM Work	PO	220 KV
220/132 KV 150 MVA ICT-2 @BHENDA	07-06-2023	18:17	07-06-2023	19:40	For attending hotspot of LV Y PH Bushing	EO	220 KV
220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR)	07-06-2023	8:34	07-06-2023	12:16	Outage is required for Diagnostic testing and maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 1	07-06-2023	12:47	07-06-2023	18:49	Pre-moon maintenance work.	PO	220 KV
220/132 KV 200 MVA ICT 2 @ AMALNER	07-06-2023	18:10	07-06-2023	20:30	Diagnostic testing work carried by mobile testing unit nashik and pre-moon maintenance work.	PO	220 KV
220/132 KV 200 MVA ICT 3	07-06-2023	8:37	07-06-2023	12:42	Pre-moon maintenance work.	PO	220 KV
220KV WARORA(400KV)-WARORA CKT 2	07-06-2023	7:59	07-06-2023	11:11	Attending hot spot on Y ph line isolator towards line side.		220 KV
KALWA SALSETTE - 4	07-06-2023	22:33	08-06-2023	1:38	For 2A2 phase LA replacement at Salsette	PO	220 KV
KHARGHAR - KHANDESHWAR CKT - 1	07-06-2023	7:28	08-06-2023	19:45	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.	PO	220 KV
KHARGHAR - KHANDESHWAR CKT - 2	07-06-2023	7:22	08-06-2023	19:46	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.	PO	220 KV
NEW KOYNA - LOTEPARSHURAM	07-06-2023	15:38	07-06-2023	17:28	Tripped on Distance Protection.	T	220 KV
NEW KOYNA - PEDAMBE	07-06-2023	16:03	07-06-2023	16:25	Tripped due to overloading at New Koyana end only.	T	220 KV
VITA - MIRAJ	07-06-2023	17:27	07-06-2023	19:46	Jump Replacement work at Loc No.84 B Ph	PO	220 KV
AMBAZARI-KALMESHWAR	08-06-2023	10:00	08-06-2023	15:27	Faulty dist prot relay replacement & bus-2 isolator alignment work.	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
HALKARNI - TILARI LINE	08-06-2023	9:30	08-06-2023	20:38	Erection of Bph and Yph Pedestrial Wave Traps at 220KV Halkarni bay @ Tillari SS, cleaning of EHV equipmants and line side tension, suspension insulator strings	PO	220 KV
IPCL - SPCL	08-06-2023	10:22	09-06-2023	16:13	ABB MAKE CB OVERHAULUING WORK AT IPCL END CB	PO	220 KV
KANDALGAON - PIRANGUT	08-06-2023	12:20	08-06-2023	18:18	Work :-1) Attending hot spots. Loc no 36,61,63,64,81,83,88 2) Earth wire restringing loc no 37,38,40,68-72	PO	220 KV
MIRAJ - ICHALKARANJI	08-06-2023	17:19	09-06-2023	2:38	Emergency outage for project work.	HT	220 KV
TALOJA II - OCIL 2	08-06-2023	7:55	08-06-2023	18:10	220KV OCIL-2 Bay Maintanence OCIL end	PO	220 KV
WARORA - HINGANGHAT	08-06-2023	14:04	08-06-2023	17:53	For replacement of keypad & display of backup relay by agency & relay testing work.	PO	220 KV
220 KV MAIN BUS - I	08-06-2023	10:51	08-06-2023	19:19	At that time whole 220 kv bus-1 free for work & bus-2 jump removed & reconnected with the help of hot line unit, Jalgaon & 220 kv pt-1 diagnostic testing work.	PO	220 KV
220 KV NANDED(400 KV) - WAGHALA CKT- II	08-06-2023	7:56	08-06-2023	9:09	At loc85 bphase cross arm one angle piece came near to jumper hence for refixing it.	PO	220 KV
220 KV PHULAMBRI - BHOKARDHAN	08-06-2023	13:06	08-06-2023	17:12	Diagnostic testing i.e ct tandelta measurment test.	PO	220 KV
220/100 KV 200 MVA ICT 1 @ PAL- DOMBIVALI	08-06-2023	10:15	08-06-2023	16:05	Plastic paper wrapping & RM Work	PO	220 KV
220/100 KV 200 MVA ICT 2 @ TROMBAY	08-06-2023	7:36	08-06-2023	11:30	For 1) Premonsoon maintenance work & 2) RM work.	PO	220 KV
220/132KV 100 MVA ICT 2@ PETH	08-06-2023	10:01	08-06-2023	12:16	Structure Painting Work	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
AIS 220KV BUS COUPLER @ GHODBUNDER	08-06-2023	10:57	08-06-2023	12:15	Premonsoon maintenance of Circuit Breaker	PO	220 KV
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	08-06-2023	2:01	08-06-2023	8:46	1. Attending of low clearance in between loc.no.62 to 63 & 63-64. 2. Conversion of single jump into twin jump of tension tower at various locations. (as per current loading, frequent Red-Hot comes frequently).	PO	220 KV
KURKUMBH - SHIRSHUPHAL CKT	08-06-2023	9:10	08-06-2023	14:30	Premonsoon Maintenance, attending HOT spot on R CT.	PO	220 KV
MALEGAON (ZODGA) - BALAPUR CKT 1	08-06-2023	13:24	08-06-2023	16:10	For relay testing work and scada point to point testing with Id.	PO	220 KV
VANKUSWADE - KDPH	08-06-2023	11:00	08-06-2023	11:45	Fixing of earth wire expansion clamp at Loc No.99	PO	220 KV
CHIKHALI-JALNA I	09-06-2023	10:31	09-06-2023	13:01	IN VIEW OF 220KV PARAS-CHIKHLI CKT 2 UNDER OUTAGE.	HT	220 KV
CHIKHALI-JALNA II	09-06-2023	10:36	09-06-2023	13:08	IN VIEW OF 220KV PARAS-CHIKHLI CKT 2 UNDER OUTAGE.	HT	220 KV
COLOURCHEM - TEMGHAR	09-06-2023	22:32	10-06-2023	3:55	To attend Hotspot on B phase jumper Cone at Line Incoming gantry near LA. Also Y phase WT jumper will be replace which looks deteriorated.	EO	220 KV
KANHAN-UMRED 1	09-06-2023	10:38	09-06-2023	17:22	FOR DIAGNOSTIC TESTING WORK.	PO	220 KV
MAHAD - KANDALGAON	09-06-2023	1:15	10-06-2023	15:54	1. Erection of 2 nos. inline monopole 2. Stringing of 3 nos. conductor on new erected monopole. 3. Stringing of 3 nos. conductor both sides of 2 nos. erected monopole. 4. Dismantling of old conductor.	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MALINAGAR - TEMBHURNI	09-06-2023	16:40	09-06-2023	18:12	Outage is required for Tree trimming coming under induction zone at Loc no. 79-80, 81-82	EO	220 KV
PARAS-CHIKHALI CKT NO-II	09-06-2023	10:40	09-06-2023	12:51	REPLACEMENT OF JUMPER FROM LINE ISOLATOR 29D TO CT -R PHASE FOR ATTENDING HOT SPOT.	PO	220 KV
SONKHAR - TROMBAY	09-06-2023	5:29	09-06-2023	8:10	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL	PO	220 KV
WPCL-WARORA 2	09-06-2023	13:25	09-06-2023	22:05	CKT EMERGENCY HANDTRIPPED DUE TO BURNING OF WAVE TRAP AT WPCI END.	HT	220 KV
100 MVA 220/132 KV ICT - I @ JALKOT	09-06-2023	18:24	09-06-2023	19:43	PREMONSOON MAINTENANCE WORK	PO	220 KV
100 MVA 220/132 KV ICT - II @ JALKOT	09-06-2023	12:10	09-06-2023	18:01	PREMONSOON MAINTENANCE WORK	PO	220 KV
100 MVA 220/132 KV ICT 2	09-06-2023	18:40	09-06-2023	19:50	LV SIDE PRV OPTD	HT	220 KV
220 KV TBC @ AMBAZARI	09-06-2023	8:22	09-06-2023	17:30	220 KV BUS-2 ISOLATOR ALLIGNMENT WORK	PO	220 KV
220/100 KV 100 MVA ICT 1 @ KANDALGAON	09-06-2023	9:00	09-06-2023	12:45	Plastic wrapping work to be carried out.	PO	220 KV
220/100 KV 200 MVA ICT 3 @ TROMBAY	09-06-2023	20:55	09-06-2023	23:33	For 1) Premonsoon maintenance work & 2) RM work.	PO	220 KV
220/132 KV 100 MVA ICT 1 @ BHENDA	09-06-2023	18:05	09-06-2023	19:30	To attend the red hot on 100MVA ICT -1 at LV Y Phase CT P1 Side	EO	220 KV
220/132 KV 80 MVA ICT 1 @ HINGANGHAT	09-06-2023	9:06	09-06-2023	12:01	FOR REPLACEMENT OF HV Y PH LA DUE TO HIGH LCM VALUE.(IR CORRECTED-2025μA).		220 KV
220/132-110KV 200MVA ICT 2 @ MIRAJ	09-06-2023	10:35	09-06-2023	17:15	Diagnostic testing & Quarterly maintenance work	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132KV 100MVA ICT 1 @ NAGBHID	09-06-2023	11:35	09-06-2023	14:55	PREMONSOON MAINTENANCE WORK	PO	220 KV
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	09-06-2023	7:06	09-06-2023	12:05	Pre monsoon bus maintenance work	PO	220 KV
220/33KV 100MVA TF No.1 @ BOTHE	09-06-2023	9:16	09-06-2023	12:28	Overhauling work of drive mechanism of HV CB & Quarterly maintenance work	PO	220 KV
220/33KV 100MVA TF No.2 @ BOTHE	09-06-2023	12:30	09-06-2023	18:24	Overhauling work of drive mechanism of HV CB & Quarterly maintenance work	PO	220 KV
220/33KV 50MVA PTR 2@ PETH	09-06-2023	12:15	09-06-2023	15:30	Structure painting work	PO	220 KV
CHEMBUR (AEML) - NERUL (M)	09-06-2023	4:52	09-06-2023	19:10	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL	PO	220 KV
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	09-06-2023	2:58	09-06-2023	8:11	Conversion Of single to Twin Jump at Various Cut point	PO	220 KV
KARAD -NIGADE	09-06-2023	10:59	09-06-2023	16:31	Replacement work of Y & B Ph damaged jump between Bus to isolator.	PO	220 KV
KOLSHET - KHARBAO	09-06-2023	13:04	09-06-2023	19:05	1) R-phase line wave trap to line isolator jumper replacement due to hotspot of 150+ ° c temperature 2) R-phase CT to CB jumper replacement. 3) R-phase Bus isolator to PT jumper Replacement.	EO	220 KV
TROMBAY MSETCL TIE - 2	09-06-2023	0:05	09-06-2023	2:48	Attending to CT oil leakage.	PO	220 KV
BUTIBORI 3- VIPL CKT I	10-06-2023	15:30	10-06-2023	18:21	Eavy spark seen on metering r ph pt side jumper which was open and in hanging position.	HT	220 KV
GADCHANDUR - VIRUR-I	10-06-2023	9:10	10-06-2023	11:50	For diagnostic testing work.	HT	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
HINJAWADI I- CHINCHWAD	10-06-2023	9:45	10-06-2023	19:20	1) Fixing of earthwire MS joint at loc no-172-173 2) Pilot string jump replacement at loc no-179(B ph)	PO	220 KV
KHARGHAR - SONKHAR	10-06-2023	4:09	10-06-2023	8:26	1] Attending hotspot on 1.R phase wavetrap top jumper (line side)(99degC) 2.Y phase dead end clamp on line side (97degC) 2] Taking IR values of LAs due to increasing LCM values of B phase LA 3] Diagnostic testing & RM work	EO	220 KV
PADGHE - TEMGHAR - 2	10-06-2023	1:54	10-06-2023	3:26	For safety purpose to attend hot spot on bottom ph dead end h/w of 220 kV Colourchem & Temghar line at Loc. No. 39	EO	220 KV
220 KV GIRWALI (400 KV) -PARLI U-8 CKT	10-06-2023	16:05	10-06-2023	18:22	220Kv bus section dead.	T	220 KV
220 KV HARANGUL - PARLY (PG) CKT	10-06-2023	17:38	10-06-2023	18:45	Tripped on distance protection	T	220 KV
220/100 KV 200 MVA ICT 1 @ BORIVALI	10-06-2023	9:36	10-06-2023	16:45	For Pre-monsoon maintenance work on 100MVA, 220/100KV ICT	PO	220 KV
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	10-06-2023	5:43	10-06-2023	8:30	PM CHECKS	PO	220 KV
220/110 KV 155MVA ICT-2@ BHIRA (T)-220 KV	10-06-2023	8:50	10-06-2023	12:51	PM CHECKS	PO	220 KV
220/132 100MVA ICT-1 @ AMRAPUR	10-06-2023	11:08	10-06-2023	14:31	Diagnostic testing work	PO	220 KV
220/132 100MVA ICT-2 @ AMRAPUR	10-06-2023	14:59	10-06-2023	18:38	Diagnostic testing work	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132 KV 200 MVA ICT 1 @ RAYMOND	10-06-2023	10:00	10-06-2023	17:46	1.Diagnostic testing of Bushings, Windings, Breaker and CTs. & Premonson maintenance. 2. Attending red hot and replacement of Nut bolts.	PO	220 KV
220/132 KV 200 MVA ICT 2 @ AMALNER	10-06-2023	19:05	10-06-2023	20:50	Replacement of HV R PH LA.	HT	220 KV
220/132KV 200 MVA ICT 2	10-06-2023	11:32	10-06-2023	12:20	For premansoon maint. work.	HT	220 KV
220/132KV 200 MVA ICT 2	10-06-2023	10:20	10-06-2023	11:19	For premansoon maint. work.	HT	220 KV
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	10-06-2023	10:22	10-06-2023	16:47	Quarterly Maint and pre monsoon maint. work.	PO	220 KV
EKLAHARA(OCR)-RAYMOND	10-06-2023	9:12	10-06-2023	17:21	1.Attending red hot on B ph wave trap bottom side by replacement of existing jump along with Nut bolt and bay maintenance. 2. Attending red hot on B ph CT line side by replacement of Nut bolt 3. Diagnostic testing of breaker and CTs. & Premonson maintenance.	PO	220 KV
MAHAD-KALAMBANI(TSS)	10-06-2023	19:32	12-06-2023	13:08	1) Erection of 06 nos cross-arm on 02 nos monopole. 2) Stringing of 03 nos conductor on new erected monopole. 3) Stringing of 03 nos conductor both sides of 02 nos erected monopole. 4) Dismantling of old conductor and tower (02 nos)	PO	220 KV
MAIN BUS @ ANANDNAGAR	10-06-2023	9:45	10-06-2023	15:35	For separation of common dropper jumper of 220kV PT & TBC bay & TBC bay Isolator maintenance.	PO	220 KV
TBC @ ANANDNAGAR	10-06-2023	9:45	10-06-2023	15:30	For separation of common dropper jumper of 220kV PT & TBC bay & TBC bay Isolator maintenance.	PO	220 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BORIVALI - TARAPUR	11-06-2023	14:47	12-06-2023	3:17	Bus fault at Borivali s/s due to bad whether	T	220 KV
GHATGHAR - BAPGAON	11-06-2023	14:26	11-06-2023	15:19	Tripped on distance protection	T	220 KV
GIS BHANDUP - BORIVALI	11-06-2023	14:47	11-06-2023	15:28	Bus fault at Borivali s/s due to bad whether	T	220 KV
220/100 KV 200 MVA ICT 1 @ BORIVALI	11-06-2023	14:47	11-06-2023	16:09	Bus fault at Borivali s/s due to bad weather	T	220 KV
AAREY - MSETCL BORIVALI CKT - 2	11-06-2023	14:47	11-06-2023	15:59	Bus fault at Borivali s/s due to bad weather	T	220 KV
AEML BORIVALI -MSETCL BORIVALI CKT -2	11-06-2023	14:47	11-06-2023	15:58	Bus fault at Borivali s/s due to bad weather	T	220 KV
BORIVALI - BOISAR (PG)	11-06-2023	14:47	11-06-2023	22:27	Bus fault at Borivali s/s due to bad weather	T	220 KV
CHAKAN - CHINCHWAD 2	11-06-2023	10:26	11-06-2023	18:06	1) Stringing of earth wire between loc no-23-25. 2) Replacement of damaged conductor at loc at loc no-20-21 (B ph).	PO	220 KV
GORAI -MSETCL BORIVALI CKT -2	11-06-2023	14:47	11-06-2023	16:00	Bus fault at Borivali s/s due to bad weather	T	220 KV
KHARGHAR - BORIVALI CKT - 2	11-06-2023	14:47	11-06-2023	16:54	Bus fault at Borivali s/s due to bad whether	T	220 KV
PANCHALI TSS - BOISAR (PG)	11-06-2023	14:47	11-06-2023	18:36	Tripped on distance protection	T	220 KV
TATA BORIVLI MSETCL BORIVLI - 4	11-06-2023	14:47	11-06-2023	16:02	Bus fault at Borivali s/s due to bad weather	T	220 KV
WAGHIVALI - DHARAVI 7	11-06-2023	15:06	11-06-2023	20:00	FOR INSULATOR REPLACEMENT	PO	220 KV
KANHAN-PENCH	07-06-2023	9:54	07-06-2023	20:10	Routine Maint. Work	PO	132 KV
KALWA KALYAN	05-06-2023	21:26	06-06-2023	6:35	Tower erection & conductor shifting at loc 165	PO	110 KV
NERAL - AMBERNATH	05-06-2023	7:36	05-06-2023	9:33	BIRD NEST REMOVAL	PO	110 KV
KALWA KALYAN	06-06-2023	21:05	07-06-2023	6:40	Tower erection & conductor shifting at loc 165	PO	110 KV
KALWA KALYAN	07-06-2023	21:00	08-06-2023	4:55	Tower erection & conductor shifting at loc 165	PO	110 KV

Transmission Line Outages/Trippings from 05.06.2023 to 11.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KHOPOLI - DAVDI	07-06-2023	6:55	07-06-2023	12:00	Lightning spikes installation	PO	110 KV
BHIRA (T) - KHOPOLI 2	08-06-2023	7:25	08-06-2023	12:01	Replacement of Porcelain LA on cable section on Tower	PO	110 KV
KALWA KALYAN	11-06-2023	21:56	12-06-2023	5:12	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
KALWA KALYAN	11-06-2023	21:56	12-06-2023	5:17	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
TATA BORIVLI MSETCL BORIVLI 1	11-06-2023	9:44	11-06-2023	13:53	repair sleeve compression on C Ph conductor in span 28-29	PO	110 KV
ZONE 2 (BUS SECTION 2&3) @ KHOPOLI	11-06-2023	7:30	11-06-2023	14:20	R/M AND TESTING	PO	110 KV