

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 03/Jun/2024 to 09/Jun/2024

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03-06-2024	12 Hrs	6560	464	283	7308	10364	296	5263	2290	-2214	22777	0	22777	1263	503	27286	27286	49.97
04-06-2024	12 Hrs	6836	582	282	7700	10968	255	5308	2008	-2236	23454	0	23454	1264	503	28006	28006	49.95
05-06-2024	12 Hrs	6140	240	456	6836	10355	291	5186	2088	-2600	21636	0	21636	1075	247	26078	26078	49.95
06-06-2024	12 Hrs	5996	231	363	6590	9704	364	5181	2302	-2585	21018	0	21018	1139	250	25530	25530	49.96
07-06-2024	12 Hrs	6454	199	281	6934	8891	166	5042	2208	-2580	20110	0	20110	917	492	24650	24650	49.97
08-06-2024	12 Hrs	5924	113	277	6314	8874	206	5155	2083	-2374	19741	0	19741	842	332	23806	23806	49.96
09-06-2024	12 Hrs	4726	120	143	4989	8407	503	4980	1882	-1666	18622	0	18622	720	314	21795	21795	49.93
Maximum		6836	582	456	7700	10968	503	5308	2302	-1666	23454	0	23454	1264	503	28006	28006	49.97
Minimum		4726	113	143	4989	8407	166	4980	1882	-2600	18622	0	18622	720	247	21795	21795	49.93
Average		6091	278	298	6667	9652	297	5159	2123	-2322	21051	0	21051	1031	377	25307	25307	49.96

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03-06-2024	16 Hrs	6713	482	371	7566	10271	662	6704	1335	-2388	23613	0	23613	1271	502	28310	28310	50.00
04-06-2024	15 Hrs	6964	144	365	7474	10129	718	6428	1809	-2414	23630	0	23630	1239	493	28290	28290	50.01
05-06-2024	16 Hrs	6240	298	458	6996	10806	855	5314	1247	-2896	21798	0	21798	1030	245	26492	26492	50.03
06-06-2024	16 Hrs	6988	660	363	8011	9476	675	5700	888	-2775	21440	0	21440	1224	249	26223	26223	50.03
07-06-2024	16 Hrs	7169	353	278	7800	9359	141	5629	1384	-2463	21324	0	21324	1162	503	25978	25978	50.03
08-06-2024	16 Hrs	6926	114	276	7316	8962	273	6084	1192	-2334	20981	0	20981	1022	503	25352	25352	49.97
09-06-2024	15 Hrs	5790	125	139	6054	8320	769	5176	1396	-1792	19464	0	19464	727	307	22749	22749	50.03
Maximum		7169	660	458	8011	10806	855	6704	1809	-1792	23630	0	23630	1271	503	28310	28310	50.03
Minimum		5790	114	139	6054	8320	141	5176	888	-2896	19464	0	19464	727	245	22749	22749	49.97
Average		6684	311	321	7316	9618	585	5862	1322	-2437	21750	0	21750	1096	400	26199	26199	50.01

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03-06-2024	20 Hrs	6680	1232	373	8286	8055	1342	6777	0	-1901	21991	0	21991	1175	503	26138	26138	50.04
04-06-2024	22 Hrs	7096	448	287	7830	8229	612	6768	0	-2025	20907	0	20907	1258	243	24940	24940	49.96
05-06-2024	21 Hrs	6801	858	286	7946	8696	747	6412	0	-2053	21215	0	21215	1284	251	25336	25336	50.05
06-06-2024	20 Hrs	7264	500	280	8044	7965	931	6975	0	-2275	21101	0	21101	1090	228	25233	25233	50.02
07-06-2024	20 Hrs	7038	229	285	7552	8518	1029	6660	0	-2269	20944	0	20944	823	461	25043	25043	50.02
08-06-2024	20 Hrs	6966	407	283	7656	8319	148	6972	0	-2019	20545	0	20545	913	419	24427	24427	49.96
09-06-2024	20 Hrs	6159	319	216	6694	7322	1411	5611	0	-1871	18662	0	18662	698	423	22159	22159	49.98
Maximum		7264	1232	373	8286	8696	1411	6975	0	-1871	21991	0	21991	1284	503	26138	26138	50.05
Minimum		6159	229	216	6694	7322	148	5611	0	-2275	18662	0	18662	698	228	22159	22159	49.96
Average		6858	570	287	7715	8158	889	6596	0	-2059	20766	0	20766	1034	361	24754	24754	50.00

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03-06-2024	5 Hrs	6336	126	289	6750	9186	970	6538	0	-1629	21404	0	21404	722	489	24656	24656	49.96
04-06-2024	4 Hrs	6777	124	290	7190	9114	477	6436	0	-1613	21210	0	21210	855	494	24566	24566	49.96
05-06-2024	4 Hrs	6859	160	290	7310	8135	627	6383	0	-1870	20208	0	20208	859	238	23552	23552	49.96
06-06-2024	5 Hrs	6632	126	290	7048	8753	783	6097	0	-1975	20283	0	20283	703	189	23573	23573	50.03
07-06-2024	4 Hrs	7187	184	287	7658	7545	891	5602	0	-2032	19279	0	19279	692	241	22629	22629	50.03
08-06-2024	8 Hrs	6456	209	285	6950	7887	295	5193	448	-1565	18711	0	18711	652	471	21896	21896	49.99
09-06-2024	24 Hrs	6349	181	296	6826	4575	1030	6060	0	-1397	16608	0	16608	919	495	19905	19905	50.03
Maximum		7187	209	296	7658	9186	1030	6538	448	-1397	21404	0	21404	919	495	24656	24656	50.03
Minimum		6336	124	285	6750	4575	295	5193	0	-2032	16608	0	16608	652	189	19905	19905	49.96
Average		6657	158	290	7105	7885	725	6044	64	-1726	19672	0	19672	772	374	22968	22968	49.99

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
03-06-2024	157.926	17.919	7.654	183.499	0.000	215.723	223.732	19.876	155.807	16.185	25.070	11.496	-47.809	531.291	84.375	627.656
04-06-2024	163.805	8.270	7.665	179.740	0.000	224.666	232.235	14.714	149.040	15.176	26.089	9.743	-49.488	521.854	85.320	619.168
05-06-2024	157.097	9.201	8.219	174.517	0.000	222.741	230.308	13.749	145.308	15.321	24.988	5.727	-54.064	505.752	84.779	602.351
06-06-2024	162.506	6.250	7.484	176.240	0.027	213.190	219.825	16.525	148.820	14.976	23.990	5.469	-56.031	501.687	85.490	599.210
07-06-2024	166.714	6.235	6.813	179.762	0.104	194.540	201.051	13.773	142.748	16.233	23.390	9.297	-51.893	483.362	84.580	579.743
08-06-2024	157.188	5.930	6.777	169.895	0.132	198.404	202.165	7.295	143.345	14.518	21.129	10.691	-47.704	474.159	79.524	565.277
09-06-2024	139.301	4.935	4.021	148.257	0.235	176.045	185.241	19.804	134.501	13.969	18.883	9.553	-39.761	441.587	68.197	521.012
Maximum	166.714	17.919	8.219	183.499	0.235	224.666	232.235	166.714	155.807	16.233	26.089	11.496	-39.761	531.291	85.490	627.656
Minimum	139.301	4.935	4.021	148.257	0.000	176.045	185.241	139.301	134.501	13.969	18.883	5.469	-56.031	441.587	68.197	521.012
Average	157.791	8.391	6.948	173.130	0.071	206.473	213.508	157.791	145.653	15.197	23.363	8.854	-49.536	494.242	81.752	587.774

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
03-06-2024	0.328	0.976	66.524
04-06-2024	0.133	1.109	66.391
05-06-2024	0.158	1.267	66.233
06-06-2024	0.073	1.340	66.160
07-06-2024	0.072	1.413	66.087
08-06-2024	0.082	1.495	66.005
09-06-2024	0.052	1.546	65.954

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 03/Jun/2024 to 09/Jun/2024

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
03-06-2024	MONDAY	108.804	9207	114.928	4789	223.732	9322	215.723	8988	-8.009	-334
04-06-2024	TUESDAY	110.117	9554	122.118	5088	232.235	9676	224.666	9361	-7.569	-315
05-06-2024	WEDNESDAY	109.766	9476	120.542	5023	230.308	9596	222.741	9281	-7.567	-315
06-06-2024	THURSDAY	115.761	9055	104.064	4336	219.825	9159	213.190	8883	-6.635	-276
07-06-2024	FRIDAY	109.466	8286	91.585	3816	201.051	8377	194.540	8106	-6.511	-271
08-06-2024	SATURDAY	95.214	8317	106.951	4456	202.165	8424	198.404	8267	-3.761	-157
09-06-2024	SUNDAY	101.187	7634	84.054	3502	185.241	7718	176.045	7335	-9.196	-383
Total		750.314		744.243		1494.557		1445.309		-49.248	

Generator Unit Outages/Trippings from 03.06.2024 to 09.06.2024						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	NOPPA
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	NOPPA
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	NOPPA
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	NOPPA
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	19-05-2024	02:00	05-06-2024	10:15	As per MSEDCL zero schedule.	ZEROSCH/R SD
Ghatghar Unit-2	26-05-2024	13:17		Continued.	Stator Earth Fault	FORCED
RPL(AMT) U-4	28-05-2024	18:57	04-06-2024	11:27	Due to ID Fan tripped on high vibration..	FORCED
Paras Unit 4	01-06-2024	02:27	03-06-2024	19:36	Drum level low	FORCED
Uran Unit 6	02-06-2024	02:00	03-06-2024	14:44	Due to Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Khaparkheda Unit 3	02-06-2024	03:05	04-06-2024	03:23	Boiler Tube Leakage	FORCED
Paras Unit 3	02-06-2024	06:16	03-06-2024	02:23	Valve malfunction operate.	FORCED
Chandrapur Unit 9	02-06-2024	22:52	05-06-2024	17:17	Condenser Vacuum low	FORCED
Bhusawal Unit 3	03-06-2024	00:30	06-06-2024	22:45	Boiler tube leakage (On tolling).	FORCED
Parli Unit 7	03-06-2024	22:36	05-06-2024	16:28	Boiler Tube Leakage	FORCED
Uran Unit 6	04-06-2024	02:00	04-06-2024	12:30	As MSEDCL requirement	ZEROSCH/R SD
RPL(AMT) U-5	04-06-2024	09:30	04-06-2024	11:14	Drum level low	FORCED
AEML Unit 2	04-06-2024	16:58	07-06-2024	07:46	Boiler Tube Leakage	FORCED
Uran Unit 6	04-06-2024	18:16	04-06-2024	21:58	As per MSEDCL requirement	ZEROSCH/R SD

Uran Unit 6	05-06-2024	02:00	05-06-2024	09:55	As per MSEDCL requirement	ZEROSCH/R SD
Paras Unit 4	05-06-2024	03:59		Continued.	Fire in GT	FORCED
Trombay 8	05-06-2024	08:36	05-06-2024	15:39	Tripped on Class A Protection due to GT8 -Y Phase Tower string Insulator shattering.	FORCED
Uran Unit 5	05-06-2024	17:00		Continued.	Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Uran Unit 6	05-06-2024	17:15	06-06-2024	09:50	Zero Schedule given by MSEDCL.	ZEROSCH/R SD
IEPL Unit 1	05-06-2024	17:46	05-06-2024	20:21	ID Fan Problem	FORCED
IEPL Unit 1	05-06-2024	20:25	06-06-2024	22:37	ID Fan Problem	FORCED
Bhusawal Unit 5	05-06-2024	22:05	06-06-2024	11:49	Air heater problem	FORCED
IEPL Unit 1	05-06-2024	23:25	06-06-2024	01:20	Protection MS temperature malfunction	FORCED
Uran Unit 6	06-06-2024	17:40		Continued.	Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Nasik Unit 4	06-06-2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	FORCED
Chandrapur Unit 5	07-06-2024	09:57	09-06-2024	22:07	Suspected BTL	FORCED
Chandrapur Unit 6	08-06-2024	00:14		Continued.	Boiler Tube Leakage	FORCED
Parli Unit 7	08-06-2024	21:00		Continued.	Zero Schedule by MSEDCL.	ZEROSCH/R SD
Parli Unit 6	08-06-2024	21:13		Continued.	Zero Schedule by MSEDCL.	ZEROSCH/R SD
Uran Unit 8	09-06-2024	01:41	09-06-2024	17:53	Air Filter Replacement.	FORCED
Uran Unit B0	09-06-2024	02:22	09-06-2024	08:29	Instrumentation problem	FORCED
Parli Unit 8	09-06-2024	20:50		Continued.	Zero Schedule given by MSEDCL.	ZEROSCH/R SD

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	04-06-2024	06:24	04-06-2024	14:14	Unbalanced level 2 Protection	T	500 KV
220 KV PARLI (400 KV)- GIRWALI I/C 2	26-05-2024	15:40	05-06-2024	00:26	6 Nos. Tower collapsed (Loc no 36- 41) .	T	400 KV
220 KV KHADKA (400 KV) - CHALISGAON CKT -3	03-06-2024	08:31	03-06-2024	13:35	For restringing of conductor.	PO	400 KV
BABHALESHWAR - PADGHE CKT - 2	03-06-2024	17:44	03-06-2024	23:42	Tripped on distance protection	T	400 KV
400/132 KV 200 MVA ICT - 1 @	03-06-2024	20:19	03-06-2024	22:50	Differential Protection	T	400 KV
400/132 KV 200 MVA ICT - 2 @ KHADKA	03-06-2024	20:19	03-06-2024	22:58	Differential Protection	T	400 KV
400/132 KV 200 MVA ICT - 2 @ KHADKA	03-06-2024	23:26			Differential protection	T	400 KV
400/220/33 KV 315MVA ICT - 3 @ KHADKA	03-06-2024	20:24	03-06-2024	23:10	NDR protection	T	400 KV
400/220/33KV 500 MVA ICT - 1 @ KUDUS	04-06-2024	08:39	04-06-2024	13:52	for Pre-monsoon activity work of 400/220/33kv ICT-1.	PO	400 KV
50 MVAr BUS REACTOR - 1 @ JAIGAD	04-06-2024	10:29	08-06-2024	16:00	CSD RELAY INTALLATION AND COMMISIONING AT JAIGAD END	PO	400 KV
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	05-06-2024	06:50	05-06-2024	11:50	for repairing of conductor strand at loc .9-10,51-52, 3-4	PO	400 KV
KORADI - KHAPERKHEDA CKT - 1	05-06-2024	09:14	05-06-2024	16:47	DCRM,CB Timing &CRM of Main & Tie CB	PO	400 KV
400/11.5KV STATION TRANSFORMER - 1 @ TIRORA	05-06-2024	11:23	05-06-2024	19:51	MCT Testing work	PO	400 KV
400/220/33 KV 315MVA ICT - 3 @ KARAD	05-06-2024	16:35	06-06-2024	01:59	Tripped on differential protection	T	400 KV
BUS REACTOR (125 MVAr) @ ALKUD	05-06-2024	12:28	05-06-2024	19:25	Diagnostic testing & Maintenance work	PO	400 KV
JEJURI- KOYNA STAGE-IV	05-06-2024	12:53	05-06-2024	13:42	Tripped from Koyna stage IV only with no indication	T	400 KV
LONIKAND I - KOYNA STAGE-IV	05-06-2024	12:53	06-06-2024	01:59	Tripped on distance protection	T	400 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAIN BAY (401) OF BUS REACTOR @ ALKUD	05-06-2024	12:28	05-06-2024	19:25	Diagnostic testing & Maintenance work	PO	400 KV
PUNE(GIS) - TALEGAON(PG) CKT - 4	05-06-2024	17:13	06-06-2024	00:15	Tripped on distance protection	T	400 KV
THAPTI TANDA - AURANGABAD (WALUJ)	05-06-2024	09:24	05-06-2024	23:13	DISTANCE PROTECTION RELAY RETROFITTING WORK.	PO	400 KV
TIE BAY - 402 OF BUS REACTOR @ ALKUD	05-06-2024	12:28	05-06-2024	19:25	Diagnostic testing & Maintenance work	PO	400 KV
KALWA - TALEGAON (PG)	06-06-2024	16:16	06-06-2024	16:42	HT due to heavy sparking on 29 D isolator at Kalwa ss	HT	400 KV
220 KV CHANDRAPUR (400 KV) - TADALI CKT	06-06-2024	07:00	06-06-2024	12:23	DAIGONISTIC TESTING WORK AT BOTH END	PO	400 KV
220 KV DEEPNAGAR (400 KV) - BAMBHORI CKT	06-06-2024	11:09	06-06-2024	17:00	FOR REPLACEMENT OF OLD FAULTY INSULATORS OF LOC NO 05,06,11,12 & 13	PO	400 KV
400/220KV 500MVA ICT - 1 @ KARJAT	06-06-2024	09:34	06-06-2024	20:56	All Isolator Alignment work (related to ICT-1 bay) to be done by Agency, Diagnostic Testing Pre Monsoon Maintenance and relay testing work.	PO	400 KV
DABHOL - NEW KOYNA CKT - 1	06-06-2024	05:24	06-06-2024	17:20	Tripped on distance protection	T	400 KV
JAIGAD - KARAD CKT - 2	06-06-2024	18:46	07-06-2024	15:05	Tripped on distance protection	T	400 KV
MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	06-06-2024	05:57	06-06-2024	14:51	Diagnostic testing and Pre Monsoon Maintenance	PO	400 KV
PARLI - KUMBHARGAON (NANDED) CKT - 1	06-06-2024	06:32	06-06-2024	13:03	DCRM of 410 CB and Routine maintenance & Relay Testing work.	PO	400 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	06-06-2024	05:57	06-06-2024	14:51	Diagnostic testing and Pre Monsoon Maintenance	PO	400 KV
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	07-06-2024	19:06	08-06-2024	00:10	Attending sound observed at loc 112 & attend broken conductor strands at loc 28-29.	T	400 KV
NAGOTHANE - DABHOL CKT - 2	07-06-2024	21:34	07-06-2024	23:18	Tripped at Dabhol end only	T	400 KV
105 MVA SPARE ICT @ CHAKAN	07-06-2024	13:47	07-06-2024	17:01	For Routine Pre-monsoon Maintenance and DT.	PO	400 KV
220/33 KV 50 MVA TF - 2	07-06-2024	19:53	07-06-2024	20:37	LV tripped on backup protection.	T	400 KV
400/11.5KV STATION TRANSFORMER - 2 @ TIRORA	07-06-2024	09:59	07-06-2024	18:01	MCT Testing work	PO	400 KV
400/220/33 KV 315MVA ICT - 1 @ AKOLA	07-06-2024	08:47	07-06-2024	09:11	For passing the truck of transformer of 220KV below LV 220line at 400 kV RS Akola.	PO	400 KV
400/220/33 KV 315MVA ICT - 2 @ AKOLA	07-06-2024	08:48	07-06-2024	09:13	for passing the truck of transformer of 220KV s/st below LV 220line at 400 kV RS Akola.	PO	400 KV
400/220KV 500MVA ICT - 2 @ KARJAT	07-06-2024	09:35	07-06-2024	20:26	All Isolator Alignment work (related to ICT-II bay) to be done by agency, Diagnostic Testing, Pre Monsoon Maintenance and relay testing work.	PO	400 KV
400/220kv 500MVA ICT-1 @ TAPTITANDA	07-06-2024	16:24	07-06-2024	19:12	Ref relay replacement work.	T	400 KV
400KV RPL-AKOLA2 CKT 1	07-06-2024	17:01	07-06-2024	18:44	Tripped on distance protection.	T	400 KV
400KV TIE BAY 405 GT 1 -AKOLA 2 CKT 2 @ NANDGAONPETH	07-06-2024	17:21	07-06-2024	18:15	Tripped due to ar optd of 400kv ripl akola ad ckt 2.	T	400 KV
LONIKAND 2 - KARJAT CKT - 1	07-06-2024	04:00	07-06-2024	04:56	Tripped from Karjat end only	T	400 KV
400/11.5KV STATION TRANSFORMER - 3 @ TIRORA	08-06-2024	09:48	08-06-2024	19:03	MCT Testing work	PO	400 KV
400/220/33 KV 501MVA ICT - 5 @ BABHALESHWAR	08-06-2024	10:34	08-06-2024	20:41	Bushing tan D testing work and bay maintenance work	PO	400 KV
BUS REACTOR (125 MVAR) @ LONIKAND 2	08-06-2024	08:46	08-06-2024	16:00	DT and HYM	PO	400 KV
PARLI - KARJAT CKT - 1	08-06-2024	05:51	08-06-2024	13:33	Y ph LA failure at Parly end	T	400 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BABHALESHWAR - PADGHE CKT- 1	09-06-2024	01:56	09-06-2024	10:49	Tripped on distance protection	T	400 KV
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	09-06-2024	11:29	09-06-2024	16:57	Attending red hot glow on B-ph 89L isolator		400 KV
MAIN BAY (407) OF ICT-1 @ KUDUS	09-06-2024	14:23	09-06-2024	18:13	FOR Safety purpose to carry out R phase of ICT-2 bottom plate Oil leakage attending by main gasket replacement by M/s GE . Currently 400/220/33kV, 500MVA ICT-1 is charged through Spare ICT Unit as Rph Unit of ICT-1 is faulty. And its Neutral IPS is crossing thru ICT-2 units.	PO	400 KV
MAIN BUS-1 @ BABHALESHWAR	09-06-2024	11:15	09-06-2024	16:05	Connection of Hanger rod assembly on 400 kV Main Bus-I in Reactor-II Bay by Hot Line Method	PO	400 KV
HINJEWADI 2 - HINJEWADI 3 CKT - 1	24-05-2024	12:34	03-06-2024	19:48	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay	PO	220 KV
LAMBOTI - PANDHARPUR	26-05-2024	17:25	06-06-2024	00:45	TOWER COLLAPSED AT LOC.414-419.	T	220 KV
132 KV GHATODI (220 KV) - DIGRAS CKT	26-05-2024	15:36	04-06-2024	15:59	6 Nos. Tower collapsed (Loc no 99-104).	T	220 KV
132 kv GHATODI ARNI	26-05-2024	15:36	04-06-2024	15:57	6 Nos. Tower collapsed (Loc no 99-104) .	T	220 KV
LAMBOTI - KARKAMB	26-05-2024	17:25	06-06-2024	00:44	TOWER COLLAPSED AT LOC.414-419.	T	220 KV
PARLI (OLD GCR) - PARLI (PG) CKT 2	26-05-2024	15:40	05-06-2024	00:26	6 Nos. Tower collapsed (Loc no 36- 41) .	T	220 KV
GORAI -MSETCL BORIVALI CKT -1	28-05-2024	17:59	04-06-2024	01:13	Bus fault	T	220 KV
BHUGAON - WARDHA (PG)	02-06-2024	23:10	03-06-2024	00:10	H/T due to State OD at Low frequency.	HT	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KAMBA - VASAI	02-06-2024	04:39	03-06-2024	01:17	1) Cut point formation over newly erected monopole & work will be carried out at loc no 4 9 and also related de-stringing & stringing work will be carried out. 2) Dismantling of old existing tower no. 53 & 54. 3) After cut point formation & conductor stringing work kamba- Vasai line will be charged at 22:00 Hrs of 02.06.2024.		220 KV
KAMBA - VASAI	02-06-2024	04:39	03-06-2024	01:17	work 1) Cut point formation over newly erected Monopole work will be carry out at loc.no.48,49 and amp;49A on 220kV Kamba-Vasai line and also related tower 65533;s conductor destringing & stringing work will be carry out of above said ckt. 2) Dismantaling work of old existing tower at Loc.No.48 & 49	PO	220 KV
KAMBA - VASAI	02-06-2024	04:39	03-06-2024	01:17	Work of replacement of old C&R panel by new and diagnostic testing work		220 KV
CHIKHALI-JALNA I	03-06-2024	12:24	03-06-2024	17:54	For replacement of damage earth wire span.	PO	220 KV
CHIKHALI-JALNA II	03-06-2024	12:25	03-06-2024	17:54	For replacement of damage earth wire span.	PO	220 KV
EKLAHARE (OCR) - NAVASARI CKT - 1	03-06-2024	08:46	03-06-2024	13:29	Routine maintenance	PO	220 KV
HALKARNI-OLAM AGRO (HEMRUS) LINE	03-06-2024	09:42	03-06-2024	14:02	QM work of Olam bay	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
TALANDGE - SAWANTWADI	03-06-2024	10:50	03-06-2024	14:56	Insulator replacement work	PO	220 KV
100 MVA 220/132 KV ICT II	03-06-2024	09:35	03-06-2024	14:02	Tan delta testing of ict will be carried out by mobile testing unit, Akola.	PO	220 KV
200 MVA 220/132 KV ICT 1 @ GIRWALI	03-06-2024	11:36	03-06-2024	13:34	Current mismatch and consumption mismatch observed during reading.	PO	220 KV
200 MVA 220/132 KV ICT 2 @ GIRWALI	03-06-2024	14:44	03-06-2024	17:14	To check CT cables.	PO	220 KV
220 KV /132 KV 100 MVA ICT 1 @ CHITEGAON	03-06-2024	08:15	03-06-2024	09:45	Hot spot is observe on R-ph lv side bushing.	PO	220 KV
220 KV DHULE(400 KV) - AMALNER	03-06-2024	07:37	03-06-2024	08:47	For replacement flash over string.	PO	220 KV
220 KV WARORA - CHANDRAPUR (400 KV) CKT	03-06-2024	22:54	03-06-2024	02:16	Y phase CC caught fire at warora end	HT	220 KV
220/110 KV ICT - 1 @ BHIRA	03-06-2024	09:40	03-06-2024	12:08	PM CHECKS	PO	220 KV
220/110 KV ICT - 2 @ BHIRA	03-06-2024	14:15	03-06-2024	15:33	PM CHECKS	PO	220 KV
220/33 kv 50 MVA BBL PTR 2 @ MUDSHINGI	03-06-2024	09:24	03-06-2024	16:28	Quarterly maint. work	PO	220 KV
220/33KV 50MVA PTR 3	03-06-2024	11:44	03-06-2024	14:21	Pre-monsoon maintenance work.	PO	220 KV
220/33kv 50MVA TF-3 @ 5 STAR MIDC	03-06-2024	10:34	03-06-2024	13:30	for pre monsoon maintenance work	PO	220 KV
KHADKI- CENTURY ENKA	03-06-2024	07:08	03-06-2024	16:28	Stringing of conductor from loc 30-30A and stringing of earthwire loc 29A-30 river crossing.	PO	220 KV
MAIN BUS @ ONI	03-06-2024	09:36	03-06-2024	18:08	1) For changing Line CT Ratio of 220 kV Oni-Kharepatan Line at both end S/s 2) Replacement of 220kV PT Y Phase of 220 kV Main Bus	PO	220 KV
MHAISAL - ALKUD	03-06-2024	17:24	04-06-2024	02:06	Wedge Connector Work	PO	220 KV
PALGHAR - NALASOPARA	03-06-2024	04:27	03-06-2024	08:30	Replacement of Insulator String Identified in PID.	PO	220 KV
BUTIBORI 3-PURTI	04-06-2024	15:00	04-06-2024	18:22	Line Maintenance work	PO	220 KV
BUTIBORI-BUTIBORI 3	04-06-2024	11:00	04-06-2024	13:00	Testing work	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PHURSUNGI-PARVATI	04-06-2024	16:46	04-06-2024	19:33	tripped on distance protection	T	220 KV
220 KV KARJAT-BELWANDI-CKT-1	04-06-2024	16:25	04-06-2024	16:49	Tripped on distance protection	T	220 KV
220 KV WARORA - CHANDRAPUR (400 KV) CKT	04-06-2024	22:54	04-06-2024	02:16	Y phase CC caught fire at warora end	HT	220 KV
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	04-06-2024	10:31	04-06-2024	12:26	Restrnging of earthwire	PO	220 KV
JEJURI - KONDHWA	04-06-2024	17:48	04-06-2024	18:02	Tripped on back up overcurrent	T	220 KV
MAIN BUS-2 @ HINJEWADI 3(GIS)	04-06-2024	13:02	05-06-2024	18:44	Bus Extension for Bay 208 of 220kV Nxta2 Ss for project work	PO	220 KV
PARANDA - OSMANABAD	04-06-2024	16:24	04-06-2024	16:38	Distance Protection	T	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 4	04-06-2024	01:42	04-06-2024	09:13	Resagging of conductor at S G Barve Metro - 2B crossing	PO	220 KV
WAGHIVALI - DHARAVI 7	04-06-2024	01:25	04-06-2024	09:40	Resagging of conductor at S G Barve Metro - 2B crossing	PO	220 KV
AMBAZARI-KALMESHWAR	05-06-2024	07:57	05-06-2024	14:42	STRINGING OF EARTHWIRE FROM LOC NO 148 - 152	PO	220 KV
BUTIBORI-BUTIBORI 3	05-06-2024	08:12	05-06-2024	14:42	FOR DIAGNOSTIC TESTING WORK.	PO	220 KV
DAHANU - VIRAJ	05-06-2024	09:31	05-06-2024	18:56	To control MVAR export form DTPS to Boisar	HT	220 KV
EKLAHARE (GCR) - AIROLI KNOW PARK	05-06-2024	00:16	05-06-2024	06:09	1) Making bunching of 220kV AKP-Nashik & 220kV NTT-Bapgaon line at Loc no. 398 for the work of 220kV GIS Substation of M/s Gigaplex (PDG)	PO	220 KV
POPHLI PEDHMBE LINE- 1	05-06-2024	11:00	05-06-2024	17:30	For emergency tree cutting work nut bolt tightening and other line maintenance work.	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
POPHLI PEDHMBE LINE- 1	05-06-2024	11:00	05-06-2024	17:30	For emergency tree cutting work nut bolt tightening and other line maintenance work.	PO	220 KV
132 KV TSS CKT - I	05-06-2024	02:50	05-06-2024	03:26	Y PH, Z1, 4.42KM	T	220 KV
200 MVA 220/132 KV ICT 3 @ GIRWALI	05-06-2024	09:44	05-06-2024	10:54	PREMANSOON MAINTENANCE WORK	PO	220 KV
220 KV ANJANGAON (VIHIGAON) - AKOLA CKT II	05-06-2024	12:40	05-06-2024	14:10	DAMPER REPLACEMENT AT LOC. NO. 105 R-PH & 109 R & B-PH	PO	220 KV
220/100 KV 200 MVA ICT 2 @ PAL-DOMBIVALI	05-06-2024	10:02	05-06-2024	12:32	Pre-Monsoon maintenance work.	PO	220 KV
220/132 KV 100 MVA ICT 2 @ BALAPUR	05-06-2024	08:40	05-06-2024	19:39	FOR RELAY TESTING AND ICT PAINTING ALONG WITH PRE-MONSOON MAINTENANCE AT 220 KV BALAPUR SUBSTATION.	PO	220 KV
220/132 KV 100 MVA ICT 2 @ PARANDA	05-06-2024	12:19	05-06-2024	15:05	FOR PRE MONSOON WORK OF ICT AND FOR PROTECTION TRAILS OF AUX RELAYS	PO	220 KV
220/132 KV 200 MVA ICT 2 @ KAULEWADA	05-06-2024	10:27	05-06-2024	16:27	RELAY REPLACEMENT	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132kV 100 MVA ICT- 2 @ PALGHAR-220 KV	05-06-2024	09:40	05-06-2024	11:53	Pre monsoon maintenance work. Covering polythene to buchholz, PRV &OSR relay.	PO	220 KV
220/7 KV 50 MVA STATION T/F II	05-06-2024	04:27	05-06-2024	17:30	HOT SPOT NEAR BUSHING R-Y PH	HT	220 KV
AMALNER(220KV)-CHOPDA CKT - 1	05-06-2024	06:15	05-06-2024	14:10	DIST PROT Z1 B PH D= 22 KM IF=3.46 KA	T	220 KV
BUS COUPLER @ PHURSUNGI	05-06-2024	10:00	05-06-2024	13:05	Replacement of Aux. switch (RPH) of CB	PO	220 KV
NTT - BAPGAON	05-06-2024	00:18	05-06-2024	06:18	1) Making bunching of 220kV AKP-Nashik & 220kV NTT-Bapgaon line at Loc no. 398 for the work of 220kV GIS Substation of M/s Gigaplex (PDG).	PO	220 KV
NTT - KALWA	05-06-2024	00:20			For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.	PO	220 KV
PALGHAR - NALASOPARA	05-06-2024	04:46	05-06-2024	09:17	Replacement of Insulator String Identified in PID.	PO	220 KV
WAGHIVALI - DHARAVI 7	05-06-2024	01:42	05-06-2024	05:21	Resagging of conductor at S G Barve Metro - 2B crossing	PO	220 KV
WAGHIVALI - DHARAVI 8	05-06-2024	01:42	05-06-2024	05:21	Project work----Resagging of conductor in span 38-39 at S G Barve Metro - 2B crossing	PO	220 KV
ABHIJEET-WARDHA-1	06-06-2024	12:32	06-06-2024	15:40	R PH, Z1, 18.8 KM, 5.82 KA. A - Z1, R PH, 29.77 KM.	T	220 KV
DAHANU - VIRAJ	06-06-2024	09:02	06-06-2024	14:02	Inspection & Preventive Maintenance of circuit breaker	PO	220 KV
DAHANU - VIRAJ	06-06-2024	09:02	06-06-2024	14:27	Pre Monsoon Maintenance.	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
GIS BHANDUP - BORIVALI	06-06-2024	00:42	06-06-2024	06:38	For the installation of saver assembly sets at TL no. 23 & 26. (Total 12 sets are to be installed) Total Completed 24 sets out of 48 sets.	PO	220 KV
JEJURI (400KV) - BARAMATI CKT	06-06-2024	15:26	07-06-2024	01:44	Retrofitting of Distance Protection Relay to be carried out by M/s GE.	PO	220 KV
KHARGHAR - SONKHAR	06-06-2024	22:37	07-06-2024	01:54	For the installation of saver assembly sets at TL no. 679 (Total 3 sets out of 6 sets are to be installed)	PO	220 KV
TALOJA II - OCIL 1	06-06-2024	08:08	06-06-2024	19:20	Preventive Maintenance & Testing of switchgear at OCIL end	PO	220 KV
220 KV AMRAVATI - KARANJA CKT	06-06-2024	15:50	06-06-2024	20:14	R P H Y P H 3.3KA 17.8KM Z1	T	220 KV
220/100 KV 100 MVA ICT 1 @ JAMBHUL	06-06-2024	09:13	06-06-2024	11:20	Premonsoon Maintenance Work, Plastic paper wrapping to TF Auxiliaries	PO	220 KV
220/100 KV 125 MVA ICT 2 @ JAMBHUL	06-06-2024	11:26	06-06-2024	12:47	Premonsoon Maintenance Work, Plastic paper wrapping to TF Auxiliaries.	PO	220 KV
220/110kv 100MVA ICT-1@ NIWALI	06-06-2024	10:51	07-06-2024	17:44	HV CB overhauling work	PO	220 KV
220/132 KV 200 MVA ICT 3	06-06-2024	08:24	06-06-2024	10:26	FOR PREMONSOON MAINTENANCE AND RM WORK OF BAY	PO	220 KV
220/132 KV 200MVA ICT 2 @ KURKUMBH	06-06-2024	13:20	06-06-2024	14:30	Pre monsoon Maintenance work	PO	220 KV
220/132KV 200MVA ICT 1 @ KURKUMBH	06-06-2024	10:15	06-06-2024	12:35	Pre monsoon Maintenance work	PO	220 KV
35 MVA 220/ 6.6 KV STN TF - II @ PARLI U-8	06-06-2024	09:35	06-06-2024	11:30	PREMANSOON MAINT WORK	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KHARGHAR - BORIVALI CKT - 2	06-06-2024	00:44	06-06-2024	06:41	For the installation of saver assembly sets at TL no. 23 & 26. (Total 12 sets are to be installed) Total Completed 24 sets out of 48 sets	PO	220 KV
KHARGHAR - NET MAGIC GIS	06-06-2024	22:26	07-06-2024	02:07	For safety purpose during saver assembly installation work on 220 kV Kharghar-Sonkhar line	PO	220 KV
PALGHAR - NALASOPARA	06-06-2024	04:44	06-06-2024	09:02	Replacement of Insulator String Identified in PID.	PO	220 KV
PALGHAR - PANCHALI TSS	06-06-2024	04:20	06-06-2024	08:59	Replacement of Rusted Insulator strings at Loc No.06, 21 &18.	PO	220 KV
THEUR - SERUM	06-06-2024	13:26	06-06-2024	21:43	1)Attending hotspot by double jumpering work at L. N -1 (DC tower)- Y Phase-52.9 Degree L.N.-26(MC tower)-B Phase-65 Degree L.N.-30A(MC tower)-B Phase-58 degree	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 3	06-06-2024	01:35	06-06-2024	07:40	Project Work for - Resagging of conductor in span 38-39 at S G Barve Metro - 2B crossing	PO	220 KV
WAGHIVALI - DHARAVI 8	06-06-2024	01:19	06-06-2024	07:30	METRO PROJECT WORK	PO	220 KV
ABHIJEET-WARDHA-1	07-06-2024	10:51	07-06-2024	18:01	Testing backup & distance relay of 220kv abhijit ckt i & cb timing & crm testing (work will be carried out by testing sdn, wardha.	T	220 KV
ALEPHATA-PARGAON(KATHAPUR)	07-06-2024	18:02	08-06-2024	14:05	Tripped on distance protection.	T	220 KV
KALWA - TFIPL	07-06-2024	09:27	07-06-2024	22:41	For removing the jumpers at Loc. No. 40, for making LILO through at 220 Pawane GIS S/st.	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KANDALGAON - SONA ALLOYS	07-06-2024	08:24	07-06-2024	14:31	Emergency tree cutting at Loc.No.59-61,126-127 and Other line maintenance work.	PO	220 KV
NAGOTHANE - ACCIL	07-06-2024	17:18	07-06-2024	17:36	Premonsoon maintenance work.	PO	220 KV
NAGOTHANE - IPCL	07-06-2024	09:04	07-06-2024	12:07	Premonsoon maintenance work.	PO	220 KV
NAGOTHANE - POSCO	07-06-2024	17:56	07-06-2024	18:11	Premonsoon maintenance work.	PO	220 KV
NAGOTHANE - SPCL	07-06-2024	12:39	07-06-2024	15:48	Premonsoon maintenance work.	PO	220 KV
TALOJA II - OCIL 2	07-06-2024	13:30	07-06-2024	21:00	Preventive Maintenance & Testing of switchgear at OCIL end	PO	220 KV
TILLARI - AMONA LINE	07-06-2024	02:55	07-06-2024	04:46	Tripped on distance protection	T	220 KV
220 KV CHANDRAPUR - 2-BALLARSHAH CKT	07-06-2024	07:52	07-06-2024	22:02	Line maintenance .	T	220 KV
220/132 KV 100 MVA ICT 1 @ BALAPUR	07-06-2024	08:29	07-06-2024	19:44	Pre- Monsoon.	HT	220 KV
220/132 KV 200 MVA ICT 1	07-06-2024	08:44	07-06-2024	10:32	Pre- Monsoon work.	HT	220 KV
220/132KV 100MVA ICT 2 @ SATARA MIDC	07-06-2024	11:08	07-06-2024	16:40	Replacement of unhealthy 100MVA 220/132kV ICT-2 LV back up relay	PO	220 KV
220/132KV 100MVA ICT I	07-06-2024	09:04	07-06-2024	17:12	Pre- Monsoon work.	HT	220 KV
220/22KV 50MVA PTR - 1 @ PALAVA	07-06-2024	08:15	07-06-2024	09:42	Pre-monsoon maintenance work.	PO	220 KV
220/22KV 50MVA PTR - 2 @ PALAVA	07-06-2024	10:10	07-06-2024	11:37	Pre-monsoon maintenance work	PO	220 KV
220/33 KV 50 MVA PTR 1 @ MALEGAON	07-06-2024	13:55	07-06-2024	15:36	For LV Incomer CB overhauling work	PO	220 KV
220KV PADEGAON WALUJ CKT 3	07-06-2024	09:15	07-06-2024	21:57	Distance relay retrofitting.	HT	220 KV
BADNERA - NANDGAON PETH	07-06-2024	17:03	07-06-2024	17:48	AT B E= R PH, Z2, IF = 2.917KA, D=42.21KM, AT N E= R PH, D=9.50KM, IF=2.92KA.	T	220 KV
BORIVALI - BOISAR II LINE	07-06-2024	22:31	08-06-2024	07:06	For the installation of saver assembly sets at TL no. 181, 182 & 184 (Total 24 sets to be installed).	PO	220 KV
EKLAHARE (OCR) - NAVASARI CKT - 2	07-06-2024	16:30	07-06-2024	23:22	Tripped on distance protection.	T	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
GHODBUNDER - MSETCL BOISAR	07-06-2024	22:29	08-06-2024	07:01	or the installation of saver assembly sets at TL no. 181, 182 & 184 (Total 24 sets to be installed).	PO	220 KV
KHARGHAR - BORIVALI CKT - 2	07-06-2024	09:33	07-06-2024	15:27	Simultaneously outage is required on 220 KV Kharghar-Borivali Ckt-2 & Kharghar-Netmagic line for safety purpose on 07.06.2024 from @ 08:00 Hrs to 12:00 Hrs during removing the jumpers at Loc. No. 40, for making LILO through at 220 Pawane GIS S/st on 220kV Kalwa-Tfipl.	PO	220 KV
KHARGHAR - NET MAGIC GIS	07-06-2024	09:23	07-06-2024	15:12	Simultaneously outage is required on 220 KV Kharghar-Borivali Ckt-2 & Kharghar-Netmagic line for safety purpose on 07.06.2024 from @ 08:00 Hrs to 12:00 Hrs during removing the jumpers at Loc. No. 40, for making LILO through at 220 Pawane GIS S/st on 220kV Kalwa-Tfipl.	PO	220 KV
NANDGAON PETH-AMRAVATI	07-06-2024	17:22	07-06-2024	17:53	AT N E= R PH, IF=956KA, D=22.59KM, AT AMT E= R PH, IF=5.044KA, D=15.26KM.	T	220 KV
VANKUSWADE - KDPH	07-06-2024	08:35	07-06-2024	15:15	Cold washing of insulator strings from Loc No.01 to 47	PO	220 KV
AMBAZARI-KALMESHWAR	08-06-2024	10:53	08-06-2024	11:42	Testing work	PO	220 KV
CHIKHALI-JALNA I	08-06-2024	00:35	08-06-2024	00:44	Distance Protection	T	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
EKLAHARE (GCR) - AIROLI KNOW PARK	08-06-2024	12:36	08-06-2024	16:42	To open jumpers of 220 kV AKP-Nashik line at TL No. 396 to make portion of the line from loc no.396 to Eklahare dead for erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333. This arrangement will be kept for 2 days.	PO	220 KV
KHARGHAR - SONKHAR	08-06-2024	22:40	09-06-2024	02:27	FOR FIXING OF 220KV SONKHAR LINE B PHASE BUSHING AFTER CONNECTION OF NEW CABLE END TERMINATION AND STRAIGHT JOINT	PO	220 KV
220 / 110 / 33kV 250MVA ICT 2 @ BORIVALI (TATA)	08-06-2024	08:08	08-06-2024	09:09	BIRD NEST REMOVAL	PO	220 KV
220/100 KV 200 MVA ICT 1 @ APTA	08-06-2024	10:14	08-06-2024	11:40	"1. CTR NIFPS reinstallation and preventive mainetenance work 2.Arresting of oil leakages 3. Bay maintenance work"	PO	220 KV
220/100 KV 200 MVA ICT 2 @ APTA	08-06-2024	11:45	08-06-2024	12:34	Pre monsoon polythene paper wrapping work.	PO	220 KV
220/132 KV 100 MVA ICT 1 @ BALAPUR	08-06-2024	11:38	08-06-2024	18:00	Oil Top Up work	PO	220 KV
220/132 KV 100 MVA ICT 3 @ LONAND	08-06-2024	09:35	08-06-2024	14:03	Pre-monsoon maintenance work & main tank oil top up	PO	220 KV
220/132 KV 100MVA ICT - 1 @ MANMAD	08-06-2024	13:08	08-06-2024	17:42	Diagnostic Testing work & Quarterly Bay maintenance work.	PO	220 KV
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	08-06-2024	10:06	08-06-2024	15:18	1) Diagnostic testing, premansoon work,Attending oil leakage 2) Premansoon work.	PO	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	08-06-2024	16:17	08-06-2024	17:21	1) Diagnostic testing, premansoon work,Attending oil leakage 2) Premansoon work.	PO	220 KV
220/132 KV 200 MVA PTR NO 5 @ PARVATI	08-06-2024	07:50	08-06-2024	12:55	For 132 kV Half Bus Maint. work before monsoon	PO	220 KV
220/33 KV 25MVA PTR2 @ NIWALI	08-06-2024	10:21	09-06-2024	13:15	HV CB overhauling work	PO	220 KV
BOISAR II - VIRAJ	08-06-2024	14:19	08-06-2024	17:57	Pre Monsoon Maintenance.	PO	220 KV
KOLSHET - KHARBAO	08-06-2024	04:17	08-06-2024	15:47	Tripped on distance protection	T	220 KV
MHAISAL - ALKUD	08-06-2024	18:11	08-06-2024	21:24	Wedge connector work	PO	220 KV
NTT - BAPGAON	08-06-2024	12:36	08-06-2024	16:42	1) Currently 220kV Bapgaon-NTT line is tapped on 220kV AKP- Eklahare line & jumper at LILO tower to NTT is open towards 220kV Kalwa. Therefore during above work /s NTT will not have power supply during outage. 2) To open jumpers of 220 kV AKP-Nashik line at TL No. 396 to make portion of the line from loc no.396 to Eklahare dead for erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333. This arrangement will be kept for 2 days.	PO	220 KV
WAGHIVALI - DHARAVI 8	08-06-2024	00:14	08-06-2024	09:05	MANDALE PROJECT WORK IN VICINITY	PO	220 KV
EKLAHARE (OCR) - NAVASARI CKT - 1	09-06-2024	23:20	10-06-2024	01:37	Tripped on distance protection from Nashik end only.	T	220 KV
PADGHE - NALASOPARA	09-06-2024	06:03	09-06-2024	10:56	Tripped on distance protection	T	220 KV

Transmission Line Outages/Trippings from 03.06.2024 to 09.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PIRANGUT - HINJAWADI 2	09-06-2024	07:32	09-06-2024	16:37	Erection of monopole Loc No. 154 & 155 for height raising purpose and stringing of conductor at New Monopole Loc. No. 154-155	PO	220 KV
SADAWAGHAPUR KARAD CKT 1	09-06-2024	23:43	09-06-2024	11:16	HT due to sparking at Karad end Bph WT	HT	220 KV
SADAWAGHAPUR KARAD CKT 2	09-06-2024	11:26	09-06-2024	13:12	Emergency outage availed by Karad	HT	220 KV
220/100 KV 100 MVA ICT 2 @ VASAI II	09-06-2024	11:13	09-06-2024	13:55	For Premonsoon maintenance work, CTR AMC, Hotspot attending, Panel shifting at 100kV Vasai.	PO	220 KV
220/132 KV 100 MVA ICT 1 @ BUTIBORI	09-06-2024	15:11	09-06-2024	19:01	Oil leakage on Y ph bushing		220 KV
220/132kV 100 MVA ICT- 2 @ PALGHAR-220 KV	09-06-2024	06:35	09-06-2024	06:47	HT for safety purpose since Palghar ss went into dark	HT	220 KV
NERLE - PEDAMBE	09-06-2024	01:26	09-06-2024	02:36	Tripped on distance protection	T	220 KV
PANCHALI TSS - BOISAR (PG)	09-06-2024	05:46	09-06-2024	06:38	Maintenance Work at Panchali TSS.	PO	220 KV
VIKHROLI (GIS) - SAKI 7	09-06-2024	11:01	09-06-2024	18:11	ATTENDING HOT SPOT	PO	220 KV
KANHAN-PENCH	05-06-2024	10:30	05-06-2024	16:17	For routine maintenance work	PO	132 KV
KALWA KALYAN	07-06-2024	06:42	07-06-2024	10:57	Guard wire replacement	PO	110 KV
ZONE 1 (BUS SECTION 1& 2) @ KHOPOLI	09-06-2024	06:51	09-06-2024	13:46	R/M AND TESTING	PO	110 KV