

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 28/Jun/2021 to 04/Jul/2021**

**Supply Position During Morning Peak (MW)**

| Date       | Time   | MSGENCO |       |     |       | Central Sector Receipt | Wind | CPP  | SOLAR | TPCL Exch. | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|------------|--------|---------|-------|-----|-------|------------------------|------|------|-------|------------|-----------------------|--------------------|--------------------------|-----------|--------------|------------------|-------------------------|-------|
|            |        | THM     | HYDRO | GAS | Total |                        |      |      |       |            |                       |                    |                          |           |              |                  |                         |       |
|            |        | MW      | MW    | MW  | MW    | MW                     | MW   | MW   | MW    | MW         | MW                    | MW                 | MW                       | MW        | MW           | MW               | MW                      | Hzs   |
| 28-06-2021 | 12 Hrs | 4402    | 443   | 265 | 5110  | 6485                   | 238  | 5477 | 756   | -1495      | 16571                 | 0                  | 16571                    | 1018      | 249          | 19333            | 19333                   | 49.98 |
| 29-06-2021 | 11 Hrs | 4482    | 945   | 276 | 5703  | 6240                   | 285  | 5501 | 874   | -1584      | 17019                 | 0                  | 17019                    | 896       | 248          | 19747            | 19747                   | 50.03 |
| 30-06-2021 | 12 Hrs | 4670    | 325   | 266 | 5261  | 6784                   | 753  | 5483 | 981   | -1565      | 17697                 | 0                  | 17697                    | 1030      | 248          | 20540            | 20540                   | 50.08 |
| 01-07-2021 | 10 Hrs | 3841    | 620   | 264 | 4725  | 7078                   | 1721 | 5339 | 622   | -1460      | 18025                 | 0                  | 18025                    | 947       | 249          | 20681            | 20681                   | 49.95 |
| 02-07-2021 | 12 Hrs | 3236    | 372   | 215 | 3823  | 7014                   | 2081 | 5614 | 894   | -1703      | 17723                 | 0                  | 17723                    | 947       | 249          | 20622            | 20622                   | 50.03 |
| 03-07-2021 | 10 Hrs | 4535    | 417   | 139 | 5091  | 7904                   | 888  | 5664 | 787   | -1414      | 18920                 | 0                  | 18920                    | 818       | 250          | 21402            | 21402                   | 50.00 |
| 04-07-2021 | 12 Hrs | 4301    | 1120  | 137 | 5558  | 8195                   | 310  | 5763 | 1055  | -1353      | 19528                 | 0                  | 19528                    | 599       | 250          | 21730            | 21730                   | 49.87 |
| Maximum    |        | 4670    | 1120  | 276 | 5703  | 8195                   | 2081 | 5763 | 1055  | -1353      | 19528                 | 0                  | 19528                    | 1030      | 250          | 21730            | 21730                   | 50.08 |
| Minimum    |        | 3236    | 325   | 137 | 3823  | 6240                   | 238  | 5339 | 622   | -1703      | 16571                 | 0                  | 16571                    | 599       | 248          | 19333            | 19333                   | 49.87 |
| Average    |        | 4210    | 606   | 223 | 5039  | 7100                   | 897  | 5549 | 853   | -1511      | 17926                 | 0                  | 17926                    | 894       | 249          | 20579            | 20579                   | 49.99 |

**Supply Position During Day Peak (MW)**

| Date       | Time   | MSGENCO |       |     |       | Central Sector Receipt | Wind | CPP  | SOLAR | TPCL Exch. | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|------------|--------|---------|-------|-----|-------|------------------------|------|------|-------|------------|-----------------------|--------------------|--------------------------|-----------|--------------|------------------|-------------------------|-------|
|            |        | THM     | HYDRO | GAS | Total |                        |      |      |       |            |                       |                    |                          |           |              |                  |                         |       |
|            |        | MW      | MW    | MW  | MW    | MW                     | MW   | MW   | MW    | MW         | MW                    | MW                 | MW                       | MW        | MW           | MW               | MW                      | Hzs   |
| 28-06-2021 | 15 Hrs | 4632    | 542   | 275 | 5449  | 6074                   | 447  | 5272 | 487   | -1374      | 16355                 | 0                  | 16355                    | 1017      | 249          | 18995            | 18995                   | 49.97 |
| 29-06-2021 | 16 Hrs | 4555    | 898   | 362 | 5815  | 5806                   | 470  | 5577 | 668   | -1548      | 16788                 | 0                  | 16788                    | 890       | 248          | 19474            | 19474                   | 49.97 |
| 30-06-2021 | 16 Hrs | 4574    | 521   | 262 | 5357  | 6472                   | 985  | 5630 | 651   | -1420      | 17676                 | 0                  | 17676                    | 1030      | 249          | 20374            | 20374                   | 50.02 |
| 01-07-2021 | 16 Hrs | 4109    | 265   | 263 | 4637  | 6473                   | 1711 | 5606 | 563   | -1549      | 17440                 | 0                  | 17440                    | 970       | 247          | 20206            | 20206                   | 50.04 |
| 02-07-2021 | 16 Hrs | 3256    | 1176  | 137 | 4569  | 6740                   | 1905 | 5545 | 590   | -1599      | 17750                 | 0                  | 17750                    | 934       | 250          | 20533            | 20533                   | 50.04 |
| 03-07-2021 | 16 Hrs | 4383    | 1859  | 136 | 6378  | 7298                   | 1094 | 5465 | 662   | -1684      | 19213                 | 0                  | 19213                    | 703       | 250          | 21850            | 21850                   | 50.02 |
| 04-07-2021 | 15 Hrs | 4403    | 852   | 137 | 5392  | 8581                   | 451  | 5640 | 836   | -1335      | 19565                 | 0                  | 19565                    | 613       | 251          | 21764            | 21764                   | 50.02 |
| Maximum    |        | 4632    | 1859  | 362 | 6378  | 8581                   | 1905 | 5640 | 836   | -1335      | 19565                 | 0                  | 19565                    | 1030      | 251          | 21850            | 21850                   | 50.04 |
| Minimum    |        | 3256    | 265   | 136 | 4569  | 5806                   | 447  | 5272 | 487   | -1684      | 16355                 | 0                  | 16355                    | 613       | 247          | 18995            | 18995                   | 49.97 |
| Average    |        | 4273    | 873   | 225 | 5371  | 6778                   | 1009 | 5534 | 637   | -1501      | 17827                 | 0                  | 17827                    | 880       | 249          | 20457            | 20457                   | 50.01 |

**Supply Position During Evening Peak (MW)**

| Date       | Time   | MSGENCO |       |     |       | Central Sector Receipt | Wind | CPP  | SOLAR | TPCL Exch. | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|------------|--------|---------|-------|-----|-------|------------------------|------|------|-------|------------|-----------------------|--------------------|--------------------------|-----------|--------------|------------------|-------------------------|-------|
|            |        | THM     | HYDRO | GAS | Total |                        |      |      |       |            |                       |                    |                          |           |              |                  |                         |       |
|            |        | MW      | MW    | MW  | MW    | MW                     | MW   | MW   | MW    | MW         | MW                    | MW                 | MW                       | MW        | MW           | MW               | MW                      | Hzs   |
| 28-06-2021 | 20 Hrs | 4463    | 622   | 275 | 5360  | 5047                   | 1226 | 5700 | 0     | -1069      | 16264                 | 0                  | 16264                    | 1017      | 250          | 18600            | 18600                   | 49.90 |
| 29-06-2021 | 20 Hrs | 4536    | 1266  | 395 | 6197  | 5394                   | 951  | 5622 | 0     | -1086      | 17078                 | 0                  | 17078                    | 1038      | 248          | 19450            | 19450                   | 49.94 |
| 30-06-2021 | 21 Hrs | 4570    | 1232  | 268 | 6070  | 5030                   | 1261 | 5828 | 0     | -1207      | 16982                 | 0                  | 16982                    | 902       | 249          | 19340            | 19340                   | 50.01 |
| 01-07-2021 | 20 Hrs | 3964    | 657   | 258 | 4879  | 5668                   | 1507 | 5720 | 0     | -1179      | 16595                 | 0                  | 16595                    | 978       | 248          | 19000            | 19000                   | 50.02 |
| 02-07-2021 | 21 Hrs | 3818    | 1048  | 139 | 5005  | 6242                   | 1074 | 5576 | 0     | -1151      | 16746                 | 0                  | 16746                    | 1001      | 251          | 19149            | 19149                   | 50.04 |
| 03-07-2021 | 20 Hrs | 4354    | 1243  | 138 | 5735  | 5576                   | 1667 | 5636 | 0     | -1143      | 17471                 | 0                  | 17471                    | 979       | 251          | 19844            | 19844                   | 49.93 |
| 04-07-2021 | 22 Hrs | 4706    | 1560  | 140 | 6406  | 5400                   | 1098 | 5664 | 0     | -1136      | 17432                 | 0                  | 17432                    | 907       | 251          | 19726            | 19726                   | 50.01 |
| Maximum    |        | 4706    | 1560  | 395 | 6406  | 6242                   | 1667 | 5828 | 0     | -1069      | 17471                 | 0                  | 17471                    | 1038      | 251          | 19844            | 19844                   | 50.04 |
| Minimum    |        | 3818    | 622   | 138 | 4879  | 5030                   | 951  | 5576 | 0     | -1207      | 16264                 | 0                  | 16264                    | 902       | 248          | 18600            | 18600                   | 49.90 |
| Average    |        | 4344    | 1090  | 230 | 5665  | 5480                   | 1255 | 5678 | 0     | -1139      | 16938                 | 0                  | 16938                    | 975       | 250          | 19301            | 19301                   | 49.98 |

### Supply Position During Night Off Peak (MW)

| Date           | Time  | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding (LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.  | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|-------|-------------|------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
|                |       | THM         | HYDRO      | GAS        | Total       |                        |             |             |          |              |                       |                    |                          |            |              |                  |                         |              |
|                |       | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW         | MW           | MW               | MW                      | Hzs          |
| 28-06-2021     | 3 Hrs | 3786        | 282        | 272        | 4340        | 5040                   | 686         | 4334        | 0        | -934         | 13466                 | 0                  | 13466                    | 663        | 144          | 15207            | 15207                   | 49.99        |
| 29-06-2021     | 4 Hrs | 4190        | 272        | 283        | 4745        | 4492                   | 407         | 5573        | 0        | -934         | 14283                 | 0                  | 14283                    | 661        | 144          | 16022            | 16022                   | 50.00        |
| 30-06-2021     | 4 Hrs | 4233        | 316        | 272        | 4821        | 4334                   | 1398        | 5454        | 0        | -991         | 15016                 | 0                  | 15016                    | 618        | 248          | 16873            | 16873                   | 50.05        |
| 01-07-2021     | 4 Hrs | 4188        | 328        | 272        | 4788        | 5288                   | 1291        | 4978        | 0        | -931         | 15414                 | 0                  | 15414                    | 697        | 250          | 17292            | 17292                   | 49.96        |
| 02-07-2021     | 3 Hrs | 3318        | 391        | 266        | 3975        | 5187                   | 1571        | 5647        | 0        | -968         | 15412                 | 0                  | 15412                    | 796        | 248          | 17424            | 17424                   | 50.03        |
| 03-07-2021     | 4 Hrs | 4370        | 288        | 142        | 4800        | 5254                   | 1273        | 5601        | 0        | -936         | 15992                 | 0                  | 15992                    | 773        | 251          | 17952            | 17952                   | 49.97        |
| 04-07-2021     | 4 Hrs | 4374        | 360        | 142        | 4876        | 5567                   | 1543        | 5659        | 0        | -1053        | 16592                 | 0                  | 16592                    | 743        | 251          | 18639            | 18639                   | 50.05        |
| <b>Maximum</b> |       | <b>4374</b> | <b>391</b> | <b>283</b> | <b>4876</b> | <b>5567</b>            | <b>1571</b> | <b>5659</b> | <b>0</b> | <b>-931</b>  | <b>16592</b>          | <b>0</b>           | <b>16592</b>             | <b>796</b> | <b>251</b>   | <b>18639</b>     | <b>18639</b>            | <b>50.05</b> |
| <b>Minimum</b> |       | <b>3318</b> | <b>272</b> | <b>142</b> | <b>3975</b> | <b>4334</b>            | <b>407</b>  | <b>4334</b> | <b>0</b> | <b>-1053</b> | <b>13466</b>          | <b>0</b>           | <b>13466</b>             | <b>618</b> | <b>144</b>   | <b>15207</b>     | <b>15207</b>            | <b>49.96</b> |
| <b>Average</b> |       | <b>4066</b> | <b>320</b> | <b>236</b> | <b>4621</b> | <b>5023</b>            | <b>1167</b> | <b>5321</b> | <b>0</b> | <b>-964</b>  | <b>15168</b>          | <b>0</b>           | <b>15168</b>             | <b>707</b> | <b>219</b>   | <b>17058</b>     | <b>17058</b>            | <b>50.01</b> |

### Details of Supply Position (MUs)

| Date           | MSGENCO        |               |              |                | Pench (MS)   | Central Sector Receipt | Central Sector Share | WIND           | CPP            | SOLAR        | TPCL Gen.     | R-INFRA Gen. | TPCL Exch.     | Energy Requirement |               |                |
|----------------|----------------|---------------|--------------|----------------|--------------|------------------------|----------------------|----------------|----------------|--------------|---------------|--------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS          | Total          |              |                        |                      |                |                |              |               |              |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus          | Mus            | Mus          | Mus                    | Mus                  | Mus            | Mus            | Mus          | Mus           | Mus          | Mus            | Mus                | Mus           | Mus            |
| 28-06-2021     | 103.499        | 10.801        | 6.496        | 120.796        | 0.559        | 132.659                | 131.616              | 16.708         | 122.999        | 5.284        | 21.059        | 5.024        | -27.653        | 370.234            | 53.736        | 423.970        |
| 29-06-2021     | 105.056        | 19.614        | 7.371        | 132.041        | 0.550        | 128.958                | 129.466              | 13.394         | 133.371        | 7.424        | 21.814        | 5.631        | -27.714        | 387.474            | 55.159        | 442.633        |
| 30-06-2021     | 107.710        | 14.081        | 6.496        | 128.287        | 0.514        | 133.140                | 133.279              | 27.606         | 133.464        | 7.692        | 20.985        | 5.967        | -29.595        | 400.594            | 56.548        | 457.142        |
| 01-07-2021     | 97.823         | 12.222        | 6.424        | 116.469        | 0.458        | 141.695                | 143.016              | 35.899         | 131.908        | 6.727        | 21.233        | 5.971        | -29.906        | 402.792            | 57.110        | 459.902        |
| 02-07-2021     | 82.364         | 16.846        | 4.945        | 104.155        | 0.458        | 151.590                | 151.233              | 38.640         | 134.117        | 6.891        | 20.874        | 5.993        | -31.075        | 404.318            | 57.942        | 462.260        |
| 03-07-2021     | 105.999        | 22.006        | 3.376        | 131.381        | 0.522        | 153.057                | 154.509              | 28.989         | 134.204        | 7.448        | 19.175        | 6.017        | -31.236        | 423.843            | 56.428        | 480.271        |
| 04-07-2021     | 107.341        | 22.670        | 3.369        | 133.380        | 0.334        | 161.868                | 164.848              | 23.906         | 135.701        | 7.879        | 17.868        | 6.014        | -28.020        | 434.714            | 51.902        | 486.616        |
| <b>Maximum</b> | <b>107.710</b> | <b>22.670</b> | <b>7.371</b> | <b>133.380</b> | <b>0.559</b> | <b>161.868</b>         | <b>164.848</b>       | <b>107.710</b> | <b>135.701</b> | <b>7.879</b> | <b>21.814</b> | <b>6.017</b> | <b>-27.653</b> | <b>434.714</b>     | <b>57.942</b> | <b>486.616</b> |
| <b>Minimum</b> | <b>82.364</b>  | <b>10.801</b> | <b>3.369</b> | <b>104.155</b> | <b>0.334</b> | <b>128.958</b>         | <b>129.466</b>       | <b>82.364</b>  | <b>122.999</b> | <b>5.284</b> | <b>17.868</b> | <b>5.024</b> | <b>-31.236</b> | <b>370.234</b>     | <b>51.902</b> | <b>423.970</b> |
| <b>Average</b> | <b>101.399</b> | <b>16.891</b> | <b>5.497</b> | <b>123.787</b> | <b>0.485</b> | <b>143.281</b>         | <b>143.995</b>       | <b>101.399</b> | <b>132.252</b> | <b>7.049</b> | <b>20.430</b> | <b>5.802</b> | <b>-29.314</b> | <b>403.424</b>     | <b>55.546</b> | <b>458.971</b> |

| Details of Koyana Water Consumption<br>(in TMC) |             |               |         |
|-------------------------------------------------|-------------|---------------|---------|
| Date                                            | For the Day | For the Month | Balance |
| 28-06-2021                                      | 0.098       | 4.026         | 63.474  |
| 29-06-2021                                      | 0.299       | 4.325         | 63.175  |
| 30-06-2021                                      | 0.196       | 4.520         | 62.980  |
| 01-07-2021                                      | 0.174       | 0.174         | 62.806  |
| 02-07-2021                                      | 0.269       | 0.443         | 62.537  |
| 03-07-2021                                      | 0.386       | 0.829         | 62.151  |
| 04-07-2021                                      | 0.383       | 1.212         | 61.768  |

**State Load Despatch Center, Airoli (MSETCL)**  
**Central Sector Share/Drawal from 28/Jun/2021 to 04/Jul/2021**

| Date         | DAY       | Central Sector Share |         | Total Interstate |         | Total Share     |         | Total Drawal    |         | Overdrawal(+) / |         |
|--------------|-----------|----------------------|---------|------------------|---------|-----------------|---------|-----------------|---------|-----------------|---------|
|              |           | MUs                  | Avg. MW | MUs              | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW |
|              |           | <b>1</b>             |         | <b>2</b>         |         | <b>1+2=3</b>    |         | <b>4</b>        |         | <b>3-4=5</b>    |         |
| 28-06-2021   | MONDAY    | 94.472               | 5447    | 37.144           | 1548    | 131.616         | 5484    | 132.659         | 5527    | 1.043           | 43      |
| 29-06-2021   | TUESDAY   | 97.364               | 5362    | 32.102           | 1338    | 129.466         | 5394    | 128.958         | 5373    | -0.508          | -21     |
| 30-06-2021   | WEDNESDAY | 96.686               | 5517    | 36.593           | 1525    | 133.279         | 5553    | 133.140         | 5548    | -0.138          | -6      |
| 01-07-2021   | THURSDAY  | 100.294              | 5916    | 42.722           | 1780    | 143.016         | 5959    | 141.695         | 5904    | -1.321          | -55     |
| 02-07-2021   | FRIDAY    | 99.833               | 6250    | 51.400           | 2142    | 151.233         | 6301    | 151.590         | 6316    | 0.357           | 15      |
| 03-07-2021   | SATURDAY  | 100.018              | 6383    | 54.491           | 2270    | 154.509         | 6438    | 153.057         | 6377    | -1.452          | -60     |
| 04-07-2021   | SUNDAY    | 97.404               | 6801    | 67.444           | 2810    | 164.848         | 6869    | 161.868         | 6744    | -2.980          | -124    |
| <b>Total</b> |           | <b>686.072</b>       |         | <b>321.895</b>   |         | <b>1007.967</b> |         | <b>1002.968</b> |         | <b>-5.000</b>   |         |

| Generator Unit Outages/Trippings from 28.06.2021 to 04.07.2021 |            |           |            |            |                                                                     |             |
|----------------------------------------------------------------|------------|-----------|------------|------------|---------------------------------------------------------------------|-------------|
| Name of Unit                                                   | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                              | Outage Type |
| Koyna STG-IV Unit-3                                            | 01-07-2021 | 20.03     | 02-07-2021 | 0          | Shaft seal water circulation loss.                                  | FORCED      |
| Koyna STG-IV Unit-4                                            | 03-07-2021 | 22.38     | 03-07-2021 | 23.15      | Turbine bearing Vibration high                                      | FORCED      |
| Koyna STG-IV Unit-4                                            | 01-07-2021 | 19.57     | 01-07-2021 | 20.45      | Sensor Malfunction                                                  | FORCED      |
| Koyna STG-IV Unit-4                                            | 30-06-2021 | 21.5      | 30-06-2021 | 22.3       | Turbine oil Leakage                                                 | FORCED      |
| Parli Unit 8                                                   | 08-06-2021 | 0.3       |            | Continued. | Zero Schedule.                                                      | FORCED      |
| IEPL Unit 1                                                    | 28-08-2018 | 21.26     |            | Continued. | No PPA                                                              | FORCED      |
| PGPL U1                                                        | 07-02-2017 | 17.3      |            | Continued. | No Schedule (NO PPA)                                                | FORCED      |
| PGPL U2                                                        | 07-02-2017 | 17.3      |            | Continued. | No Schedule.(NO PPA)                                                | FORCED      |
| Khaparkheda Unit 1                                             | 11-06-2021 | 23.58     |            | Continued. | Annual Overhaul                                                     | PLANNED     |
| Khaparkheda Unit 2                                             | 02-07-2021 | 0         |            | Continued. | Zero schedule.                                                      | FORCED      |
| Khaparkheda Unit 3                                             | 02-07-2021 | 0         |            | Continued. | Zero schedule.                                                      | FORCED      |
| Khaparkheda Unit 4                                             | 02-07-2021 | 0         |            | Continued. | Zero schedule.                                                      | FORCED      |
| Khaparkheda Unit 4                                             | 29-06-2021 | 19.58     | 30-06-2021 | 9.15       | Generator Protection operated                                       | FORCED      |
| Chandrapur Unit 4                                              | 03-07-2021 | 23.49     |            | Continued. | Super Heater Spray valve heavy Leakage                              | FORCED      |
| Chandrapur Unit 6                                              | 01-07-2021 | 8.57      | 03-07-2021 | 16.52      | Boiler Tube Leakage                                                 | FORCED      |
| Chandrapur Unit 7                                              | 20-02-2021 | 23.43     |            | Continued. | Generator Earth Fault.                                              | FORCED      |
| Koradi Unit 6                                                  | 27-04-2021 | 19.59     |            | Continued. | Zero Schedule.                                                      | FORCED      |
| Koradi Unit 7                                                  | 27-04-2021 | 20.03     |            | Continued. | Zero Schedule.                                                      | FORCED      |
| Bhusawal Unit 3                                                | 08-06-2021 | 0.34      |            | Continued. | Zero Schedule.                                                      | FORCED      |
| Bhusawal Unit 4                                                | 11-06-2021 | 16.11     | 02-07-2021 | 17.12      | Zero Schedule By MSEDCL                                             | FORCED      |
| Bhusawal Unit 5                                                | 11-06-2021 | 16.35     | 02-07-2021 | 16.25      | Zero Schedule By MSEDCL                                             | FORCED      |
| Nasik Unit 3                                                   | 03-12-2020 | 6.45      |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021). | FORCED      |
| Nasik Unit 4                                                   | 28-06-2021 | 23.45     | 29-06-2021 | 16.52      | HP heaters level high.                                              | FORCED      |
| Nasik Unit 4                                                   | 28-06-2021 | 16.45     | 28-06-2021 | 22.43      | Rotor Earth fault.                                                  | FORCED      |
| Nasik Unit 4                                                   | 04-07-2021 | 11.03     |            | Continued. | Boiler Tube Leakage                                                 | FORCED      |
| Nasik Unit 5                                                   | 17-05-2021 | 12.5      |            | Continued. | Zero schedule.                                                      | FORCED      |
| Parli Unit 6                                                   | 04-05-2021 | 20        |            | Continued. | Zero Schedule By MSEDCL                                             | FORCED      |
| Parli Unit 7                                                   | 05-05-2021 | 19        |            | Continued. | Zero Schedule.                                                      | FORCED      |
| Paras Unit 4                                                   | 10-06-2021 | 17        | 05-07-2021 | 2.49       | zero scheduled given by MSEDCL                                      | FORCED      |
| Trombay 8                                                      | 29-06-2021 | 9.12      |            | Continued. | Boiler Tube Leakage                                                 | FORCED      |
| JSW (J) U2                                                     | 20-06-2021 | 4.3       |            | Continued. | Generator maintenance work.                                         | FORCED      |
| SWPGPL U-1                                                     | 16-02-2016 | 17.09     |            | Continued. | No PPA.                                                             | FORCED      |
| SWPGPL U-2                                                     | 25-06-2021 | 1.22      |            | Continued. | ID Fan High Vibration.                                              | FORCED      |
| SWPGPL U-3                                                     | 08-06-2021 | 0.24      |            | Continued. | Zero Schedule.                                                      | FORCED      |
| VIPL U-1                                                       | 29-12-2018 | 0.3       |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                             | FORCED      |
| VIPL U-2                                                       | 17-01-2019 | 0.15      |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                              | FORCED      |
| Uran Unit 5                                                    | 02-07-2021 | 13.33     |            | Continued. | Gas shortage                                                        | FORCED      |
| Uran Unit 6                                                    | 29-06-2021 | 22.18     |            | Continued. | Gas shortage                                                        | FORCED      |
| Uran Unit 6                                                    | 23-06-2021 | 16.1      | 29-06-2021 | 12.4       | Gas shortage                                                        | FORCED      |
| Uran Unit 7                                                    | 25-05-2020 | 12.51     |            | Continued. | Turbine Blade Failure                                               | FORCED      |
| Uran Unit A0                                                   | 02-07-2021 | 13.36     |            | Continued. | Gas shortage                                                        | FORCED      |
| AEML Unit 1                                                    | 19-05-2021 | 9.52      |            | Continued. | HP turbine replacement.                                             | PLANNED     |

**Transmission Line Outages/Trippings from 28.06.2021 to 04.07.2021**

| Name of Line                                 | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                                                                        | Outage Type | Voltage |
|----------------------------------------------|------------|-----------|------------|------------|-------------------------------------------------------------------------------------------------------------------------------|-------------|---------|
| Mudshingi Chikodi                            | 24-09-2019 | 17.12     |            | Continued. | No Schedule(Charge from Mudshingi end only)                                                                                   | PO          | 220 KV  |
| Talandage - Chikodi                          | 01-10-2019 | 17.1      |            | Continued. | No Schedule(Close at Chikodi end only)                                                                                        | PO          | 220 KV  |
| MSETCL Borivli Aarey 2                       | 07-06-2021 | 9.05      | 04-07-2021 | 11.18      | In Pointing Y-Ph Cable Sheath Fault Between Section JC-14 To JC-16.(sock test at 22.54 dt.03/07/21)                           | PO          | 220 KV  |
| MSETCL Borivli Aarey 1                       | 17-06-2021 | 13.25     |            | Continued. | Distance Protection                                                                                                           | T           | 220 KV  |
| BHIRA (T) - KARANJADE CKT - 8                | 21-06-2021 | 7.16      | 30-06-2021 | 22.06      | Conductor replacement in span 136 -137 DFCC work.                                                                             | PO          | 220 KV  |
| 220/100 Kv 200 MVA ICT I @Pal-Dombivali      | 28-06-2021 | 10.05     | 28-06-2021 | 13.45      | Rectification of DC Leakage on OSR cable.                                                                                     | PO          | 220 KV  |
| 220/100 Kv 200 Mva Vijai Ict 3 @Trombay      | 28-06-2021 | 14.59     | 28-06-2021 | 23.15      | Heavy sparking observed in tata yard.                                                                                         | HT          | 220 KV  |
| 220/132 kv 100 MVA ICT II@Malegaon           | 28-06-2021 | 10.14     | 28-06-2021 | 17.3       | Diagnostic Testing Work.                                                                                                      | PO          | 220 KV  |
| 220/132-110kv 100mva Imp Ptr 2 @Wathar       | 28-06-2021 | 9.57      | 28-06-2021 | 20.11      | Quarterly Maintenance Work & Diagnostic testing work.                                                                         | PO          | 220 KV  |
| 220/132KV 100MVA - 1@Alephata                | 28-06-2021 | 9.32      | 28-06-2021 | 15.51      | For LV Circuit Breaker Drive Mechanism overhauling work.                                                                      | PO          | 220 KV  |
| Chandrapur GCR - Cpurrlytss1                 | 28-06-2021 | 11.32     | 28-06-2021 | 16.44      | Testing Work.                                                                                                                 | PO          | 220 KV  |
| Chandrapur(MIDC)-Ballarshah II               | 28-06-2021 | 11.1      | 28-06-2021 | 14.4       | Abnormal Sound From BPH CC.                                                                                                   | HT          | 220 KV  |
| Karad(400kv) -Nigade                         | 28-06-2021 | 12.5      | 28-06-2021 | 15.19      | For extension of New PT metering core, CT Tan Delta and routine maintenance.                                                  | PO          | 220 KV  |
| Pophali - Nerale                             | 28-06-2021 | 9.5       | 28-06-2021 | 15.5       | To Attend Hot Spot At Pophali End, Requesting Since Saturday.                                                                 | EO          | 220 KV  |
| Sonkhar - Trombay                            | 28-06-2021 | 14.43     | 28-06-2021 | 18.47      | Distance Protection                                                                                                           | T           | 220 KV  |
| Uran - Apta IV                               | 28-06-2021 | 11.43     | 28-06-2021 | 16.45      | For Y-ph CT replacement and relay testing work.                                                                               | PO          | 220 KV  |
| 220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 2 | 29-06-2021 | 12.52     | 29-06-2021 | 16.49      | Relay Routine Testing.                                                                                                        | PO          | 220 KV  |
| Chandrapur GCR - Cpur Rly Tss 2              | 29-06-2021 | 10.34     | 29-06-2021 | 14.2       | For drilling holes, cable in warding, glanding & dressing at CP/RP panel, fixing of MFM METER & CMR RELAY on panel for MTAMC. | PO          | 220 KV  |
| Flagship-Chinchwad                           | 29-06-2021 | 7.5       | 29-06-2021 | 8.1        | Bird Nest Removal.                                                                                                            | EO          | 220 KV  |
| Lamboti - Solapur li(Bale) Ckt-I             | 29-06-2021 | 21.35     | 30-06-2021 | 2.09       | Distance Protection                                                                                                           | T           | 220 KV  |
| Lamboti -Solapur li(Bale) Ckt-II             | 29-06-2021 | 21.35     | 29-06-2021 | 22.5       | Distance Protection                                                                                                           | T           | 220 KV  |
| Maisal-Jath I                                | 29-06-2021 | 11.21     | 29-06-2021 | 17.48      | String replacement & earth bond fixing.                                                                                       | PO          | 220 KV  |
| Malharpeth - Karad(400kv)                    | 29-06-2021 | 10.13     | 29-06-2021 | 15.11      | For extension of new PT metering core, CT Tan Delta and routine maintenance.                                                  | PO          | 220 KV  |

**Transmission Line Outages/Trippings from 28.06.2021 to 04.07.2021**

| Name of Line                          | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                                                                                                | Outage Type | Voltage |
|---------------------------------------|------------|-----------|------------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|---------|
| New Koyna - Loteparshuram             | 29-06-2021 | 10.24     | 29-06-2021 | 13.12      | Emergency outage on 50 MVA TF 1 & 220 KV New Koyna Line for replacing earth wire.                                                                     | EO          | 220 KV  |
| Peth- Mudshingi -I                    | 29-06-2021 | 11.03     | 29-06-2021 | 14.45      | Relay testing work.                                                                                                                                   | PO          | 220 KV  |
| Sadawaghapur Karad Ckt 2              | 29-06-2021 | 14.07     | 29-06-2021 | 18.46      | Replacement of R ph LA, CB timing and CRM test on CB.                                                                                                 | PO          | 220 KV  |
| Satana-Gangapur                       | 29-06-2021 | 11.22     | 29-06-2021 | 18.35      | Replacements of Jumpers with Jump cone at location No. 183,184,185,186,187,188,194,201, 202,204,205,206,207&211.                                      | PO          | 220 KV  |
| Tuljapur-Lamboti(Tap to Vairag s/st.) | 29-06-2021 | 11.13     | 29-06-2021 | 17.19      | For alignment of 89 A isolator of 220 Kv Tuljapur ckt-2                                                                                               | PO          | 220 KV  |
| Flagship-Chinchwad                    | 30-06-2021 | 10.57     | 30-06-2021 | 11.07      | Distance Protection                                                                                                                                   | T           | 220 KV  |
| Gcr Chandrapur - Grace Ltd            | 30-06-2021 | 9.51      | 30-06-2021 | 15.33      | Fixing of MFM meter & CMR relay on CP panel for MTAMC project, Measurement of Tan delta                                                               | PO          | 220 KV  |
| Kanhan-Umred 1                        | 30-06-2021 | 10.38     | 30-06-2021 | 14.01      | Testing Work                                                                                                                                          | PO          | 220 KV  |
| Koyna (Pophali) - Kdph                | 30-06-2021 | 4.5       | 30-06-2021 | 17.5       | Distance Protection                                                                                                                                   | T           | 220 KV  |
| Lamboti -Solapur li(Bale) Ckt-II      | 30-06-2021 | 7.26      | 30-06-2021 | 13.59      | R-Ph LA to BE Replaced.                                                                                                                               | HT          | 220 KV  |
| Mumewadi-Belewadi                     | 30-06-2021 | 9.5       | 30-06-2021 | 16.58      | Siemens make CB Overhauling work.                                                                                                                     | PO          | 220 KV  |
| Pandharpur - Malinagar                | 30-06-2021 | 13.1      | 30-06-2021 | 15.4       | Tree cutting work.                                                                                                                                    | PO          | 220 KV  |
| Satana-Gangapur                       | 30-06-2021 | 10.3      | 30-06-2021 | 18.03      | Jumper replacement work.                                                                                                                              | PO          | 220 KV  |
| Waluj- Padegaon li                    | 30-06-2021 | 12.42     | 30-06-2021 | 16.44      | Jumper Tightening and Fixing of Nut Bolts                                                                                                             | PO          | 220 KV  |
| Wpcl-Warora 1                         | 30-06-2021 | 10.17     | 30-06-2021 | 15.53      | Bus jumper tightening work by hot line method at 220kv warora S/STN end by M/S. SWPL authority                                                        | PO          | 220 KV  |
| 220/132kv 100MVA ICT-II @ Alephata    | 01-07-2021 | 10.13     | 01-07-2021 | 13.4       | LV circuit breaker drive mechanism overhauling work.                                                                                                  | PO          | 220 KV  |
| 220/132kv 200mva Emco ICT-1 @Kurkumbh | 01-07-2021 | 11.25     | 01-07-2021 | 15.3       | Relay testing work                                                                                                                                    | PO          | 220 KV  |
| CHAKAN (400 KV)-Chinchwad2            | 01-07-2021 | 11        | 01-07-2021 | 20.16      | Routine Maintenance Work                                                                                                                              | PO          | 220 KV  |
| Chandrapur GCR - Sicom I              | 01-07-2021 | 9.51      | 01-07-2021 | 16.27      | Routine Maintenance Work                                                                                                                              | PO          | 220 KV  |
| Kalmeshwar - JSW                      | 01-07-2021 | 7.33      | 01-07-2021 | 18.15      | Tan delta and capacitance measurement of CTS and CB timing, CRM of CB.                                                                                | PO          | 220 KV  |
| Kalwa - Mulund 1                      | 01-07-2021 | 9.39      |            | Continued. | project work of bay strengthening on 220kv Mulund-Bhandup GIS line bay along with replacement of C&R panel of 220 kalwa-1 at 220kv Mulund substation. | PO          | 220 KV  |
| Kandalgaon - Sona Alloys              | 01-07-2021 | 9         | 01-07-2021 | 18         | Damage conductor work                                                                                                                                 | PO          | 220 KV  |
| Mulund - GIS Bhandup                  | 01-07-2021 | 9.37      |            | Continued. | project work of bay strengthening on 200kv Mulund-Bhandup GIS line bay at 220kv Mulund substation                                                     | PO          | 220 KV  |

**Transmission Line Outages/Trippings from 28.06.2021 to 04.07.2021**

| Name of Line                              | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                  | Outage Type | Voltage |
|-------------------------------------------|------------|-----------|------------|------------|-------------------------------------------------------------------------|-------------|---------|
| Mumewadi -Halkarni ckt-II                 | 01-07-2021 | 10.25     | 01-07-2021 | 17.3       | Siemens make CB Overhauling work.                                       | PO          | 220 KV  |
| Uran - Kharghar I                         | 01-07-2021 | 10.4      |            | Continued. | Construction work.                                                      | PO          | 220 KV  |
| 220/132 Kv 150 MVA ICT @Boisar-II         | 02-07-2021 | 15.39     | 02-07-2021 | 19.11      | Pre-monsoon maintenance work                                            | PO          | 220 KV  |
| 220/132 Kv 200 Mva Cgl Ict 3 @Babhleshwar | 02-07-2021 | 10.38     | 02-07-2021 | 14.45      | Attending Oil Leakage                                                   | PO          | 220 KV  |
| 220/132 kv 200 Mva ICT-II @Boisar-Ii      | 02-07-2021 | 11.44     | 02-07-2021 | 14.04      | Pre-monsoon maintenance work                                            | PO          | 220 KV  |
| 220/132kv 200mva Vijai Ptr 2 @Lonand      | 02-07-2021 | 12.47     | 02-07-2021 | 13.42      | Remove Kite from HV R ph LA                                             | EO          | 220 KV  |
| Abhijeet-Wardha-Ii                        | 02-07-2021 | 12.16     | 02-07-2021 | 17.53      | Relay testing work at 220KV abhijit S/S end by testing division nagpur. | PO          | 220 KV  |
| Butibori - Purti                          | 02-07-2021 | 11.42     | 02-07-2021 | 16.07      | Replacement of BPH CT for high tan delta value.                         | PO          | 220 KV  |
| Karad(400kv) -Mudshingi Ckt 2-Tak         | 02-07-2021 | 17.55     | 02-07-2021 | 18.07      | To Reconnect HT LIS Consumer                                            | PO          | 220 KV  |
| Karad(400kv) -Mudshingi Ckt 2-Tak         | 02-07-2021 | 4.14      | 02-07-2021 | 4.58       | Distance Protection                                                     | T           | 220 KV  |
| Koradi-Ambazari-I                         | 02-07-2021 | 10.12     | 02-07-2021 | 14.46      | Replacement of flashover string at various location.                    | PO          | 220 KV  |
| Nagothane-Wadkhal-I                       | 02-07-2021 | 11.32     | 02-07-2021 | 15.44      | Attending Hot Spot                                                      | EO          | 220 KV  |
| Padghe - Wada                             | 02-07-2021 | 10.39     | 02-07-2021 | 18.24      | Replace Faulty Insulator string                                         | PO          | 220 KV  |
| Parli 3 (Old Gcr)-Girwali Ckt-3           | 02-07-2021 | 10.48     |            | Continued. | CB overhauling.                                                         | PO          | 220 KV  |
| Vankuswadi- Ajinkyatara                   | 02-07-2021 | 14.15     | 02-07-2021 | 18.4       | Replacement work                                                        | PO          | 220 KV  |
| Wpcl-Warora 1                             | 02-07-2021 | 10.05     | 02-07-2021 | 16.37      | Jumper tightening work of 21 nos. of location (cut point).              | PO          | 220 KV  |
| ACCIL - Apta                              | 03-07-2021 | 14.35     | 03-07-2021 | 16.42      | consumer bus Isolator maintenance work at ACCIL end                     | PO          | 220 KV  |
| Bhosari- Bhosari 2                        | 03-07-2021 | 10.58     | 03-07-2021 | 11.24      | over current                                                            | T           | 220 KV  |
| Chakan-Chinchwad                          | 03-07-2021 | 10.57     | 04-07-2021 | 0.1        | Distance Protection                                                     | T           | 220 KV  |
| Chinchwad- Parvati                        | 03-07-2021 | 10.57     | 03-07-2021 | 15.57      | Half yearly maintenance work                                            | PO          | 220 KV  |
| EKLAHARE (OCR) Nasik Navsari II           | 03-07-2021 | 10.51     | 03-07-2021 | 14.26      | Replacement work                                                        | PO          | 220 KV  |
| Hinjawadi I- Chinchwad                    | 03-07-2021 | 10.58     | 03-07-2021 | 11.16      | Over Current                                                            | T           | 220 KV  |
| Kalwa - Mulund 2                          | 03-07-2021 | 7.03      | 03-07-2021 | 14.3       | Online shifting of 220kv mulund-kalwa2                                  | PO          | 220 KV  |
| Karad(400kv) -Mudshingi Ckt 2-Tak         | 03-07-2021 | 4.14      | 03-07-2021 | 4.58       | Distance Protection                                                     | T           | 220 KV  |
| Nagothane - ACCIL                         | 03-07-2021 | 14.2      | 03-07-2021 | 17.07      | isolator maintenance work                                               | PO          | 220 KV  |
| OSMANABAD PARANDA                         | 03-07-2021 | 6.09      | 03-07-2021 | 6.3        | Tripped on backup.                                                      | T           | 220 KV  |
| Osmanabad - Barshi                        | 03-07-2021 | 5.19      | 03-07-2021 | 9.19       | Distance Protection                                                     | T           | 220 KV  |
| Osmanabad - Solapur (Bale)                | 03-07-2021 | 6.09      | 04-07-2021 | 4.07       | Distance Protection/over current.                                       | T           | 220 KV  |
| PARANDA BARSHI                            | 03-07-2021 | 6.09      | 03-07-2021 | 6.3        | Tripped on backup.                                                      | T           | 220 KV  |
| PARLY (PG) - OSMANABAD                    | 03-07-2021 | 5.19      | 03-07-2021 | 6.3        | Tripped only at Parly PG end.                                           | T           | 220 KV  |
| Urse-Chinchwad (ST tap)                   | 03-07-2021 | 10.58     | 03-07-2021 | 11.32      | Distance Protection                                                     | T           | 220 KV  |
| Vankuswade - Kdph                         | 03-07-2021 | 10.05     | 03-07-2021 | 15.25      | Replacement work                                                        | PO          | 220 KV  |

**Transmission Line Outages/Trippings from 28.06.2021 to 04.07.2021**

| Name of Line                                      | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                                          | Outage Type | Voltage |
|---------------------------------------------------|------------|-----------|------------|------------|-------------------------------------------------------------------------------------------------|-------------|---------|
| Main Bus I @ Dahanu                               | 04-07-2021 | 11.27     | 04-07-2021 | 21.01      | Isolator overhauling of bay 02,07 isolator & bus coupler annual maintenance work.               | PO          | 220 KV  |
| Karad Solapur (PG)                                | 03-05-2017 | 11:49     |            | Continued. | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                        | PO          | 400 KV  |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | 10-08-2020 | 9.58      |            | Continued. | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                           | PO          | 400 KV  |
| Warora -IEPL                                      | 18-06-2021 | 7.28      | 29-06-2021 | 17.06      | Shifting of Line on Newly erected Tower                                                         | PO          | 400 KV  |
| Bableshtar- Aurangabad (Waluj)                    | 23-06-2021 | 9.26      |            | Continued. | Samruddhi expressway crossing 400kv line diversion work.                                        | PO          | 400 KV  |
| Khadka-Aurangabad (Waluj)                         | 26-06-2021 | 22.24     | 28-06-2021 | 9.58       | Over Voltage                                                                                    | HT          | 400 KV  |
| Karad-Jaigad - I                                  | 27-06-2021 | 20.01     | 28-06-2021 | 9.36       | Over Voltage                                                                                    | HT          | 400 KV  |
| 400/220kv 315 Mva ICT I @Karad                    | 28-06-2021 | 8.29      | 28-06-2021 | 11.33      | To attend DC leakage in FD(Fire Detector) on to body of R ph unit of ICT-I unit.                | PO          | 400 KV  |
| Karad - Jaigad - II                               | 28-06-2021 | 22.14     | 29-06-2021 | 7.38       | Over Voltage                                                                                    | HT          | 400 KV  |
| Khadka-Aurangabad (Waluj)                         | 28-06-2021 | 22.02     | 29-06-2021 | 8.11       | Over Voltage                                                                                    | HT          | 400 KV  |
| Padghe - Nagothane - II                           | 28-06-2021 | 9         | 28-06-2021 | 14.47      | For R ph jumper replacement work at loc no 1.                                                   | PO          | 400 KV  |
| karad -kolhapur-I                                 | 28-06-2021 | 23.22     | 29-06-2021 | 7.4        | Over Voltage                                                                                    | HT          | 400 KV  |
| 400/220 Kv 500 MVA ICT II @Lamboti                | 29-06-2021 | 21.35     | 29-06-2021 | 23.12      | tripped On Jerk.                                                                                | T           | 400 KV  |
| Jejuri- Koynastage-IV                             | 29-06-2021 | 5.07      | 29-06-2021 | 12.29      | Distance Protection                                                                             | T           | 400 KV  |
| Karad - Talandge Ckt 2                            | 29-06-2021 | 12.45     | 29-06-2021 | 17.08      | attending Hot Spot on 29 A Y ph PG isolator Bus-I Quadruple spacer by Hot Line Unit, Ogalewadi. | EO          | 400 KV  |
| Karad-Jaigad - I                                  | 29-06-2021 | 22.55     | 30-06-2021 | 9          | Over Voltage                                                                                    | HT          | 400 KV  |
| Khadka-Aurangabad (Waluj)                         | 29-06-2021 | 21.11     | 30-06-2021 | 10.42      | Over Voltage                                                                                    | HT          | 400 KV  |
| karad -kolhapur-I                                 | 29-06-2021 | 22.54     | 30-06-2021 | 15.12      | Over Voltage                                                                                    | HT          | 400 KV  |
| Karad - Talandge Ckt 1                            | 30-06-2021 | 9.38      | 30-06-2021 | 15.12      | Attending Hot Spot                                                                              | EO          | 400 KV  |
| Khadka-Aurangabad (Waluj)                         | 30-06-2021 | 21.32     | 01-07-2021 | 9.49       | Over Voltage                                                                                    | HT          | 400 KV  |
| 400/220 Kv 315 Mva Ict 1 @Chakan                  | 01-07-2021 | 10.21     | 01-07-2021 | 19.26      | Outage for oil top up in ICT-1 R-ph unit due to low oil level.                                  | PO          | 400 KV  |
| 400/220 Kv 500 MVA ICT-IV @Kalwa                  | 01-07-2021 | 22.07     | 01-07-2021 | 23.54      | Attending Hot Spot on B Ph LV bushing connecting jumper.                                        | EO          | 400 KV  |
| 400/220/33 Kv 500 MVA ICT-III @Parali (Girwali)   | 01-07-2021 | 9.24      | 01-07-2021 | 19.39      | ICT Unit bushing and winding C & Tan delta measurement work.                                    | PO          | 400 KV  |
| 400/220/33 Kv 500 Mva Ict-3 @Nagothane            | 01-07-2021 | 3.5       | 01-07-2021 | 13.47      | Tripped on OSR                                                                                  | T           | 400 KV  |
| Khadka-Aurangabad (Waluj)                         | 01-07-2021 | 21.07     | 02-07-2021 | 9.14       | Over Voltage                                                                                    | HT          | 400 KV  |
| 167MVA 400/220 SPARE ICT @ Parali (Girwali)       | 02-07-2021 | 10.18     | 02-07-2021 | 17.01      | Jumper tightening work of 21nos. of location (cut point).                                       | PO          | 400 KV  |



**Transmission Line Outages/Trippings from 28.06.2021 to 04.07.2021**

| <b>Name of Line</b>               | <b>Date Trip</b> | <b>Time Trip</b> | <b>Date Sync</b> | <b>Time Sync</b> | <b>Reason</b>                                       | <b>Outage Type</b> | <b>Voltage</b> |
|-----------------------------------|------------------|------------------|------------------|------------------|-----------------------------------------------------|--------------------|----------------|
| Bus Coupler @ Padgha              | 02-07-2021       | 10.21            | 02-07-2021       | 20.4             | Attending Hot Spot                                  | PO                 | 400 KV         |
| Khadka-Aurangabad (Waluj)         | 02-07-2021       | 18.3             | 03-07-2021       | 6.52             | Over Voltage                                        | HT                 | 400 KV         |
| Dhule Khandwa II                  | 03-07-2021       | 10.07            | 03-07-2021       | 21.13            | work at khandwa end                                 | PO                 | 400 KV         |
| 400/220 Kv 500 MVA ICT-III @Kalwa | 04-07-2021       | 7.03             |                  | Continued.       | Attending Hot Spot work at B-Phase LV bushing.      | EO                 | 400 KV         |
| Khadka-Aurangabad (Waluj)         | 31-12-2020       | 17.33            |                  | Continued.       | Over Voltage                                        | HT                 | 400 KV         |
| Chandrapur - Padghe HvdC Pole 1   | 02-07-2021       | 21.26            | 03-07-2021       | 5.59             | Oil topup at pole 1 Y-Phases convertor transformer. | PO                 | 500 KV         |