

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 01/Aug/2016 to 07/Aug/2016

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
01/08/2016	11 Hrs	2494	244	396	3134	5286	2013	3179	55	-1378	12289	0	12289	1063	402	15132	15132	50.08
02/08/2016	11 Hrs	2366	425	405	3196	4575	2212	3197	54	-1449	11785	0	11785	1078	402	14714	14714	49.99
03/08/2016	10 Hrs	2488	282	420	3190	4773	2137	3154	49	-1295	12008	0	12008	1031	402	14736	14736	50.01
04/08/2016	10 Hrs	2592	402	271	3265	5435	2063	2606	81	-1332	12118	0	12118	1027	403	14880	14880	49.99
05/08/2016	9 Hrs	2652	342	431	3425	5438	1928	2585	53	-995	12434	0	12434	1031	402	14862	14862	49.98
06/08/2016	10 Hrs	2837	297	389	3523	4984	2030	2386	73	-1158	11838	0	11838	1034	402	14432	14432	49.98
07/08/2016	10 Hrs	2577	255	401	3233	4792	2235	2554	98	-918	11994	0	11994	794	401	14107	14107	49.99
Maximum		2837	425	431	3523	5438	2235	3197	98	-918	12434	0	12434	1078	403	15132	15132	50.08
Minimum		2366	244	271	3134	4575	1928	2386	49	-1449	11785	0	11785	794	401	14107	14107	49.98
Average		2572	321	388	3281	5040	2088	2809	66	-1218	12066	0	12066	1008	402	14695	14695	50.00

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
01/08/2016	13 Hrs	2560	188	422	3170	4389	2034	3155	76	-1367	11457	0	11457	1012	402	14238	14238	50.03
02/08/2016	16 Hrs	2529	252	371	3152	4119	2237	3200	68	-1291	11485	0	11485	1012	402	14190	14190	49.99
03/08/2016	18 Hrs	2427	732	391	3550	3422	2306	3097	13	-1276	11112	0	11112	1042	402	13832	13832	49.97
04/08/2016	13 Hrs	2580	162	268	3010	4452	2182	2533	125	-1460	10842	0	10842	1124	402	13828	13828	50.00
05/08/2016	13 Hrs	2779	228	402	3409	3909	1957	2169	99	-1133	10410	0	10410	1264	508	13315	13315	49.98
06/08/2016	13 Hrs	2874	171	408	3453	3481	2306	2830	84	-1351	10803	0	10803	1057	403	13614	13614	50.04
07/08/2016	13 Hrs	2669	287	401	3357	3885	2196	2389	107	-961	10973	0	10973	850	402	13186	13186	49.94
Maximum		2874	732	422	3550	4452	2306	3200	125	-961	11485	0	11485	1264	508	14238	14238	50.04
Minimum		2427	162	268	3010	3422	1957	2169	13	-1460	10410	0	10410	850	402	13186	13186	49.94
Average		2631	289	380	3300	3951	2174	2768	82	-1263	11012	0	11012	1052	417	13743	13743	49.99

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
01/08/2016	20 Hrs	2609	611	412	3632	4573	2053	3260	0	-1124	12394	0	12394	1040	402	14960	14960	49.99
02/08/2016	20 Hrs	2489	561	363	3413	4626	2127	3290	0	-1137	12319	0	12319	1004	508	14968	14968	49.99
03/08/2016	20 Hrs	2422	1128	373	3923	4916	1979	2881	0	-1182	12517	0	12517	1094	401	15194	15194	49.92
04/08/2016	20 Hrs	2873	1346	256	4475	4972	1933	2789	0	-1283	12886	0	12886	1018	401	15588	15588	49.90
05/08/2016	20 Hrs	3013	1064	395	4472	4723	1826	2432	0	-1248	12205	0	12205	974	401	14828	14828	49.92
06/08/2016	20 Hrs	2987	662	407	4056	4000	2225	2954	1	-1061	12175	0	12175	1075	402	14713	14713	49.90
07/08/2016	21 Hrs	2844	1587	392	4823	3946	1679	2380	0	-834	11994	0	11994	1010	402	14240	14240	49.95
Maximum		3013	1587	412	4823	4972	2225	3290	1	-834	12886	0	12886	1094	508	15588	15588	49.99
Minimum		2422	561	256	3413	3946	1679	2380	0	-1283	11994	0	11994	974	401	14240	14240	49.90
Average		2748	994	371	4113	4537	1975	2855	0	-1124	12356	0	12356	1031	417	14927	14927	49.94

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
01/08/2016	4 Hrs	2555	79	330	2964	2879	1959	3142	0	-500	10444	0	10444	625	403	11972	11972	50.01
02/08/2016	4 Hrs	2432	181	401	3014	2050	2441	3178	0	-566	10118	0	10118	628	402	11714	11714	50.03
03/08/2016	4 Hrs	2333	102	392	2827	2456	2354	3165	0	-563	10239	0	10239	622	403	11827	11827	49.98
04/08/2016	4 Hrs	2453	229	256	2938	3220	1918	2656	0	-577	10155	0	10155	639	402	11773	11773	49.96
05/08/2016	4 Hrs	2588	238	423	3249	3061	1979	2617	0	-606	10300	0	10300	638	403	11947	11947	50.00
06/08/2016	4 Hrs	3014	294	394	3702	2679	1819	2191	0	-573	9818	0	9818	642	403	11436	11436	49.94
07/08/2016	4 Hrs	2566	199	407	3172	3641	1853	2183	0	-603	10246	0	10246	621	402	11872	11872	49.97
Maximum		3014	294	423	3702	3641	2441	3178	0	-500	10444	0	10444	642	403	11972	11972	50.03
Minimum		2333	79	256	2827	2050	1819	2183	0	-606	9818	0	9818	621	402	11436	11436	49.94
Average		2563	189	372	3124	2855	2046	2733	0	-570	10189	0	10189	631	403	11792	11792	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
01/08/2016	61.318	6.100	9.263	76.681	0.172	97.689	101.090	48.090	75.825	0.523	22.048	9.649	-23.009	275.799	54.706	330.505
02/08/2016	58.170	7.667	9.121	74.958	0.141	89.036	91.968	54.107	76.781	0.517	21.783	9.866	-24.530	270.869	56.179	327.048
03/08/2016	58.124	7.621	9.318	75.063	0.359	88.563	91.481	53.420	74.118	0.546	22.606	9.649	-24.625	267.085	56.880	323.965
04/08/2016	64.010	9.221	6.452	79.683	0.532	100.775	102.334	48.986	65.228	0.976	22.577	9.649	-25.654	269.994	57.877	327.871
05/08/2016	66.737	9.715	9.772	86.224	0.482	95.633	98.595	46.255	58.564	0.827	23.517	10.082	-23.048	264.455	56.646	321.101
06/08/2016	70.326	7.196	9.716	87.238	0.524	85.646	90.043	49.074	61.797	0.716	22.325	9.645	-22.881	261.590	54.852	316.442
07/08/2016	64.199	16.983	9.664	90.846	0.228	85.786	86.673	48.457	57.075	0.802	19.843	9.652	-18.396	264.570	47.894	312.464
Maximum	70.326	16.983	9.772	90.846	0.532	100.775	102.334	70.326	76.781	0.976	23.517	10.082	-18.396	275.799	57.877	330.505
Minimum	58.124	6.100	6.452	74.958	0.141	85.646	86.673	58.124	57.075	0.517	19.843	9.645	-25.654	261.590	47.894	312.464
Average	63.269	9.215	9.044	81.528	0.348	91.875	94.598	63.269	67.055	0.701	22.100	9.742	-23.163	267.766	55.005	322.771

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
01/08/2016	0.057	0.057	62.402
02/08/2016	0.046	0.103	62.356
03/08/2016	0.067	0.170	62.289
04/08/2016	0.110	0.280	62.179
05/08/2016	0.088	0.368	62.091
06/08/2016	0.064	0.432	62.027
07/08/2016	0.295	0.727	61.732

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 01/Aug/2016 to 07/Aug/2016

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
01/08/2016	MONDAY	73.803	4185	27.287	1137	101.090	4212	97.689	4070	-3.401	-142
02/08/2016	TUESDAY	68.304	3808	23.664	986	91.968	3832	89.036	3710	-2.932	-122
03/08/2016	WEDNESDA	67.899	3788	23.582	983	91.481	3812	88.563	3690	-2.918	-122
04/08/2016	THURSDAY	78.939	4241	23.395	975	102.334	4264	100.775	4199	-1.559	-65
05/08/2016	FRIDAY	74.275	4084	24.320	1013	98.595	4108	95.633	3985	-2.962	-123
06/08/2016	SATURDAY	73.092	3735	16.951	706	90.043	3752	85.646	3569	-4.397	-183
07/08/2016	SUNDAY	71.711	3596	14.962	623	86.673	3611	85.786	3574	-0.887	-37
Total		508.022		154.162		662.184		643.128		-19.056	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 01/08/2016 TO 07/08/2016							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Koyna Unit 10	80MW	29/Dec/2015	08:00		Continued.	Annual Overhaul
MSPGCL	Khaparkheda Unit 1	210MW	25/Jun/2016	23.45		Continued.	Zero Schedule by MSEDCL from 00.00Hrs Dt.19-7-16 and A.O.H from 25/06/2016 to 18/07/2016
MSPGCL	Bhusawal Unit 4	500MW	01/Jul/2016	23.55		Continued.	A.O.H.(Zero Schedule from 01/07/2016 to 16/07/2016)
IPP	VIPL U-2	300MW	15/Jul/2016	00.16	06/Aug/2016	06.36	Genrator Inspection.
FORCED OUTAGES							
RGPP	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPP	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	WPCL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	WPCL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
IPP	RPL(AMT) U-5	270MW	24/May/2016	00.05		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 7	108MW	24/May/2016	17.42		Continued.	Generation Bearing Vibration High.
MSPGCL	Koradi Unit 9	660MW	04/Jun/2016	14.45		Continued.	No concent to operate
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-2	270MW	18/Jun/2016	06.54		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Nasik Unit 4	210MW	19/Jun/2016	00.20	02/Aug/2016	10:20	C.O.H from 19/06/2016 to 27/06/2016 and converted to zero schedule from 00.00hrs of 28/06/2016
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01		Continued.	Zero Shedule By MSEDCL.
IPP	RPL(AMT) U-4	270MW	30/Jun/2016	10.11		Continued.	Zero Schedule By MSEDCL.
IPP	RPL(AMT) U-1	270MW	01/Jul/2016	18.40		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Koradi Unit 5	200MW	01/Jul/2016	02.23		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Koradi Unit 7	210MW	01/Jul/2016	04.43		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Bhusawal Unit 5	500MW	01/Jul/2016	23.59		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Chandrapur Unit 9	500MW	02/Jul/2016	07.26	03/Aug/2016	20.03	M.S.Temp.Low.
MSPGCL	Khaparkheda Unit 2	210MW	05/Jul/2016	23.46		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Khaparkheda Unit 3	210MW	05/Jul/2016	23.52		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Bhusawal Unit 3	210MW	08/Jul/2016	23.57		Continued.	ID Fan Problem (Converted to Zero schedule by MSEDCL from 11-07-2016)
MSPGCL	Khaparkheda Unit 4	210MW	08/Jul/2016	03.07		Continued.	Zero Shedule By MSEDCL.
IPP	Adani U-4	660MW	13/Jul/2016	02.29			Zero Shedule By MSEDCL.
IPP	Adani U-1	660MW	13/Jul/2016	02.22	26/Jul/2016	15.07	Zero Shedule By MSEDCL.
RGPP	Dabhol 3B	230MW	18/Jul/2016	12.40		Continued.	Tripped.
IPP	WPCL U-3	135MW	21/Jul/2016	00.02	29/Jul/2016	22.33	Boiler Tube Leakage
Cent_Sect	TARAPUR-3	540MW	22/Jul/2016	20.30	26/Jul/2016	09.11	Reactor PCP mechanical seal damage
RGPP	Dabhol 2B	230MW	24/Jul/2016	17.13		Continued.	Change Over
MSPGCL	Koradi Unit-8	660MW	29/Jul/2016	22.38	04/Aug/2016	07.28	DCS Failure.
IPP	JSW (J) U3	300MW	31/Jul/2016	19.29		Continued.	Generator Hydrogen leakage
MSPGCL	Chandrapur Unit-8	500MW	01/Aug/2016	22.43	07/Aug/2016	10.39	Drum level high
MSPGCL	Uran Unit 6	108MW	03/Aug/2016	23.12	04/Aug/2016	21.31	gas restriction

LINE OUTAGES FOR THE WEEK FROM 01/08/2016 TO 07/08/2016

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Ektuni-Bableshtar ckt I	01/Jul/2016	18.00	01/Aug/2016	09.52	To control Load on Padgha-BBLSR Line
400 KV	Bhusawal-Aurangabad	27/Jul/2016	13.09		Continued.	Over Voltage
400 KV	Karad-Jaigad - I	27/Jul/2016	21.07		Continued.	Over Voltage
400 KV	Kolhapur Solapur(PG) I	29/Jul/2016	03.01	01/Aug/2016	06.28	Over Voltage
400 KV	karad -kolhapur-I	29/Jul/2016	21.22	02/Aug/2016	09.25	Over Voltage
400 KV	Dhule Sar'Sarovar I	31/Jul/2016	12.01	01/Aug/2016	06.48	Over Voltage
400 KV	Padghe - Nagothane - II	31/Jul/2016	20.04	01/Aug/2016	20.26	Distance Protection
400 KV	Kolhapur Solapur (PG) II	31/Jul/2016	23.56	01/Aug/2016	10.26	Over Voltage
400 KV	Kolhapur Solapur(PG) I	01/Aug/2016	00.02	02/Aug/2016	09.33	Over Voltage
400 KV	Chandrapur-II - Nanded	01/Aug/2016	00.54	02/Aug/2016	06.38	Over Voltage
400 KV	Koradi-India Bulls	01/Aug/2016	01.36	03/Aug/2016	19.22	Over Voltage
400 KV	karad -kolhapur-II	01/Aug/2016	02.35		Continued.	Over Voltage
400 KV	Ektuni-Bableshtar ckt II	01/Aug/2016	09.53		Continued.	To control Padgha-BBLSR L/L
400 KV	Padghe - Nagothane - II	01/Aug/2016	14.00	01/Aug/2016	20.26	opportunity outage
400 KV	Dhule Sar'Sarovar I	01/Aug/2016	17.06	01/Aug/2016	18.40	Over Voltage
400 KV	Kolhapur Solapur (PG) II	01/Aug/2016	22.54	02/Aug/2016	09.44	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	01/Aug/2016	23.00	02/Aug/2016	08.44	Over Voltage
400 KV	Kolhapur Solapur (PG) II	02/Aug/2016	14.09	03/Aug/2016	09.44	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	02/Aug/2016	21.49	03/Aug/2016	08.23	Over Voltage
400 KV	Khadka- Deepnagar Ckt 1	02/Aug/2016	22.25	04/Aug/2016	07.39	Over Voltage
400 KV	Chandrapur-II - Nanded	03/Aug/2016	00.29	03/Aug/2016	08.30	Over Voltage
400 KV	Chandrapur Bhadravati II	03/Aug/2016	01.59		Continued.	Over Voltage
400 KV	Chandrapur-Parali III	03/Aug/2016	09.25	03/Aug/2016	18.43	Quarterly Maintenance Work
400 KV	Padghe - Kalwa- I	03/Aug/2016	11.23	04/Aug/2016	00.18	R phase wave Trap jumper broken
400 KV	Kolhapur Solapur (PG) II	03/Aug/2016	15.49		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	03/Aug/2016	23.09	04/Aug/2016	09.26	Over Voltage
400 KV	Chandrapur-II - Nanded	04/Aug/2016	00.13	04/Aug/2016	06.39	Over Voltage
400 KV	Koradi-Bhusawal	04/Aug/2016	07.19	04/Aug/2016	14.48	To attend Hot Spot
400 KV	Girwali - Lonikand 1	04/Aug/2016	09.28	04/Aug/2016	19.17	Routine Maintenance Work
400 KV	Akola Wardha I	04/Aug/2016	15.50	04/Aug/2016	17.35	AMP work
400 KV	Lonikand I - Koyna stage-IV	04/Aug/2016	22.35	05/Aug/2016	09.39	Over Voltage
400 KV	Chandrapur-II - Nanded	05/Aug/2016	02.51	05/Aug/2016	06.54	Over Voltage
400 KV	Parly(MS)- Nanded	05/Aug/2016	08.08	06/Aug/2016	05.46	LA and Corona ring maint.work
400 KV	Akola Wardha II	05/Aug/2016	10.47	05/Aug/2016	17.04	Testing Work
400 KV	Bus Coupler @ Parly(Girwali)	05/Aug/2016	11.56		Continued.	Tripped without Indication,while charging trial failed at 18.08hrs on PDR problem
400 KV	Chandrapur-II - Nanded	05/Aug/2016	13.06	05/Aug/2016	19.52	Over Voltage
400 KV	Akola Aurangabad(PG) II	05/Aug/2016	18.33	05/Aug/2016	20.20	Over Voltage
400 KV	Chandrapur-II - Nanded	05/Aug/2016	22.24	06/Aug/2016	06.40	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	05/Aug/2016	23.35	06/Aug/2016	09.35	Over Voltage
400 KV	Bus Coupler @ New Koyna	06/Aug/2016	10.46	06/Aug/2016	14.50	Maintenance.
400 KV	Lonikand I - Koyna stage-IV	06/Aug/2016	22.25	07/Aug/2016	08.51	Over Voltage
400 KV	Chandrapur-II - Nanded	07/Aug/2016	00.53		Continued.	Over Voltage
400 KV	Girwali-Solapur (Lamboti)	07/Aug/2016	09.23	08/Aug/2016	06.40	Line signature analysis and reactor cold welding work for oil leakage.
400 KV	Lonikand I - Koyna stage-IV	07/Aug/2016	13.17		Continued.	Over Voltage
400 KV	Dhule Khandwa II	07/Aug/2016	14.34		Continued.	To convert line reactor as bus reactor at khandwa end.
400 KV	Padghe - Kharghar	07/Aug/2016	17.07		Continued.	Shifted on TBC at kharghar end
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	GIS Bhandup - Borivali	11/Jan/2016	07.42		Continued.	Tower Erection Work.
220 KV	Aurangabad (Waluj)-Bhenda	22/Jun/2016	23.02		Continued.	Hand Tripped.
220 KV	Kalwa-Salsette-IV	28/Jun/2016	18.17		Continued.	Distance Protection
220 KV	Bableshtar- Alephata	24/Jul/2016	07.57		Continued.	Load Diversion.
220 KV	Padgha - Temghar I	30/Jul/2016	17.05	01/Aug/2016	01.50	Due To Bus Outage At Padgha End.
220 KV	Padgha-Temghar-II	30/Jul/2016	17.05	01/Aug/2016	01.50	Due To Bus Outage At Padgha End.
220 KV	Chandrapur GCR - Sicom II	31/Jul/2016	02.38	01/Aug/2016	18.35	Distance Protection
220 KV	Nasik Navsari I	01/Aug/2016	06.14	01/Aug/2016	06.46	Tripped At Navsari End.
220 KV	Kandalgaon - Sona Alloys	02/Aug/2016	10.05	02/Aug/2016	16.05	Emergency treecutting work
220 KV	Vita-Wayphale	02/Aug/2016	12.16	02/Aug/2016	14.09	Isolator maintenance work
220 KV	Niwali - Pawas Line	03/Aug/2016	00.22	03/Aug/2016	00.55	Distance Protection
220 KV	Siemens - Mahape	03/Aug/2016	04.12	03/Aug/2016	05.12	Bus Bar Protection Operated
220 KV	Talandge-Mudshingi Ckt-I	03/Aug/2016	10.41	03/Aug/2016	13.50	Quarterly Maintenance Work
220 KV	Niwali - Pawas Line	03/Aug/2016	17.15	03/Aug/2016	19.46	Emergency work
220 KV	Kharepatan -Pawas Line	03/Aug/2016	17.21	03/Aug/2016	19.48	Emergency work
220 KV	Deepnagar Khadaka 2	04/Aug/2016	09.03	04/Aug/2016	17.04	Red Hot
220 KV	Telco- Chinchwad	04/Aug/2016	09.37	04/Aug/2016	10.13	Distance Protection
220 KV	Bhosari 2 - Telco	04/Aug/2016	09.37	04/Aug/2016	12.46	Distance Protection
220 KV	Nadgaonpeth-Amravati	04/Aug/2016	10.17	04/Aug/2016	19.18	To attend Hot Spot

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Khaparkheda-Kalmeshwar	04/Aug/2016	11.22	04/Aug/2016	21.38	Distance Protection
220 KV	Kalwa - Borivali	05/Aug/2016	05.16	05/Aug/2016	13.04	Distance Protection
220 KV	Bus section @ Kalwa	05/Aug/2016	09.18	05/Aug/2016	10.29	Routine Maintenance Work
220 KV	Chandrapur GCR - Sicom I	05/Aug/2016	09.36	05/Aug/2016	15.55	Tan Delta Measurment of CTs
220 KV	220KV Sawangi- Bhokardan	05/Aug/2016	11.02	05/Aug/2016	17.15	To attend Hot Spot
220 KV	Talandage(400kv) - Five Star Midc	05/Aug/2016	12.20	05/Aug/2016	20.05	Distance Relay Testing Work
220 KV	Kalwa - Airoli Knowledge Park	05/Aug/2016	13.15	05/Aug/2016	19.12	replacement of faulty distance protection relay
220 KV	Nashik-Airoli Knowledge Park	05/Aug/2016	18.24	05/Aug/2016	18.32	to remove hanging earth wire
220 KV	Boisar II - PGCIL II	05/Aug/2016	22.06	06/Aug/2016	00.16	Tripped on PDR
220 KV	Hinjawadi 2 - Infosys	06/Aug/2016	10.06	06/Aug/2016	17.34	Half yearly maintenance work
220 KV	REL Borivali TPC Borivali line	06/Aug/2016	10.1	06/Aug/2016	12.29	Annual bay maintenance work.
220 KV	Pedambe-Pophali	06/Aug/2016	11.22	06/Aug/2016	18.05	Distance Protection
220 KV	Bhosari 2 - Telco	06/Aug/2016	14.42	06/Aug/2016	19.30	Relay replacement work & RMW
220 KV	Trombay Salsette 1 Backbay	06/Aug/2016	22.49	07/Aug/2016	07.45	Attending Hot Spot
220 KV	Talandage(400kv) - Five Star Midc	06/Aug/2016	9.49	06/Aug/2016	20.42	Testing & RMW work.
220 KV	Kalwa-Salsette-VI	07/Aug/2016	01.20	07/Aug/2016	07.03	Attending Hot Spot
220 KV	REL Borivali MSETCL Borivali Line-1	07/Aug/2016	09.14	07/Aug/2016	12.12	Annual bay maintance work.
220 KV	Borivali(M)- Vasai	07/Aug/2016	09.43	07/Aug/2016	17.48	Outage on bus section.
220 KV	Tata Borivli MSETCL Borivli 5	07/Aug/2016	10.02	07/Aug/2016	17.39	Outage on bus section.
220 KV	Borivali - Ghodbunder	07/Aug/2016	10.19	07/Aug/2016	17.13	Outage on bus section.
220 KV	REL Borivali MSETCL Borivali Line-2	07/Aug/2016	12.16	07/Aug/2016	13.58	Annual bay maintance work.
132 KV	Padegaon - Sillod	01/Aug/2016	10.52	01/Aug/2016	14.46	Differential protection
132 KV	Girwali-Renapur-Ahamadpur	04/Aug/2016	07.02	04/Aug/2016	07.12	Distance Protection
132 KV	Amalner(220kv)-Amalner (132 Kv)	05/Aug/2016	14.40	05/Aug/2016	15.03	Bus Bar Protection Operated
132 KV	Amalner - Nardhana	05/Aug/2016	14.40	05/Aug/2016	14.44	Bus Bar Protection Operated
132 KV	Amalner(220kv)-Chopda	05/Aug/2016	14.40	05/Aug/2016	14.42	Bus Bar Protection Operated
132 KV	Amalner(220) Dharangaon	05/Aug/2016	14.40	05/Aug/2016	14.43	Bus Bar Protection Operated