

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 02/Aug/2021 to 08/Aug/2021**

**Supply Position During Morning Peak (MW)**

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |             |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 02-08-2021     | 10 Hrs | 4147        | 503        | 262        | 4912        | 5826                   | 2588        | 4795        | 424        | -1138        | 17407                 | 0                  | 17407                    | 1008        | 499          | 20052            | 20052                   | 49.99        |
| 03-08-2021     | 10 Hrs | 3903        | 830        | 263        | 4996        | 6143                   | 2647        | 4861        | 580        | -962         | 18265                 | 0                  | 18265                    | 1184        | 501          | 20912            | 20912                   | 49.99        |
| 04-08-2021     | 10 Hrs | 4824        | 484        | 253        | 5562        | 6168                   | 2643        | 4969        | 439        | -1178        | 18602                 | 0                  | 18602                    | 1028        | 464          | 21272            | 21272                   | 50.01        |
| 05-08-2021     | 11 Hrs | 4844        | 510        | 257        | 5610        | 6558                   | 2665        | 4498        | 640        | -1467        | 18504                 | 0                  | 18504                    | 895         | 491          | 21358            | 21358                   | 49.96        |
| 06-08-2021     | 10 Hrs | 5491        | 458        | 136        | 6086        | 7166                   | 2188        | 4574        | 512        | -1389        | 19136                 | 0                  | 19136                    | 810         | 500          | 21836            | 21836                   | 49.97        |
| 07-08-2021     | 12 Hrs | 5604        | 685        | 134        | 6423        | 8155                   | 949         | 4895        | 771        | -1412        | 19781                 | 0                  | 19781                    | 884         | 501          | 22578            | 22578                   | 49.99        |
| 08-08-2021     | 12 Hrs | 6469        | 410        | 139        | 7018        | 7785                   | 193         | 5013        | 820        | -1013        | 19816                 | 0                  | 19816                    | 768         | 501          | 22098            | 22098                   | 50.04        |
| <b>Maximum</b> |        | <b>6469</b> | <b>830</b> | <b>263</b> | <b>7018</b> | <b>8155</b>            | <b>2665</b> | <b>5013</b> | <b>820</b> | <b>-962</b>  | <b>19816</b>          | <b>0</b>           | <b>19816</b>             | <b>1184</b> | <b>501</b>   | <b>22578</b>     | <b>22578</b>            | <b>50.04</b> |
| <b>Minimum</b> |        | <b>3903</b> | <b>410</b> | <b>134</b> | <b>4912</b> | <b>5826</b>            | <b>193</b>  | <b>4498</b> | <b>424</b> | <b>-1467</b> | <b>17407</b>          | <b>0</b>           | <b>17407</b>             | <b>768</b>  | <b>464</b>   | <b>20052</b>     | <b>20052</b>            | <b>49.96</b> |
| <b>Average</b> |        | <b>5040</b> | <b>554</b> | <b>206</b> | <b>5801</b> | <b>6829</b>            | <b>1982</b> | <b>4801</b> | <b>598</b> | <b>-1223</b> | <b>18788</b>          | <b>0</b>           | <b>18788</b>             | <b>940</b>  | <b>494</b>   | <b>21444</b>     | <b>21444</b>            | <b>49.99</b> |

**Supply Position During Day Peak (MW)**

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |             |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 02-08-2021     | 13 Hrs | 3527        | 444        | 263        | 4234        | 6247                   | 2659        | 4482        | 631        | -1637        | 16616                 | 0                  | 16616                    | 812         | 286          | 19351            | 19351                   | 49.96        |
| 03-08-2021     | 13 Hrs | 3919        | 489        | 264        | 4672        | 6020                   | 2544        | 4879        | 549        | -1164        | 17500                 | 0                  | 17500                    | 1144        | 500          | 20308            | 20308                   | 49.97        |
| 04-08-2021     | 13 Hrs | 4112        | 432        | 259        | 4802        | 5869                   | 2882        | 5023        | 727        | -1531        | 17772                 | 0                  | 17772                    | 784         | 498          | 20586            | 20586                   | 50.05        |
| 05-08-2021     | 13 Hrs | 4530        | 494        | 261        | 5286        | 6544                   | 2572        | 4475        | 672        | -1465        | 18084                 | 0                  | 18084                    | 887         | 499          | 20934            | 20934                   | 50.02        |
| 06-08-2021     | 13 Hrs | 5334        | 424        | 135        | 5894        | 6830                   | 2105        | 4507        | 703        | -1493        | 18546                 | 0                  | 18546                    | 924         | 503          | 21466            | 21466                   | 50.04        |
| 07-08-2021     | 16 Hrs | 5760        | 548        | 134        | 6442        | 7685                   | 1140        | 5154        | 643        | -1191        | 19873                 | 0                  | 19873                    | 970         | 501          | 22535            | 22535                   | 50.01        |
| 08-08-2021     | 15 Hrs | 6580        | 416        | 135        | 7131        | 7527                   | 236         | 5069        | 666        | -945         | 19684                 | 0                  | 19684                    | 731         | 501          | 21861            | 21861                   | 50.05        |
| <b>Maximum</b> |        | <b>6580</b> | <b>548</b> | <b>264</b> | <b>7131</b> | <b>7685</b>            | <b>2882</b> | <b>5154</b> | <b>727</b> | <b>-945</b>  | <b>19873</b>          | <b>0</b>           | <b>19873</b>             | <b>1144</b> | <b>503</b>   | <b>22535</b>     | <b>22535</b>            | <b>50.05</b> |
| <b>Minimum</b> |        | <b>3527</b> | <b>416</b> | <b>134</b> | <b>4234</b> | <b>5869</b>            | <b>236</b>  | <b>4475</b> | <b>549</b> | <b>-1637</b> | <b>16616</b>          | <b>0</b>           | <b>16616</b>             | <b>731</b>  | <b>286</b>   | <b>19351</b>     | <b>19351</b>            | <b>49.96</b> |
| <b>Average</b> |        | <b>4823</b> | <b>464</b> | <b>207</b> | <b>5494</b> | <b>6675</b>            | <b>2020</b> | <b>4798</b> | <b>656</b> | <b>-1347</b> | <b>18296</b>          | <b>0</b>           | <b>18296</b>             | <b>893</b>  | <b>470</b>   | <b>21006</b>     | <b>21006</b>            | <b>50.01</b> |

**Supply Position During Evening Peak (MW)**

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |             |             |          |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 02-08-2021     | 20 Hrs | 4215        | 934        | 262        | 5411        | 4794                   | 2520        | 4763        | 0        | -760         | 16728                 | 0                  | 16728                    | 1182        | 501          | 19171            | 19171                   | 49.81        |
| 03-08-2021     | 20 Hrs | 4111        | 836        | 263        | 5210        | 5495                   | 1806        | 4978        | 0        | -780         | 16709                 | 0                  | 16709                    | 1194        | 501          | 19184            | 19184                   | 49.81        |
| 04-08-2021     | 20 Hrs | 4761        | 466        | 264        | 5492        | 5366                   | 2268        | 5186        | 0        | -976         | 17336                 | 0                  | 17336                    | 1035        | 500          | 19846            | 19846                   | 50.01        |
| 05-08-2021     | 20 Hrs | 5436        | 730        | 259        | 6424        | 5856                   | 1834        | 4583        | 0        | -928         | 17770                 | 0                  | 17770                    | 1145        | 500          | 20342            | 20342                   | 49.91        |
| 06-08-2021     | 20 Hrs | 5344        | 864        | 136        | 6344        | 6250                   | 1609        | 4543        | 0        | -1002        | 17744                 | 0                  | 17744                    | 1073        | 500          | 20318            | 20318                   | 49.89        |
| 07-08-2021     | 20 Hrs | 6127        | 764        | 135        | 7026        | 6322                   | 1090        | 5158        | 0        | -1017        | 18579                 | 0                  | 18579                    | 1011        | 501          | 21108            | 21108                   | 49.85        |
| 08-08-2021     | 20 Hrs | 6640        | 347        | 138        | 7125        | 5970                   | 988         | 5205        | 0        | -1106        | 18182                 | 0                  | 18182                    | 752         | 331          | 20371            | 20371                   | 50.04        |
| <b>Maximum</b> |        | <b>6640</b> | <b>934</b> | <b>264</b> | <b>7125</b> | <b>6322</b>            | <b>2520</b> | <b>5205</b> | <b>0</b> | <b>-760</b>  | <b>18579</b>          | <b>0</b>           | <b>18579</b>             | <b>1194</b> | <b>501</b>   | <b>21108</b>     | <b>21108</b>            | <b>50.04</b> |
| <b>Minimum</b> |        | <b>4111</b> | <b>347</b> | <b>135</b> | <b>5210</b> | <b>4794</b>            | <b>988</b>  | <b>4543</b> | <b>0</b> | <b>-1106</b> | <b>16709</b>          | <b>0</b>           | <b>16709</b>             | <b>752</b>  | <b>331</b>   | <b>19171</b>     | <b>19171</b>            | <b>49.81</b> |
| <b>Average</b> |        | <b>5233</b> | <b>706</b> | <b>208</b> | <b>6147</b> | <b>5722</b>            | <b>1731</b> | <b>4917</b> | <b>0</b> | <b>-938</b>  | <b>17578</b>          | <b>0</b>           | <b>17578</b>             | <b>1056</b> | <b>476</b>   | <b>20049</b>     | <b>20049</b>            | <b>49.90</b> |

### Supply Position During Night Off Peak (MW)

| Date           | Time  | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.  | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|-------|-------------|------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
|                |       | THM         | HYDRO      | GAS        | Total       |                        |             |             |          |              |                       |                    |                          |            |              |                  |                         |              |
|                |       | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW         | MW           | MW               | MW                      | Hzs          |
| 02-08-2021     | 4 Hrs | 3009        | 333        | 266        | 3608        | 4302                   | 2896        | 3856        | 0        | -903         | 13759                 | 0                  | 13759                    | 541        | 285          | 15488            | 15488                   | 50.01        |
| 03-08-2021     | 4 Hrs | 3174        | 328        | 276        | 3778        | 4483                   | 2887        | 4200        | 0        | -922         | 14426                 | 0                  | 14426                    | 516        | 285          | 16149            | 16149                   | 50.03        |
| 04-08-2021     | 4 Hrs | 3898        | 326        | 265        | 4490        | 4572                   | 1905        | 4911        | 0        | -832         | 15046                 | 0                  | 15046                    | 630        | 285          | 16792            | 16792                   | 49.99        |
| 05-08-2021     | 4 Hrs | 4361        | 334        | 265        | 4960        | 4535                   | 2547        | 4429        | 0        | -967         | 15504                 | 0                  | 15504                    | 522        | 286          | 17280            | 17280                   | 49.95        |
| 06-08-2021     | 4 Hrs | 4859        | 320        | 137        | 5316        | 5065                   | 2248        | 4539        | 0        | -1108        | 16060                 | 0                  | 16060                    | 414        | 285          | 17868            | 17868                   | 50.03        |
| 07-08-2021     | 2 Hrs | 5357        | 327        | 137        | 5821        | 5576                   | 1079        | 4561        | 0        | -849         | 16188                 | 0                  | 16188                    | 698        | 500          | 18235            | 18235                   | 49.90        |
| 08-08-2021     | 3 Hrs | 6169        | 327        | 139        | 6635        | 5573                   | 614         | 5046        | 0        | -831         | 17037                 | 0                  | 17037                    | 622        | 501          | 18991            | 18991                   | 50.04        |
| <b>Maximum</b> |       | <b>6169</b> | <b>334</b> | <b>276</b> | <b>6635</b> | <b>5576</b>            | <b>2896</b> | <b>5046</b> | <b>0</b> | <b>-831</b>  | <b>17037</b>          | <b>0</b>           | <b>17037</b>             | <b>698</b> | <b>501</b>   | <b>18991</b>     | <b>18991</b>            | <b>50.04</b> |
| <b>Minimum</b> |       | <b>3009</b> | <b>320</b> | <b>137</b> | <b>3608</b> | <b>4302</b>            | <b>614</b>  | <b>3856</b> | <b>0</b> | <b>-1108</b> | <b>13759</b>          | <b>0</b>           | <b>13759</b>             | <b>414</b> | <b>285</b>   | <b>15488</b>     | <b>15488</b>            | <b>49.90</b> |
| <b>Average</b> |       | <b>4404</b> | <b>328</b> | <b>212</b> | <b>4944</b> | <b>4872</b>            | <b>2025</b> | <b>4506</b> | <b>0</b> | <b>-916</b>  | <b>15432</b>          | <b>0</b>           | <b>15432</b>             | <b>563</b> | <b>347</b>   | <b>17258</b>     | <b>17258</b>            | <b>49.99</b> |

### Details of Supply Position (MUs)

| Date           | MSGENCO        |               |              |                | Pench (MS)   | Central Sector Receipt | Central Sector Share | WIND           | CPP            | SOLAR        | TPCL Gen.     | R-INFRA Gen.  | TPCL Exch.     | Energy Requirement |               |                |
|----------------|----------------|---------------|--------------|----------------|--------------|------------------------|----------------------|----------------|----------------|--------------|---------------|---------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS          | Total          |              |                        |                      |                |                |              |               |               |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus          | Mus            | Mus          | Mus                    | Mus                  | Mus            | Mus            | Mus          | Mus           | Mus           | Mus            | Mus                | Mus           | Mus            |
| 02-08-2021     | 89.964         | 10.347        | 6.322        | 106.633        | 0.100        | 123.596                | 124.722              | 63.400         | 109.113        | 4.764        | 19.092        | 8.041         | -27.884        | 379.622            | 55.017        | 434.639        |
| 03-08-2021     | 90.481         | 13.102        | 6.355        | 109.938        | 0.102        | 131.914                | 126.454              | 58.258         | 113.097        | 4.998        | 22.148        | 10.423        | -22.763        | 395.442            | 55.334        | 450.776        |
| 04-08-2021     | 102.388        | 10.104        | 6.301        | 118.793        | 0.095        | 131.178                | 129.386              | 58.304         | 119.893        | 4.912        | 20.208        | 9.427         | -26.414        | 406.666            | 56.049        | 462.715        |
| 05-08-2021     | 116.130        | 10.696        | 5.753        | 132.579        | 0.341        | 140.018                | 137.588              | 56.349         | 108.482        | 5.284        | 19.584        | 9.897         | -27.409        | 415.303            | 56.890        | 472.193        |
| 06-08-2021     | 126.157        | 11.559        | 3.273        | 140.989        | 0.592        | 149.794                | 147.178              | 45.330         | 108.742        | 5.367        | 19.162        | 11.047        | -27.595        | 422.627            | 57.804        | 480.431        |
| 07-08-2021     | 137.691        | 12.664        | 3.277        | 153.632        | 0.591        | 163.026                | 159.345              | 25.225         | 117.315        | 6.672        | 19.854        | 11.537        | -25.073        | 440.797            | 56.464        | 497.261        |
| 08-08-2021     | 151.358        | 9.947         | 3.333        | 164.638        | 0.591        | 159.066                | 155.279              | 12.664         | 122.439        | 6.419        | 18.138        | 11.367        | -21.181        | 444.045            | 50.686        | 494.731        |
| <b>Maximum</b> | <b>151.358</b> | <b>13.102</b> | <b>6.355</b> | <b>164.638</b> | <b>0.592</b> | <b>163.026</b>         | <b>159.345</b>       | <b>151.358</b> | <b>122.439</b> | <b>6.672</b> | <b>22.148</b> | <b>11.537</b> | <b>-21.181</b> | <b>444.045</b>     | <b>57.804</b> | <b>497.261</b> |
| <b>Minimum</b> | <b>89.964</b>  | <b>9.947</b>  | <b>3.273</b> | <b>106.633</b> | <b>0.095</b> | <b>123.596</b>         | <b>124.722</b>       | <b>89.964</b>  | <b>108.482</b> | <b>4.764</b> | <b>18.138</b> | <b>8.041</b>  | <b>-27.884</b> | <b>379.622</b>     | <b>50.686</b> | <b>434.639</b> |
| <b>Average</b> | <b>116.310</b> | <b>11.203</b> | <b>4.945</b> | <b>132.457</b> | <b>0.345</b> | <b>142.656</b>         | <b>139.993</b>       | <b>116.310</b> | <b>114.154</b> | <b>5.488</b> | <b>19.741</b> | <b>10.248</b> | <b>-25.474</b> | <b>414.929</b>     | <b>55.463</b> | <b>470.392</b> |

**Details of Koyna Water Consumption  
(in TMC)**

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 02-08-2021 | 0.057       | 0.087         | 59.148  |
| 03-08-2021 | 0.098       | 0.185         | 59.050  |
| 04-08-2021 | 0.046       | 0.231         | 59.004  |
| 05-08-2021 | 0.042       | 0.273         | 58.962  |
| 06-08-2021 | 0.061       | 0.333         | 58.901  |
| 07-08-2021 | 0.075       | 0.409         | 58.826  |
| 08-08-2021 | 0.044       | 0.453         | 58.782  |

**State Load Despatch Center,Airoli (MSETCL)  
Central Sector Share/Drawal from 02/Aug/2021 to 08/Aug/2021**

| Date         | DAY       | Central Sector Share |         | Total Interstate |         | Total Share    |         | Total Drawal   |         | Overdrawal(+) / |         |
|--------------|-----------|----------------------|---------|------------------|---------|----------------|---------|----------------|---------|-----------------|---------|
|              |           | MUs                  | Avg. MW | MUs              | Avg. MW | MUs            | Avg. MW | MUs            | Avg. MW | MUs             | Avg. MW |
|              |           | <b>1</b>             |         | <b>2</b>         |         | <b>1+2=3</b>   |         | <b>4</b>       |         | <b>3-4=5</b>    |         |
| 02-08-2021   | MONDAY    | 88.050               | 5160    | 36.672           | 1528    | 124.722        | 5197    | 123.596        | 5150    | -1.126          | -47     |
| 03-08-2021   | TUESDAY   | 86.184               | 5229    | 40.270           | 1678    | 126.454        | 5269    | 131.914        | 5496    | 5.460           | 228     |
| 04-08-2021   | WEDNESDAY | 87.800               | 5349    | 41.586           | 1733    | 129.386        | 5391    | 131.178        | 5466    | 1.792           | 75      |
| 05-08-2021   | THURSDAY  | 99.821               | 5695    | 37.767           | 1574    | 137.588        | 5733    | 140.018        | 5834    | 2.430           | 101     |
| 06-08-2021   | FRIDAY    | 110.895              | 6096    | 36.283           | 1512    | 147.178        | 6132    | 149.794        | 6241    | 2.616           | 109     |
| 07-08-2021   | SATURDAY  | 111.289              | 6591    | 48.056           | 2002    | 159.345        | 6639    | 163.026        | 6793    | 3.681           | 153     |
| 08-08-2021   | SUNDAY    | 109.153              | 6424    | 46.126           | 1922    | 155.279        | 6470    | 159.066        | 6628    | 3.787           | 158     |
| <b>Total</b> |           | <b>693.191</b>       |         | <b>286.761</b>   |         | <b>979.952</b> |         | <b>998.592</b> |         | <b>18.640</b>   |         |

| Generator Unit Outages/Trippings from 02.08.2021 to 08.08.2021 |            |           |            |            |                                                                                  |             |
|----------------------------------------------------------------|------------|-----------|------------|------------|----------------------------------------------------------------------------------|-------------|
| Name of Unit                                                   | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                           | Outage Type |
| RPL(AMT) U-3                                                   | 15-07-2021 | 0         | 29-08-2021 | 5.52       | Annual Overhaul                                                                  | PLANNED     |
| Chandrapur Unit 9                                              | 15-07-2021 | 2         | 18-08-2021 | 9.39       | Annual Overhaul                                                                  | PLANNED     |
| Paras Unit 3                                                   | 20-07-2021 | 0.35      | 30-08-2021 | 20.12      | Annual Overhaul                                                                  | PLANNED     |
| Trombay 7A                                                     | 05-08-2021 | 22.39     |            | Continued. | Gas Shortage(Converted to AOH 00.00Hrs from Dt.09/08/2021)                       | PLANNED     |
| Trombay 7B                                                     | 05-08-2021 | 22.19     |            | Continued. | Gas Shortage(Converted to AOH 00.00Hrs from Dt.09/08/2021)                       | PLANNED     |
| Koradi Unit-8                                                  | 08-08-2021 | 22.53     | 09-08-2021 | 3.07       | Generator protection of other system.                                            | FORCED      |
| Koradi Unit-8                                                  | 30-07-2021 | 16.31     | 04-08-2021 | 7.32       | Boiler Tube Leakage                                                              | FORCED      |
| Parli Unit 8                                                   | 12-07-2021 | 18        | 05-08-2021 | 3.07       | Zero Schedule.                                                                   | FORCED      |
| IEPL Unit 1                                                    | 28-08-2018 | 21.26     |            | Continued. | No PPA                                                                           | FORCED      |
| PGPL U1                                                        | 07-02-2017 | 17.3      |            | Continued. | No Schedule (NO PPA)                                                             | FORCED      |
| PGPL U2                                                        | 07-02-2017 | 17.3      |            | Continued. | No Schedule.(NO PPA)                                                             | FORCED      |
| Koradi Unit 10                                                 | 04-08-2021 | 11.03     | 07-08-2021 | 14.31      | Boiler Tube Leakage                                                              | FORCED      |
| Koyna Unit 6                                                   | 05-08-2021 | 21.25     | 08-08-2021 | 19.4       | Differential protection                                                          | FORCED      |
| Khaparkheda Unit 1                                             | 05-08-2021 | 14.01     | 05-08-2021 | 17.1       | Flame Failure                                                                    | FORCED      |
| Khaparkheda Unit 1                                             | 04-08-2021 | 7.36      | 04-08-2021 | 23.07      | Flashover in Boiler.                                                             | FORCED      |
| Khaparkheda Unit 1                                             | 15-07-2021 | 23.57     | 04-08-2021 | 5.19       | Zero schedule                                                                    | FORCED      |
| Khaparkheda Unit 2                                             | 16-07-2021 | 0.12      | 04-08-2021 | 7.07       | Zero schedule                                                                    | FORCED      |
| Khaparkheda Unit 3                                             | 16-07-2021 | 0.29      | 04-08-2021 | 4.55       | Zero schedule                                                                    | FORCED      |
| Khaparkheda Unit 4                                             | 16-07-2021 | 2         | 04-08-2021 | 5.34       | Zero schedule                                                                    | FORCED      |
| Chandrapur Unit 7                                              | 30-07-2021 | 0         | 04-08-2021 | 1.03       | Zero Schedule.                                                                   | FORCED      |
| Koradi Unit 6                                                  | 27-04-2021 | 19.59     | 07-08-2021 | 5.06       | Zero Schedule.                                                                   | FORCED      |
| Koradi Unit 7                                                  | 27-04-2021 | 20.03     |            | Continued. | Retired (04/08/2021 At 00.00)                                                    | FORCED      |
| Bhusawal Unit 3                                                | 08-08-2021 | 3.4       | 08-08-2021 | 5.18       | Due To Drum Level High.                                                          | FORCED      |
| Bhusawal Unit 3                                                | 08-06-2021 | 0.34      | 08-08-2021 | 3.08       | Zero Schedule.                                                                   | FORCED      |
| Nasik Unit 3                                                   | 03-12-2020 | 6.45      | 08-08-2021 | 16.2       | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).              | FORCED      |
| Nasik Unit 4                                                   | 04-07-2021 | 11.03     | 08-08-2021 | 6          | Boiler Tube Leakage(Converted into to Zero Schedule from 20.00Hrs DT.06-07-2021) | FORCED      |
| Nasik Unit 5                                                   | 07-08-2021 | 20.45     |            | Continued. | Boiler Tube Leakage                                                              | FORCED      |
| Parli Unit 6                                                   | 07-08-2021 | 17.45     | 07-08-2021 | 20.52      | Due To EHFC Fault.                                                               | FORCED      |
| Parli Unit 6                                                   | 04-05-2021 | 20        | 07-08-2021 | 17.27      | Zero Schedule By MSEDCL                                                          | FORCED      |
| Parli Unit 7                                                   | 05-05-2021 | 19        | 07-08-2021 | 14.24      | Zero Schedule.                                                                   | FORCED      |
| Parli Unit 7                                                   | 07-08-2021 | 12.2      | 07-08-2021 | 14.24      | Drum level low                                                                   | FORCED      |
| JSW (J) U4                                                     | 16-07-2021 | 17.44     | 19-08-2021 | 8.42       | Air Preheater problem.                                                           | FORCED      |
| SWPGPL U-1                                                     | 16-02-2016 | 17.09     |            | Continued. | No PPA.                                                                          | FORCED      |
| SWPGPL U-3                                                     | 29-07-2021 | 9.11      | 04-08-2021 | 21.17      | PA fan bearing issue.(ready & under zero sch. from 12.30 hrs of 30.07.2021)      | FORCED      |
| SWPGPL U-4                                                     | 19-07-2021 | 23.45     | 05-08-2021 | 1.06       | Zero schedule.                                                                   | FORCED      |
| SWPGPL U-4                                                     | 05-08-2021 | 3.04      |            | Continued. | Turbine Vibration High.                                                          | FORCED      |
| Adani U-5                                                      | 04-08-2021 | 23.52     | 07-08-2021 | 10.2       | APH-B Gear Box Abnormal Sound.                                                   | FORCED      |
| VIPL U-1                                                       | 29-12-2018 | 0.3       |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                          | FORCED      |
| VIPL U-2                                                       | 17-01-2019 | 0.15      |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                           | FORCED      |
| Uran Unit 5                                                    | 05-08-2021 | 20.02     | 14-08-2021 | 19.56      | Gas shortage                                                                     | FORCED      |
| Uran Unit 6                                                    | 29-06-2021 | 22.18     | 13-08-2021 | 17.25      | Gas shortage                                                                     | FORCED      |
| Uran Unit 7                                                    | 25-05-2020 | 12.51     |            | Continued. | Turbine Blade Failure                                                            | FORCED      |
| Uran Unit A0                                                   | 05-08-2021 | 20.02     | 14-08-2021 | 0.43       | Gas shortage                                                                     | FORCED      |

**Transmission Line Outages/Tripping from 02.08.2021 to 08.08.2021**

| Name of Line                   | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                     | Outage Type | Voltage |
|--------------------------------|------------|-----------|------------|------------|----------------------------------------------------------------------------|-------------|---------|
| Mudshingi Chikodi              | 24-09-2019 | 17.12     |            | Continued. | No Schedule(Charge from Mudshingi end only)                                | PO          | 220 KV  |
| Talandage - Chikodi            | 01-10-2019 | 17.1      |            | Continued. | No Schedule(Close at Chikodi end only)                                     | PO          | 220 KV  |
| Kalwa-TIFIL                    | 23-07-2021 | 11.12     |            | Continued. | For Complete Tower erection work at loc no. 75A & 76 (behind M/s Siemens). | PO          | 220 KV  |
| Kharghar-Borivali ckt II       | 23-07-2021 | 8.43      |            | Continued. | To Carry out bunching work.                                                | PO          | 220 KV  |
| Kalwa - Siemens                | 24-07-2021 | 18.16     |            | Continued. | Tower Erection & Bunching work                                             | PO          | 220 KV  |
| Kharghar-Borivali ckt I        | 24-07-2021 | 8.46      |            | Continued. | Tower Erection & Bunching work                                             | PO          | 220 KV  |
| Chikhli-Jalna-II               | 30-07-2021 | 15.37     | 02-08-2021 | 11.18      | To control ICT loading                                                     | HT          | 220 KV  |
| Chikhli-Jalna-I                | 31-07-2021 | 21.54     | 02-08-2021 | 11.18      | To control Akola ICT loading.                                              | HT          | 220 KV  |
| Mahad-Kandalgaon               | 02-08-2021 | 9.35      | 02-08-2021 | 18.47      | JCB come in induction zone while ground cutting work.                      | HT          | 220 KV  |
| 220/132 kV 200 MVA ICT- I @    | 03-08-2021 | 16.05     | 03-08-2021 | 18.25      | Attending Hot Spot                                                         | EO          | 220 KV  |
| Apta - Bombay Dyeing           | 03-08-2021 | 16.45     | 03-08-2021 | 17.36      | Removing of rusted and damaged earthwire between Loc no.LILO 21 to 21.     | PO          | 220 KV  |
| Bableshtar - Bhenda            | 03-08-2021 | 14        | 03-08-2021 | 17.46      | Replacement of faulty flashover cut point string loc 21 B ph.              | PO          | 220 KV  |
| Bapgaon - Kalwa                | 03-08-2021 | 17.04     | 03-08-2021 | 18.04      | Attending water ingress in R ph CB density meter.                          | PO          | 220 KV  |
| Bhugaon- Wardha                | 03-08-2021 | 19.17     | 04-08-2021 | 0.02       | HT For Overdrawal                                                          | HT          | 220 KV  |
| Bhugaon-WardhaPG (Deoli)       | 03-08-2021 | 19.17     | 03-08-2021 | 23.56      | Overdrawal 950MW H/T at PG end only.                                       | HT          | 220 KV  |
| Karad - Vita Ckt- II           | 03-08-2021 | 11.25     | 03-08-2021 | 16.53      | Allied equipment maintenance work.                                         | PO          | 220 KV  |
| Nagothane - Spcl               | 03-08-2021 | 11.04     | 03-08-2021 | 13.19      | To attend trip circuit faulty indications.                                 | PO          | 220 KV  |
| New Koyna - Pedambe            | 03-08-2021 | 9.35      | 03-08-2021 | 20.45      | R-phase conductor broken indication received at pedambe end.               | HT          | 220 KV  |
| Osmanabad - Solapur (Bale)     | 03-08-2021 | 11.24     | 03-08-2021 | 17.19      | Relay testing work.                                                        | PO          | 220 KV  |
| Panchanand Taloja              | 03-08-2021 | 9.45      | 03-08-2021 | 14.08      | Jumper replacement for line isolator to breaker Y-Phase and B-Phase.       | PO          | 220 KV  |
| Pophali - New Koyna            | 03-08-2021 | 21        | 04-08-2021 | 15         | Due to Y-ph current zero also conductor stand is damaged at pophali end.   | HT          | 220 KV  |
| Talandage(400kv) - Five Star M | 03-08-2021 | 11.15     | 03-08-2021 | 13.55      | Relay testing work of 220KV Talandge ckt 2.                                | PO          | 220 KV  |
| Virur - Virur Rly Tss 2        | 03-08-2021 | 15.4      | 03-08-2021 | 17.45      | Work at TSS end.                                                           | PO          | 220 KV  |
| WARDHA - WARDHA (PG) (Deoli)   | 03-08-2021 | 19.14     | 03-08-2021 | 23.56      | Overdrawal 950MW H/T at PG end only.                                       | HT          | 220 KV  |
| 220/132 Kv 200 Mva Bb lct 2 @  | 04-08-2021 | 11.01     | 04-08-2021 | 18.47      | For Diagnostic Testing Work & Routine Maintenance Work.                    | PO          | 220 KV  |
| 220/132 kV 100MVA ICT-I @ S    | 04-08-2021 | 3.3       | 04-08-2021 | 4.07       | E/F 86 Operated. B PH Insulator String Of 33/44 KV Station 1 Burst.        | T           | 220 KV  |

**Transmission Line Outages/Tripping from 02.08.2021 to 08.08.2021**

| Name of Line                    | Date Trip  | Time Trip | Date Sync  | Time Sync | Reason                                                                                                                                       | Outage Type | Voltage |
|---------------------------------|------------|-----------|------------|-----------|----------------------------------------------------------------------------------------------------------------------------------------------|-------------|---------|
| 220/132 kV 200MVA ICT II @ A    | 04-08-2021 | 11.09     | 04-08-2021 | 18.45     | Testing Of ICT,CT,CB.RMW                                                                                                                     | PO          | 220 KV  |
| 220/132KV 100MVA ICT-II@Sh      | 04-08-2021 | 3.3       | 04-08-2021 | 3.55      | E/F 86 Operated. B PH Insulator String Of 33/44 KV Station 1 Burst.                                                                          | T           | 220 KV  |
| 220/22 Kv 50 Mva Cgl Ptr 4 @    | 04-08-2021 | 12.57     | 04-08-2021 | 20.05     | For Hot Spot Attending work on 50 MVA TF-4 LV B PH. Isolator Bus Side .                                                                      | EO          | 220 KV  |
| 220/33kV 125 MVA Transform      | 04-08-2021 | 23.03     | 05-08-2021 | 4.13      | Bucholz protection.                                                                                                                          | T           | 220 KV  |
| BADNERA - WARDHA (PG) (De       | 04-08-2021 | 11.25     | 04-08-2021 | 18.23     | Work At Wardha PG End.                                                                                                                       | PO          | 220 KV  |
| Bhigwan-Baramat lagro           | 04-08-2021 | 11.1      | 04-08-2021 | 15.25     | For attending oil leakage through Y PH CT secondary & Testing work at 220kV Baramati Agro ss.                                                | PO          | 220 KV  |
| Khaparkheda-Ambazari-I          | 04-08-2021 | 9.36      | 04-08-2021 | 18.32     | Replacement of Flashover String At various Locations.                                                                                        | PO          | 220 KV  |
| Khaparkheda-Butibori 3          | 04-08-2021 | 9.37      | 04-08-2021 | 15        | Replacement of Flashover String At various Locations.                                                                                        | PO          | 220 KV  |
| Lamboti - Solapur li(Bale) Ckt- | 04-08-2021 | 9.4       | 04-08-2021 | 12.28     | Quarterly Maintainance Work                                                                                                                  | PO          | 220 KV  |
| Peth- Mudshingi -I              | 04-08-2021 | 10.53     | 04-08-2021 | 12.53     | Quarterly Maintainance Work                                                                                                                  | PO          | 220 KV  |
| Wadkhal(GIS)-JSW(GIS) II        | 04-08-2021 | 9.26      | 19-08-2021 | 15.54     | Outage required for replacement of existing 1200/1A GIS Metering CTs with New 1600/1A GIS CTs.(CB Opened At JSW End On 02/04/2021 At 10:18). | PO          | 220 KV  |
| 220/100 Kv 100mva Bharat Bij    | 05-08-2021 | 10.07     | 05-08-2021 | 18.36     | Half yearly maintenance & diagnostic testing work                                                                                            | PO          | 220 KV  |
| Jamde-Dondaicha 1               | 05-08-2021 | 17.36     | 05-08-2021 | 19.56     | Attending Hot Spot                                                                                                                           | EO          | 220 KV  |
| Jejuri ( 400 Kv)-Jejuri ckt-I   | 05-08-2021 | 11.25     | 05-08-2021 | 17.46     | Annual CT testing & maintenance work.                                                                                                        | PO          | 220 KV  |
| Kandalgaon - Koyna (Pophali)    | 05-08-2021 | 21.25     | 07-08-2021 | 14.5      | Y-Ph wave trap jumper of kandalgaon line broken                                                                                              | T           | 220 KV  |
| NERUL - SEAWOOD CABLE CKT       | 05-08-2021 | 11.25     | 05-08-2021 | 17.46     | Energy meter checking by testing team                                                                                                        | PO          | 220 KV  |
| NERUL - SEAWOOD CABLE CKT       | 05-08-2021 | 14.25     | 05-08-2021 | 15.48     | Energy meter checking by testing team                                                                                                        | PO          | 220 KV  |
| Nandedcity-Parvati              | 05-08-2021 | 11.05     | 05-08-2021 | 12.45     | Distance Protection                                                                                                                          | PO          | 220 KV  |
| Pohali-Nerle                    | 05-08-2021 | 21.25     | 08-08-2021 | 18.35     | Y-Ph wave trap jumper of kandalgaon line broken                                                                                              | T           | 220 KV  |
| Pophali - New Koyna             | 05-08-2021 | 21.25     | 06-08-2021 | 1.45      | Y-Ph wave trap jumper of kandalgaon line broken                                                                                              | T           | 220 KV  |
| Pophali - Pedambe II            | 05-08-2021 | 21.25     | 07-08-2021 | 11        | Y-Ph wave trap jumper of kandalgaon line broken                                                                                              | T           | 220 KV  |
| Uran - Apta III                 | 05-08-2021 | 0.43      | 05-08-2021 | 13.17     | Red Hot On Wave Trap At Uran S/S.                                                                                                            | HT          | 220 KV  |
| 220/110 Kv 200 Mva Vel Ptr 1    | 06-08-2021 | 11        | 06-08-2021 | 12.55     | Quarterly Maintenance Work                                                                                                                   | PO          | 220 KV  |
| 220/22 Kv 50 Mva Bhel Ptr 1 @   | 06-08-2021 | 14        | 06-08-2021 | 16.4      | To attend hot spot on power Transformer B-Ph LV side cable Bus Bar plate Nut bolts                                                           | PO          | 220 KV  |

| Transmission Line Outages/Trippings from 02.08.2021 to 08.08.2021 |            |           |            |            |                                                                                                                                                              |             |         |
|-------------------------------------------------------------------|------------|-----------|------------|------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|---------|
| Name of Line                                                      | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                                                                                                       | Outage Type | Voltage |
| 220/22 Kv 50 Mva T&R Ptr 2 @                                      | 06-08-2021 | 9.34      | 07-08-2021 | 22.3       | Retrofitting of HV back up numerical relay, Master trip relays 86A, 86B, connection of metering CT & PT cores, BI & BOs to BCU                               | PO          | 220 KV  |
| 220/22 Kv 50 Mva Vijai Ptr 3 @                                    | 06-08-2021 | 9.33      | 06-08-2021 | 12.4       | To attend hot spot of 105deg C on power Transformer R-Ph LV bushing end palm by jumper replacement work.                                                     | PO          | 220 KV  |
| Chalishaon - Babhaleshwar                                         | 06-08-2021 | 12.5      | 06-08-2021 | 15         | Replacement of faulty flashover Normal string loc 277 B ph. WORK WILL BE CARRIED OUT IN LIVE LINE BY HOT LINE UNIT                                           | EO          | 220 KV  |
| Ghatghar - Jindal                                                 | 06-08-2021 | 5.15      | 06-08-2021 | 8.23       | Distance Protection                                                                                                                                          | T           | 220 KV  |
| Padghe - Jindal                                                   | 06-08-2021 | 5.15      | 06-08-2021 | 12.56      | Distance Protection                                                                                                                                          | T           | 220 KV  |
| Pandarpur-Khanapur                                                | 06-08-2021 | 9.22      | 06-08-2021 | 14.33      | Jumper Replacement Work At Loc No.28 B-Phase & Loc No. 36 Y-Phase & B,26 Y&B Phase Nut Bolt Tightening.                                                      | PO          | 220 KV  |
| Trombay - Mulund                                                  | 06-08-2021 | 6.15      | 06-08-2021 | 9.15       | Attending Hot Spot                                                                                                                                           | PO          | 220 KV  |
| Vankuswade - Kdph                                                 | 06-08-2021 | 3.55      | 06-08-2021 | 16.5       | B-Ph wave trap jumper open                                                                                                                                   | HT          | 220 KV  |
| 220/132 Kv 200 Mva Emco lct                                       | 07-08-2021 | 10.24     | 07-08-2021 | 17.38      | Testing Work                                                                                                                                                 | PO          | 220 KV  |
| 220/132kv 200mva Vijai Ptr 1                                      | 07-08-2021 | 9.02      | 07-08-2021 | 12         | Quarterly Maintenance Work                                                                                                                                   | PO          | 220 KV  |
| 220/132kv 200mva Vijai Ptr 2                                      | 07-08-2021 | 13.12     | 07-08-2021 | 15.38      | Quarterly Maintenance Work                                                                                                                                   | PO          | 220 KV  |
| 220/33kv 125 MVA Transform                                        | 07-08-2021 | 10.25     | 07-08-2021 | 17.55      | Replacement Of OSR Of OLTC And Filtration Of OLTC Oil.                                                                                                       | PO          | 220 KV  |
| GIS KONDHWA NANDED CITY                                           | 07-08-2021 | 8.19      | 07-08-2021 | 20.46      | Constriction Of 3 Pile Foundations For Isolator Under The Gantry Beam Of Main Bus Section-2 For Extension Of Main Bus For New 50 MVA Power Transformer Work. | PO          | 220 KV  |
| Kalwa-Salsette-IV                                                 | 07-08-2021 | 6.07      | 07-08-2021 | 9.3        | Emergency Tree Trimming.                                                                                                                                     | PO          | 220 KV  |
| Koyna (Pophali) - Kdph                                            | 07-08-2021 | 16.4      | 07-08-2021 | 19.2       | Replacement Of Conductor B Phase CT To Breaker And Line Side Isolator To CT.                                                                                 | PO          | 220 KV  |
| Mahape - TIFIL                                                    | 07-08-2021 | 9.19      | 07-08-2021 | 14.05      | For Attending Critical Hotspot On 220KV Main Bus On Priority And Other Maintenance Work At 220KV TIFIL Under Mahape.                                         | PO          | 220 KV  |
| PAL DOMBIVALI - PALAVA                                            | 07-08-2021 | 10.02     | 07-08-2021 | 13.48      | Fixing Of Repairing Sleeve To Damage Conductor Between Loc No. 136-137.                                                                                      | PO          | 220 KV  |
| SAKI (REL) - SAKI (TATA) CKT -                                    | 07-08-2021 | 11.28     | 07-08-2021 | 16.33      | Relay Testing Work.                                                                                                                                          | PO          | 220 KV  |
| Gangapur-Valve                                                    | 08-08-2021 | 18.5      | 08-08-2021 | 19.33      | B-PH of T/F 1 burst.                                                                                                                                         | T           | 220 KV  |
| Malegaon-Satana                                                   | 08-08-2021 | 17.33     | 09-08-2021 | 13.22      | Distance Protection                                                                                                                                          | T           | 220 KV  |
| Salsette - Sahara                                                 | 08-08-2021 | 9.43      | 08-08-2021 | 12.47      | Tree Trimming                                                                                                                                                | PO          | 220 KV  |
| Salsette - Saki 7                                                 | 08-08-2021 | 13.59     | 08-08-2021 | 16.31      | Tree Trimming                                                                                                                                                | PO          | 220 KV  |
| Karad Solapur (PG)                                                | 03-05-2017 | 11:49     |            | Continued. | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                                     | PO          | 400 KV  |

**Transmission Line Outages/Trippings from 02.08.2021 to 08.08.2021**

| Name of Line                  | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                                                                        | Outage Type | Voltage |
|-------------------------------|------------|-----------|------------|------------|-------------------------------------------------------------------------------------------------------------------------------|-------------|---------|
| Chandrapur Bhadravati II      | 26-07-2021 | 15.36     | 02-08-2021 | 19.52      | Maintenance work.                                                                                                             | PO          | 400 KV  |
| Deepnagar - Aurangabad        | 30-07-2021 | 10.47     | 02-08-2021 | 6.53       | Insulator string replacement. (RFC.16:29)                                                                                     | PO          | 400 KV  |
| Koradi-Khaperkheda li         | 30-07-2021 | 23.59     | 02-08-2021 | 7.12       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| Dhule Sar'Sarovar I           | 31-07-2021 | 13.32     | 02-08-2021 | 8.33       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| Chandrapur-II - Nanded ckt II | 01-08-2021 | 14        | 02-08-2021 | 7.33       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| Karad - Jaigad - II           | 01-08-2021 | 22.45     | 02-08-2021 | 8.29       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| Khadka-Aurangabad (Waluj)     | 02-08-2021 | 22.01     | 03-08-2021 | 8.17       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| New Koyna - Dabhol - II       | 02-08-2021 | 9         | 02-08-2021 | 15.04      | Hill cutting work at LOC no. 94-95.                                                                                           | PO          | 400 KV  |
| Waluj Aurangabad(PG)- I       | 02-08-2021 | 10.05     | 02-08-2021 | 16.21      | ACPG-1 line CT AMP works @MSETCL waluj.                                                                                       | PO          | 400 KV  |
| 400/220/33 Kv 315 MVA ICT-    | 03-08-2021 | 23.02     | 04-08-2021 | 0.48       | Attending Hot Spot                                                                                                            | EO          | 400 KV  |
| Koradi-Khaperkheda I          | 03-08-2021 | 9.57      | 03-08-2021 | 12.12      | Attending Hot Spot                                                                                                            | EO          | 400 KV  |
| New Koyna - Dabhol-I          | 03-08-2021 | 5.04      | 04-08-2021 | 17.38      | Over Voltage                                                                                                                  | T           | 400 KV  |
| Khadka-Aurangabad (Waluj)     | 04-08-2021 | 17.47     | 05-08-2021 | 9.14       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| Koradi-RattanIndia            | 04-08-2021 | 10.12     | 04-08-2021 | 13.41      | Bus-2 B PH Isolator Fixed Contact Rod (connected to Bus) Replacement Work by Hot Line Unit, Nagpur.                           | PO          | 400 KV  |
| Padghe - Kalwa- I             | 04-08-2021 | 4.26      | 04-08-2021 | 6.58       | Attending Hot Spot                                                                                                            | EO          | 400 KV  |
| 400/220/33 Kv 500 MVA ICT-I   | 05-08-2021 | 9.05      | 05-08-2021 | 16.3       | Half yearly maintenance and diagnostic testing work.                                                                          | PO          | 400 KV  |
| 400/220kv 500MVA ICT-1 @ T    | 06-08-2021 | 11.28     | 06-08-2021 | 19.03      | Quarterly Maintenance Work                                                                                                    | PO          | 400 KV  |
| Akola Aurangabad(PG) I        | 06-08-2021 | 10.07     | 06-08-2021 | 10.39      | For Unswitchable L/R AMP Works At Aurangabad End. Line Outage Required To Take LR Out Of Service.                             | PO          | 400 KV  |
| Bhusawal-Aurangabad           | 06-08-2021 | 20.04     | 07-08-2021 | 7.53       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| Dabhol Nagothane I            | 06-08-2021 | 9.58      | 06-08-2021 | 19.08      | Routine Maintenance Work                                                                                                      | PO          | 400 KV  |
| Kalwa - Kharghar              | 06-08-2021 | 10.59     | 06-08-2021 | 12.2       | Attending Hot Spot                                                                                                            | EO          | 400 KV  |
| Kolhapur Solapur (PG) II      | 06-08-2021 | 14.38     | 06-08-2021 | 17.56      | While making online operation, the R-ph blade of C-bus Pantograph Isolator not closing properly because of tilted bus hanger. | EO          | 400 KV  |
| Koradi-Bhusawal               | 06-08-2021 | 23.39     | 07-08-2021 | 4.56       | Attending Hot Spot                                                                                                            | EO          | 400 KV  |
| Lonikand 1 - Talegaon(Pgcil)  | 06-08-2021 | 13        | 06-08-2021 | 21.48      | Insulator String Replacement.                                                                                                 | EO          | 400 KV  |
| Warora -IEPL                  | 06-08-2021 | 18.5      | 06-08-2021 | 19.59      | DT Received At Warora End.                                                                                                    | T           | 400 KV  |
| Aurangabad - Aurangabad(PG    | 07-08-2021 | 10.26     | 07-08-2021 | 12.15      | DT Received From PG End.                                                                                                      | T           | 400 KV  |
| Nagothane - Dabhol-II         | 07-08-2021 | 9.56      | 07-08-2021 | 19.03      | Routine Maintenance Work                                                                                                      | PO          | 400 KV  |
| Padghe - Kalwa- I             | 07-08-2021 | 13.02     | 07-08-2021 | 18.06      | SSN To DSN Insulator Replacement.                                                                                             | PO          | 400 KV  |
| Khadka-Aurangabad (Waluj)     | 08-08-2021 | 18.18     | 09-08-2021 | 6.42       | Over Voltage                                                                                                                  | HT          | 400 KV  |
| Padghe - Kalwa-II             | 08-08-2021 | 9.3       | 08-08-2021 | 17.24      | Diagnostic Testing Work                                                                                                       | PO          | 400 KV  |
| Khadka-Aurangabad (Waluj)     | 31-12-2020 | 17.33     |            | Continued. | Over Voltage                                                                                                                  | HT          | 400 KV  |
| HVDC Pole-I                   | 03-08-2021 | 23.22     | 04-08-2021 | 3.42       | At Chandrapur base filter Z1,Z2 hot spot attending.                                                                           | EO          | 500 KV  |