

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 03/Oct/2016 to 09/Oct/2016

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03/10/2016	10 Hrs	3843	254	446	4543	5068	319	4144	38	-1245	12867	0	12867	1029	387	15528	15528	49.94
04/10/2016	10 Hrs	3700	291	304	4295	4891	1022	3994	73	-1319	12956	0	12956	1008	384	15667	15667	50.00
05/10/2016	10 Hrs	3756	292	301	4349	4777	1354	3841	94	-1409	13006	0	13006	860	385	15660	15660	50.01
06/10/2016	9 Hrs	4031	487	305	4823	4613	724	4423	97	-1149	13531	0	13531	821	384	15885	15885	49.95
07/10/2016	10 Hrs	4047	342	459	4848	5073	151	4520	101	-1296	13397	0	13397	1019	501	16213	16213	49.96
08/10/2016	10 Hrs	4069	393	445	4907	5358	269	4144	117	-1144	13651	0	13651	1040	385	16220	16220	49.98
09/10/2016	10 Hrs	3666	446	452	4564	5424	369	4171	120	-1062	13586	0	13586	725	385	15758	15758	49.99
Maximum		4069	487	459	4907	5424	1354	4520	120	-1062	13651	0	13651	1040	501	16220	16220	50.01
Minimum		3666	254	301	4295	4613	151	3841	38	-1409	12867	0	12867	725	384	15528	15528	49.94
Average		3873	358	387	4618	5029	601	4177	91	-1232	13285	0	13285	929	402	15847	15847	49.98

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03/10/2016	18 Hrs	3655	233	455	4343	4626	751	4017	2	-1329	12410	0	12410	966	385	15090	15090	50.00
04/10/2016	18 Hrs	3604	560	301	4465	4455	1029	4018	1	-1443	12525	0	12525	1033	192	15193	15193	49.95
05/10/2016	18 Hrs	3523	363	297	4183	4363	1054	4040	17	-1327	12330	0	12330	1033	385	15075	15075	49.96
06/10/2016	18 Hrs	3496	246	297	4039	4811	844	4326	14	-1354	12680	0	12680	1025	389	15448	15448	49.94
07/10/2016	18 Hrs	3714	252	451	4417	5049	386	4225	21	-1379	12719	0	12719	1072	386	15556	15556	49.93
08/10/2016	13 Hrs	4054	280	421	4755	5007	387	3996	128	-1242	13032	0	13032	1008	386	15668	15668	50.00
09/10/2016	13 Hrs	3670	142	438	4250	4877	248	4242	182	-1167	12632	0	12632	697	385	14881	14881	50.01
Maximum		4054	560	455	4755	5049	1054	4326	182	-1167	13032	0	13032	1072	389	15668	15668	50.01
Minimum		3496	142	297	4039	4363	248	3996	1	-1443	12330	0	12330	697	192	14881	14881	49.93
Average		3674	297	380	4350	4741	671	4124	52	-1320	12618	0	12618	976	358	15273	15273	49.97

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03/10/2016	20 Hrs	3970	865	443	5278	5270	784	4441	0	-1355	14418	0	14418	1039	386	17198	17198	50.01
04/10/2016	20 Hrs	3667	1325	303	5295	5219	939	4387	0	-1451	14390	0	14390	1084	234	17159	17159	50.00
05/10/2016	20 Hrs	4166	621	311	5098	5274	1004	4474	0	-1223	14627	0	14627	1140	477	17467	17467	50.02
06/10/2016	20 Hrs	3885	1375	310	5570	4801	837	4563	0	-1301	14470	0	14470	1082	503	17356	17356	49.99
07/10/2016	20 Hrs	4285	1257	437	5979	5066	441	4600	0	-1303	14783	0	14783	1124	507	17717	17717	50.00
08/10/2016	20 Hrs	4388	280	446	5114	4952	1128	4537	0	-1099	14632	0	14632	1173	481	17385	17385	50.01
09/10/2016	20 Hrs	4120	829	460	5409	4936	611	4451	0	-1113	14294	0	14294	977	384	16768	16768	50.00
Maximum		4388	1375	460	5979	5274	1128	4600	0	-1099	14783	0	14783	1173	507	17717	17717	50.02
Minimum		3667	280	303	5098	4801	441	4387	0	-1451	14294	0	14294	977	234	16768	16768	49.99
Average		4069	936	387	5392	5074	821	4493	0	-1264	14516	0	14516	1088	425	17293	17293	50.00

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
03/10/2016	4 Hrs	3811	66	449	4326	2594	476	3740	0	-463	10673	0	10673	696	387	12219	12219	49.96
04/10/2016	3 Hrs	3582	188	302	4072	2785	791	3868	0	-582	10934	0	10934	695	386	12597	12597	50.00
05/10/2016	4 Hrs	3727	119	314	4160	2795	966	3667	0	-499	11089	0	11089	696	385	12669	12669	49.99
06/10/2016	3 Hrs	3369	100	313	3782	3010	689	4184	0	-603	11062	0	11062	698	386	12749	12749	49.97
07/10/2016	4 Hrs	3540	125	338	4003	3460	495	4003	0	-565	11396	0	11396	701	387	13049	13049	49.97
08/10/2016	3 Hrs	3767	90	461	4318	3154	562	3963	0	-688	11309	0	11309	698	386	13081	13081	49.98
09/10/2016	4 Hrs	3714	222	454	4390	3049	486	3949	0	-664	11210	0	11210	695	385	12954	12954	50.01
Maximum		3811	222	461	4390	3460	966	4184	0	-463	11396	0	11396	701	387	13081	13081	50.01
Minimum		3369	66	302	3782	2594	476	3667	0	-688	10673	0	10673	695	385	12219	12219	49.96
Average		3644	130	376	4150	2978	638	3911	0	-581	11096	0	11096	697	386	12760	12760	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
03/10/2016	91.122	4.992	10.739	106.853	0.796	98.800	99.607	13.953	96.142	0.541	20.656	9.263	-26.120	290.169	56.039	346.208
04/10/2016	87.348	7.493	7.380	102.221	0.794	100.715	100.612	23.124	95.861	0.582	20.766	8.334	-27.163	295.340	56.263	351.603
05/10/2016	88.017	6.516	7.436	101.969	0.545	102.775	100.100	24.274	93.378	1.031	20.565	9.357	-26.504	296.924	56.435	353.359
06/10/2016	89.196	9.001	7.315	105.512	0.905	98.194	96.811	16.668	104.808	1.064	21.195	9.804	-27.009	299.238	58.008	357.246
07/10/2016	91.325	8.160	10.192	109.677	0.859	107.442	107.768	8.891	103.313	1.036	22.172	9.925	-27.149	303.210	59.247	362.457
08/10/2016	94.792	4.106	10.715	109.613	0.007	112.128	110.289	14.494	96.963	0.950	20.759	9.463	-26.244	307.903	56.466	364.369
09/10/2016	89.743	6.211	10.664	106.618	0.243	107.637	110.879	11.699	98.393	1.168	17.685	9.248	-24.556	300.959	51.489	352.448
Maximum	94.792	9.001	10.739	109.677	0.905	112.128	110.879	94.792	104.808	1.168	22.172	9.925	-24.556	307.903	59.247	364.369
Minimum	87.348	4.106	7.315	101.969	0.007	98.194	96.811	87.348	93.378	0.541	17.685	8.334	-27.163	290.169	51.489	346.208
Average	90.220	6.640	9.206	106.066	0.593	103.956	103.724	90.220	98.408	0.910	20.543	9.342	-26.392	299.106	56.278	355.384

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
03/10/2016	0.071	0.274	54.387
04/10/2016	0.092	0.366	54.295
05/10/2016	0.065	0.431	54.230
06/10/2016	0.119	0.550	54.111
07/10/2016	0.100	0.650	54.011
08/10/2016	0.050	0.700	53.961
09/10/2016	0.086	0.786	53.875

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 03/Oct/2016 to 09/Oct/2016

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
03/10/2016	MONDAY	80.163	4131	19.444	810	99.607	4150	98.800	4117	-0.807	-34
04/10/2016	TUESDAY	84.024	4176	16.588	691	100.612	4192	100.715	4196	0.103	4
05/10/2016	WEDNESDA	84.055	4155	16.045	669	100.100	4171	102.775	4282	2.675	111
06/10/2016	THURSDAY	90.665	4028	6.146	256	96.811	4034	98.194	4091	1.383	58
07/10/2016	FRIDAY	94.060	4477	13.708	571	107.768	4490	107.442	4477	-0.326	-14
08/10/2016	SATURDAY	95.834	4581	14.455	602	110.289	4595	112.128	4672	1.839	77
09/10/2016	SUNDAY	96.837	4606	14.042	585	110.879	4620	107.637	4485	-3.242	-135
Total		625.639		100.427		726.066		727.692		1.626	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 03/10/2016 TO 09/10/2016							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Uran Unit 5	108MW	04/Oct/2016	00.13	05/Oct/2016	19.34	Maintenance work
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage (Zero Schedule by MSEDCL at 21:51 Hrs on 30.09.2016)
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
IPP	WPCL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	WPCL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
IPP	RPL(AMT) U-5	270MW	24/May/2016	00.05		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
MSPGCL	Uran Unit B0	120MW	14/Aug/2016	07.56		Continued.	Maintenance work
MSPGCL	Koyna Unit 8	80MW	19/Aug/2016	11.00		Continued.	High Vibration On LGB & UGB.
RGPPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Nasik Unit 3	210MW	28/Aug/2016	21.45	07/Oct/2016	13.45	Zero Shedule By MSEDCL.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan Problem
IPP	RPL(AMT) U-2	270MW	12/Sep/2016	00.03		Continued.	Zero Schedule by MSEDCL
IPP	PGPL U2	126MW	14/Sep/2016	00.16		Continued.	Due To No Shedule.
IPP	PGPL U1	262MW	14/Sep/2016	00.20		Continued.	Due To No Shedule.
IPP	RPL(AMT) U-1	270MW	14/Sep/2016	23.55		Continued.	Zero Schedule by MSEDCL
MSPGCL	Bhusawal Unit 4	500MW	15/Sep/2016	23.59		Continued.	Zero Schedule by MSEDCL
IPP	RPL(AMT) U-4	270MW	15/Sep/2016	18.09		Continued.	Zero Schedule by MSEDCL
MSPGCL	Bhusawal Unit 3	210MW	16/Sep/2016	00.02		Continued.	Zero Schedule by MSEDCL
MSPGCL	Koradi Unit 7	210MW	16/Sep/2016	00.06		Continued.	Zero Schedule by MSEDCL
MSPGCL	Khaparkheda Unit 4	210MW	17/Sep/2016	20.48		Continued.	Zero Schedule by MSEDCL
MSPGCL	Khaparkheda Unit 1	210MW	17/Sep/2016	13.39		Continued.	Zero Schedule by MSEDCL
MSPGCL	Khaparkheda Unit 2	210MW	17/Sep/2016	13.43		Continued.	Zero Schedule by MSEDCL
MSPGCL	Bhusawal Unit 5	500MW	17/Sep/2016	13.51		Continued.	Zero Schedule by MSEDCL
MSPGCL	Parli Unit 7	250MW	22/Sep/2016	13.47		Continued.	Zero Schedule By MSEDCL
MSPGCL	Koyna Unit 11	80MW	24/Sep/2016	03.20		Continued.	Stator Earth Fault
MSPGCL	Koradi Unit 9	660MW	02/Oct/2016	07.08	03/Oct/2016	01.55	No concern from pollution department.
MSPGCL	Chandrapur Unit 3	210MW	03/Oct/2016	08.23	07/Oct/2016	09.41	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 4	210MW	04/Oct/2016	14.45	04/Oct/2016	17.18	Stator Rotor Flow Problem.
IPP	REL Unit 1	250MW	04/Oct/2016	15.12	04/Oct/2016	19.34	Generator Elect. Fault
MSPGCL	Chandrapur Unit 9	500MW	04/Oct/2016	19.15	05/Oct/2016	00.05	Electrical Protection Operated.
MSPGCL	Chandrapur Unit 9	500MW	05/Oct/2016	09.47	06/Oct/2016	04.21	Generator Protection operated
IPP	WPCL U-4	135MW	05/Oct/2016	04.00	05/Oct/2016	16.04	Esp Back Filtter Problem.
MSPGCL	Uran Unit 5	108MW	05/Oct/2016	21.09	06/Oct/2016	23.33	Maintenance work
MSPGCL	Khaparkheda Unit 3	210MW	05/Oct/2016	20.56		Continued.	Zero Schedule By MSEDCL
MSPGCL	Chandrapur Unit 4	210MW	05/Oct/2016	14.20	08/Oct/2016	09.36	Boiler Tube Leakage
IPP	WPCL U-3	135MW	05/Oct/2016	07.26	06/Oct/2016	06.35	Wet Coal Problem
MSPGCL	Koyna Unit 1	75MW	06/Oct/2016	01.35	07/Oct/2016	03.15	TGB oil cooler leakage
MSPGCL	Chandrapur Unit 9	500MW	07/Oct/2016	13.08	07/Oct/2016	16.09	Low Vaccum
MSPGCL	Uran Unit 5	108MW	07/Oct/2016	02.13	07/Oct/2016	02.27	Tripped
IPP	WPCL U-3	135MW	07/Oct/2016	21.00	10/Oct/2016	03.05	ID Fan Problem
MSPGCL	Nasik Unit 5	210MW	07/Oct/2016	16.30		Continued.	Zero Schedule By MSEDCL
MSPGCL	Chandrapur Unit 9	500MW	09/Oct/2016	10.37		Continued.	Coal Shortage

LINE OUTAGES FOR THE WEEK FROM 03/10/2016 TO 09/10/2016

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Ektuni-Bableshtar ckt II	01/Aug/2016	09.53	09/Oct/2016	12.08	To control Padghe-BBLSR L/L
400 KV	Karad -kolhapur-I	17/Sep/2016	03.43		Continued.	Over Voltage,B Pole of Breaker Burst.RFC @1905 DT 20.09.2016.
400 KV	Karad-Jaigad - I	30/Sep/2016	20.35	08/Oct/2016	09.36	Over Voltage
400 KV	Kolhapur Solapur(PG) I	30/Sep/2016	20.57	03/Oct/2016	07:53	Over Voltage
400 KV	Kolhapur Solapur (PG) II	03/Oct/2016	02.01	04/Oct/2016	07.29	Over Voltage
400 KV	Girwali-Solapur (Lamboti)	03/Oct/2016	08.59	03/Oct/2016	09.22	Testing Work
400 KV	Deepnagar Waluj 1	03/Oct/2016	09.20	03/Oct/2016	19.43	Line Maintenance work
400 KV	N.Koyana-Karad -Ckt II	03/Oct/2016	09.52	07/Oct/2016	07.34	R.M Work (RFC at 17.48 hrs at 03/10/2016) Kept open for overvoltage
400 KV	Koradi Satpur	03/Oct/2016	10.46	04/Oct/2016	21.35	Replacement work
400 KV	Khadka-Aurangabad (Waluj)	03/Oct/2016	19.47	03/Oct/2016	09.05	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	03/Oct/2016	23.55	04/Oct/2016	06.36	Over Voltage
400 KV	Deepnagar Waluj 1	04/Oct/2016	08.01	04/Oct/2016	18.57	Annual Maintenance Work
400 KV	Padghe - Nagothane - II	04/Oct/2016	11.40	04/Oct/2016	16.53	To Attend C Bus Isolator Problem.
400 KV	Khadka-Aurangabad (Waluj)	04/Oct/2016	19.59	05/Oct/2016	06.47	Over Voltage
400 KV	Kolhapur Solapur(PG) I	04/Oct/2016	21.00	05/Oct/2016	10.01	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	04/Oct/2016	23.27	05/Oct/2016	07.21	Over Voltage
400 KV	Deepnagar - Aurangabad	05/Oct/2016	06.55	05/Oct/2016	18.36	Line Maintenance work
400 KV	New Koyana -Koyana Stage IV-I	05/Oct/2016	10.04	05/Oct/2016	19.41	Routine Maintenance Work
400 KV	Kolhapur Solapur (PG) II	05/Oct/2016	15.47	06/Oct/2016	08.31	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	05/Oct/2016	21.57	06/Oct/2016	07.05	Over Voltage
400 KV	Bhusawal-Aurangabad	05/Oct/2016	22.14	06/Oct/2016	06.47	Over Voltage
400 KV	Deepnagar - Aurangabad	06/Oct/2016	04.01	07/Oct/2016	16.39	Distance Protection
400 KV	Jejuri- Koyanastage-IV	06/Oct/2016	08.12	06/Oct/2016	18.14	Disc Isolator Replacement Work
400 KV	Bus Coupler @ Koradi	06/Oct/2016	10.49	06/Oct/2016	18.25	Testing Work
400 KV	Kolhapur Solapur(PG) I	06/Oct/2016	22.00	07/Oct/2016	06.28	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	07/Oct/2016	00.50	07/Oct/2016	06.38	Over Voltage
400 KV	Dhule Khandwa I	07/Oct/2016	23.48	08/Oct/2016	07.43	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	08/Oct/2016	01.21	08/Oct/2016	08.10	Over Voltage
400 KV	Koradi-Bhusawal	08/Oct/2016	09.28	08/Oct/2016	17.11	R.M.W. & Testing.
400 KV	Lonikand 1 - Chakan	08/Oct/2016	11.45	08/Oct/2016	14.44	Attending Hot Spot
400 KV	Ektuni-Bableshtar ckt I	08/Oct/2016	15.14	08/Oct/2016	15.22	For Chaging Bus from Bus-I TO Bus-II.
400 KV	Karad - Jaigad - II	08/Oct/2016	17.20		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	08/Oct/2016	21.30		Continued.	Over Voltage
400 KV	Kolhapur Solapur(PG) I	08/Oct/2016	21.56	09/Oct/2016	07.46	Over Voltage
400 KV	Jejuri- Koyanastage-IV	09/Oct/2016	08.14	09/Oct/2016	18.24	Maintenance Work & LE Scheme Work.
400 KV	Ektuni-Bableshtar ckt I	09/Oct/2016	12.29		Continued.	Attending Hot Spot
400 KV	Kolhapur Solapur(PG) I	09/Oct/2016	23.58		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	GIS Bhandup - Borivali	11/Jan/2016	07.42		Continued.	Tower Erection Work.
220 KV	Bableshtar - Ranjangaon	06/Jun/2016	07.22		Continued.	Hand Tripped for Ranjangaon End.
220 KV	Bableshtar- Alephata	26/Aug/2016	20.54		Continued.	Hand tripped.
220 KV	Mudshingi - Chikodi	01/Sep/2016	00.00		Continued.	No schedule from Karnataka(H/T from Chikodi end)
220 KV	Talandage - Chikodi	01/Sep/2016	00.00		Continued.	No schedule from Karnataka(H/T from Talandage end) (QM work done from 13:05Hrs to 17:23Hrs on 5/10/2016)
220 KV	Kalwa - Borivali	28/Sep/2016	08.02		Continued.	Balance tower erection work
220 KV	Taloja II - OCIL-I	03/Oct/2016	08.42	05/Oct/2016	16.06	Routine Maintenance Work
220 KV	Loteaparshuram- Dasturi Line	03/Oct/2016	09.37	03/Oct/2016	19.10	Bus outage at Lote.
220 KV	New Koyana - Loteaparshuram	03/Oct/2016	10.05	03/Oct/2016	18.44	Bus outage at Lote.
220 KV	Pedhambe - Oni	03/Oct/2016	10.14	03/Oct/2016	10.35	Distance Protection
220 KV	Bus @ Lote	03/Oct/2016	10.30	03/Oct/2016	18.45	Replacement of damage Y PH bus conductor.
220 KV	Kamba - Kolshet	03/Oct/2016	11.38	03/Oct/2016	15.19	Line Maintenance work
220 KV	Eklahare (Gcr) - Ghatghar	03/Oct/2016	13.25	03/Oct/2016	15.05	Distance Protection
220 KV	Pophali - Pedambe II	04/Oct/2016	08.05	04/Oct/2016	18.40	Annual Maintenance Work
220 KV	New Koyana - Niwali	04/Oct/2016	09.32	04/Oct/2016	20.18	Diagnostic Work.
220 KV	Uran - Kharghar I	04/Oct/2016	09.38	04/Oct/2016	18.55	LA Replacement.
220 KV	Theur-Jejuri	04/Oct/2016	14.53	04/Oct/2016	19.19	Relay testing Work.
220 KV	Shivajinagar - Malegaon	04/Oct/2016	22.37	04/Oct/2016	23.54	Distance Protection
220 KV	Deepnagar Khadaka 2	05/Oct/2016	08.33	05/Oct/2016	18.17	Replacement of CT
220 KV	Bhugaon- Wardha	05/Oct/2016	09.20	05/Oct/2016	15.49	Measurement of contact Resistances measurement of Breaker Timings
220 KV	Beed-Patoda Ckt 1	05/Oct/2016	10.06	05/Oct/2016	13.40	Quarterly Maintanance Work
220 KV	Mudshingi-Wathar	05/Oct/2016	10.10	05/Oct/2016	12.15	Routine Maintenance Work
220 KV	Lamboti -Solapur II(Bale) Ckt- II	05/Oct/2016	10.41	05/Oct/2016	13.38	Quarterly Maintenance Work
220 KV	Shivajinagar - Malegaon	05/Oct/2016	11.05	05/Oct/2016	18.17	Bottom Conductor Snapped
220 KV	Oni Kharepatan Line	05/Oct/2016	11.10	05/Oct/2016	17.05	Testing Work
220 KV	Babhaleshtar - Degaoan Rangari	06/Oct/2016	05.45	06/Oct/2016	18.13	Work at BBLSR end
220 KV	Vsni-512 Khadki	06/Oct/2016	08.50	06/Oct/2016	18.08	Line Maintenance work
220 KV	New Koyana - Pedambe	06/Oct/2016	09.17	06/Oct/2016	16.30	Testing Work
220 KV	Adlabs - Pedambe	06/Oct/2016	09.30	06/Oct/2016	18.10	Line Maintenance work
220 KV	Bhaveghar - Kolshet	06/Oct/2016	09.38	06/Oct/2016	20.28	Construction work
220 KV	Waluj - Chitegaon II	06/Oct/2016	10.09	06/Oct/2016	22.09	CT Replacement
220 KV	Parli 3 (Old Gcr)-Osmanabad	06/Oct/2016	10.24	06/Oct/2016	18.08	To attend Flashover
220 KV	Bhaveghar - Kolshet	07/Oct/2016	09.11	07/Oct/2016	19.55	Roma builder substation LLO work
220 KV	Temghar - Kalwa	07/Oct/2016	10.20	07/Oct/2016	18.12	Routine Maintenance Work
220 KV	Hamidwada-Mumewadi	07/Oct/2016	15.22	07/Oct/2016	17.00	Testing Work

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Bhaveghar - Kolshet	08/Oct/2016	08.38	08/Oct/2016	20.30	For Construction Releted Work(LILO for ROMA New S/S) For LILO Work.
220 KV	220kv Halkarni- Tillary	08/Oct/2016	09.05	08/Oct/2016	14.20	R.M.W. & Testing.
220 KV	Warora - Wardha	08/Oct/2016	21.08	08/Oct/2016	21.21	Distance Protection
220 KV	Bhaveghar - Kolshet	09/Oct/2016	09.02	09/Oct/2016	20.18	Routine Maintenance Work
220 KV	Pusad-WardhaPG(Deoli)	09/Oct/2016	09.58	09/Oct/2016	10.18	Tripped @ Wardha PG End Only.
220 KV	Padghe - Jambhul 1	09/Oct/2016	11.43	09/Oct/2016	20.45	Maintenance Work.
132 KV	Butibori-Khapri I	05/Oct/2016	14.26	05/Oct/2016	16.59	Distance Protection
132 KV	Parli 2(Girwali)- Renapur	05/Oct/2016	14.40	05/Oct/2016	17.37	Disc Decapping
132 KV	Boisar li - Viraj	07/Oct/2016	09.05	07/Oct/2016	17.20	jumper Replacement work
132 KV	Yavatmal-Pandharkawada	08/Oct/2016	05.30	08/Oct/2016	05.40	Distance Protection
132 KV	Arvi - Talegaon	08/Oct/2016	14.18	08/Oct/2016	15.00	Distance Protection
132 KV	Ambazari-Arvi	08/Oct/2016	14.18	08/Oct/2016	14.42	Distance Protection
132 KV	Pbn-li - Jintoor	08/Oct/2016	19.07	08/Oct/2016	19.25	Distance Protection
132 KV	Malegaon-Washim	09/Oct/2016	17.30		Continued.	R Ph CT Burst @ Washim End.
132 KV	Kalmeshwar-Saoner 2	09/Oct/2016	17.31	09/Oct/2016	17.57	Distance Protection