

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 02/Oct/2017 to 08/Oct/2017**

**Supply Position During Morning Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 02/10/2017     | 12 Hrs | 4356        | 127         | 396        | 4879        | 8059                   | 352        | 3775        | 324        | -1562        | 15827                 | 0                  | 15827                    | 1024        | 250          | 18663            | 18663                   | 49.99        |
| 03/10/2017     | 12 Hrs | 4888        | 1476        | 387        | 6751        | 6901                   | 63         | 4192        | 310        | -1803        | 16414                 | 808                | 17222                    | 1351        | 248          | 19816            | 20624                   | 49.93        |
| 04/10/2017     | 12 Hrs | 4314        | 1544        | 395        | 6253        | 6824                   | 503        | 4232        | 417        | -1856        | 16373                 | 1062               | 17435                    | 1287        | 250          | 19766            | 20828                   | 49.98        |
| 05/10/2017     | 12 Hrs | 4422        | 1070        | 261        | 5753        | 7048                   | 334        | 4229        | 408        | -1831        | 15941                 | 1478               | 17419                    | 1323        | 250          | 19345            | 20823                   | 49.97        |
| 06/10/2017     | 12 Hrs | 4665        | 1388        | 250        | 6303        | 6595                   | 314        | 4185        | 328        | -1908        | 15817                 | 1627               | 17444                    | 1286        | 251          | 19262            | 20889                   | 50.01        |
| 07/10/2017     | 12 Hrs | 4479        | 1269        | 252        | 6000        | 6305                   | 161        | 4762        | 320        | -1683        | 15865                 | 693                | 16558                    | 1204        | 250          | 19002            | 19695                   | 49.93        |
| 08/10/2017     | 12 Hrs | 4537        | 279         | 135        | 4951        | 7032                   | 46         | 4072        | 367        | -1559        | 14909                 | 0                  | 14909                    | 506         | 195          | 17169            | 17169                   | 49.99        |
| <b>Maximum</b> |        | <b>4888</b> | <b>1544</b> | <b>396</b> | <b>6751</b> | <b>8059</b>            | <b>503</b> | <b>4762</b> | <b>417</b> | <b>-1559</b> | <b>16414</b>          | <b>1627</b>        | <b>17444</b>             | <b>1351</b> | <b>251</b>   | <b>19816</b>     | <b>20889</b>            | <b>50.01</b> |
| <b>Minimum</b> |        | <b>4314</b> | <b>127</b>  | <b>135</b> | <b>4879</b> | <b>6305</b>            | <b>46</b>  | <b>3775</b> | <b>310</b> | <b>-1908</b> | <b>14909</b>          | <b>0</b>           | <b>14909</b>             | <b>506</b>  | <b>195</b>   | <b>17169</b>     | <b>17169</b>            | <b>49.93</b> |
| <b>Average</b> |        | <b>4523</b> | <b>1022</b> | <b>297</b> | <b>5841</b> | <b>6966</b>            | <b>253</b> | <b>4207</b> | <b>353</b> | <b>-1743</b> | <b>15878</b>          | <b>810</b>         | <b>16688</b>             | <b>1140</b> | <b>242</b>   | <b>19003</b>     | <b>19813</b>            | <b>49.97</b> |

**Supply Position During Day Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 02/10/2017     | 16 Hrs | 4449        | 391         | 394        | 5234        | 8057                   | 171        | 3851        | 153        | -1553        | 15913                 | 0                  | 15913                    | 1020        | 250          | 18736            | 18736                   | 49.94        |
| 03/10/2017     | 15 Hrs | 4996        | 1423        | 392        | 6811        | 7067                   | 161        | 3868        | 250        | -1798        | 16359                 | 858                | 17217                    | 1333        | 250          | 19740            | 20598                   | 49.87        |
| 04/10/2017     | 16 Hrs | 4363        | 1509        | 381        | 6253        | 6801                   | 259        | 4259        | 227        | -1849        | 15950                 | 1257               | 17207                    | 1297        | 251          | 19347            | 20604                   | 49.94        |
| 05/10/2017     | 16 Hrs | 4803        | 674         | 240        | 5717        | 6597                   | 470        | 4228        | 225        | -1905        | 15332                 | 2519               | 17851                    | 1251        | 250          | 18738            | 21257                   | 49.95        |
| 06/10/2017     | 13 Hrs | 4726        | 1045        | 258        | 6029        | 6598                   | 292        | 4196        | 354        | -1903        | 15566                 | 1360               | 16926                    | 1269        | 251          | 18989            | 20349                   | 49.99        |
| 07/10/2017     | 13 Hrs | 4628        | 1251        | 262        | 6141        | 6328                   | 227        | 4768        | 342        | -1713        | 16093                 | 788                | 16881                    | 1192        | 248          | 19246            | 20034                   | 49.96        |
| 08/10/2017     | 13 Hrs | 4584        | 157         | 136        | 4877        | 6908                   | 53         | 4143        | 370        | -1623        | 14728                 | 0                  | 14728                    | 510         | 193          | 17054            | 17054                   | 49.98        |
| <b>Maximum</b> |        | <b>4996</b> | <b>1509</b> | <b>394</b> | <b>6811</b> | <b>8057</b>            | <b>470</b> | <b>4768</b> | <b>370</b> | <b>-1553</b> | <b>16359</b>          | <b>2519</b>        | <b>17851</b>             | <b>1333</b> | <b>251</b>   | <b>19740</b>     | <b>21257</b>            | <b>49.99</b> |
| <b>Minimum</b> |        | <b>4363</b> | <b>157</b>  | <b>136</b> | <b>4877</b> | <b>6328</b>            | <b>53</b>  | <b>3851</b> | <b>153</b> | <b>-1905</b> | <b>14728</b>          | <b>0</b>           | <b>14728</b>             | <b>510</b>  | <b>193</b>   | <b>17054</b>     | <b>17054</b>            | <b>49.87</b> |
| <b>Average</b> |        | <b>4650</b> | <b>921</b>  | <b>295</b> | <b>5866</b> | <b>6908</b>            | <b>233</b> | <b>4188</b> | <b>274</b> | <b>-1763</b> | <b>15706</b>          | <b>969</b>         | <b>16675</b>             | <b>1125</b> | <b>242</b>   | <b>18836</b>     | <b>19805</b>            | <b>49.95</b> |

## Supply Position During Evening Peak (MW)

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR     | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |           |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW        | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 02/10/2017     | 20 Hrs | 4800        | 1123        | 403        | 6326        | 6058                   | 473        | 4040        | 0         | -1218        | 15679                 | 0                  | 15679                    | 1301        | 250          | 18448            | 18448                   | 49.94        |
| 03/10/2017     | 20 Hrs | 5171        | 858         | 415        | 6444        | 5834                   | 326        | 3888        | 0         | -1714        | 14778                 | 1189               | 15967                    | 1131        | 249          | 17872            | 19061                   | 49.98        |
| 04/10/2017     | 20 Hrs | 4567        | 1180        | 405        | 6152        | 5917                   | 192        | 4101        | 0         | -1640        | 14722                 | 1340               | 16062                    | 1252        | 250          | 17864            | 19204                   | 49.96        |
| 05/10/2017     | 20 Hrs | 4706        | 875         | 264        | 5845        | 6257                   | 197        | 4240        | 0         | -1629        | 14910                 | 1501               | 16411                    | 1285        | 250          | 18074            | 19575                   | 49.98        |
| 06/10/2017     | 19 Hrs | 4877        | 181         | 276        | 5334        | 6008                   | 105        | 4292        | 24        | -1644        | 14119                 | 1127               | 15246                    | 1219        | 250          | 17232            | 18359                   | 49.96        |
| 07/10/2017     | 19 Hrs | 4939        | 128         | 275        | 5342        | 5946                   | 102        | 4662        | 0         | -1499        | 14553                 | 0                  | 14553                    | 1165        | 250          | 17467            | 17467                   | 49.90        |
| 08/10/2017     | 19 Hrs | 4860        | 150         | 270        | 5280        | 5774                   | 173        | 4154        | 3         | -1442        | 13942                 | 0                  | 13942                    | 667         | 191          | 16242            | 16242                   | 50.01        |
| <b>Maximum</b> |        | <b>5171</b> | <b>1180</b> | <b>415</b> | <b>6444</b> | <b>6257</b>            | <b>473</b> | <b>4662</b> | <b>24</b> | <b>-1218</b> | <b>15679</b>          | <b>1501</b>        | <b>16411</b>             | <b>1301</b> | <b>250</b>   | <b>18448</b>     | <b>19575</b>            | <b>50.01</b> |
| <b>Minimum</b> |        | <b>4567</b> | <b>128</b>  | <b>264</b> | <b>5280</b> | <b>5774</b>            | <b>102</b> | <b>3888</b> | <b>0</b>  | <b>-1714</b> | <b>13942</b>          | <b>0</b>           | <b>13942</b>             | <b>667</b>  | <b>191</b>   | <b>16242</b>     | <b>16242</b>            | <b>49.90</b> |
| <b>Average</b> |        | <b>4846</b> | <b>642</b>  | <b>330</b> | <b>5818</b> | <b>5970</b>            | <b>224</b> | <b>4197</b> | <b>4</b>  | <b>-1541</b> | <b>14672</b>          | <b>737</b>         | <b>15409</b>             | <b>1146</b> | <b>241</b>   | <b>17600</b>     | <b>18337</b>            | <b>49.96</b> |

## Supply Position During Night Off Peak (MW)

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |          |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 02/10/2017     | 3 Hrs  | 4390        | 63          | 408        | 4861        | 5621                   | 364        | 3852        | 0        | -1218        | 13480                 | 0                  | 13480                    | 686         | 190          | 15574            | 15574                   | 50.00        |
| 03/10/2017     | 4 Hrs  | 4445        | 823         | 415        | 5683        | 5273                   | 74         | 3730        | 0        | -901         | 13859                 | 0                  | 13859                    | 836         | 251          | 15847            | 15847                   | 49.98        |
| 04/10/2017     | 1 Hrs  | 4279        | 1309        | 420        | 6008        | 5387                   | 140        | 3867        | 0        | -1374        | 14028                 | 131                | 14159                    | 847         | 251          | 16500            | 16631                   | 49.93        |
| 05/10/2017     | 1 Hrs  | 4348        | 700         | 281        | 5329        | 5721                   | 256        | 4278        | 0        | -1509        | 14075                 | 117                | 14192                    | 892         | 251          | 16727            | 16844                   | 49.96        |
| 06/10/2017     | 24 Hrs | 4664        | 128         | 276        | 5068        | 5477                   | 141        | 4186        | 0        | -1197        | 13675                 | 173                | 13848                    | 1175        | 252          | 16299            | 16472                   | 49.95        |
| 07/10/2017     | 24 Hrs | 4513        | 70          | 277        | 4860        | 5115                   | 157        | 4337        | 0        | -1491        | 12978                 | 0                  | 12978                    | 654         | 192          | 15315            | 15315                   | 49.93        |
| 08/10/2017     | 2 Hrs  | 4167        | 50          | 276        | 4493        | 5831                   | 112        | 3789        | 0        | -1465        | 12760                 | 0                  | 12760                    | 480         | 192          | 14897            | 14897                   | 49.93        |
| <b>Maximum</b> |        | <b>4664</b> | <b>1309</b> | <b>420</b> | <b>6008</b> | <b>5831</b>            | <b>364</b> | <b>4337</b> | <b>0</b> | <b>-901</b>  | <b>14075</b>          | <b>173</b>         | <b>14192</b>             | <b>1175</b> | <b>252</b>   | <b>16727</b>     | <b>16844</b>            | <b>50.00</b> |
| <b>Minimum</b> |        | <b>4167</b> | <b>50</b>   | <b>276</b> | <b>4493</b> | <b>5115</b>            | <b>74</b>  | <b>3730</b> | <b>0</b> | <b>-1509</b> | <b>12760</b>          | <b>0</b>           | <b>12760</b>             | <b>480</b>  | <b>190</b>   | <b>14897</b>     | <b>14897</b>            | <b>49.93</b> |
| <b>Average</b> |        | <b>4401</b> | <b>449</b>  | <b>336</b> | <b>5186</b> | <b>5489</b>            | <b>178</b> | <b>4005</b> | <b>0</b> | <b>-1308</b> | <b>13551</b>          | <b>60</b>          | <b>13611</b>             | <b>796</b>  | <b>226</b>   | <b>15880</b>     | <b>15940</b>            | <b>49.95</b> |

## Details of Supply Position (MUs)

| Date           | MSGENCO        |               |              |                | Pench (MS)   | Central Sector Receipt | Central Sector Share | WIND           | CPP            | SOLAR        | TPCL Gen.     | R-INFRA Gen. | TPCL Exch.     | Energy Requirement |               |                |
|----------------|----------------|---------------|--------------|----------------|--------------|------------------------|----------------------|----------------|----------------|--------------|---------------|--------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS          | Total          |              |                        |                      |                |                |              |               |              |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus          | Mus            | Mus          | Mus                    | Mus                  | Mus            | Mus            | Mus          | Mus           | Mus          | Mus            | Mus                | Mus           | Mus            |
| 02/10/2017     | 107.906        | 8.359         | 9.662        | 125.927        | 0.000        | 158.738                | 154.770              | 6.698          | 92.936         | 2.185        | 22.871        | 5.481        | -31.334        | 355.150            | 59.686        | 414.836        |
| 03/10/2017     | 114.212        | 23.171        | 9.716        | 147.099        | 0.000        | 150.057                | 144.280              | 3.395          | 92.615         | 2.201        | 26.595        | 6.000        | -34.469        | 360.898            | 67.064        | 427.962        |
| 04/10/2017     | 103.661        | 29.465        | 9.704        | 142.830        | 0.010        | 147.170                | 142.605              | 5.668          | 97.385         | 2.984        | 26.525        | 6.008        | -35.487        | 360.550            | 68.020        | 428.570        |
| 05/10/2017     | 108.517        | 17.929        | 6.357        | 132.803        | 0.255        | 144.384                | 143.431              | 6.061          | 101.465        | 2.844        | 26.501        | 6.013        | -36.415        | 351.142            | 68.929        | 420.071        |
| 06/10/2017     | 113.349        | 13.301        | 6.488        | 133.138        | 0.420        | 144.352                | 143.002              | 3.933          | 99.498         | 2.473        | 25.909        | 6.026        | -35.884        | 347.510            | 67.819        | 415.329        |
| 07/10/2017     | 108.885        | 6.267         | 6.624        | 121.776        | 0.676        | 138.411                | 140.710              | 5.804          | 112.374        | 2.286        | 23.552        | 5.799        | -33.229        | 347.422            | 62.579        | 410.001        |
| 08/10/2017     | 109.008        | 2.584         | 5.903        | 117.495        | 0.801        | 143.406                | 142.804              | 2.889          | 97.930         | 2.405        | 13.380        | 4.613        | -34.202        | 329.923            | 52.195        | 382.118        |
| <b>Maximum</b> | <b>114.212</b> | <b>29.465</b> | <b>9.716</b> | <b>147.099</b> | <b>0.801</b> | <b>158.738</b>         | <b>154.770</b>       | <b>114.212</b> | <b>112.374</b> | <b>2.984</b> | <b>26.595</b> | <b>6.026</b> | <b>-31.334</b> | <b>360.898</b>     | <b>68.929</b> | <b>428.570</b> |
| <b>Minimum</b> | <b>103.661</b> | <b>2.584</b>  | <b>5.903</b> | <b>117.495</b> | <b>0.000</b> | <b>138.411</b>         | <b>140.710</b>       | <b>103.661</b> | <b>92.615</b>  | <b>2.185</b> | <b>13.380</b> | <b>4.613</b> | <b>-36.415</b> | <b>329.923</b>     | <b>52.195</b> | <b>382.118</b> |
| <b>Average</b> | <b>109.363</b> | <b>14.439</b> | <b>7.779</b> | <b>131.581</b> | <b>0.309</b> | <b>146.645</b>         | <b>144.515</b>       | <b>109.363</b> | <b>99.172</b>  | <b>2.483</b> | <b>23.619</b> | <b>5.706</b> | <b>-34.431</b> | <b>350.371</b>     | <b>63.756</b> | <b>414.127</b> |

## Details of Koyna Water Consumption (in TMC)

---

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 02/10/2017 | 0.156       | 0.251         | 50.726  |
| 03/10/2017 | 0.492       | 0.743         | 50.234  |
| 04/10/2017 | 0.604       | 1.347         | 49.630  |
| 05/10/2017 | 0.373       | 1.720         | 49.257  |
| 06/10/2017 | 0.267       | 1.987         | 48.990  |
| 07/10/2017 | 0.120       | 2.107         | 48.870  |
| 08/10/2017 | 0.034       | 2.141         | 48.836  |

**State Load Despatch Center, Airoli (MSETCL)**  
**Central Sector Share/Drawal from 02/Oct/2017 to 08/Oct/2017**

| Date         | DAY      | Central Sector Share |         | Total Interstate Bilateral Purchase |         | Total Share     |         | Total Drawal    |         | Overdrawal(+) / UnderDrawal(-) |         |
|--------------|----------|----------------------|---------|-------------------------------------|---------|-----------------|---------|-----------------|---------|--------------------------------|---------|
|              |          | MUs                  | Avg. MW | MUs                                 | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW | MUs                            | Avg. MW |
|              |          | <b>1</b>             |         | <b>2</b>                            |         | <b>1+2=3</b>    |         | <b>4</b>        |         | <b>3-4=5</b>                   |         |
| 02/10/2017   | MONDAY   | 113.596              | 6408    | 41.174                              | 1716    | 154.770         | 6449    | 158.738         | 6614    | 3.968                          | 165     |
| 03/10/2017   | TUESDAY  | 107.106              | 5974    | 37.174                              | 1549    | 144.280         | 6012    | 150.057         | 6252    | 5.777                          | 241     |
| 04/10/2017   | WEDNESDA | 112.724              | 5912    | 29.881                              | 1245    | 142.605         | 5942    | 147.170         | 6132    | 4.565                          | 190     |
| 05/10/2017   | THURSDAY | 115.444              | 5948    | 27.987                              | 1166    | 143.431         | 5976    | 144.384         | 6016    | 0.953                          | 40      |
| 06/10/2017   | FRIDAY   | 112.586              | 5928    | 30.416                              | 1267    | 143.002         | 5958    | 144.352         | 6015    | 1.350                          | 56      |
| 07/10/2017   | SATURDAY | 112.302              | 5835    | 28.408                              | 1184    | 140.710         | 5863    | 138.411         | 5767    | -2.299                         | -96     |
| 08/10/2017   | SUNDAY   | 100.212              | 5908    | 42.592                              | 1775    | 142.804         | 5950    | 143.406         | 5975    | 0.602                          | 25      |
| <b>Total</b> |          | <b>773.971</b>       |         | <b>237.631</b>                      |         | <b>1011.602</b> |         | <b>1026.518</b> |         | <b>14.916</b>                  |         |

| GENERATING UNITS OUTAGES FOR THE WEEK FROM 02/10/2017 TO 08/10/2017 |                        |          |              |              |             |            |                                                                                                                                                                  |
|---------------------------------------------------------------------|------------------------|----------|--------------|--------------|-------------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Generator                                                           | Generating Unit        | Capacity | Tripped Date | Tripped Time | Synch. Date | Synch Time | Reason                                                                                                                                                           |
| PLANNED OUTAGES                                                     |                        |          |              |              |             |            |                                                                                                                                                                  |
| IPP                                                                 | Tata Trombay 6         | 500MW    | 15/Jul/2015  | 17.08        |             | Continued. | Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)                                                                                         |
| CS                                                                  | TARAPUR 4              | 540MW    | 23/Apr/2017  | 19.55        |             | Continued. | Annual Maintenance                                                                                                                                               |
| CS                                                                  | Tarapur 1              | 160MW    | 04/Jun/2017  | 19.09        |             | Continued. | 3 months outage for refuelling.                                                                                                                                  |
| MSPGCL                                                              | Khaparkheda Unit 4     | 210MW    | 13/Jul/2017  | 03.36        | 06/Oct/2017 | 16.52      | Drum level low. on Dated 14.07.2017 converted to zero schedule. Converted into COH from 00:00Hrs of 02.08.2017                                                   |
| MSPGCL                                                              | Nasik Unit 3           | 210MW    | 10/Aug/2017  | 00.00        | 02/Oct/2017 | 17.50      | Withdrawn for maintenance work. Converted to COH from 15.08.2017.                                                                                                |
| MSPGCL                                                              | Koradi Unit 9          | 660MW    | 07/Sep/2017  | 00.38        |             | Continued. | Coal shortage form 12.09.2017 converted to AOH dt.1.10.2017.                                                                                                     |
| FORCED OUTAGES                                                      |                        |          |              |              |             |            |                                                                                                                                                                  |
| RGPL                                                                | Dabhol Dabhol 1B       | 230MW    | 28/May/2013  | 22.02        |             | Continued. | Gas Shortage.                                                                                                                                                    |
| RGPL                                                                | Dabhol Dabhol 1X       | 230MW    | 27/Jun/2013  | 21.46        |             | Continued. | Gas Shortage                                                                                                                                                     |
| RGPL                                                                | Dabhol Dabhol 1A       | 230MW    | 27/Jun/2013  | 21.47        |             | Continued. | Gas Shortage                                                                                                                                                     |
| MSPGCL                                                              | Koradi Unit 6          | 210MW    | 20/Mar/2015  | 01.02        |             | Continued. | EE R&M LE Work                                                                                                                                                   |
| IPP                                                                 | SWPGL U-1              | 135MW    | 16/Feb/2016  | 17.09        |             | Continued. | Change Over , No Schedule                                                                                                                                        |
| IPP                                                                 | SWPGL U-2              | 135MW    | 29/Feb/2016  | 21.46        |             | Continued. | Change over against Unit III                                                                                                                                     |
| MSPGCL                                                              | Parli Unit 4           | 210MW    | 01/Apr/2016  | 00.00        |             | Continued. | Economic shutdown                                                                                                                                                |
| MSPGCL                                                              | Parli Unit 5           | 210MW    | 01/Apr/2016  | 00.00        |             | Continued. | Economic shutdown                                                                                                                                                |
| MSPGCL                                                              | Bhusawal Unit 2        | 210MW    | 14/Jun/2016  | 19.35        |             | Continued. | Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)                                                                               |
| MSPGCL                                                              | Uran Unit 8            | 108MW    | 14/Aug/2016  | 07.56        |             | Continued. | Maintenance work                                                                                                                                                 |
| RGPL                                                                | Dabhol 2A              | 230MW    | 24/Aug/2016  | 13.31        |             | Continued. | Change Over.                                                                                                                                                     |
| MSPGCL                                                              | Koradi Unit 5          | 200MW    | 05/Sep/2016  | 00.21        |             | Continued. | ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work |
| IPP                                                                 | PGPL U1                | 262MW    | 07/Feb/2017  | 17.30        |             | Continued. | No Schedule                                                                                                                                                      |
| IPP                                                                 | PGPL U2                | 126MW    | 07/Feb/2017  | 17.30        |             | Continued. | No Schedule                                                                                                                                                      |
| IPP                                                                 | VIPL U-1               | 300MW    | 13/Jun/2017  | 08.30        | 07/Oct/2017 | 23.59      | GT WORK                                                                                                                                                          |
| MSPGCL                                                              | Ghatghar Unit-2        | 125MW    | 28/Jul/2017  | 00.00        |             | Continued. | due to common pressure shaft with unit 1.                                                                                                                        |
| MSPGCL                                                              | Ghatghar Unit-1        | 125MW    | 28/Jul/2017  | 00.00        | 05/Oct/2017 | 11.25      | RBDV leakage attending work.                                                                                                                                     |
| IPP                                                                 | SWPGL U-3              | 135MW    | 26/Aug/2017  | 17.40        |             | Continued. | Boiler Tube Leakage                                                                                                                                              |
| MSPGCL                                                              | Bhusawal Unit 3        | 210MW    | 27/Aug/2017  | 07.43        |             | Continued. | Coal Shortage From 29.08.2017.                                                                                                                                   |
| IPP                                                                 | Adani U-4              | 660MW    | 06/Sep/2017  | 21.47        | 06/Oct/2017 | 23.02      | Changeover from U-4 to U1                                                                                                                                        |
| MSPGCL                                                              | Khaparkheda Unit 1     | 210MW    | 08/Sep/2017  | 12.23        |             | Continued. | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Chandrapur Unit 6      | 500MW    | 09/Sep/2017  | 04.40        | 02/Oct/2017 | 16.45      | Coal Shortage form 12.09.2017.                                                                                                                                   |
| MSPGCL                                                              | Koradi Unit 7          | 210MW    | 12/Sep/2017  | 00.12        |             | Continued. | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Chandrapur Unit 3      | 210MW    | 12/Sep/2017  | 00.00        |             | Continued. | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Khaparkheda Unit 3     | 210MW    | 12/Sep/2017  | 00.00        |             | Continued. | Coal Shortage                                                                                                                                                    |
| IPP                                                                 | RPL(AMT) U-3           | 270MW    | 17/Sep/2017  | 00.02        |             | Continued. | Coal Shortage                                                                                                                                                    |
| IPP                                                                 | RPL(AMT) U-5           | 270MW    | 17/Sep/2017  | 02.01        |             | Continued. | Coal Shortage                                                                                                                                                    |
| IPP                                                                 | REL Unit 2             | 250MW    | 22/Sep/2017  | 00.11        | 10/Oct/2017 | 02.24      | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Khaparkheda Unit 2     | 210MW    | 25/Sep/2017  | 06.50        |             | Continued. | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Koradi Unit 10         | 660MW    | 25/Sep/2017  | 11.59        | 25/Sep/2017 | 14.58      | Air Heater A Drive Fail.                                                                                                                                         |
| MSPGCL                                                              | Chandrapur Unit 5      | 500MW    | 27/Sep/2017  | 12.22        | 28/Sep/2017 | 01.29      | Generator Protection operated                                                                                                                                    |
| MSPGCL                                                              | Parli Unit 7           | 250MW    | 28/Sep/2017  | 21.12        | 03/Oct/2017 | 11.27      | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Koradi Unit 10         | 660MW    | 29/Sep/2017  | 21.56        | 29/Sep/2017 | 23.34      | Electrical overspeed protection operated.                                                                                                                        |
| MSPGCL                                                              | Koradi Unit-8          | 660MW    | 29/Sep/2017  | 22.32        | 30/Sep/2017 | 20.40      | Turbine tripped.                                                                                                                                                 |
| MSPGCL                                                              | Chandrapur Unit 4      | 210MW    | 30/Sep/2017  | 18.33        | 01/Oct/2017 | 00.49      | malfunction of dcs board.                                                                                                                                        |
| MSPGCL                                                              | Koradi Unit 10         | 660MW    | 30/Sep/2017  | 13.32        | 30/Sep/2017 | 15.12      | water superheater drain tank level malfunction.                                                                                                                  |
| MSPGCL                                                              | Chandrapur Unit 4      | 210MW    | 30/Sep/2017  | 03.56        | 30/Sep/2017 | 05.52      | Vaccum protection operated.                                                                                                                                      |
| MSPGCL                                                              | Chandrapur Unit 4      | 210MW    | 01/Oct/2017  | 09.51        | 02/Oct/2017 | 01.30      | DCS malfunction.                                                                                                                                                 |
| IPP                                                                 | JSW (J) U3             | 300MW    | 02/Oct/2017  | 22.58        | 03/Oct/2017 | 11:03      | PA Fan problem                                                                                                                                                   |
| IPP                                                                 | RPL(AMT) U-2           | 270MW    | 02/Oct/2017  | 00.00        | 06/Oct/2017 | 06.09      | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Parli Unit 8           | 250MW    | 03/Oct/2017  | 17.00        |             | Continued. | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Nasik Unit 4           | 210MW    | 03/Oct/2017  | 00.08        |             | Continued. | Coal Shortage                                                                                                                                                    |
| MSPGCL                                                              | Koradi Unit 10         | 660MW    | 03/Oct/2017  | 21.48        | 04/Oct/2017 | 18.20      | Turbine oil Leakage                                                                                                                                              |
| MSPGCL                                                              | Parli Unit 7           | 250MW    | 03/Oct/2017  | 18.48        | 03/Oct/2017 | 22.03      | Coal mill broblem                                                                                                                                                |
| MSPGCL                                                              | Chandrapur Unit-8      | 500MW    | 03/Oct/2017  | 08.45        | 05/Oct/2017 | 07.11      | Boiler Tube Leakage                                                                                                                                              |
| MSPGCL                                                              | Koyna STG- IV Unit - 1 | 250MW    | 03/Oct/2017  | 09.00        | 07/Oct/2017 | 19.56      | rotor earth fault optd.                                                                                                                                          |
| IPP                                                                 | JSW (J) U3             | 300MW    | 04/Oct/2017  | 17.54        | 04/Oct/2017 | 19.12      | Turbine Control Oil Leakage                                                                                                                                      |
| MSPGCL                                                              | Uran Unit B0           | 120MW    | 05/Oct/2017  | 00.11        |             | Continued. | Gas Turbine Work                                                                                                                                                 |
| IPP                                                                 | Adani U-3              | 660MW    | 05/Oct/2017  | 04.07        |             | Continued. | Control Valve Problem                                                                                                                                            |
| MSPGCL                                                              | Parli Unit 7           | 250MW    | 05/Oct/2017  | 12.20        | 05/Oct/2017 | 14.16      | Boiler Tripped                                                                                                                                                   |
| MSPGCL                                                              | Uran Unit 7            | 108MW    | 05/Oct/2017  | 00.06        |             | Continued. | Gas Turbine Work                                                                                                                                                 |
| MSPGCL                                                              | Khaparkheda Unit 5     | 500MW    | 05/Oct/2017  | 09.43        | 05/Oct/2017 | 12.39      | Tripped on DCS N/W failed                                                                                                                                        |
| MSPGCL                                                              | Chandrapur Unit 9      | 500MW    | 05/Oct/2017  | 21.32        | 08/Oct/2017 | 03.17      | Boiler Tube Leakage                                                                                                                                              |
| IPP                                                                 | RPL(AMT) U-1           | 270MW    | 06/Oct/2017  | 00.45        |             | Continued. | Problem in submerged Scrapper chain                                                                                                                              |
| MSPGCL                                                              | Khaparkheda Unit 4     | 210MW    | 07/Oct/2017  | 06.18        | 08/Oct/2017 | 16.13      | Turbine Vibration                                                                                                                                                |
| MSPGCL                                                              | Chandrapur Unit 6      | 500MW    | 07/Oct/2017  | 00.35        |             | Continued. | Boiler Tube Leakage                                                                                                                                              |
| MSPGCL                                                              | Uran Unit 6            | 108MW    | 08/Oct/2017  | 09.44        | 08/Oct/2017 | 12.57      | Filter replacement work.                                                                                                                                         |
| MSPGCL                                                              | Chandrapur Unit 4      | 210MW    | 08/Oct/2017  | 22.57        |             | Continued. | Coal Shortage                                                                                                                                                    |

**LINE OUTAGES AND RIPPING FOR THE WEEK FROM 02/10/2017 TO 08/10/2017**

| Voltage | Name of Line                     | Tripping Date | Tripping Time | Synch Date  | Synch Time | Reason                                                                                                               |
|---------|----------------------------------|---------------|---------------|-------------|------------|----------------------------------------------------------------------------------------------------------------------|
| 400 KV  | Karad Solapur (PG)               | 03/May/2017   | 11:49         |             | Continued. | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                             |
| 400 KV  | Ektuni-Bableshtar ckt I          | 15/Sep/2017   | 19.16         | 06/Oct/2017 | 14.44      | Attending Hot Spot                                                                                                   |
| 400 KV  | karad -kolhapur-II               | 28/Sep/2017   | 21.37         | 03/Oct/2017 | 09.31      | Over Voltage                                                                                                         |
| 400 KV  | Bhusawal-Aurangabad              | 29/Sep/2017   | 18.07         | 03/Oct/2017 | 11.48      | Over Voltage                                                                                                         |
| 400 KV  | Babhaleshwar - Padghe-I          | 30/Sep/2017   | 18.01         | 04/Oct/2017 | 12.46      | Distance Protection                                                                                                  |
| 400 KV  | Dhule Sar'Sarovar I              | 01/Oct/2017   | 18.08         | 02/Oct/2017 | 06.40      | Over Voltage                                                                                                         |
| 400 KV  | Dhule Sar'Sarovar I              | 02/Oct/2017   | 13.19         | 03/Oct/2017 | 06.50      | Distance Protection                                                                                                  |
| 400 KV  | Jaigad-New Koyana Ckt-I          | 02/Oct/2017   | 19.20         | 02/Oct/2017 | 19.42      | Distance Protection                                                                                                  |
| 400 KV  | Aikud-Solapur(PG)                | 02/Oct/2017   | 21.38         | 02/Oct/2017 | 22.57      | Distance Protection                                                                                                  |
| 400 KV  | N Koyana-Karad -Ckt II           | 03/Oct/2017   | 11.02         | 03/Oct/2017 | 19.24      | Annual Maintenance Work                                                                                              |
| 400 KV  | Ektuni - Tapitanda Ckt I         | 03/Oct/2017   | 12.00         | 03/Oct/2017 | 16.24      | Routine Maintenance Work                                                                                             |
| 400 KV  | Dhule Sar'Sarovar II             | 03/Oct/2017   | 17.36         | 04/Oct/2017 | 12.10      | Over Voltage                                                                                                         |
| 400 KV  | karad -kolhapur-I                | 03/Oct/2017   | 23.26         | 05/Oct/2017 | 10.58      | Over Voltage                                                                                                         |
| 400 KV  | Koradi-Bhusawal                  | 04/Oct/2017   | 08.10         | 04/Oct/2017 | 14.36      | To attend Hot Spot(Shifted on TBC)                                                                                   |
| 400 KV  | Koradi-India Bulls               | 04/Oct/2017   | 09.22         | 04/Oct/2017 | 19.10      | Testing Work                                                                                                         |
| 400 KV  | Lamboti - Solapur (PG)           | 04/Oct/2017   | 10.05         | 04/Oct/2017 | 15.05      | Line Maintenance work                                                                                                |
| 400 KV  | Dhule Sar'Sarovar I              | 04/Oct/2017   | 12.26         | 05/Oct/2017 | 09.28      | Distance Protection                                                                                                  |
| 400 KV  | Dabhol New koyana I              | 04/Oct/2017   | 12.48         | 04/Oct/2017 | 13.50      | Distance Protection                                                                                                  |
| 400 KV  | Padgha Tarapur I                 | 04/Oct/2017   | 13.28         | 06/Oct/2017 | 18.55      | outage By WRLDC                                                                                                      |
| 400 KV  | Nagothane - Dabhol-II            | 04/Oct/2017   | 14.55         | 05/Oct/2017 | 00.16      | Distance Protection                                                                                                  |
| 400 KV  | Bhusawal-Aurangabad              | 04/Oct/2017   | 21.23         | 05/Oct/2017 | 10.52      | Over Voltage                                                                                                         |
| 400 KV  | Babhaleshwar - Bhusawal II       | 05/Oct/2017   | 17.06         | 05/Oct/2017 | 20.26      | Line Signature Analysis Test                                                                                         |
| 400 KV  | Dhule Sar'Sarovar II             | 05/Oct/2017   | 18.26         | 07/Oct/2017 | 15.30      | Over Voltage                                                                                                         |
| 400 KV  | Bhusawal-Aurangabad              | 05/Oct/2017   | 20.13         | 06/Oct/2017 | 14.40      | Over Voltage                                                                                                         |
| 400 KV  | karad -kolhapur-II               | 05/Oct/2017   | 23.23         |             | Continued. | Over Voltage                                                                                                         |
| 400 KV  | Ektuni-Bableshtar ckt II         | 06/Oct/2017   | 15.03         |             | Continued. | To attend Hot Spot                                                                                                   |
| 400 KV  | Bhusawal-Aurangabad              | 06/Oct/2017   | 21.04         | 09/Oct/2017 | 09.27      | Over Voltage                                                                                                         |
| 400 KV  | Bus Coupler @ Kharghar           | 07/Oct/2017   | 06.13         | 07/Oct/2017 | 09.34      | damage jumper replacement work.                                                                                      |
| 400 KV  | Parli(MS)-Parli (PG) II          | 07/Oct/2017   | 09.33         | 07/Oct/2017 | 18.46      | Testing Work                                                                                                         |
| 400 KV  | Padghe - Nagothane - I           | 07/Oct/2017   | 18.06         | 07/Oct/2017 | 21.17      | heavy sparking on isolator at padgha end cb burst at nagothane end.                                                  |
| 400 KV  | Padghe - Nagothane - II          | 07/Oct/2017   | 18.08         | 07/Oct/2017 | 19.07      | heavy sparking on isolator at nagothane end.                                                                         |
| 400 KV  | Dhule Sar'Sarovar I              | 07/Oct/2017   | 19.22         | 10/Oct/2017 | 06.10      | Over Voltage                                                                                                         |
| 400 KV  | Koradi 2-IEPL                    | 08/Oct/2017   | 08.51         | 08/Oct/2017 | 15.19      | line signature test.                                                                                                 |
| 400 KV  | Bus Coupler @ Padgha             | 08/Oct/2017   | 09.25         | 08/Oct/2017 | 15.16      | isolator hot spot.                                                                                                   |
| 400 KV  | Chandrapur-II - Nanded ckt II    | 09/Oct/2017   | 11.32         |             | Continued. | Routine Maintenance Work                                                                                             |
| 400 KV  | Bhusawal-Aurangabad              | 09/Oct/2017   | 21.25         |             | Continued. | Over Voltage                                                                                                         |
| 400 KV  | Karad-Jaigad - I                 | 10/Oct/2017   | 22.09         |             | Continued. | Over Voltage                                                                                                         |
| 220 KV  | Chandrapur GCR - Warora - I      | 05/Apr/2015   | 09.13         |             | Continued. | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| 220 KV  | Chandrapur GCR - Wani            | 05/Apr/2015   | 09.15         |             | Continued. | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| 220 KV  | Talandage - Chikodi              | 01/Jun/2017   | 00.01         |             | Continued. | NO SCHEDULE.                                                                                                         |
| 220 KV  | Mudshingi - Chikodi              | 01/Jun/2017   | 00.06         |             | Continued. | NO SCHEDULE.                                                                                                         |
| 220 KV  | Pusad - Hingoli                  | 11/Sep/2017   | 20.06         |             | Continued. | Distance Relay Faulty at pusad end                                                                                   |
| 220 KV  | Pedambe-Nerle                    | 23/Sep/2017   | 00.50         |             | Continued. | B Phase CT Burst at Pedambe End                                                                                      |
| 220 KV  | Adlabs - Pedambe                 | 02/Oct/2017   | 06.55         | 02/Oct/2017 | 14.45      | bus section 2 outage.                                                                                                |
| 220 KV  | Pophali - Pedambe II             | 02/Oct/2017   | 07.10         | 02/Oct/2017 | 13.40      | bus section 2 outage.                                                                                                |
| 220 KV  | Pedhambe - Oni                   | 02/Oct/2017   | 07.12         | 02/Oct/2017 | 13.41      | bus section 2 outage.                                                                                                |
| 220 KV  | Talandage(400kv)- Ichalkaranji 1 | 02/Oct/2017   | 10.08         | 02/Oct/2017 | 15.54      | Quarterly Maintenance Work                                                                                           |
| 220 KV  | Miraj - Ichalkaranji II          | 02/Oct/2017   | 11.43         | 02/Oct/2017 | 16.00      | for controlling talangade ckt load.                                                                                  |
| 220 KV  | Padghe - Nalasopara              | 02/Oct/2017   | 11.46         | 02/Oct/2017 | 12.00      | due to sparking on isolator.                                                                                         |
| 220 KV  | Niwali - Pawas Line              | 02/Oct/2017   | 11.47         | 02/Oct/2017 | 12.00      | Distance Protection                                                                                                  |
| 220 KV  | Chandrapur GCR - Sicom II        | 02/Oct/2017   | 14.47         | 02/Oct/2017 | 16.50      | mainc.b.trials                                                                                                       |
| 220 KV  | Pedhambe - Oni                   | 02/Oct/2017   | 17.56         | 02/Oct/2017 | 18.20      | Distance Protection                                                                                                  |
| 220 KV  | Maisal-Jath I                    | 02/Oct/2017   | 21.40         | 04/Oct/2017 | 03.10      | Distance Protection                                                                                                  |
| 220 KV  | Mahalakshmi Amona                | 03/Oct/2017   | 02.15         | 03/Oct/2017 | 08.35      | Over Voltage                                                                                                         |
| 220 KV  | Tillari Amona                    | 03/Oct/2017   | 02.15         | 03/Oct/2017 | 08.01      | Over Voltage                                                                                                         |
| 220 KV  | Mahad - Pedambe                  | 03/Oct/2017   | 09.07         | 03/Oct/2017 | 10.25      | Attending Hot Spot                                                                                                   |
| 220 KV  | Ranjangaon-Lonikand              | 03/Oct/2017   | 10.27         | 03/Oct/2017 | 19.40      | line changes work.                                                                                                   |
| 220 KV  | Gadchandur - Virur-II            | 03/Oct/2017   | 11.01         | 03/Oct/2017 | 15.38      | replacement of flash over disc insulator.                                                                            |
| 220 KV  | Karad(400kv)- Wathar             | 03/Oct/2017   | 11.31         | 03/Oct/2017 | 14.59      | Testing Work                                                                                                         |
| 220 KV  | Mahalakshmi Amona                | 04/Oct/2017   | 00.23         | 04/Oct/2017 | 08.31      | Tripped from Amona end only                                                                                          |
| 220 KV  | Versova Aarey Line 1             | 04/Oct/2017   | 07.20         | 04/Oct/2017 | 21.06      | LA Replacement                                                                                                       |
| 220 KV  | Koradi II - Kawlewada            | 04/Oct/2017   | 09.06         | 04/Oct/2017 | 16.24      | Replacement of Wavetrap Jumper                                                                                       |
| 220 KV  | Mudshingi-Wathar                 | 04/Oct/2017   | 10.05         | 04/Oct/2017 | 14.20      | Isolator Maint.work                                                                                                  |
| 220 KV  | Deoli(Pgci)-Badnera              | 04/Oct/2017   | 10.07         | 04/Oct/2017 | 17.58      | Line Maintenance work                                                                                                |
| 220 KV  | Beed-Patoda Ckt 1                | 04/Oct/2017   | 10.33         | 04/Oct/2017 | 13.40      | Quarterly Maintenance Work                                                                                           |
| 220 KV  | Vilebagad-Kandalgaon( Inox tap)  | 04/Oct/2017   | 10.37         | 04/Oct/2017 | 11.10      | Distance Protection                                                                                                  |
| 220 KV  | Dhamangaon New- Tss-II           | 04/Oct/2017   | 10.38         | 04/Oct/2017 | 16.26      | Tan Delta Measurement of CTs                                                                                         |
| 220 KV  | Solapur(PG)- Jeur                | 04/Oct/2017   | 10.45         | 04/Oct/2017 | 18.18      | Quarterly Maintenance Work                                                                                           |
| 220 KV  | Parli 3 (Old Gcr)-Girwali Ckt 2  | 04/Oct/2017   | 11.04         | 04/Oct/2017 | 15.25      | Tan Delta Measurement of CB Timing and CRM                                                                           |
| 220 KV  | Wardha Deoli (Pg)                | 04/Oct/2017   | 11.28         | 04/Oct/2017 | 12.36      | Hand Tripped by WRLDC due to high Overdrawal                                                                         |
| 220 KV  | Virur - Gadchiroli               | 04/Oct/2017   | 11.52         | 04/Oct/2017 | 13.15      | Tree Cutting                                                                                                         |
| 220 KV  | Pophali - Nerale                 | 04/Oct/2017   | 12.40         | 04/Oct/2017 | 17.45      | Routine Maintenance Work                                                                                             |
| 220 KV  | Pedhambe - Oni                   | 04/Oct/2017   | 13.30         | 04/Oct/2017 | 20.35      | Distance Protection                                                                                                  |
| 220 KV  | Parli 3 (Old Gcr)-Girwali Ckt-3  | 04/Oct/2017   | 15.33         | 04/Oct/2017 | 19.45      | Tan Delta Measurement and Breaker Timing                                                                             |
| 220 KV  | Mahalakshmi Amona                | 04/Oct/2017   | 17.32         | 04/Oct/2017 | 18.08      | Tripped from Amona end only                                                                                          |
| 220 KV  | Bableshtar- Alephata ckt I       | 05/Oct/2017   | 04.46         | 06/Oct/2017 | 05.01      | LILO arrangement work for UTECH Sugar Factory                                                                        |
| 220 KV  | Bableshtar- Ranjangaon           | 05/Oct/2017   | 05.27         | 06/Oct/2017 | 15.24      | LILO arrangement work for UTECH Sugar Factory                                                                        |
| 220 KV  | Trombay - Mulund                 | 05/Oct/2017   | 06.05         | 05/Oct/2017 | 12.19      | Line Maintenance work                                                                                                |
| 220 KV  | Lonikand-VSNL                    | 05/Oct/2017   | 09.31         | 05/Oct/2017 | 11.48      | Testing Work                                                                                                         |
| 220 KV  | Walchandnagar-Bhigwan            | 05/Oct/2017   | 10.05         | 05/Oct/2017 | 15.14      | Testing Work                                                                                                         |
| 220 KV  | Sahara-Urse                      | 05/Oct/2017   | 10.18         | 05/Oct/2017 | 13.23      | Testing Work                                                                                                         |
| 220 KV  | Kandalgaon - ONGC Panvel         | 05/Oct/2017   | 10.25         | 05/Oct/2017 | 18.17      | To attend Hot Spot                                                                                                   |
| 220 KV  | Eklahare (Gcr) - Ghatghar        | 05/Oct/2017   | 10.32         | 05/Oct/2017 | 18.15      | Insulator Cleaning work                                                                                              |
| 220 KV  | Dhamangaon New- Tss -I           | 05/Oct/2017   | 10.47         | 05/Oct/2017 | 16.00      | Measurement of CB Timing and CRM                                                                                     |
| 220 KV  | Dhule-Chalisagaon                | 05/Oct/2017   | 10.50         | 05/Oct/2017 | 16.12      | Jumper Tightening work                                                                                               |
| 220 KV  | Hingoli- Girawali                | 05/Oct/2017   | 10.56         | 05/Oct/2017 | 18.07      | Routine Maintenance Work                                                                                             |
| 220 KV  | Dhule - Malegaon                 | 05/Oct/2017   | 11.26         | 05/Oct/2017 | 15.18      | Line Maintenance work                                                                                                |
| 220 KV  | Mumewadi - Halakarni I           | 05/Oct/2017   | 13.20         | 05/Oct/2017 | 13.30      | Distance Protection                                                                                                  |
| 220 KV  | Chakan-Chinchwad                 | 05/Oct/2017   | 13.26         | 05/Oct/2017 | 20.36      | Routine Maintenance Work                                                                                             |
| 220 KV  | Badnera - Deoli (PG)             | 05/Oct/2017   | 14.06         | 05/Oct/2017 | 14.59      | To control Overdrawal                                                                                                |
| 220 KV  | Waluj-Padegaon I                 | 05/Oct/2017   | 18.33         | 05/Oct/2017 | 19.56      | To attend Hot Spot                                                                                                   |
| 220 KV  | Hingoli- Girawali                | 06/Oct/2017   | 09.12         | 06/Oct/2017 | 18.23      | Fixing of Vibration Dampers                                                                                          |
| 220 KV  | 220KV Sawangi- Bhokardan         | 06/Oct/2017   | 10.18         | 06/Oct/2017 | 13.12      | Carrying out Signature Test                                                                                          |
| 220 KV  | Alephata-Pargaon(Kathapur)       | 06/Oct/2017   | 10.25         | 06/Oct/2017 | 15.25      | Bunching work                                                                                                        |
| 220 KV  | Ghatghar - Bapgaon               | 06/Oct/2017   | 12.38         | 06/Oct/2017 | 15.58      | Distance Protection                                                                                                  |
| 220 KV  | sawangi-Phulambri                | 06/Oct/2017   | 13.42         | 06/Oct/2017 | 16.12      | Carrying out Signature Test                                                                                          |
| 220 KV  | Washala - Ghatghar               | 06/Oct/2017   | 14.00         | 06/Oct/2017 | 21.36      | Testing Work                                                                                                         |
| 220 KV  | Versova Aarey Line 1             | 06/Oct/2017   | 14.43         | 06/Oct/2017 | 16.51      | R phase LA Replacement                                                                                               |
| 220 KV  | Nagothane - Ipcl                 | 06/Oct/2017   | 15.24         | 07/Oct/2017 | 20.00      | Distance Protection                                                                                                  |
| 220 KV  | IPCL - SPCL                      | 06/Oct/2017   | 15.24         | 06/Oct/2017 | 22.30      | Distance Protection                                                                                                  |

| Voltage | Name of Line                       | Tripping Date | Tripping Time | Synch Date  | Synch Time | Reason                                         |
|---------|------------------------------------|---------------|---------------|-------------|------------|------------------------------------------------|
| 220 KV  | Uran - Apta II                     | 06/Oct/2017   | 15.45         | 06/Oct/2017 | 16.12      | Backup Protection                              |
| 220 KV  | Uran - Apta III                    | 06/Oct/2017   | 15.48         | 06/Oct/2017 | 15.57      | Distance Protection                            |
| 220 KV  | Uran - Kharghar 2                  | 06/Oct/2017   | 15.55         | 06/Oct/2017 | 16.00      | Distance Protection                            |
| 220 KV  | Uran - Apta IV                     | 06/Oct/2017   | 16.03         | 06/Oct/2017 | 16.09      | Distance Protection                            |
| 220 KV  | Trombay Dharavi 9                  | 06/Oct/2017   | 16.27         | 06/Oct/2017 | 16.44      | Distance Protection                            |
| 220 KV  | Pophali - Nerale                   | 07/Oct/2017   | 05.25         | 07/Oct/2017 | 10.55      | from pophale end.                              |
| 220 KV  | Bableshtar - Bhenda                | 07/Oct/2017   | 10.17         | 07/Oct/2017 | 19.45      | Routine Maintenance Work                       |
| 220 KV  | Balapur-Akola I                    | 07/Oct/2017   | 10.42         | 07/Oct/2017 | 16.07      | Tan Delta Measurement of CTs                   |
| 220 KV  | Pedhambhe - Oni                    | 07/Oct/2017   | 12.13         | 07/Oct/2017 | 18.45      | Distance Protection                            |
| 220 KV  | Eklahara(Gcr)(Nasik)- Bableshtar-I | 07/Oct/2017   | 13.21         | 07/Oct/2017 | 14.00      | Distance Protection                            |
| 220 KV  | Bableshtar- Alephata ckt I         | 07/Oct/2017   | 14.28         | 07/Oct/2017 | 15.29      | due to lbb oper.load affected 139 mw.          |
| 220 KV  | Uran - Kharghar 2                  | 07/Oct/2017   | 18.38         | 07/Oct/2017 | 18.43      | only from uran end.                            |
| 220 KV  | Abhijeet-Wardha-II                 | 07/Oct/2017   | 18.55         | 07/Oct/2017 | 19.45      | Distance Protection                            |
| 220 KV  | Mahalakshmi Amona                  | 08/Oct/2017   | 00.50         | 08/Oct/2017 | 07.27      | Over Voltage                                   |
| 220 KV  | Trombay - Mulund                   | 08/Oct/2017   | 05.53         | 08/Oct/2017 | 12.18      | Jumper replacement work.                       |
| 220 KV  | Ghatghar - Bapgaon                 | 08/Oct/2017   | 16.35         | 08/Oct/2017 | 17.25      | Distance Protection                            |
| 220 KV  | Bhira Dharavi 8                    | 08/Oct/2017   | 19.55         | 08/Oct/2017 | 20.26      | Distance Protection                            |
| 220 KV  | Nanded-Ghatodi                     | 09/Oct/2017   | 17.25         |             | Continued. | Distance Protection                            |
| 220 KV  | Parli 3 (Old Gcr)-Osmanabad        | 10/Oct/2017   | 02.50         | 10/Oct/2017 | Continued. | Bus Bar Protection Operated                    |
| 220 KV  | Chalisgaon -Babhaleshtar           | 10/Oct/2017   | 13.21         |             | Continued. | Distance Protection                            |
| 132 KV  | Malegaon-Washim                    | 01/Oct/2017   | 00.00         | 02/Oct/2017 | 13.53      | Distance Protection                            |
| 132 KV  | Malegaon-Washim                    | 02/Oct/2017   | 00.46         | 02/Oct/2017 | 13.53      | y ph conductor snapped to attend breakdown.    |
| 132 KV  | Washim - Mangrulpir                | 02/Oct/2017   | 08.00         | 02/Oct/2017 | 14.00      | for outage on 220kv malegaon -132 kv washim.   |
| 132 KV  | Bableshtar - Sangamner             | 02/Oct/2017   | 11.45         | 02/Oct/2017 | 16.15      | la burst.                                      |
| 132 KV  | Parli 2(Girwali) - Latur Midc      | 03/Oct/2017   | 06.58         | 03/Oct/2017 | 07.17      | Distance Protection                            |
| 132 KV  | Suprim - Pahur                     | 03/Oct/2017   | 09.00         | 03/Oct/2017 | 09.47      | Distance Protection                            |
| 132 KV  | Gangakhed - Kandhar                | 03/Oct/2017   | 12.42         | 03/Oct/2017 | 13.01      | Distance Protection                            |
| 132 KV  | Waghala (Nanded2) - Tamsa          | 03/Oct/2017   | 14.45         | 03/Oct/2017 | 15.06      | no indication .load affected approx 39 mw.     |
| 132 KV  | Waghala (Nanded2) - Tamsa          | 03/Oct/2017   | 15.20         | 03/Oct/2017 | 15.55      | trip ckt faulty.                               |
| 132 KV  | Kaulewada-Gondia-II                | 04/Oct/2017   | 06.39         | 04/Oct/2017 | 06.57      | Distance Protection                            |
| 132 KV  | Waghala -Nanded-I(Jangamwadi)      | 04/Oct/2017   | 09.33         | 04/Oct/2017 | 09.59      | Distance Protection                            |
| 132 KV  | Mansar Pench                       | 04/Oct/2017   | 09.59         | 10/Oct/2017 | 18.02      | Line Extension Work.                           |
| 132 KV  | Kanhan Pench                       | 04/Oct/2017   | 10.10         | 10/Oct/2017 | 17.53      | C B Replacement Work.                          |
| 132 KV  | Mansar Pench                       | 04/Oct/2017   | 10.10         | 10/Oct/2017 | 17.53      | Outage at pench end                            |
| 132 KV  | Dhule(220kv)-Dondaicha(132 Kv)     | 05/Oct/2017   | 12.58         | 05/Oct/2017 | 13.28      | Distance Protection                            |
| 132 KV  | Kaulewada-Madgi-II                 | 05/Oct/2017   | 15.18         | 06/Oct/2017 | 14.40      | Distance Protection                            |
| 132 KV  | Kaulewada-Madgi-I                  | 05/Oct/2017   | 15.19         | 05/Oct/2017 | 16.22      | Distance Protection                            |
| 132 KV  | Parbhani-Purna                     | 05/Oct/2017   | 17.30         | 07/Oct/2017 | 13.35      | Problem in CB at purna end.                    |
| 132 KV  | Parbhani-Bageshwari                | 06/Oct/2017   | 04.27         | 06/Oct/2017 | 04.38      | Distance Protection                            |
| 132 KV  | Raimoha - Pathardi                 | 06/Oct/2017   | 20.24         | 07/Oct/2017 | 05.05      | Distance Protection                            |
| 132 KV  | Shahada-Taloda                     | 07/Oct/2017   | 01.00         | 07/Oct/2017 | 01.12      | Distance Protection                            |
| 132 KV  | Parbhani - Parbhani I              | 07/Oct/2017   | 16.58         | 07/Oct/2017 | 17.28      | Backup Protection                              |
| 132 KV  | Kalmeshwar-Saoner 1                | 07/Oct/2017   | 18.44         | 08/Oct/2017 | 21.06      | CT Ckt Faulty Indication on Bus-II             |
| 132 KV  | Parbhani - Parbhani I              | 07/Oct/2017   | 18.48         | 07/Oct/2017 | 19.10      | B-PH burst.                                    |
| 132 KV  | Parbhani-Bageshwari                | 07/Oct/2017   | 18.48         | 07/Oct/2017 | 20.11      | Due to tripping of ICT 1&2 AT 220kv parbhani.  |
| 132 KV  | Waghala (Nanded2) - Umri 1         | 07/Oct/2017   | 18.48         | 07/Oct/2017 | 19.10      | LST operated at 220kv parbhani.                |
| 132 KV  | Parbhani-Purna                     | 07/Oct/2017   | 18.48         | 07/Oct/2017 | 20.08      | Due to tripping of ICT 1&2 at 220 kv parbhani. |
| 132 KV  | Parbhani-Bageshwari                | 07/Oct/2017   | 20.23         | 07/Oct/2017 | 20.52      | Carrier fail indication at 132kv bageshwari.   |
| 132 KV  | Gadchiroli - Mul                   | 07/Oct/2017   | 23.14         | 08/Oct/2017 | 00.18      | Distance Protection                            |
| 132 KV  | Dhule- Nardane                     | 08/Oct/2017   | 01.30         | 08/Oct/2017 | 06.30      | Distance Protection                            |
| 132 KV  | Girwali-Renapur-Ahamadpur          | 08/Oct/2017   | 17.36         | 09/Oct/2017 | 09.13      | Distance Protection                            |
| 132 KV  | Ujani - Ausa                       | 08/Oct/2017   | 19.27         | 08/Oct/2017 | 19.52      | Distance Protection                            |
| 132 KV  | Gangakhed- Sonpeth Ckt-II          | 09/Oct/2017   | 21.30         |             | Continued. | Distance Protection                            |