

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 04/Oct/2021 to 10/Oct/2021**

**Supply Position During Morning Peak (MW)**

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
04-10-2021	12 Hrs	3733	1582	234	5549	7656	34	4104	1018	-1475	16886	0	16886	1214	502	20077	20077	50.01
05-10-2021	11 Hrs	4354	1344	155	5853	7452	120	3787	1022	-1488	16746	0	16746	1119	503	19856	19856	49.99
06-10-2021	10 Hrs	4596	1915	238	6749	6928	165	4041	773	-1344	17312	0	17312	1038	502	20196	20196	50.02
07-10-2021	11 Hrs	4623	928	90	5641	7187	410	4171	910	-1543	16776	0	16776	1103	490	19912	19912	49.97
08-10-2021	9 Hrs	5231	1284	139	6654	6607	37	4479	598	-1072	17303	0	17303	1012	488	19875	19875	50.00
09-10-2021	11 Hrs	5283	1261	228	6772	6574	64	3884	816	-1321	16789	0	16789	1035	478	19623	19623	50.02
10-10-2021	9 Hrs	4722	1332	242	6296	5968	201	3993	514	-966	16006	0	16006	674	485	18131	18131	50.06
<b>Maximum</b>		<b>5283</b>	<b>1915</b>	<b>242</b>	<b>6772</b>	<b>7656</b>	<b>410</b>	<b>4479</b>	<b>1022</b>	<b>-966</b>	<b>17312</b>	<b>0</b>	<b>17312</b>	<b>1214</b>	<b>503</b>	<b>20196</b>	<b>20196</b>	<b>50.06</b>
<b>Minimum</b>		<b>3733</b>	<b>928</b>	<b>90</b>	<b>5549</b>	<b>5968</b>	<b>34</b>	<b>3787</b>	<b>514</b>	<b>-1543</b>	<b>16006</b>	<b>0</b>	<b>16006</b>	<b>674</b>	<b>478</b>	<b>18131</b>	<b>18131</b>	<b>49.97</b>
<b>Average</b>		<b>4649</b>	<b>1378</b>	<b>189</b>	<b>6216</b>	<b>6910</b>	<b>147</b>	<b>4066</b>	<b>807</b>	<b>-1316</b>	<b>16831</b>	<b>0</b>	<b>16831</b>	<b>1028</b>	<b>493</b>	<b>19667</b>	<b>19667</b>	<b>50.01</b>

**Supply Position During Day Peak (MW)**

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
04-10-2021	13 Hrs	3933	1031	203	5167	7931	57	4104	979	-1783	16455	0	16455	1012	350	19600	19600	50.01
05-10-2021	18 Hrs	4607	2306	205	7118	6336	144	4218	83	-1262	16637	0	16637	1290	501	19690	19690	49.92
06-10-2021	13 Hrs	4332	1447	205	5984	7171	92	4027	1029	-1632	16671	0	16671	1059	500	19862	19862	50.03
07-10-2021	18 Hrs	5140	1810	169	7119	6201	94	4129	72	-1250	16365	0	16365	1311	491	19417	19417	49.80
08-10-2021	13 Hrs	5320	342	135	5797	6628	52	4499	906	-1607	16275	0	16275	1044	493	19419	19419	49.93
09-10-2021	13 Hrs	5287	852	226	6365	6456	60	3874	715	-1469	16001	0	16001	970	451	18891	18891	50.03
10-10-2021	13 Hrs	4786	364	228	5378	6131	38	3961	850	-1217	15141	0	15141	745	487	17590	17590	50.04
<b>Maximum</b>		<b>5320</b>	<b>2306</b>	<b>228</b>	<b>7119</b>	<b>7931</b>	<b>144</b>	<b>4499</b>	<b>1029</b>	<b>-1217</b>	<b>16671</b>	<b>0</b>	<b>16671</b>	<b>1311</b>	<b>501</b>	<b>19862</b>	<b>19862</b>	<b>50.04</b>
<b>Minimum</b>		<b>3933</b>	<b>342</b>	<b>135</b>	<b>5167</b>	<b>6131</b>	<b>38</b>	<b>3874</b>	<b>72</b>	<b>-1783</b>	<b>15141</b>	<b>0</b>	<b>15141</b>	<b>745</b>	<b>350</b>	<b>17590</b>	<b>17590</b>	<b>49.80</b>
<b>Average</b>		<b>4772</b>	<b>1165</b>	<b>196</b>	<b>6133</b>	<b>6693</b>	<b>77</b>	<b>4116</b>	<b>662</b>	<b>-1460</b>	<b>16221</b>	<b>0</b>	<b>16221</b>	<b>1062</b>	<b>468</b>	<b>19210</b>	<b>19210</b>	<b>49.97</b>

**Supply Position During Evening Peak (MW)**

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
04-10-2021	20 Hrs	4634	1793	236	6663	6883	323	4457	0	-1148	17178	0	17178	1222	501	20049	20049	49.98
05-10-2021	20 Hrs	4829	2222	241	7292	6818	515	4405	0	-1116	17914	0	17914	1295	500	20825	20825	49.98
06-10-2021	19 Hrs	4404	2058	250	6712	6793	245	4153	1	-1158	16746	0	16746	1318	500	19722	19722	49.83
07-10-2021	19 Hrs	5311	2068	197	7576	6929	57	4224	0	-1224	17562	0	17562	1315	491	20592	20592	49.76
08-10-2021	20 Hrs	5448	1576	228	7252	5775	900	4641	0	-1219	17349	0	17349	1250	484	20302	20302	49.95
09-10-2021	19 Hrs	5381	1252	73	6706	6315	753	4075	0	-1084	16765	0	16765	1213	491	19553	19553	49.83
10-10-2021	20 Hrs	5306	2062	231	7599	5708	108	4106	0	-751	16770	0	16770	1251	501	19273	19273	50.05
<b>Maximum</b>		<b>5448</b>	<b>2222</b>	<b>250</b>	<b>7599</b>	<b>6929</b>	<b>900</b>	<b>4641</b>	<b>1</b>	<b>-751</b>	<b>17914</b>	<b>0</b>	<b>17914</b>	<b>1318</b>	<b>501</b>	<b>20825</b>	<b>20825</b>	<b>50.05</b>
<b>Minimum</b>		<b>4404</b>	<b>1252</b>	<b>73</b>	<b>6663</b>	<b>5708</b>	<b>57</b>	<b>4075</b>	<b>0</b>	<b>-1224</b>	<b>16746</b>	<b>0</b>	<b>16746</b>	<b>1213</b>	<b>484</b>	<b>19273</b>	<b>19273</b>	<b>49.76</b>
<b>Average</b>		<b>5045</b>	<b>1862</b>	<b>208</b>	<b>7114</b>	<b>6460</b>	<b>414</b>	<b>4294</b>	<b>0</b>	<b>-1100</b>	<b>17183</b>	<b>0</b>	<b>17183</b>	<b>1266</b>	<b>495</b>	<b>20045</b>	<b>20045</b>	<b>49.91</b>

### Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW													
04-10-2021	3 Hrs	4112	1540	200	5852	5351	95	3960	0	-719	14539	0	14539	828	501	16587	16587	49.99
05-10-2021	4 Hrs	4166	1129	139	5434	5120	237	4022	0	-631	14182	0	14182	866	502	16181	16181	49.99
06-10-2021	4 Hrs	4262	1844	150	6256	4878	400	4031	0	-728	14837	0	14837	800	503	16868	16868	50.00
07-10-2021	3 Hrs	4007	2101	100	6208	4736	473	3963	0	-697	14683	0	14683	867	443	16690	16690	49.99
08-10-2021	3 Hrs	5074	1271	140	6485	4630	112	4636	0	-818	15045	0	15045	846	475	17184	17184	49.96
09-10-2021	3 Hrs	5078	822	240	6140	4567	406	4074	0	-704	14483	0	14483	940	479	16606	16606	49.91
10-10-2021	4 Hrs	4625	1058	194	5877	4760	315	3994	0	-720	14226	0	14226	805	471	16222	16222	50.03
<b>Maximum</b>		<b>5078</b>	<b>2101</b>	<b>240</b>	<b>6485</b>	<b>5351</b>	<b>473</b>	<b>4636</b>	<b>0</b>	<b>-631</b>	<b>15045</b>	<b>0</b>	<b>15045</b>	<b>940</b>	<b>503</b>	<b>17184</b>	<b>17184</b>	<b>50.03</b>
<b>Minimum</b>		<b>4007</b>	<b>822</b>	<b>100</b>	<b>5434</b>	<b>4567</b>	<b>95</b>	<b>3960</b>	<b>0</b>	<b>-818</b>	<b>14182</b>	<b>0</b>	<b>14182</b>	<b>800</b>	<b>443</b>	<b>16181</b>	<b>16181</b>	<b>49.91</b>
<b>Average</b>		<b>4475</b>	<b>1395</b>	<b>166</b>	<b>6036</b>	<b>4863</b>	<b>291</b>	<b>4097</b>	<b>0</b>	<b>-717</b>	<b>14571</b>	<b>0</b>	<b>14571</b>	<b>850</b>	<b>482</b>	<b>16620</b>	<b>16620</b>	<b>49.98</b>

### Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus										Mus	Mus	Mus
04-10-2021	96.967	39.534	4.999	141.500	0.590	159.932	161.524	4.103	98.207	7.383	25.085	11.757	-26.595	384.530	63.437	447.967
05-10-2021	105.842	39.125	4.212	149.179	0.725	151.295	153.940	6.586	96.403	7.875	25.835	12.039	-26.413	384.925	64.287	449.212
06-10-2021	104.972	43.080	4.754	152.806	0.501	148.291	147.916	8.197	97.441	6.796	25.536	11.987	-26.387	387.144	63.910	451.054
07-10-2021	113.011	37.970	3.032	154.013	0.598	147.118	148.807	7.561	99.001	7.098	25.704	11.381	-27.136	387.655	64.221	451.876
08-10-2021	125.517	27.965	4.174	157.656	0.839	134.744	139.809	6.986	106.286	6.725	26.556	11.468	-26.189	386.208	64.213	450.421
09-10-2021	125.810	28.517	4.577	158.904	0.582	135.639	138.461	7.488	95.522	5.676	24.996	11.203	-24.358	378.871	60.557	439.428
10-10-2021	116.227	26.662	5.135	148.024	0.389	135.494	136.662	4.045	96.137	6.203	21.508	11.315	-22.000	367.903	54.823	422.726
<b>Maximum</b>	<b>125.810</b>	<b>43.080</b>	<b>5.135</b>	<b>158.904</b>	<b>0.839</b>	<b>159.932</b>	<b>161.524</b>	<b>125.810</b>	<b>106.286</b>	<b>7.875</b>	<b>26.556</b>	<b>12.039</b>	<b>-22.000</b>	<b>387.655</b>	<b>64.287</b>	<b>451.876</b>
<b>Minimum</b>	<b>96.967</b>	<b>26.662</b>	<b>3.032</b>	<b>141.500</b>	<b>0.389</b>	<b>134.744</b>	<b>136.662</b>	<b>96.967</b>	<b>95.522</b>	<b>5.676</b>	<b>21.508</b>	<b>11.203</b>	<b>-27.136</b>	<b>367.903</b>	<b>54.823</b>	<b>422.726</b>
<b>Average</b>	<b>112.621</b>	<b>34.693</b>	<b>4.412</b>	<b>151.726</b>	<b>0.603</b>	<b>144.645</b>	<b>146.731</b>	<b>112.621</b>	<b>98.428</b>	<b>6.822</b>	<b>25.031</b>	<b>11.593</b>	<b>-25.583</b>	<b>382.462</b>	<b>62.207</b>	<b>444.669</b>

<b>Details of Koyna Water Consumption (in TMC)</b>			
<b>Date</b>	<b>For the Day</b>	<b>For the Month</b>	<b>Balance</b>
04-10-2021	0.696	1.931	46.822
05-10-2021	0.683	2.614	46.139
06-10-2021	0.789	3.403	45.350
07-10-2021	0.682	4.085	44.668
08-10-2021	0.445	4.530	44.223
09-10-2021	0.474	5.004	43.749
10-10-2021	0.409	5.413	43.340

**State Load Despatch Center,Airoli (MSETCL)  
Central Sector Share/Drawal from 04/Oct/2021 to 10/Oct/2021**

<b>Date</b>	<b>DAY</b>	<b>Central Sector Share</b>		<b>Total Interstate</b>		<b>Total Share</b>		<b>Total Drawal</b>		<b>Overdrawal(+)/</b>	
		<b>MUs</b>	<b>Avg. MW</b>	<b>MUs</b>	<b>Avg. MW</b>	<b>MUs</b>	<b>Avg. MW</b>	<b>MUs</b>	<b>Avg. MW</b>	<b>MUs</b>	<b>Avg. MW</b>
		<b>1</b>		<b>2</b>		<b>1+2=3</b>		<b>4</b>		<b>3-4=5</b>	
04-10-2021	MONDAY	116.125	6685	45.399	1892	161.524	6730	159.932	6664	-1.592	-66
05-10-2021	TUESDAY	114.917	6375	39.023	1626	153.940	6414	151.295	6304	-2.645	-110
06-10-2021	WEDNESDAY	107.484	6123	40.432	1685	147.916	6163	148.291	6179	0.375	16
07-10-2021	THURSDAY	103.188	6155	45.619	1901	148.807	6200	147.118	6130	-1.689	-70
08-10-2021	FRIDAY	99.954	5786	39.855	1661	139.809	5825	134.744	5614	-5.065	-211
09-10-2021	SATURDAY	102.959	5734	35.502	1479	138.461	5769	135.639	5652	-2.822	-118
10-10-2021	SUNDAY	103.391	5661	33.271	1386	136.662	5694	135.494	5646	-1.168	-49
<b>Total</b>		<b>748.018</b>		<b>279.101</b>		<b>1027.119</b>		<b>1012.513</b>		<b>-14.606</b>	

Generator Unit Outages/Trippings from 04.10.2021 to 10.10.2021						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
Chandrapur Unit 3	04-09-2021	23.58		Continued.	Annual Overhaul	PLANNED
RPL(AMT) U-3	04-10-2021	22.14	05-10-2021	13.14	Withdrawn on Turbine Vibrations High.	FORCED
Chandrapur Unit-8	04-10-2021	6.37	04-10-2021	10.43	Flame Failure	FORCED
IEPL Unit 1	28-08-2018	21.26		Continued.	No PPA	FORCED
Koradi Unit 9	04-10-2021	4.29	04-10-2021	12.03	BFP Tripped	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
Koradi Unit 10	28-09-2021	22.46	07-10-2021	9.29	Poor coal receipt	FORCED
RPL(AMT) U-5	23-09-2021	0.44		Continued.	Bottom Ash Prob.(conv. to coal shortage 18.00hrs,28.09.2021)	FORCED
Koyna Unit 2	09-10-2021	12	09-10-2021	17.05	Carbon brush replacement and oil checking work	FORCED
Koyna Unit 7	08-10-2021	12	08-10-2021	16.55	Carbon brush replacement and oil checking work.	FORCED
Khaparkheda Unit 5	06-10-2021	11.15	07-10-2021	4.34	Y-ph PRV of GT operated.	FORCED
Khaparkheda Unit 5	03-10-2021	15.02	06-10-2021	3.38	Boiler Tube Leakage	FORCED
Chandrapur Unit 4	15-09-2021	23.54	07-10-2021	12.2	Poor coal receipt	FORCED
Chandrapur Unit 5	07-10-2021	21.26		Continued.	Coal Shortage	FORCED
Koradi Unit 6	06-10-2021	3.22	08-10-2021	18.28	sparkling at exciter of the generator	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Bhusawal Unit 3	18-09-2021	3.3		Continued.	Coal Shortage	FORCED
Bhusawal Unit 5	06-10-2021	21.05		Continued.	Poor coal receipt.	FORCED
Nasik Unit 3	30-08-2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	FORCED
Nasik Unit 5	19-09-2021	20.5		Continued.	Coal Shortage.	FORCED
Parli Unit 6	26-08-2021	21.06		Continued.	Coal Shortage (Converted to AOH 00.00Hrs from Dt.01/09/2021)	FORCED
Paras Unit 4	26-09-2021	7.47		Continued.	Coal Shortage	FORCED
JSW (J) U1	02-09-2021	8.41		Continued.	Turbine vibrations high.	FORCED
SWPGPL U-1	16-02-2016	17.09		Continued.	No PPA.	FORCED
SWPGPL U-2	01-10-2021	15.3	05-10-2021	13.59	ID Fan Problem	FORCED
SWPGPL U-4	05-08-2021	3.04		Continued.	Turbine Vibration High.	FORCED
Adani U-3	08-10-2021	21.12		Continued.	APH-B hot PA below leakage.	FORCED
Adani U-5	19-09-2021	3.47	07-10-2021	21.35	Abnormal Sound in Turbine governing system.	FORCED
RPL(AMT) U-1	05-10-2021	22.15		Continued.	Coal Shortage	FORCED
RPL(AMT) U-2	29-09-2021	1.15		Continued.	Coal Shortage	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Uran Unit 5	02-10-2021	20.45		Continued.	Gas shortage	FORCED
Uran Unit 6	09-10-2021	15.1	09-10-2021	19.2	Gas shortage	FORCED
Uran Unit 6	07-10-2021	22.09		Continued.	Gas shortage	FORCED
Uran Unit 6	05-10-2021	22.18	06-10-2021	6.51	Gas shortage	FORCED
Uran Unit 7	25-05-2020	12.51		Continued.	Turbine Blade Failure	FORCED
Uran Unit 8	09-10-2021	18.39	09-10-2021	20.26	excitation fault.	FORCED
Uran Unit 8	07-10-2021	0.05	07-10-2021	14.49	Gas shortage	FORCED
Uran Unit A0	10-09-2021	1.54		Continued.	Turbine bearing Vibration high	FORCED
Uran Unit B0	07-10-2021	0.05	07-10-2021	18.01	Gas shortage	FORCED
Uran Unit B0	09-10-2021	18.39	09-10-2021	22.31	Due To GT 8 Tripped.	FORCED

**Transmission Line Outages/Trippings from 04.10.2021 to 10.10.2021**

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Mudshingi Chikodi	24-09-2019	17.12		Continued.	No Schedule(Charge from Mudshingi er	PO	220 KV
Talandage - Chikodi	01-10-2019	17.1		Continued.	No Schedule(Close at Chikodi end only)	PO	220 KV
Tata Borivli MSETCL Borivli 4	26-09-2021	20.49	04-10-2021	22.4	for shifting to Spare bay in GIS.	PO	220 KV
Chandrapur MIDC - GEPL Ckt I	02-10-2021	18.36		Continued.	Energy bill pending at GEPL end.	HT	220 KV
220/22 Kv 50 Mva Bb Ptr 2 @V	04-10-2021	10.19	04-10-2021	15.11	For checking Healthiness of Transforme	PO	220 KV
ACCIL - Apta	04-10-2021	13.35	04-10-2021	16.2	Routine Maintenance Work	PO	220 KV
AKOLA ANJANGAON (VIHIGAC	04-10-2021	9.35	05-10-2021	19.55	Testing Work	PO	220 KV
Adlabs - Pedambe	04-10-2021	15.56	04-10-2021	16.5	Distance Protection	T	220 KV
Adlabs - Pedambe	04-10-2021	10.48	04-10-2021	12.53	Distance Protection	T	220 KV
Balapur-Akola li	04-10-2021	9.54	05-10-2021	19.53	Bus section outage at Akola	PO	220 KV
Bhugaon-WardhaPG (Deoli)	04-10-2021	6.47	04-10-2021	13.52	To Control OD.	HT	220 KV
Dondaicha(220)-Amalner(220)	04-10-2021	11.4	04-10-2021	20.06	Line Maintenance work	PO	220 KV
Jejuri-Parvati	04-10-2021	19.58	04-10-2021	20.12	A/R LOCKOUT AT KONDHAWA END.	T	220 KV
Loteparshuram- Dasturi Line	04-10-2021	16.02	04-10-2021	22.4	Distance Protection	T	220 KV
Midc Chandrapur-Gadchandur	04-10-2021	15.04	04-10-2021	15.22	Distance Protection	T	220 KV
Parli New Tps - Beed Ckt 1	04-10-2021	10.5	04-10-2021	14.24	To Replace Various Jumpers.	PO	220 KV
Pophali - Nerale	04-10-2021	10.3	04-10-2021	17.15	B-Ph Bus isolator stranded jumper repla	PO	220 KV
Salsette Borivli 2	04-10-2021	22.39	04-10-2021	22.4	For test-charging of BO-BO-4 cables.	HT	220 KV
VARKUTI(MALWADI) HIWARW	04-10-2021	9.58	04-10-2021	17.14	Conversion of SSN to DSN work.	PO	220 KV
A'bad(PG)-Shendra Ckt II	05-10-2021	16.57	05-10-2021	19.5	To control Overdrawal	HT	220 KV
ACCIL - Apta	05-10-2021	14.3	05-10-2021	17.36	Bus Fault at ACCIL end	T	220 KV
BADNERA - WARDHA (PG) (De	05-10-2021	22.23	05-10-2021	23.41	To control Overdrawal	HT	220 KV
Bhugaon-WardhaPG (Deoli)	05-10-2021	16.28	25-09-2021	19.31	To control Overdrawal	HT	220 KV
Chandrapur(MIDC)-Ballarshah	05-10-2021	10	05-10-2021	15.38	Testing Work	PO	220 KV
Kamba - Kolshet	05-10-2021	9.46	05-10-2021	21.35	Metro work	PO	220 KV
Khadka-Bhadli-1	05-10-2021	8.32	05-10-2021	16.15	MTAMC work	PO	220 KV
Lamboti -Solapur li(Bale) Ckt- I	05-10-2021	11.24	05-10-2021	13.24	CB Compressor faulty and CB is in Lockd	EO	220 KV
Nagothane - ACCIL	05-10-2021	14.3	05-10-2021	15.09	Bus Fault at ACCIL	T	220 KV
Nanded - Parli Ext. Ckt I	05-10-2021	11.25	05-10-2021	21.47	Distance Protection	T	220 KV
PARLY (PG) - OLD GCR PARLI	05-10-2021	19.02	05-10-2021	20.19	To control Overdrawal	HT	220 KV
Pophali - Pedambe II	05-10-2021	8.4	05-10-2021	14.25	To attend cut and unwound strands of #	PO	220 KV
Pusad-WardhaPG(Deoli)	05-10-2021	22.23	05-10-2021	23.39	To control Overdrawal	HT	220 KV
Topworth - Kharghar	05-10-2021	10.52	05-10-2021	17.21	Routine Maintenance Work	PO	220 KV
Uran - Apta II	05-10-2021	17.48	05-10-2021	22.04	Distance Protection	T	220 KV
Uran - Apta IV	05-10-2021	13.14	05-10-2021	17.18	Distance Protection	T	220 KV
Uran - Kharghar I	05-10-2021	18.54	05-10-2021	22.55	Distance Protection	T	220 KV
VSNL - STT 1 GIS	05-10-2021	10.18	05-10-2021	15.1	Testing Work	PO	220 KV
VSNL - STT 2 GIS	05-10-2021	15.46	05-10-2021	19.47	Testing Work	PO	220 KV
Vita Alkud	05-10-2021	10.15	05-10-2021	17.27	Distance Protection	T	220 KV
sawangi-Phulambri	05-10-2021	13.1	05-10-2021	17.52	Testing Work	PO	220 KV
220/100 Kv 100 Mva Vijai lct 1	06-10-2021	19.2	06-10-2021	20	Overcurrent & Earthfault protection	T	220 KV
220/132kv 200mva Emco ICT-	06-10-2021	12.15	06-10-2021	13.47	replacement of old Al cable by Cu cable	PO	220 KV
A'bad(PG)-Shendra Ckt II	06-10-2021	4.41	06-10-2021	23.13	To Control OD.	HT	220 KV
ANANDNAGAR - PALAVA	06-10-2021	18.28	06-10-2021	19.44	Distance Protection	T	220 KV
Ambazari-Kalmeshwar	06-10-2021	10.02	06-10-2021	17.12	Replacement of flashover string at vari	HT	220 KV
Apta - Taloja	06-10-2021	18.04	06-10-2021	18.25	Distance Protection	T	220 KV
Aurangabad PG (Chitepimpalg	06-10-2021	21.47	06-10-2021	23.08	TO Control OD.	HT	220 KV
Aurangabad PG (Chitepimpalg	06-10-2021	11.46	06-10-2021	14.48	Replacement of TNC switch	PO	220 KV
Balapur-Malegaon	06-10-2021	10.53	06-10-2021	18.58	Safety, Ckt 1 work.	EO	220 KV
Bappaon - Kalwa	06-10-2021	18.49	06-10-2021	19.01	Distance Protection	T	220 KV
Bhugaon-WardhaPG (Deoli)	06-10-2021	21.15	06-10-2021	22.54	To Control OD.	HT	220 KV
Chikhli-Jalna-I	06-10-2021	19.15	06-10-2021	20.05	Control ICT loading.	HT	220 KV
Chikhli-Jalna-II	06-10-2021	19.15	06-10-2021	20.05	Control ICT loading.	HT	220 KV
Eklahara(Gcr)(Nasik)- Bables	06-10-2021	14.24	06-10-2021	14.34	Distance Protection	T	220 KV
Ghatghar - Jindal	06-10-2021	16.34	06-10-2021	17.52	Distance Protection	T	220 KV

**Transmission Line Outages/Trippings from 04.10.2021 to 10.10.2021**

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Kandalgaon - Sona Alloys	06-10-2021	2.5	06-10-2021	4.12	Distance Protection	T	220 KV
Kandalgaon - Sona Alloys	06-10-2021	10.02	06-10-2021	18.05	Replacement of polymer insulators by I	PO	220 KV
Karad - Vita Ckt- II	06-10-2021	9.01	06-10-2021	17.09	Conversion of SSN to DSN work.	PO	220 KV
Lamboti(solapur)-Karkamb	06-10-2021	10	06-10-2021	13.47	Quarterly Maintenance Work	PO	220 KV
Lonand Sona Alloys	06-10-2021	2.48	06-10-2021	9.08	Distance Protection	T	220 KV
PANDHARPUR BHALVANI	06-10-2021	21.26	07-10-2021	20.55	CC Burst.	T	220 KV
PARLY (PG) - OSMANABAD	06-10-2021	21.55	06-10-2021	22.58	To Control OD.	HT	220 KV
Pusad-WardhaPG(Deoli)	06-10-2021	21.23	06-10-2021	22.52	To Control OD.	HT	220 KV
Solapur (Pg) South Solapur I	06-10-2021	11.22	06-10-2021	16.38	Quarterly Maintenance Work	PO	220 KV
Trombay-Salsette II	06-10-2021	23.12	07-10-2021	4.25	Metro work.	PO	220 KV
Uran - Ongc Uran	06-10-2021	10.52	05-10-2021	18.55	Testing Work	PO	220 KV
220/132 Kv 200 MVA ICT II @	07-10-2021	10.11	07-10-2021	17.05	Bay Maintenance work	PO	220 KV
220/132kv 100mva Cgl Ict 3 @	07-10-2021	8.55	07-10-2021	16.3	OLTC Overhauling work	PO	220 KV
A'bad(PG)-Shendra Ckt II	07-10-2021	4.41	07-10-2021	7.31	To control Overdrawal	HT	220 KV
Akola-Paras Ckt No-I	07-10-2021	13.02	07-10-2021	16.45	To attend Hot Spot	PO	220 KV
Aurangabad PG (Chitepimpalg	07-10-2021	18.27	08-10-2021	0.21	To control Overdrawal	HT	220 KV
BHUGAON WARORA CKT-II	07-10-2021	9.25	07-10-2021	14.24	Testing Work	PO	220 KV
Chakan-Bhosari	07-10-2021	10.4	07-10-2021	18.04	Testing Work	PO	220 KV
Dhamangaon New- Tss -I	07-10-2021	8.55	07-10-2021	13.53	Routine Maintenance Work	PO	220 KV
Khaparkheda-Kalmeshwar	07-10-2021	10.45	07-10-2021	14.54	Replacement of Damaged B Phase CT Ju	PO	220 KV
Niwali - Pawas Line	07-10-2021	19.3	08-10-2021	5.14	Distance Protection	T	220 KV
PARLY (PG) - OLD GCR PARLI	07-10-2021	19.11	08-10-2021	0.47	To control Overdrawal	HT	220 KV
PARLY (PG) - OSMANABAD	07-10-2021	18.59	08-10-2021	0.44	To control Overdrawal	HT	220 KV
Padghe - Nalasopara	07-10-2021	10.1	07-10-2021	11.5	Jumper Replacement	PO	220 KV
Pedhambe - Oni	07-10-2021	16.01	08-10-2021	19.55	Distance Protection	T	220 KV
Pusad-WardhaPG(Deoli)	07-10-2021	18.22	08-10-2021	0.11	To control Overdrawal	HT	220 KV
Shirsuphal-Kurkumbh	07-10-2021	11.07	07-10-2021	14.37	Testing Work	PO	220 KV
Theur-Jejuri	07-10-2021	11.45	08-10-2021	16.01	Testing Work	PO	220 KV
Trombay Salsette 1 Backbay	07-10-2021	23.3	08-10-2021	6.33	Metro work	PO	220 KV
Trombay-Salsette II	07-10-2021	23.3	08-10-2021	6.41	Metro work	PO	220 KV
Uran - Apta II	07-10-2021	11.18	07-10-2021	16.12	Routine Maintenance Work	PO	220 KV
Vasai Kamba	07-10-2021	11.56	07-10-2021	14.58	Jumper replacement	PO	220 KV
WARDHA WARDHA (PG) (DEC	07-10-2021	18.55	08-10-2021	0.15	To control Overdrawal	HT	220 KV
220 KV KRUSHNOOR - NANDE	08-10-2021	19.57	08-10-2021	20.2	Distance Protection	T	220 KV
220/100kv 100mva Cgl Ict 1 @	08-10-2021	11.3	08-10-2021	18.3	Outage is required for OLTC Overhauling work.	PO	220 KV
220/132 Kv 200 Mva Bbl Ict 1	08-10-2021	10.2	08-10-2021	18.32	CTR maintenance work.	PO	220 KV
220/132Kv 200MVA ICT-II @ N	08-10-2021	10.05	08-10-2021	14.55	Quarterly Maintainance Work	PO	220 KV
220/33kv 100 MVA Transform	08-10-2021	11.53	08-10-2021	13.55	Attending Hot Spot	EO	220 KV
ANANDNAGAR - PALAVA	08-10-2021	10.34	08-10-2021	13.03	Attending hotspot on bottom of Y-phase Wavetrap on 220kv Palava line at Anandnagar S/S.	PO	220 KV
Adlabs - Pedambe	08-10-2021	15.35	08-10-2021	22.25	Distance Protection	T	220 KV
Apta - Taloja	08-10-2021	11.39	08-10-2021	14.52	Replacement of damaged twin conduct	EO	220 KV
Bableshtar - Bableshtar-II	08-10-2021	10.57	08-10-2021	19.05	CT and relay testing.	PO	220 KV
Butibori - Khaperkheda	08-10-2021	11.01	08-10-2021	16.03	CTS & cvts tan delta & capacitances tes	PO	220 KV
Chandrapur GCR - Wani	08-10-2021	9.08	08-10-2021	19.27	Tan Delta Measurment of CTs	PO	220 KV
Dhamangaon New- Tss-II	08-10-2021	8.3	08-10-2021	14.07	Measurement of c&tan delta of ct crm,	PO	220 KV
Eklahara(Gcr)(Nasik)- Bableshtar	08-10-2021	9.57	08-10-2021	14.14	Urgent basis to attend red hot at loc.guide tower ckt 2(temp 105 deg cel). and loc.4 ckt 1, temp 81 and 72.7 deg cel works shall be done by hot line unit Nashik.	PO	220 KV
Ghugus- Lloyds	08-10-2021	11.15	08-10-2021	19.3	C & tan-delta of metering & protection	PO	220 KV
Hingoli- Girawali	08-10-2021	5.51	08-10-2021	6.17	Distance Protection	T	220 KV

**Transmission Line Outages/Trippings from 04.10.2021 to 10.10.2021**

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Jamde-Dondaicha 1	08-10-2021	11.07	08-10-2021	16.3	Cut point nut bolt tightening work.	PO	220 KV
Kalwa Panchanand	08-10-2021	8.1	08-10-2021	10.59	For attending the partial discharge of insulator and conductor of Y phase Cable Bushing.	EO	220 KV
Kandalgaon - Sona Alloys	08-10-2021	10.33	08-10-2021	18.1	Replacement of polymer insulators by long rod porcelain insulators or conductor restringing work.	PO	220 KV
Karad - Vita Ckt- I	08-10-2021	10.02	08-10-2021	13.05	C & Tan delta testing of CTs.	PO	220 KV
Midc Chandrapur-Gadchandur	08-10-2021	12.41	08-10-2021	13.05	Distance Protection	T	220 KV
New Koyna - Pedambe	08-10-2021	11.35	08-10-2021	15.3	Emergency to attend red hot.	EO	220 KV
New Koyna - Pedambe	08-10-2021	11.43	08-10-2021	15.02	Line Maintenance work	PO	220 KV
Padghe - Kambha	08-10-2021	14.46	08-10-2021	17	Attending red hot on a bus y phase isolator	EO	220 KV
Padghe-Kamba II	08-10-2021	9.31	08-10-2021	14.1	For attending hot spot on Y & B phase CT.	PO	220 KV
Theur-Phursungi	08-10-2021	9.24	08-10-2021	13.47	Half yearly Maintenance and Tan Delta	PO	220 KV
220/132 Kv 200 Mva Bb Ict 2 @	09-10-2021	10.2		Continued.	Diagnostic Testing Work.	PO	220 KV
220/132 Kv 200 Mva Cgl Ict 1	09-10-2021	10.22	09-10-2021	16.45	Oil Sample Collection & Work Of Attending	PO	220 KV
220/132kv 100MVA ICT @ KA	09-10-2021	10.44	09-10-2021	13.33	Maintenance Work.	PO	220 KV
Aurangabad (Waluj)-Bhenda	09-10-2021	13.55	10-10-2021	11.28	Distance Protection	T	220 KV
Bableshtar -Ahamadnagar-I	09-10-2021	11.32	09-10-2021	16.4	Attending hotspot at R-ph. wave trap junction	PO	220 KV
Carnac : 220 / 110 / 33 315 MVA	09-10-2021	10.35	09-10-2021	14.16	Survey work for 110KV GIS work.	PO	220 KV
Chandrapur GCR - Sicom II	09-10-2021	9.04	09-10-2021	19.53	MFM Meter Retrofitting.	PO	220 KV
Ghatghar - Bapgaon	09-10-2021	16.1	09-10-2021	18.26	Distance Protection	T	220 KV
Hingoli- Girawali	09-10-2021	13.16	09-10-2021	17.14	Line Maintenance work	PO	220 KV
Kadegaon-Miraj	09-10-2021	9.56	09-10-2021	17.42	Conversion of SSN to DSN work.	PO	220 KV
Kandalgaon - Sona Alloys	09-10-2021	9.2	09-10-2021	17.55	Replacement of polymer Insulator string	PO	220 KV
Umred-Kanhan 2	09-10-2021	11.42	09-10-2021	12.56	Distance Protection	T	220 KV
Vita Alkud	09-10-2021	14.12	09-10-2021	17.58	Testing Work.	PO	220 KV
220/132kv 200mva Bbl Ict 2 @	10-10-2021	8.24	10-10-2021	15.3	Outage Required For OLTC Overhauling	PO	220 KV
Adlabs - Pedambe	10-10-2021	8.15	10-10-2021	18.45	Outage For Pedambe Bus Outage.	PO	220 KV
Badnera - Nandgaonpeth	10-10-2021	12.42	10-10-2021	14.24	BB1 Protection Operated.	T	220 KV
Badnera Tss-I	10-10-2021	12.42	10-10-2021	14.45	BB1 Protection Operated.	T	220 KV
Badnera-Akola I	10-10-2021	12.42	11-10-2021	0.06	BB1 Protection Operated.	T	220 KV
Badnera-Akola li	10-10-2021	12.45	10-10-2021	13.5	BB1 Protection Operated.	T	220 KV
Boisar Tarapur	10-10-2021	9.06	10-10-2021	15.55	Cutting Of Wild Grass & Trees Grown Under	PO	220 KV
Borivali - Tarapur	10-10-2021	9.14	10-10-2021	15.33	Cutting Of Wild Grass & Trees Grown Under	PO	220 KV
Dhamangaon New - Badnera	10-10-2021	12.42	10-10-2021	14.1	BB1 Protection Operated.	T	220 KV
Dharavi : 220 / 105 / 23 250 MVA	10-10-2021	9.02	10-10-2021	16.5	Cu IPS modification & Dismantling of transformer	PO	220 KV
Kandalgaon - Sona Alloys	10-10-2021	9.27	10-10-2021	18.1	For Replacement Of Polymer Insulator string	PO	220 KV
Kharghar - Tss Panvel	10-10-2021	13.24	10-10-2021	17.07	Distance Protection	T	220 KV
Main bus section-II @ Pedambe	10-10-2021	8.25	10-10-2021	18.33	B PH Main Bus To Main Bus Isolator Junction	PO	220 KV
Padghe - Kambha	10-10-2021	17.28		Continued.	Distance Protection	T	220 KV
Pedhambe - Oni	10-10-2021	8.13	10-10-2021	18.47	Outage For Pedambe Bus Outage.	PO	220 KV
Trombay-Salsette II	10-10-2021	16.47	10-10-2021	17.54	For Tree Cutting.	EO	220 KV
Karad Solapur (PG)	03-05-2017	11:49		Continued.	Line Converted As 220 Kv Solapur (PG)-	PO	400 KV
Koradi 2-IEPL	26-09-2021	7	09-10-2021	21.1	For height raising work.	PO	400 KV
koaradi II - Wardha(PG)	26-09-2021	7.29	08-10-2021	15.4	For height raising work across Samrudd	PO	400 KV
Khadka-Aurangabad (Waluj)	02-10-2021	20.04	05-10-2021	11.04	Over Voltage	HT	400 KV
400/220/33kv 500MVA ICT 5	03-10-2021	22.18	04-10-2021	1.28	Y-Phase Jumper Replacement.	PO	400 KV
400/220/33 Kv 315 Mva ICT 2	04-10-2021	22.01	05-10-2021	9.28	Replacement of Y-Ph Bushing due to Over	HT	400 KV
400/220kv, 500 Mva ICT-1 @D	04-10-2021	8.34	04-10-2021	16.55	MAIN BAY CT TAN DELTA & CB DCRM &	PO	400 KV
Dabhol Nagothane I	04-10-2021	13.2	04-10-2021	18.18	Earth wire replacement Work	PO	400 KV
Dhule - Ssnnl I	04-10-2021	10.46	04-10-2021	13.18	CB O/H WORK.	PO	400 KV

**Transmission Line Outages/Trippings from 04.10.2021 to 10.10.2021**

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400/220 kv 500MVA ICT-I @ A	05-10-2021	12.05	05-10-2021	12.27	Quarterly Maintenance Work	PO	400 KV
400/220/33kv, 500 Mva Ict-2	05-10-2021	10	05-10-2021	17.3	Testing Work	PO	400 KV
Babhaleshwar - Padghe-II	05-10-2021	17.12	05-10-2021	22.05	Distance Protection	T	400 KV
Dhule Sar'Sarovar I	05-10-2021	9.34	05-10-2021	17.3	Line Maintenance work	PO	400 KV
400/220/33 Kv 315 Mva ICT I	06-10-2021	18.48	06-10-2021	19.54	LBB Protection malfunction at 220KV side	T	400 KV
Bhusawal-Aurangabad	06-10-2021	22.31		Continued.	Over Voltage	HT	400 KV
Jejuri- Koynastage-IV	06-10-2021	21.22	07-10-2021	10.14	Distance Protection	T	400 KV
Khadka- Deepnagar Ckt 2	06-10-2021	10.22	06-10-2021	14.34	DCRM testing of own CB of 400KV deep	PO	400 KV
400/220/33 Kv 315 MVA ICT-II	07-10-2021	11.18	09-10-2021	18.28	PG Isolator overhauling work	PO	400 KV
Dabhol Nagothane I	07-10-2021	17.06	07-10-2021	19.46	Distance Protection	T	400 KV
Jejuri- Koynastage-IV	07-10-2021	14.18	07-10-2021	21.27	Distance Protection	T	400 KV
New Koyna - Dabhol - II	07-10-2021	11.1	07-10-2021	11.59	For attending partially opened B Phase	EO	400 KV
400/220/33 Kv 315 Mva Ict 2	08-10-2021	8.24	09-10-2021	0.19	33kv (tertiary) bushing of y phase unit	PO	400 KV
Dhule Sar'Sarovar I	08-10-2021	14.16	08-10-2021	19.08	Distance Protection	T	400 KV
Ektuni-Bableswhar ckt II	08-10-2021	16.36	08-10-2021	20.05	Distance Protection	T	400 KV
Jejuri- Koynastage-IV	08-10-2021	23.58	09-10-2021	4.16	Chemical washing of insulator.	PO	400 KV
400/220kv, 500 MVA ICT-III @	09-10-2021	9.44	09-10-2021	22.27	Diagnostic Testing Work.	PO	400 KV
Chakan Talegaon(Pg)	09-10-2021	11.15	09-10-2021	12.42	To attend Hot Spot	EO	400 KV
Ektuni-Bableswhar ckt II	09-10-2021	15.36	09-10-2021	19.17	Distance Protection	T	400 KV
Jaigad-New Koyna Ckt-II	09-10-2021	9.55	09-10-2021	19.27	for additional earthing.	PO	400 KV
Padghe - Kalwa- I	09-10-2021	4.5	09-10-2021	7.23	Attending Hot Spot	EO	400 KV
Girwali- Lonikand 2	10-10-2021	11.02	11-10-2021	6.34	Reactor Backup Relay Retrofitting Work	PO	400 KV
Karad-Jaigad - I	10-10-2021	21.16		Continued.	Over Voltage	HT	400 KV
Khadka-Aurangabad (Waluj)	31-12-2020	17.33		Continued.	Over Voltage	HT	400 KV
Chandrapur - Padghe HvdC Po	05-10-2021	23.47	06-10-2021	6.07	Radiator pump problem rectification	EO	500 KV
765/400KV 1500MVA ICT II @	06-10-2021	10.45	06-10-2021	15.37	Diagnostic testing & Routine maintenar	PO	765 KV