

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 31/Oct/2016 to 06/Nov/2016

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
31/10/2016	10 Hrs	5626	227	438	6291	4788	361	4079	137	-926	14730	0	14730	764	385	16805	16805	50.00
01/11/2016	10 Hrs	5815	429	413	6657	4830	390	4119	127	-1034	15089	0	15089	831	387	17341	17341	49.98
02/11/2016	10 Hrs	5710	784	446	6940	4989	390	4259	131	-806	15903	0	15903	1260	508	18477	18477	49.94
03/11/2016	10 Hrs	5753	1577	311	7641	5230	423	4368	126	-916	16872	0	16872	1219	509	19516	19516	49.94
04/11/2016	11 Hrs	5633	1128	445	7206	5735	40	4792	168	-934	17007	0	17007	1327	509	19777	19777	49.96
05/11/2016	10 Hrs	5782	1083	465	7330	6025	103	5027	124	-833	17776	45	17821	1097	506	20212	20257	49.97
06/11/2016	10 Hrs	5650	1009	449	7108	5113	88	5230	129	-419	17249	0	17249	1016	506	19190	19190	49.97
Maximum		5815	1577	465	7641	6025	423	5230	168	-419	17776	45	17821	1327	509	20212	20257	50.00
Minimum		5626	227	311	6291	4788	40	4079	124	-1034	14730	0	14730	764	385	16805	16805	49.94
Average		5710	891	424	7025	5244	256	4553	135	-838	16375	6	16381	1073	473	18760	18766	49.97

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
31/10/2016	18 Hrs	5639	174	435	6248	4846	187	4129	11	-899	14522	0	14522	874	386	16681	16681	49.93
01/11/2016	18 Hrs	5491	155	412	6058	5013	66	4219	6	-742	14620	0	14620	1070	478	16910	16910	49.96
02/11/2016	18 Hrs	5921	829	437	7187	5462	55	4257	8	-808	16161	0	16161	1373	508	18850	18850	49.89
03/11/2016	18 Hrs	5818	1439	294	7551	5763	86	4234	8	-809	16833	0	16833	1370	509	19521	19521	49.95
04/11/2016	14 Hrs	5551	613	424	6588	5832	72	4928	171	-930	16661	0	16661	1249	513	19353	19353	50.00
05/11/2016	18 Hrs	5929	1388	442	7759	5088	142	5133	7	-833	17296	18	17314	1155	509	19793	19811	49.95
06/11/2016	15 Hrs	5589	1018	424	7031	5227	33	4681	150	-488	16634	0	16634	987	508	18617	18617	50.00
Maximum		5929	1439	442	7759	5832	187	5133	171	-488	17296	18	17314	1373	513	19793	19811	50.00
Minimum		5491	155	294	6058	4846	33	4129	6	-930	14522	0	14522	874	386	16681	16681	49.89
Average		5705	802	410	6917	5319	92	4511	52	-787	16104	3	16106	1154	487	18532	18535	49.95

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
31/10/2016	20 Hrs	5677	371	456	6504	5497	241	4151	0	-839	15554	0	15554	1105	485	17983	17983	50.00
01/11/2016	20 Hrs	5428	592	434	6454	5518	83	4193	0	-861	15387	0	15387	1114	486	17848	17848	49.96
02/11/2016	19 Hrs	5901	1599	439	7939	5631	75	4225	0	-877	16993	0	16993	1375	509	19754	19754	50.00
03/11/2016	19 Hrs	5826	1950	296	8072	5735	139	4268	0	-848	17366	0	17366	1376	508	20098	20098	49.94
04/11/2016	19 Hrs	5162	1618	446	7226	5827	82	5165	0	-843	17457	0	17457	1349	509	20158	20158	49.97
05/11/2016	19 Hrs	5986	1891	443	8320	5028	156	5110	0	-967	17647	18	17665	1168	508	20290	20308	50.00
06/11/2016	20 Hrs	5675	1945	450	8070	5200	102	4693	0	-586	17479	0	17479	1155	510	19730	19730	50.02
Maximum		5986	1950	456	8320	5827	241	5165	0	-586	17647	18	17665	1376	510	20290	20308	50.02
Minimum		5162	371	296	6454	5028	75	4151	0	-967	15387	0	15387	1105	485	17848	17848	49.94
Average		5665	1424	423	7512	5491	125	4544	0	-832	16840	3	16843	1235	502	19409	19411	49.98

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
31/10/2016	4 Hrs	4653	86	451	5190	2416	702	3696	0	-614	11390	0	11390	695	386	13085	13085	49.98
01/11/2016	4 Hrs	4747	81	451	5279	2539	728	3556	0	-659	11443	0	11443	696	387	13185	13185	49.95
02/11/2016	3 Hrs	4524	179	460	5163	2908	657	3564	0	-643	11649	0	11649	698	387	13377	13377	49.97
03/11/2016	4 Hrs	4868	118	311	5297	3357	488	3652	0	-612	12182	0	12182	699	387	13880	13880	49.94
04/11/2016	2 Hrs	4797	366	469	5632	3540	237	4101	0	-700	12810	0	12810	695	386	14591	14591	49.95
05/11/2016	4 Hrs	4511	107	467	5085	3887	51	4297	0	-540	12780	25	12805	698	386	14404	14429	49.95
06/11/2016	4 Hrs	4719	108	461	5288	3828	105	4735	0	-529	13427	0	13427	696	386	15038	15038	49.98
Maximum		4868	366	469	5632	3887	728	4735	0	-529	13427	25	13427	699	387	15038	15038	49.98
Minimum		4511	81	311	5085	2416	51	3556	0	-700	11390	0	11390	695	386	13085	13085	49.94
Average		4688	149	439	5276	3211	424	3943	0	-614	12240	4	12244	697	386	13937	13941	49.96

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
31/10/2016	123.616	5.237	10.517	139.370	0.873	100.826	101.160	9.640	95.209	1.311	18.757	9.433	-21.922	324.434	50.112	374.546
01/11/2016	122.707	5.594	10.528	138.829	1.090	106.998	106.723	9.089	94.922	1.235	19.931	9.598	-22.149	328.926	51.678	380.604
02/11/2016	129.169	11.045	10.668	150.882	0.969	109.461	109.725	7.819	97.165	1.257	24.831	10.815	-20.412	346.172	56.058	402.230
03/11/2016	130.476	17.025	7.923	155.424	0.928	116.915	114.984	6.649	100.831	1.296	25.488	10.896	-19.943	361.172	56.326	417.498
04/11/2016	124.293	13.584	10.894	148.771	1.067	126.708	124.849	2.394	112.189	1.233	24.124	10.482	-20.791	369.437	55.397	424.834
05/11/2016	129.417	12.884	10.900	153.201	0.977	120.903	120.789	2.393	116.159	1.203	23.045	10.799	-19.395	374.464	53.239	427.703
06/11/2016	127.847	16.458	10.907	155.212	0.707	115.116	116.632	2.248	114.237	1.255	21.699	10.865	-14.024	374.044	46.588	420.632
Maximum	130.476	17.025	10.907	155.424	1.090	126.708	124.849	130.476	116.159	1.311	25.488	10.896	-14.024	374.464	56.326	427.703
Minimum	122.707	5.237	7.923	138.829	0.707	100.826	101.160	122.707	94.922	1.203	18.757	9.433	-22.149	324.434	46.588	374.546
Average	126.789	11.690	10.334	148.813	0.944	113.847	113.552	126.789	104.387	1.256	22.554	10.413	-19.805	354.093	52.771	406.864

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
31/10/2016	0.072	4.822	49.839
01/11/2016	0.071	0.071	49.768
02/11/2016	0.181	0.252	49.587
03/11/2016	0.307	0.559	49.280
04/11/2016	0.220	0.779	49.060
05/11/2016	0.204	0.983	48.856
06/11/2016	0.289	1.272	48.567

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 31/Oct/2016 to 06/Nov/2016

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
31/10/2016	MONDAY	87.426	4201	13.734	572	101.160	4215	100.826	4201	-0.334	-14
01/11/2016	TUESDAY	82.923	4423	23.800	992	106.723	4447	106.998	4458	0.275	11
02/11/2016	WEDNESDA	84.227	4546	25.498	1062	109.725	4572	109.461	4561	-0.264	-11
03/11/2016	THURSDAY	99.025	4775	15.959	665	114.984	4791	116.915	4871	1.931	80
04/11/2016	FRIDAY	110.084	5187	14.765	615	124.849	5202	126.708	5280	1.859	77
05/11/2016	SATURDAY	103.908	5016	16.881	703	120.789	5033	120.903	5038	0.114	5
06/11/2016	SUNDAY	101.897	4845	14.735	614	116.632	4860	115.116	4796	-1.516	-63
Total		669.490		125.372		794.862		796.927		2.065	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 31/10/2016 TO 06/11/2016							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Paras Unit 3	250MW	25/Oct/2016	08.54		Continued.	Stator Fault, continued under AOH.26/10/2016 00.00hrs
FORCED OUTAGES							
RGPPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
IPP	WPCL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	WPCL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
IPP	RPL(AMT) U-5	270MW	24/May/2016	00.05	07/Nov/2016	08.19	Zero Shedule By MSEDCL.
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
MSPGCL	Uran Unit B0	120MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPPPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	RPL(AMT) U-2	270MW	12/Sep/2016	00.03	07/Nov/2016	06.21	Zero Schedule by MSEDCL
IPP	PGPL U2	126MW	14/Sep/2016	00.16	09/Nov/2016	14.39	Due To No Shedule.
IPP	PGPL U1	262MW	14/Sep/2016	00.20	09/Nov/2016	14.27	Due To No Shedule.
MSPGCL	Bhusawal Unit 3	210MW	16/Sep/2016	00.02		Continued.	Zero Schedule by MSEDCL
MSPGCL	Koyna Unit 11	80MW	24/Sep/2016	03.20		Continued.	Stator Earth Fault
MSPGCL	Nasik Unit 5	210MW	07/Oct/2016	16.30	03/Nov/2016	09.30	Zero Schedule By MSEDCL
MSPGCL	Chandrapur Unit 9	500MW	24/Oct/2016	21.37		Continued.	Bearing vibration high
MSPGCL	Parli Unit 7	250MW	29/Oct/2016	07.13	01/Nov/2016	05.30	Boiler Tube Leakage
MSPGCL	Koradi Unit 9	660MW	29/Oct/2016	23.37	07/Nov/2016	23.09	Generator Seal Oil Leakage
IPP	RPL(AMT) U-4	270MW	29/Oct/2016	23.00	04/Nov/2016	15.16	Zero Schedule By MSEDCL
MSPGCL	Koradi Unit 7	210MW	29/Oct/2016	20.13	02/Nov/2016	22.58	Boiler Tube Leakage
IPP	RPL(AMT) U-1	270MW	29/Oct/2016	22.00	04/Nov/2016	09.11	Zero Schedule By MSEDCL
IPP	WPCL U-3	135MW	30/Oct/2016	06.55	02/Nov/2016	22.11	ID Fan Problem
IPP	JSW (J) U4	300MW	31/Oct/2016	19.35	31/Oct/2016	21.38	Turbine Vibration
MSPGCL	Parli Unit 8	250MW	31/Oct/2016	10.37	31/Oct/2016	12.38	Turbine emergency.
IPP	VIPL U-2	300MW	31/Oct/2016	05:16	03/Nov/2016	10.06	Water tube leakage
MSPGCL	Chandrapur Unit 5	500MW	01/Nov/2016	12.32	02/Nov/2016	07.26	Due to electrical protection operated.
MSPGCL	Parli Unit 8	250MW	02/Nov/2016	22.13	06/Nov/2016	01.00	Air heater problem
MSPGCL	Khaparkhedha Unit 4	210MW	03/Nov/2016	08.48	05/Nov/2016	05.19	Boiler Tube Leakage
MSPGCL	Uran Unit 5	108MW	03/Nov/2016	00.41	03/Nov/2016	19.12	Plan Maintenance.
IPP	WPCL U-3	135MW	03/Nov/2016	01.26	03/Nov/2016	05.00	Turbine Vibration
IPP	VIPL U-1	300MW	03/Nov/2016	16.40	03/Nov/2016	21.34	Genrator Protection Operated.
MSPGCL	Nasik Unit 4	210MW	03/Nov/2016	13.00		Continued.	Interchange With Unit-5
MSPGCL	Khaparkhedha Unit 1	210MW	04/Nov/2016	18.08	04/Nov/2016	21.00	Flame Failure
MSPGCL	Khaparkhedha Unit 1	210MW	04/Nov/2016	21.03	05/Nov/2016	07.58	Stator Earth Fault
MSPGCL	Parli Unit 6	250MW	04/Nov/2016	16.43	08/Nov/2016	15.53	Boiler Feed Pump Problem.
MSPGCL	Koradi Unit-8	660MW	05/Nov/2016	22.28	06/Nov/2016	00.36	High Metal Temperature.
MSPGCL	Koradi Unit-8	660MW	06/Nov/2016	20.16	06/Nov/2016	00.36	Coal mill problem
MSPGCL	Parli Unit 8	250MW	06/Nov/2016	08.44	06/Nov/2016	18.36	vaccum problem.
IPP	Adani U-1	660MW	06/Nov/2016	11.10		Continued.	Coal Shortage

LINE OUTAGES FOR THE WEEK FROM 31/10/2016 TO 06/11/2016

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Ektuni-Bableswhar ckt I	09/Oct/2016	12.29		Continued.	Over Voltage
400 KV	Dabhol Nagothane I	28/Oct/2016	12.48	01/Nov/2016	14.39	Distance Protection(RFC 07.40Hrs)
400 KV	Karad - Jaigad - II	28/Oct/2016	23.57	03/Nov/2016	12.53	Over Voltage
400 KV	karad -kolhapur-I	30/Oct/2016	02.09	04/Nov/2016	10.39	Over Voltage
400 KV	Dhule Sar'Sarovar I	30/Oct/2016	21.01	02/Nov/2016	09.25	Over Voltage
400 KV	Kolhapur Solapur(PG) I	30/Oct/2016	23.04	31/Oct/2016	06.04	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	31/Oct/2016	00.06	31/Oct/2016	07.00	Over Voltage
400 KV	Kolhapur Solapur (PG) II	31/Oct/2016	22.04	01/Nov/2016	07.56	Over Voltage
400 KV	Solapur - Parli(PG) I	02/Nov/2016	11.58	02/Nov/2016	17.28	Attending Hot Spot
400 KV	Dabhol Nagothane II	03/Nov/2016	15.09	03/Nov/2016	17.26	Distance Protection
400 KV	Dhule Sar'Sarovar I	03/Nov/2016	20.07	03/Nov/2016	06.41	Over Voltage
400 KV	Karad - Jaigad - II	03/Nov/2016	22.34	04/Nov/2016	11.12	Over Voltage
400 KV	Solapur - Parli(PG) II	04/Nov/2016	10.21	04/Nov/2016	14.09	Heavy Oil Leakage
400 KV	Girwali- Lonikand 2	04/Nov/2016	11.30	05/Nov/2016	00.04	Attend Heavy CVT Oil Leakge
400 KV	Dhule Sar'Sarovar II	04/Nov/2016	19.49	05/Nov/2016	06.32	Over Voltage
400 KV	karad -kolhapur-II	04/Nov/2016	23.57	05/Nov/2016	08.24	Over Voltage
400 KV	Wardha (Pg) Warora I	05/Nov/2016	12.38	05/Nov/2016	15.30	Emergency tree cutting.
400 KV	Chakan Talegaon(Pg)	05/Nov/2016	13.50	05/Nov/2016	13.58	Direct Trip Command Send.
400 KV	Dhule Sar'Sarovar I	05/Nov/2016	19.45	06/Nov/2016	10.46	Over Voltage
400 KV	Karad-Jaigad - I	05/Nov/2016	23.01	06/Nov/2016	08.56	Over Voltage
400 KV	Padghe - Kalwa - I	06/Nov/2016	11.20	06/Nov/2016	12.11	Attending Hot Spot
400 KV	Parly(MS)- Nanded	06/Nov/2016	11.21	06/Nov/2016	16.42	Quarterly Maintainance Work
400 KV	Dhule Sar'Sarovar II	06/Nov/2016	17.25	07/Nov/2016	07.30	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	06/Nov/2016	23.44	07/Nov/2016	08.01	Over Voltage
400 KV	karad -kolhapur-II	06/Nov/2016	23.47	07/Nov/2016	09.31	Over Voltage
400 KV	Koradi Bhilai	10/Nov/2016	10.25		Continued.	RMW & CT Repalacement Work.
400 KV	Dhule Sar'Sarovar I	10/Nov/2016	20.05		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107
220 KV	Bableswhar- Ranjangaon	06/Jun/2016	07.22		Continued.	Hand Tripped for Ranjangaon End.
220 KV	Talandage - Chikodi	01/Sep/2016	00.00		Continued.	No schedule from Kamataka(H/T from Talandage end) (QM work done from
220 KV	Mudshingi - Chikodi	01/Sep/2016	00.00		Continued.	No schedule from Kamataka(H/T from Chikodi end)
220 KV	Bableswhar -Bhenda	24/Oct/2016	06.57		Continued.	Alephata line loading.
220 KV	Kalwa - Borivali	27/Oct/2016	08.32		Continued.	Outage availed on28.10.2016 at 08:09 hrs for construction activity of Mumbai
220 KV	Mulund - GIS Bhandup	27/Oct/2016	08.53		Continued.	outage availed on 28.10.2016 at 09:30hrs for construction activity of mumbai
220 KV	Ghatghar - Jindal	30/Oct/2016	16.59	31/Oct/2016	20.14	Distance Protection
220 KV	Karad - Sadawagpur I	31/Oct/2016	21.01	31/Oct/2016	22.07	Distance Protection
220 KV	Waluj - Degaon Rangari	01/Nov/2016	11.39	01/Nov/2016	15.55	In view of aurangabad ICT I U/O.
220 KV	Parli 3(Old Gcr)- Girwali Ckt 4	01/Nov/2016	12.54	01/Nov/2016	17.46	Attending oil leakages of CT.
220 KV	Kolhapur-Birdi	02/Nov/2016	10.30	02/Nov/2016	17.15	Replacement work
220 KV	Kharepatan -Pawas Line	03/Nov/2016	10.00	03/Nov/2016	15.58	Attending Oil Leakage
220 KV	Phursungi-Parvati	03/Nov/2016	10.05	03/Nov/2016	17.27	Half Yearly Maintenance Work.
220 KV	220/100 Kv 200 MVA ICT IV @Padghe	03/Nov/2016	10.10	03/Nov/2016	16.48	Annual Maintenance Work
220 KV	Lonikand -Bhosari	03/Nov/2016	10.22	03/Nov/2016	16.09	Line Maintenance work
220 KV	Baramati- Kalyani	03/Nov/2016	10.30	03/Nov/2016	12.53	Diagnostic Testing Work.
220 KV	Babhaleshwar - Degaon Rangari	03/Nov/2016	11.25	03/Nov/2016	13.55	R&M Work.
220 KV	Bhigwan-Baramat lagro	03/Nov/2016	14.20	03/Nov/2016	16.28	Daignostic Testing Work.
220 KV	Nanded-Ghatodi	03/Nov/2016	18.07	06/Nov/2016	00.23	H/T to controlwardha -ytml L/L
220 KV	Temghar - Kalwa	04/Nov/2016	09.19	04/Nov/2016	12.50	CB Maintenance Work.
220 KV	Wada - Bhaveghar	04/Nov/2016	09.20	04/Nov/2016	13.11	Testing Work
220 KV	Mahape - TIFIL	04/Nov/2016	09.20	04/Nov/2016	11.40	IR Testing Of LA
220 KV	Parli 2-(Girwali) -Murud	04/Nov/2016	11.05	04/Nov/2016	16.43	Attending Hot Spot
220 KV	Bhira Dharavi 7	04/Nov/2016	16.19	04/Nov/2016	16.50	Distance Protection
220 KV	Pirangut - Hinjawadi 2	05/Nov/2016	09.12	05/Nov/2016	17.32	Tree trimming work.
220 KV	Padghe - Wada	05/Nov/2016	11.03	05/Nov/2016	18.16	Testing Work
220 KV	Pusad-Ghatodi	06/Nov/2016	00.09	06/Nov/2016	02.43	H/T in view of outage on wardha yeotmal ckt.
220 KV	Nanded-Ghatodi	06/Nov/2016	02.40		Continued.	TO CONTROL WARDHA YEOTMAL L/L
220 KV	Padgha-Temghar-II	06/Nov/2016	08.58	06/Nov/2016	19.30	Bus outages.
220 KV	Padgha - Temghar I	06/Nov/2016	08.58	06/Nov/2016	19.30	Bus outages.
220 KV	Kalwa - Mulund 1	06/Nov/2016	10.56		Continued.	Conductor Replacement.
220 KV	Bus B at Padgha	06/Nov/2016	11.56	06/Nov/2016	16.36	Attending Hot Spot
220 KV	Kalwa-Salsette-VI	06/Nov/2016	13.35	06/Nov/2016	17.52	Attending Hot Spot
220 KV	Osmanabad - Solapur (Bale)	10/Nov/2016	08.20		Continued.	DP,Zone-1, R-Y-B,Current-5Kamp ,Distance-Normalise From Parali End,Loa
220 KV	Ghodbunder - Versova	10/Nov/2016	13.34		Continued.	Relay Testing Work.
220 KV	Chakan-Chinchwad	10/Nov/2016	22.18		Continued.	String Work Of Multicircut Tower.
220 KV	Telco- Chinchwad	10/Nov/2016	22.28		Continued.	String Work Of Multicircut Tower.
132 KV	Padegaon - Canpack	01/Nov/2016	11.42	01/Nov/2016	16.02	In view of aurangabad ICT I U/O.
132 KV	Babhaleshwar-Rahuri	02/Nov/2016	03.07	02/Nov/2016	07.45	Distance Protection
132 KV	Mansar Pench	04/Nov/2016	14.00	04/Nov/2016	17.50	Attend D C Leakage.
132 KV	Jaina220- Jaina Midc	05/Nov/2016	03.32	05/Nov/2016	19.20	B P H ct Brust.