

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 08/Jan/2018 to 14/Jan/2018

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/01/2018	12 Hrs	5367	823	390	6580	6290	272	5601	473	-1534	17682	0	17682	628	250	20094	20094	49.94
09/01/2018	12 Hrs	5282	397	380	6059	6713	419	5544	397	-1606	17526	0	17526	629	253	20014	20014	49.95
10/01/2018	12 Hrs	5472	524	396	6392	6545	603	5355	427	-1839	17483	0	17483	459	254	20035	20035	49.97
11/01/2018	12 Hrs	5279	1147	405	6831	6874	233	5215	479	-1751	17881	0	17881	621	252	20505	20505	49.99
12/01/2018	12 Hrs	5362	1192	273	6827	6237	359	5412	462	-1818	17479	0	17479	620	253	20170	20170	49.96
13/01/2018	12 Hrs	5466	756	281	6504	6741	400	5756	448	-1633	18215	0	18215	648	253	20749	20749	49.95
14/01/2018	12 Hrs	5308	1662	436	7406	6353	183	5299	417	-1201	18457	0	18457	646	251	20555	20555	50.02
Maximum		5472	1662	436	7406	6874	603	5756	479	-1201	18457	0	18457	648	254	20749	20749	50.02
Minimum		5279	397	273	6059	6237	183	5215	397	-1839	17479	0	17479	459	250	20014	20014	49.94
Average		5362	929	366	6657	6536	353	5455	443	-1626	17818	0	17818	607	252	20303	20303	49.97

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/01/2018	13 Hrs	5352	650	390	6392	6291	228	5530	490	-1515	17416	0	17416	611	253	19795	19795	49.93
09/01/2018	13 Hrs	5273	328	390	5991	6331	341	5505	429	-1480	17117	0	17117	629	253	19479	19479	49.98
10/01/2018	13 Hrs	5410	382	396	6188	6527	431	5133	440	-1771	16948	0	16948	471	255	19445	19445	50.02
11/01/2018	13 Hrs	5278	806	410	6494	6706	188	5200	511	-1717	17382	0	17382	621	254	19974	19974	49.98
12/01/2018	13 Hrs	5388	943	260	6591	6098	323	5366	489	-1773	17094	0	17094	625	253	19745	19745	49.93
13/01/2018	13 Hrs	5526	720	276	6522	6501	216	5702	438	-1603	17777	0	17777	646	253	20279	20279	49.94
14/01/2018	13 Hrs	5305	1125	421	6851	6486	142	5307	401	-1222	17965	0	17965	604	252	20043	20043	50.00
Maximum		5526	1125	421	6851	6706	431	5702	511	-1222	17965	0	17965	646	255	20279	20279	50.02
Minimum		5273	328	260	5991	6098	142	5133	401	-1773	16948	0	16948	471	252	19445	19445	49.93
Average		5362	708	363	6433	6420	267	5392	457	-1583	17385	0	17385	601	253	19823	19823	49.97

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/01/2018	19 Hrs	4965	296	401	5662	5927	266	4675	0	-1512	15018	0	15018	566	253	17349	17349	50.00
09/01/2018	19 Hrs	5009	508	393	5910	5941	318	4777	0	-1589	15357	0	15357	597	254	17797	17797	49.98
10/01/2018	19 Hrs	5000	546	400	5946	5836	338	4605	0	-1708	15017	0	15017	526	254	17505	17505	49.96
11/01/2018	19 Hrs	5020	558	279	5857	5922	158	4851	0	-1637	15151	0	15151	610	252	17650	17650	49.98
12/01/2018	19 Hrs	4757	443	276	5476	5939	216	4960	2	-1736	14857	0	14857	599	253	17445	17445	49.94
13/01/2018	19 Hrs	4860	250	368	5478	6117	296	4999	0	-1564	15326	0	15326	647	252	17789	17789	49.99
14/01/2018	19 Hrs	4415	262	430	5107	5867	168	4481	0	-1248	14375	0	14375	516	251	16390	16390	49.97
Maximum		5020	558	430	5946	6117	338	4999	2	-1248	15357	0	15357	647	254	17797	17797	50.00
Minimum		4415	250	276	5107	5836	158	4481	0	-1736	14375	0	14375	516	251	16390	16390	49.94
Average		4861	409	364	5634	5936	251	4764	0	-1571	15014	0	15014	580	253	17418	17418	49.97

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/01/2018	3 Hrs	4404	123	407	4934	3876	79	4186	0	-844	12231	0	12231	130	254	13459	13459	50.01
09/01/2018	4 Hrs	4043	122	387	4552	4210	503	4203	0	-872	12596	0	12596	125	253	13846	13846	50.00
10/01/2018	3 Hrs	4220	119	382	4721	3713	795	4150	0	-958	12421	0	12421	127	254	13760	13760	49.99
11/01/2018	4 Hrs	4256	122	418	4796	3939	712	4171	0	-962	12656	0	12656	151	253	14022	14022	49.96
12/01/2018	4 Hrs	4359	118	300	4777	4344	475	4406	0	-1009	12993	0	12993	133	253	14388	14388	50.00
13/01/2018	4 Hrs	4461	96	368	4925	4582	331	4233	0	-1002	13069	0	13069	182	253	14506	14506	50.00
14/01/2018	3 Hrs	4429	100	450	4979	4405	370	4367	0	-1075	13046	0	13046	182	253	14556	14556	49.98
Maximum		4461	123	450	4979	4582	795	4406	0	-844	13069	0	13069	182	254	14556	14556	50.01
Minimum		4043	96	300	4552	3713	79	4150	0	-1075	12231	0	12231	125	253	13459	13459	49.96
Average		4310	114	387	4812	4153	466	4245	0	-960	12716	0	12716	147	253	14077	14077	49.99

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
08/01/2018	116.867	9.008	9.463	135.338	0.053	128.818	127.678	4.815	116.710	3.088	10.362	6.077	-29.732	359.037	46.171	405.208
09/01/2018	114.432	7.069	9.339	130.840	0.036	133.062	130.727	9.555	116.700	2.722	10.358	6.082	-31.487	361.392	47.927	409.319
10/01/2018	116.851	8.106	9.628	134.585	0.113	129.811	129.987	12.988	113.812	2.840	9.219	6.095	-33.954	360.083	49.268	409.351
11/01/2018	116.633	12.492	8.845	137.970	0.131	135.222	132.605	8.335	114.538	3.277	10.623	6.068	-33.925	365.417	50.615	416.032
12/01/2018	118.211	12.423	6.760	137.394	0.148	131.740	129.695	8.258	118.943	3.174	10.229	6.079	-35.328	364.181	51.636	415.817
13/01/2018	119.582	9.803	8.536	137.921	0.166	134.979	132.798	6.993	121.168	2.592	11.085	6.058	-32.543	371.110	49.686	420.796
14/01/2018	116.321	13.578	10.557	140.456	0.000	131.380	128.340	4.318	115.832	2.465	10.659	5.837	-27.740	366.711	44.235	410.946
Maximum	119.582	13.578	10.557	140.456	0.166	135.222	132.798	119.582	121.168	3.277	11.085	6.095	-27.740	371.110	51.636	420.796
Minimum	114.432	7.069	6.760	130.840	0.000	128.818	127.678	114.432	113.812	2.465	9.219	5.837	-35.328	359.037	44.235	405.208
Average	116.985	10.354	9.018	136.358	0.092	132.145	130.261	116.985	116.815	2.880	10.362	6.042	-32.101	363.990	48.505	412.496

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
08/01/2018	0.076	0.852	40.484
09/01/2018	0.058	0.910	40.426
10/01/2018	0.072	0.982	40.354
11/01/2018	0.182	1.164	40.172
12/01/2018	0.181	1.345	39.991
13/01/2018	0.142	1.487	39.849
14/01/2018	0.237	1.724	39.612

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 08/Jan/2018 to 14/Jan/2018

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
08/01/2018	MONDAY	106.013	5298	21.665	903	127.678	5320	128.818	5367	1.140	48
09/01/2018	TUESDAY	108.275	5425	22.452	935	130.727	5447	133.062	5544	2.335	97
10/01/2018	WEDNESDA	111.952	5398	18.035	751	129.987	5416	129.811	5409	-0.176	-7
11/01/2018	THURSDAY	112.396	5505	20.209	842	132.605	5525	135.222	5634	2.617	109
12/01/2018	FRIDAY	109.855	5384	19.840	827	129.695	5404	131.740	5489	2.045	85
13/01/2018	SATURDAY	111.117	5512	21.681	903	132.798	5533	134.979	5624	2.181	91
14/01/2018	SUNDAY	109.438	5329	18.902	788	128.340	5348	131.380	5474	3.040	127
Total		769.047		142.783		911.830		925.012		13.182	

Generating Unit Outages for week 08-14 Jan 2018

Sr No	Outage Type	Name	Trip Date	Trip Time	Synch Date	Synch Time	Reason
1	PLANNED	Trombay 6	15-Jul-15	17.08		Continued.	Economic shutdown.
2	PLANNED	Tarapur 1	04-Jun-17	19.09		Continued.	3 months outage for refuelling.
3	PLANNED	Chandrapur Unit-8	16-Dec-17	0.16		Continued.	Annual Overhaul
4	PLANNED	Trombay 5	02-Jan-18	23.48	17-Jan-18	20.2	Boiler Recertification Work.
5	PLANNED	REL Unit 2	06-Jan-18	0.46		Continued.	Annual Overhaul
6	FORCED	Dabhol 1B	28-May-13	22:02		Continued.	Gas Shortage.
7	FORCED	Dabhol 1X	27-Jun-13	21.46		Continued.	Gas Shortage
8	FORCED	Dabhol 1A	27-Jun-13	21.47		Continued.	Gas Shortage
9	FORCED	Koradi Unit 6	09-Jul-15	0		Continued.	EE R&M LE Work
10	FORCED	SWPGL U-1	16-Feb-16	17.09		Continued.	No PPA
11	FORCED	SWPGL U-2	29-Feb-16	21.46		Continued.	No PPA
12	FORCED	Parli Unit 5	01-Apr-16	0		Continued.	Economic shutdown
13	FORCED	Parli Unit 4	01-Apr-16	0		Continued.	Economic shutdown
14	FORCED	Bhusawal Unit 2	14-Jun-16	19.35		Continued.	De-commissioned on dt. 01.04.2017
15	FORCED	Dabhol 2A	24-Aug-16	13.31		Continued.	Change Over.
16	FORCED	Koradi Unit 5	05-Sep-16	0.21		Continued.	De-commissioned on dt.02.03.2017
17	FORCED	PGPL U2	07-Feb-17	17.3		Continued.	No Schedule
18	FORCED	PGPL U1	07-Feb-17	17.3		Continued.	No Schedule
19	FORCED	Ghatghar Unit-2	28-Jul-17	0		Continued.	due to common pressure shaft with unit 1.
20	FORCED	Khaparkheda Unit 3	12-Sep-17	0		Continued.	Coal Shortage
21	FORCED	RPL(AMT) U-5	17-Sep-17	2.01	19-Jan-18	16.51	Coal Shortage
22	FORCED	Dhariwal	27-Oct-17	17.31		Continued.	Drum level Not Maintained
23	FORCED	Paras Unit 3	29-Nov-17	22.55	09-Jan-18	3.29	bunkering problem, Water shortage
24	FORCED	JSW (J) U2	01-Dec-17	24		Continued.	no schedule.
25	FORCED	Chandrapur Unit 4	03-Dec-17	14.17		Continued.	Water Shortage
26	FORCED	Parli Unit 7	03-Dec-17	23.35		Continued.	Poor Coal Receipt.
27	FORCED	Chandrapur Unit 3	03-Dec-17	1.35		Continued.	Water Shortage
28	FORCED	RPL(AMT) U-1	12-Dec-17	8.49	13-Jan-18	6.14	switch gear problem (Coal shortage from 17.12.2017 00:00hrs)Converted to zero schedule w.e.f 01.01.2018, 00:00hrs)
29	FORCED	Tarapur 2	26-Dec-17	10.51		Continued.	commission of venting system.
30	FORCED	IEPL Unit 1	30-Dec-17	23.58		Continued.	No Schedule
31	FORCED	Adani U-2	02-Jan-18	15.26		Continued.	HPBP Bonnet leakage
32	FORCED	Chandrapur Unit 6	04-Jan-18	13.3		Continued.	Water Shortage
33	FORCED	Khaparkheda Unit 1	04-Jan-18	16.42	15-Jan-18	21.31	Coal Shortage
34	FORCED	Uran Unit 8	04-Jan-18	19.38	11-Jan-18	9.56	due to vibration.
35	FORCED	Bhusawal Unit 3	05-Jan-18	22.45	08-Jan-18	22.03	Coal Shortage
36	FORCED	Trombay 8	05-Jan-18	5.52	14-Jan-18	15:31	Turbine bearing temperature high.
37	FORCED	Nasik Unit 5	06-Jan-18	6.3		Continued.	PA Fan Problem (Not available due to Coal shortage from 07.01.2018 14:00Hrs)
38	FORCED	Parli Unit 8	06-Jan-18	7.07	12-Jan-18	17.05	Coal bunkering problem
39	FORCED	Koradi Unit 7	07-Jan-18	17		Continued.	Poor Coal Receipt.
40	FORCED	Bhusawal Unit 4	09-Jan-18	1.08	11-Jan-18	19.39	Boiler Tube Leakage
41	FORCED	Trombay 7A	10-Jan-18	8.3	10-Jan-18	11.58	EHC FAULT.
42	FORCED	Trombay 7B	10-Jan-18	8.3	10-Jan-18	22.48	EHC FAULT.
43	FORCED	Uran Unit 80	11-Jan-18	16.18	13-Jan-18	6.44	Hydraulic Test
44	FORCED	Uran Unit 8	11-Jan-18	15.43	17-Jan-18	13.06	thrust bearing trip.
45	FORCED	Uran Unit 7	11-Jan-18	16.22	13-Jan-18	0.27	Boiler Validity
46	FORCED	Uran Unit 8	11-Jan-18	10.41	11-Jan-18	12	Gas shortage
47	FORCED	Uran Unit 8	11-Jan-18	12.34	11-Jan-18	14.17	thrust bearing trip.
48	FORCED	Koyna STG-IV Unit-3	11-Jan-18	9:00	14-Jan-18	19:54	Replacement of Water Pump.
49	FORCED	Bhusawal Unit 3	11-Jan-18	23.33	22-Jan-18	4.57	poor coal receipt.
50	FORCED	Paras Unit 4	12-Jan-18	0.01	22-Jan-18	8.4	Water Shortage
51	FORCED	Uran Unit 6	13-Jan-18	9.43	13-Jan-18	15.48	filter replacement work.
52	FORCED	Koyna Unit 8	13-Jan-18	8.05	13-Jan-18	19.1	Maintenance work
53	FORCED	VIPL U-1	13-Jan-18	14.48	13-Jan-18	15.42	Electrical Fault
54	FORCED	Nasik Unit 4	14-Jan-18	13:15	14-Jan-18	18:55	Bus Bar Protection Operated at Nasik GCR

Line Outages for the week 08-14 Jan 2018

Voltage Level	Trip Date	Name	Trip Time	Synch Date	Synch Time	Reason
132 KV	Morshi-Warud	08-Jan-18	5.43	08-Jan-18	5.52	Distance Protection
132 KV	Mankapur - Hingna-I	14-Jan-18	11.5	14-Jan-18	14.03	Distance Protection
132 KV	Padegaon Palthan	14-Jan-18	16.46	14-Jan-18	22.13	Distance Protection
220 KV	Chandrapur GCR - Wani	05-Apr-15	9.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Talandage - Chikodi	01-Jun-17	0.01		Continued.	NO SCHEDULE.
220 KV	Mudshingi - Chikodi	01-Jun-17	0.06		Continued.	NO SCHEDULE.
220 KV	Mumewadi -Halkarni II	17-Nov-17	10		Continued.	Tower erection work (temporarily line would be Mumewadi-Tillari)
220 KV	Halkarni - Tillari II	17-Nov-17	12.25		Continued.	Tower erection work. (temporarily line would be Mumewadi-Tillari)
220 KV	Kandalgaon - Sona Alloys	08-Jan-18	8.4	09-Jan-18	19.5	Conductor replacement work
220 KV	Karad -Mudshingi Ckt- IV	08-Jan-18	10	08-Jan-18	19.5	Testing Work
220 KV	Pophli Pedhmbe Line- 1	08-Jan-18	13.2	08-Jan-18	14.3	Testing Work
220 KV	Pophli Pedhmbe Line- 2	08-Jan-18	14.45	08-Jan-18	15.55	Testing Work
220 KV	Virur - Gadchiroli	08-Jan-18	21.35	08-Jan-18	22.36	Bus Bar prot.operated Line tripped at Gadchiroli end only
220 KV	Kharghar - Nerul	09-Jan-18	6.27	09-Jan-18	8.05	Voltage surge Arrester Relay fixing work.
220 KV	Kandalgaon - Sona Alloys	09-Jan-18	8.15	09-Jan-18	17	Conductor Replacement.
220 KV	Kandalgaon - Sona Alloys	10-Jan-18	8.1	10-Jan-18	20.48	Line Maintenance work
220 KV	New Koyna - Niwali	10-Jan-18	9.32	10-Jan-18	18.29	insulator cleaning work.
220 KV	Khaparkheda-Kanhan	10-Jan-18	10.47	10-Jan-18	13.55	Routine Maintenance Work
220 KV	Beed-Patoda Ckt 1	10-Jan-18	11.49	10-Jan-18	14.48	faulty string insulator replacement work.
220 KV	Ongc Uran - Jnpt	10-Jan-18	12.14	10-Jan-18	12.5	Distance Protection
220 KV	Uran - Ongc Uran	10-Jan-18	12.14	10-Jan-18	14.43	Distance Protection
220 KV	Apta - Bombay Dyeing	10-Jan-18	13.5	10-Jan-18	14.25	Routine Maintenance Work
220 KV	Ongc Uran - Jnpt	10-Jan-18	15.32	10-Jan-18	17.54	Attending Hot Spot
220 KV	Bhosari- Bhosari 2	11-Jan-18	8.48	11-Jan-18	18.5	double jumper of cut point towers.
220 KV	Pedhambe - Oni	11-Jan-18	9.02	11-Jan-18	18.4	for cleaning of insulator string.
220 KV	Khaparkheda-Ambazari-I	11-Jan-18	10.13	11-Jan-18	13.58	Routine Maintenance Work
220 KV	Parli(U-VIII) GCR CKT	11-Jan-18	11.46	11-Jan-18	13.51	Tan Delta Measurment of CTs
220 KV	Nasik Navsari I	12-Jan-18	9.4	12-Jan-18	17.02	DIAGNOSTIC TESTING & BAY MAINTENANCE WORK.
220 KV	Loteaparshuram- Dasturi Line	12-Jan-18	9.45	12-Jan-18	18.45	Insulator Replacement Work
220 KV	Apta - Taloja	12-Jan-18	9.47	12-Jan-18	15.2	B-PHASE CT OIL LEAKAGE WORK.
220 KV	Maisal-Jath I	12-Jan-18	10.1	12-Jan-18	11.07	Y&B PHASE CT REPLACEMENT WORK.
220 KV	Walchandnagar-Bhigwan	12-Jan-18	11.4	12-Jan-18	17.4	Routine Maintenance Work
220 KV	Eklahare (Gcr) - Ghatghar	13-Jan-18	9.5	13-Jan-18	19.19	Routine Maintenance Work
220 KV	Infosys - Hinjawadi 1	13-Jan-18	10.08	13-Jan-18	16.5	Routine Maintenance Work
220 KV	New Koyna - Pedambe	13-Jan-18	10.12	13-Jan-18	17.57	CT Tan Delta Work
220 KV	Kharepatan -Pawas Line	13-Jan-18	10.23	15-Jan-18	14.46	CB Overhauling work
220 KV	Satana-Gangapur	13-Jan-18	12.22	13-Jan-18	20.35	Distance Protection
220 KV	Boisar(M) - Ghodbunder	13-Jan-18	14.53	13-Jan-18	19.14	Attending Hot Spot
220 KV	Eklahare (Gcr) - Ghatghar	14-Jan-18	9:42	14-Jan-18	18:19	Remaining work of shifting of BPI.
220 KV	Padgha-Temghar-II	14-Jan-18	9:52	14-Jan-18	15:08	Attending Hot Spot
220 KV	Sonkhar - Trombay	14-Jan-18	11:11	14-Jan-18	17:33	Jumper Replacement.
220 KV	Nagothane - Ipcl	16-Jan-18	11.42		Continued.	Line Bunching Work For Height Rising For Railway Line.
220 KV	IPCL - SPCL	16-Jan-18	12.07		Continued.	Line Bunching Work Height Rising For Railway Line.
220 KV	Kalwa - Taloja	23-Jan-18	10.28		Continued.	Bunching Arrangement At LOC No 665 For Tower Height Rising Work At Railway Crossing.
220 KV	Apta - Kalwa	23-Jan-18	10.59		Continued.	Bunching Arrangement At LOC No 665 For Tower Height Rising Work At Railway Crossing.
220 KV	Dahanu Ghodbunder Line 2	30-Jan-18	4.31		Continued.	Distance Protection
220 KV	Dahanu Ghodbunder Line 1	30-Jan-18	4.31		Continued.	Distance Protection
400 KV	Karad Solapur (PG)	03-May-17	11.49		Continued.	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
400 KV	Dhule Sar'Sarovar I	07-Jan-18	17.08	08-Jan-18	8.17	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	07-Jan-18	17.34	08-Jan-18	6.33	Over Voltage
400 KV	Karad-Jaigad - I	07-Jan-18	17.47	08-Jan-18	10.4	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	07-Jan-18	20.17	08-Jan-18	6.31	Over Voltage
400 KV	Chandrapur-II - Nanded ckt I	08-Jan-18	9.09	09-Jan-18	7.36	Testing Work
400 KV	Chandrapur Bhadravati III	08-Jan-18	9.44	08-Jan-18	14.08	Line Maintenance work
400 KV	Dhule Sar'Sarovar I	08-Jan-18	17.19	09-Jan-18	8.27	Over Voltage
400 KV	Bhusawal-Aurangabad	08-Jan-18	17.29	09-Jan-18	7.26	Over Voltage
400 KV	Karad-Jaigad - I	08-Jan-18	18.22	10-Jan-18	10.16	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	08-Jan-18	23.55	09-Jan-18	8.58	Over Voltage
400 KV	Dhule Sar'Sarovar I	09-Jan-18	8.37	09-Jan-18	9.06	Tripped At SSP Mend On PDR.
400 KV	Dhule Sar'Sarovar I	09-Jan-18	9.09	10-Jan-18	10.59	CB Not Closed At SSNL End Trial Taken At 14:26HRS But BKR Problem Persist At SSNL End Code 1018
400 KV	Chandrapur Bhadravati IV	09-Jan-18	9.2	09-Jan-18	21.07	Outage By WRLDC
400 KV	Chandrapur-Parali III	09-Jan-18	11.24	09-Jan-18	18.22	Line Maintenance work
400 KV	Chandrapur - Parli	09-Jan-18	11.24	09-Jan-18	18.22	Tightening Of Hardware At LOC908.
400 KV	Khadka-Aurangabad (Waluj)	09-Jan-18	18.01	10-Jan-18	7.52	Over Voltage
400 KV	Karad -kolhapur-I	09-Jan-18	20.03	10-Jan-18	10.34	Over Voltage
400 KV	Karad - Jaigad - II	10-Jan-18	10.36	11-Jan-18	9.46	Attending Hot Spot
400 KV	Khadka-Aurangabad (Waluj)	10-Jan-18	17.31	11-Jan-18	8.09	Over Voltage
400 KV	Dhule Sar'Sarovar II	10-Jan-18	17.58	11-Jan-18	9.5	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	11-Jan-18	1.15	11-Jan-18	7.41	Over Voltage
400 KV	Jaigad-New Koyna Ckt-I	11-Jan-18	10.02	11-Jan-18	18.1	yard equipment & gantry insulator wasing.
400 KV	Chandrapur-II - Nanded ckt II	11-Jan-18	12.47	11-Jan-18	13.18	to charge the line for taking the 400 kv 50 mvar bhel make reactor into service.

400 KV	Dhule Sar'Sarovar I	11-Jan-18	17.21	14-Jan-18	6.47	Over Voltage
400 KV	karad -kolhapur-I	11-Jan-18	17.36	12-Jan-18	10.32	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	11-Jan-18	17.57	12-Jan-18	7.24	Over Voltage
400 KV	Karad - Jaigad - II	11-Jan-18	18.12	12-Jan-18	9.09	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	11-Jan-18	21.2	12-Jan-18	7.24	Over Voltage
400 KV	Jaigad-New Koyna Ckt-II	12-Jan-18	9.5	12-Jan-18	16.22	Routine Maintenance Work
400 KV	Dabhol Nagothane I	12-Jan-18	10	13-Jan-18	8.52	STRING REPLACEMENT & EARTH WIRE REPLACEMENT.
400 KV	Karad-Jaigad - I	12-Jan-18	18.11	13-Jan-18	10.36	Over Voltage
400 KV	karad -kolhapur-I	12-Jan-18	18.17	13-Jan-18	10.33	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	12-Jan-18	18.2	13-Jan-18	7.03	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	13-Jan-18	17.43	15-Jan-18	7.11	Over Voltage
400 KV	Karad - Jaigad - II	13-Jan-18	19.35	15-Jan-18	9.5	Over Voltage
400 KV	karad -kolhapur-I	13-Jan-18	19.37	15-Jan-18	9.51	Over Voltage
400 KV	Dhule Sar'Sarovar II	14-Jan-18	12:38	15-Jan-18	10.27	Over Voltage
400 KV	Jaigad-Karad Ckt-I	29-Jan-18	17.08		Continued.	Over Voltage
400 KV	karad -kolhapur-II	29-Jan-18	17.09		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar I	29-Jan-18	17.53		Continued.	Over Voltage