

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 06/Jan/2025 to 12/Jan/2025

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/01/2025	11 Hrs	6372	218	293	6883	9804	77	7825	2722	-2149	24601	0	24601	453	307	28071	28071	50.09
07/01/2025	11 Hrs	6754	313	299	7366	9485	176	8109	2637	-1868	25370	0	25370	540	446	28759	28759	50.03
08/01/2025	11 Hrs	6049	233	293	6575	9815	270	7760	2894	-2088	24681	0	24681	463	367	28144	28144	50.00
09/01/2025	11 Hrs	6168	277	288	6733	9417	595	7772	2969	-2134	24800	0	24800	429	342	28257	28257	49.99
10/01/2025	11 Hrs	6676	476	291	7443	9119	362	8126	2660	-2011	25146	0	25146	503	456	28669	28669	49.96
11/01/2025	11 Hrs	6930	2014	297	9241	8227	200	8139	2145	-1616	25808	0	25808	693	496	29141	29141	50.03
12/01/2025	11 Hrs	6585	1303	356	8244	9306	116	7464	1891	-1238	25280	0	25280	580	483	28084	28084	49.90
Maximum		6930	2014	356	9241	9815	595	8139	2969	-1238	25808	0	25808	693	496	29141	29141	50.09
Minimum		6049	218	288	6575	8227	77	7464	1891	-2149	24601	0	24601	429	307	28071	28071	49.90
Average		6505	691	302	7498	9310	257	7885	2560	-1872	25098	0	25098	523	414	28446	28446	50.00

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/01/2025	13 Hrs	5812	217	286	6315	8987	76	7327	3269	-2161	23276	0	23276	430	308	26712	26712	50.00
07/01/2025	13 Hrs	5798	267	288	6353	9443	150	6978	3145	-2182	23354	0	23354	404	280	26753	26753	49.97
08/01/2025	13 Hrs	5495	231	283	6009	9487	105	6809	3290	-2196	22965	0	22965	438	308	26446	26446	49.97
09/01/2025	13 Hrs	5707	243	280	6230	8948	196	6962	3389	-2201	22993	0	22993	410	293	26428	26428	49.96
10/01/2025	13 Hrs	6205	242	285	6732	8661	111	7828	3125	-2218	23700	0	23700	435	307	27199	27199	49.96
11/01/2025	13 Hrs	6708	445	289	7442	9353	118	7129	2625	-1957	24181	0	24181	403	423	27493	27493	49.93
12/01/2025	13 Hrs	6423	388	289	7100	9558	70	6684	2367	-1447	23846	0	23846	398	489	26666	26666	50.04
Maximum		6708	445	289	7442	9558	196	7828	3389	-1447	24181	0	24181	438	489	27493	27493	50.04
Minimum		5495	217	280	6009	8661	70	6684	2367	-2218	22965	0	22965	398	280	26428	26428	49.93
Average		6021	290	286	6597	9205	118	7102	3030	-2052	23474	0	23474	417	344	26814	26814	49.98

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/01/2025	19 Hrs	6801	1352	293	8446	8114	228	7971	27	-1516	22711	0	22711	820	438	26044	26044	50.01
07/01/2025	19 Hrs	6795	1080	293	8168	8048	390	8241	0	-1534	22732	0	22732	825	487	26159	26159	50.03
08/01/2025	19 Hrs	6764	1721	364	8849	7675	369	8022	5	-1559	22804	0	22804	818	494	26232	26232	50.03
09/01/2025	19 Hrs	7031	1700	288	9019	7339	385	8250	1	-1572	22876	0	22876	820	495	26309	26309	49.98
10/01/2025	19 Hrs	7339	1164	292	8795	7323	250	8326	0	-1567	22564	0	22564	839	479	26012	26012	49.90
11/01/2025	19 Hrs	7011	1979	385	9375	7572	102	7664	0	-1394	22766	0	22766	808	495	26016	26016	49.98
12/01/2025	19 Hrs	6520	302	292	7114	9012	228	7006	0	-1214	21601	0	21601	636	437	24433	24433	50.03
Maximum		7339	1979	385	9375	9012	390	8326	27	-1214	22876	0	22876	839	495	26309	26309	50.03
Minimum		6520	302	288	7114	7323	102	7006	0	-1572	21601	0	21601	636	437	24433	24433	49.90
Average		6894	1328	315	8538	7869	279	7926	5	-1479	22579	0	22579	795	475	25886	25886	49.99

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/01/2025	3 Hrs	5425	230	303	5958	7198	428	6076	0	-1112	18113	0	18113	332	298	20290	20290	50.06
07/01/2025	3 Hrs	5753	257	306	6316	7177	255	6458	0	-991	18775	0	18775	359	317	20882	20882	49.99
08/01/2025	4 Hrs	5736	245	302	6283	6643	688	6527	0	-1006	18721	0	18721	353	306	20800	20800	49.97
09/01/2025	2 Hrs	5581	238	292	6111	6506	998	6665	0	-1254	18555	0	18555	318	278	20876	20876	50.03
10/01/2025	3 Hrs	5544	244	304	6092	6998	1054	6341	0	-1087	18978	0	18978	368	293	21146	21146	49.97
11/01/2025	3 Hrs	5630	245	304	6179	7125	524	6652	0	-1165	18899	0	18899	360	301	21141	21141	49.97
12/01/2025	24 Hrs	5234	223	297	5754	7488	780	6039	0	-1303	18266	0	18266	389	298	20748	20748	50.01
Maximum		5753	257	306	6316	7488	1054	6665	0	-991	18978	0	18978	389	317	21146	21146	50.06
Minimum		5234	223	292	5754	6506	255	6039	0	-1303	18113	0	18113	318	278	20290	20290	49.97
Average		5558	240	301	6099	7019	675	6394	0	-1131	18615	0	18615	354	299	20840	20840	50.00

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
06/01/2025	145.722	9.471	7.147	162.340	0.551	195.207	195.379	6.144	174.259	21.404	11.786	8.330	-37.357	509.561	57.473	579.470
07/01/2025	151.253	12.010	7.161	170.424	0.536	191.599	192.031	7.092	181.220	20.643	11.947	8.519	-36.865	521.758	57.330	591.443
08/01/2025	144.922	11.677	7.164	163.763	0.555	190.657	192.839	10.587	178.893	22.404	11.897	8.440	-38.153	515.851	58.479	586.630
09/01/2025	148.039	12.108	6.998	167.145	0.484	182.631	186.341	15.670	179.409	23.004	11.780	8.569	-38.257	517.322	58.606	588.208
10/01/2025	151.924	11.761	7.125	170.810	0.452	182.292	183.101	12.918	184.994	20.550	12.824	8.525	-37.748	521.510	59.097	592.913
11/01/2025	152.048	21.933	7.373	181.354	0.552	186.617	185.461	6.783	179.275	16.056	12.981	9.452	-33.977	524.006	56.410	592.518
12/01/2025	145.145	11.959	7.210	164.314	0.528	201.300	202.180	7.292	166.094	14.975	10.240	8.569	-30.558	511.566	49.367	572.784
Maximum	152.048	21.933	7.373	181.354	0.555	201.300	202.180	152.048	184.994	23.004	12.981	9.452	-30.558	524.006	59.097	592.913
Minimum	144.922	9.471	6.998	162.340	0.452	182.292	183.101	144.922	166.094	14.975	10.240	8.330	-38.257	509.561	49.367	572.784
Average	148.436	12.988	7.168	168.593	0.523	190.043	191.047	148.436	177.735	19.862	11.922	8.629	-36.131	517.368	56.680	586.281

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
06/01/2025	0.093	0.628	42.162
07/01/2025	0.132	0.759	42.030
08/01/2025	0.128	0.887	41.902
09/01/2025	0.136	1.023	41.767
10/01/2025	0.122	1.145	41.644
11/01/2025	0.351	1.496	41.293
12/01/2025	0.146	1.642	41.147

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 06/Jan/2025 to 12/Jan/2025

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
06/01/2025	MONDAY	110.691	8056	84.688	3529	195.379	8141	195.207	8134	-0.172	-7
07/01/2025	TUESDAY	110.630	7920	81.401	3392	192.031	8001	191.599	7983	-0.432	-18
08/01/2025	WEDNESDA	109.893	7952	82.946	3456	192.839	8035	190.657	7944	-2.182	-91
09/01/2025	THURSDAY	103.301	7681	83.040	3460	186.341	7764	182.631	7610	-3.710	-155
10/01/2025	FRIDAY	102.366	7548	80.735	3364	183.101	7629	182.292	7596	-0.809	-34
11/01/2025	SATURDAY	112.831	7655	72.630	3026	185.461	7728	186.617	7776	1.156	48
12/01/2025	SUNDAY	117.984	8340	84.196	3508	202.180	8424	201.300	8388	-0.880	-37
Total		767.696		569.636		1337.332		1330.303		-7.029	

Generator Unit Outages/Trippings from 06.01.2025 to 12.01.2025						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-17	17.3		Continued.	No Schedule.(NO PPA)	NOPPA
PGPL U1	07-02-17	17.3		Continued.	No Schedule (NO PPA)	NOPPA
VIPL U-1	29-12-18	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	NOPPA
VIPL U-2	17-01-19	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	NOPPA
Tarapur 1	08-01-20	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-20	4:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-21	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-22	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Ghatghar Unit-2	26-05-24	13:17		Continued.	Stator Earth Fault	FORCED
RPL(AMT) U-3	23-07-24	0:47	06-01-25	20:31	Turbine Vibration High	FORCED
Trombay 5	22-09-24	16:14		Continued.	Emergency withdrwan due to fire in cable vault.	FORCED
JPL Unit 2	21-11-24	1:30		Continued.	Unit Out due to Non-avaialbility of Schedule.	ZEROSCH/RSD
Chandrapur Unit 6	14-12-24	19:45		Continued.	Capital overhaul	PLANNED
Tarapur 4	21-12-24	21:50		Continued.	Annual Overhaul	PLANNED
Koyna Unit 10	25-12-24	12:00		Continued.	for upgradation of existing protection system to numerical protection system and H.S. Lubrication system work.	PLANNED
Uran Unit 5	29-12-24	20:30		Continued.	No schedule. Utilised as per requirement	ZEROSCH/RSD
Koradi Unit 9	30-12-24	16:36		Continued.	FD Fan Problem.	FORCED
Chandrapur Unit 4	02-01-25	13:07	06-01-25	5:27	Boiler Tube Leakage	FORCED
Parli Unit 7	03-01-25	17:45	06-01-25	18:56	Boiler Tube Leakage	FORCED
JSW (J) U4	05-01-25	0:52	06-01-25	5:36	Condenser choke	FORCED
Uran Unit 6	05-01-25	19:10	08-01-25	17:53	No schedule by MSEDCL	ZEROSCH/RSD
Chandrapur Unit 4	08-01-25	8:17	10-01-25	2:43	Suspected BTL	FORCED
Khaparkheda Unit 3	08-01-25	12:11	09-01-25	3:14	Air Heater 3A rotor Stopped	FORCED
RPL(AMT) U-3	08-01-25	14:32	09-01-25	14:29	Due to TG Shaft Balancing Work.	FORCED
Uran Unit 6	08-01-25	19:00	11-01-25	17:15	Zero Schedule Given By MSEDCL.	ZEROSCH/RSD
Bhusawal Unit 3	09-01-25	19:16	10-01-25	2:30	Air heater problem	FORCED
Chandrapur Unit 4	11-01-25	9:11	11-01-25	12:40	Drum level low	FORCED
Adani U-5	11-01-25	12:03		Continued.	APH-A inlet bellow leakage	FORCED
Chandrapur Unit 9	11-01-25	18:55		Continued.	Generator Protection operated	FORCED
Uran Unit 6	11-01-25	20:00	12-01-25	9:45	Due to No schedule by MSEDCL	ZEROSCH/RSD
Uran Unit 6	12-01-25	10:42	13-01-25	7:55	As per LM cell Request taken during shortage of Power in Morning Peak Load Period. after that withdrawn	ZEROSCH/RSD
Adani U-4	12-01-25	12:20		Continued.	APH-A inlet bellow leakage	FORCED

Transmission Line Outages/Trippings from 06.01.2025 to 12.01.2025							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
GIS BHANDUP - BORIVALI	03-01-25	23:02	10-01-25	14:23	For live line shifting of 220kV Borivali line on Bus- 1 to 220kV Bus-2 for attending SF6 Gas leakage of 220kV Main Bus-I.	EO	220 KV
BUS-1@GIS BHANDUP	03-01-25	23:04	10-01-25	14:20	SF6 Gas leakage observed in 220kV Main Bus-I. Outage is required for attending SF6 Gas leakage of 220kV Main Bus-I.	EO	220 KV
WAGHIVALI - CHEMBUR	04-01-25	15:48	10-01-25	23:30	pROJECT WORK-Tower erection work at Loc 78N & 126N	PO	110 KV
JAIGAD - KARAD CKT - 1	05-01-25	21:01	06-01-25	9:27	Overvoltage	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	05-01-25	20:58	06-01-25	9:21	Overvoltage	HT	400 KV
220/33-33KV 100MVA TF NO. - 1 @ ICHALKARANJI - II	06-01-25	10:00	06-01-25	14:55	1) Quaterly bay maintenance work 2) Hot spot attending work 3) Bay insulator cleaning work 4) Diagnostic testing work.	PO	220 KV
ABHIJEET-WARDHA-1	06-01-25	8:36	06-01-25	17:10	Restraining work of loose span no.35 to 38.	PO	220 KV
ALEPHATA-PARGAON(KATHAPUR)	06-01-25	11:21	06-01-25	19:02	Load Manegment	HT	220 KV
CHANDRAPUR 2 - DHARIWAL CKT - 2	06-01-25	10:42	06-01-25	19:45	Diagnostic testing & allied bay maintenance work	PO	400 KV
GHODBUNDER - GORAI	06-01-25	9:19	06-01-25	15:57	Annual Maintenance of Circuit Breaker i.e. CB 452	PO	220 KV
HINJAWADI I- CHINCHWAD	06-01-25	7:44	06-01-25	21:34	Load Manegment	HT	220 KV
MALEGAON-SATANA	06-01-25	6:38	06-01-25	17:40	Load Manegment	HT	220 KV
MUMEWADI -HALKARNI 2 LINE	06-01-25	11:16	06-01-25	16:03	Insulator cleaning work	PO	220 KV
ONI KHAREPATAN LINE	06-01-25	9:09	06-01-25	18:12	Cold washing and Replacement of flashover string if found.	PO	220 KV
132 KV PATHRI-MAJALGAON CKT	06-01-25	13:05			After completion of outage on 132kv patri parbhani ckt	HT	132 KV
220/100 KV 100 MVA ICT 2 @ TAMBATI	06-01-25	10:05	06-01-25	23:58	"1) Work of strengthening of 220/100kV, 100MVA ICT-2 LV side bay from single conductor to twin conductor by agency. 2) Dianostic testing work.Work carried out under:- R&M Code:- 0007	PO	220 KV
220/132 KV 100 MVA ICT 2 @ BHOKARDAN	06-01-25	10:29	06-01-25	19:40	Live demonstration preventive maintenance along with spare material replacement & Diagnostic testing & Winding tan delta bushing work	PO	220 KV
220/33 kV 50 MVA CGL PTR 1 @ MUDSHINGI	06-01-25	10:11	06-01-25	17:12	Attending oil leakage using cold welding and quarterly maint of TF and bay equipments	PO	220 KV
220/33KV 50MVA PTR 1 @ MUMEWADI	06-01-25	7:08	07-01-25	17:40	TF OLTC overhauling work	PO	220 KV
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	06-01-25	8:34	08-01-25	10:51	1) Replacement of LV(3.2) bushing of Rph unit of ICT-I due rise in tan delta value.	PO	400 KV
400/220KV 315 MVA ICT - 3 @ NEW KOYNA	06-01-25	8:34	06-01-25	17:38	Chemical Washing work & Diagnostic testing & Relay testing work , Routine maint. Work	PO	400 KV
BABLESHWAR- BABLESHWAR(400KV)-II	06-01-25	12:31	06-01-25	15:51	"In view of approved outage on 220 Bus coupler dated 06.01.2025 for B/U relay testing, CT Tan Delta CB CRM/DCRM Timing, hence Emergency Shifting of the 220KV Babhaleshwar-Babhaleshwar -2 from 220kV Main Bus-II to 220kV Main Bus -I is required to avoid overloading of 220kV BBLR-BBL-I and to balance the load on both 220kV Buses. The Original Bus configuration of 220kV BBLR-BBLR-II will be restored after the 220 kV bus Coupler is taken in service."	EO	220 KV
BUS COUPLER @ BABHALESHWAR	06-01-25	12:33	06-01-25	15:06	B/U relay testing, CT Tan Delta CB CRM/DCRM Timing	PO	220 KV
JAIGAD - KARAD CKT - 2	06-01-25	20:45	07-01-25	10:09	Overvoltage	HT	400 KV
KALYAN KALWA SALSETTE 2	06-01-25	7:48	06-01-25	9:27	Loop open and coil back towards Salsette side at loc. 78 (LHS & RHS Ckt) For tower erection at loc. 117 at Shangrila Metro-4 Crossing.	PO	110 KV
KALYAN KALWA SALSETTE 2	06-01-25	7:48	06-01-25	9:54	CT and CVT testing	PO	110 KV
KHADKA-AURANGABAD (WALUJ)	06-01-25	20:46	07-01-25	9:07	Overvoltage	HT	400 KV
KURKUMBH - SHIRSHUPHAL CKT	06-01-25	11:32	06-01-25	18:55	Chemical cleaning of insulator string work	PO	220 KV
MAIN BUS - 2 @ KORADI-3	06-01-25	9:25	06-01-25	18:24	Bus Outage	PO	400 KV
MALEGAON (ZODGA) - BALAPUR CKT 1	06-01-25	9:11	06-01-25	12:54	Diagnostic testing, IR stack value measurement of LA and maintenance work	PO	220 KV
VITA - GHATNANDRE	06-01-25	11:05	06-01-25	12:40	Diagnostic testing work(CB)	PO	220 KV
VITA - MIRAJ	06-01-25	16:55	07-01-25	13:22	conductor snapping	T	220 KV
ABHIJEET-WARDHA-II	07-01-25	8:43	07-01-25	13:49	Restraining of conductor between span at Loc no.35 to 38.	PO	220 KV
ADLABS - PEDAMBE	07-01-25	13:16	07-01-25	17:27	Faulty Energy Meter replacement Work	EO	220 KV
ALEPHATA-PARGAON(KATHAPUR)	07-01-25	10:16	07-01-25	19:38	Load management.	HT	220 KV

Transmission Line Outages/Trippings from 06.01.2025 to 12.01.2025							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
HALKARNI - TILARI LINE	07-01-25	10:27	07-01-25	14:58	Insulator cleaning work	PO	220 KV
HINJAWADI I- CHINCHWAD	07-01-25	7:15	07-01-25	21:36	Load management.	HT	220 KV
KALWA - MULUND 2	07-01-25	17:28	07-01-25	21:15	1. CT Diagnostic testing work 2. CB Diagnostic work. 3. Bay Maintenance work. 4. 29F & 29C isolator maintenance work by removing Jumper with help of Hotline Unit.	PO	220 KV
KORADI-NANDGAONPETH (RPL)	07-01-25	13:26	07-01-25	18:58	BREAKER TESTING (CRM, DCRM, TIMING) & bay maintenace work.	PO	400 KV
MIRAJ - ICHALKARANJI	07-01-25	14:30	07-01-25	19:00	For proper load management at 220kV Tilawani S/S 220kV Miraj- Tilawani line needs to be kept off at 220kV Tilawani S/S end during outage period of 220kV Talandage- Tilawani - II.	PO	220 KV
ONI KHAREPATAN LINE	07-01-25	9:03	07-01-25	18:03	Cold washing and Replacement of flashover string if found.	PO	220 KV
PADGHE - NALASOPARA	07-01-25	17:34	07-01-25	20:08	Distance protection.	T	220 KV
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 2	07-01-25	10:20	07-01-25	17:57	AT PG End.	PO	220 KV
TALANDGE - ICHALKARANJI 2	07-01-25	14:39	07-01-25	18:53	02 Nos. of Jump replacement and Insulator cleaning work.	PO	220 KV
220/100 KV 200 MVA ICT 4 @ PADGHE	07-01-25	11:27	07-01-25	19:52	Replacement of 220kV Y ph CT due to oil leakage	EO	220 KV
220/100 KV 200 MVA ICT 4 @ KALWA	07-01-25	9:43	07-01-25	17:41	Diagnostic testing and R&M work	PO	220 KV
220/132 KV 100 MVA ICT 1 @ BHOKARDAN	07-01-25	10:50	07-01-25	19:09	Testing work.	PO	220 KV
220/33KV 25MVA PTR 1 @ NEW KOYNA	07-01-25	10:23	07-01-25	12:53	CB oil pressure is not increasing	EO	220 KV
220kV Koradi-2 - Uppalwadi ckt 1	07-01-25	8:44	07-01-25	17:49	For safety reasons due to civil work for construction and height raising of damage power cable joint box JB 1 & JB2A at 3x660MW KTPS Premises	PO	220 KV
33KV HVDC AUXILIARY SUPPLY 1 @ PADGHE-400 KV	07-01-25	15:05	07-01-25	16:36	To check and identify XLPE power cables found during excavation of tower foundation for proposed ICT 6 at Padgha	EO	400 KV
400/220 KV 167 MVA SPARE ICT @ KALWA	07-01-25	12:19	07-01-25	18:28	167 MVA 400/220 KV Spare ICT Oil top & Air cell checking in conservator tank, Oil low indication shown in MOG	EO	400 KV
400/220 KV 315MVA ICT - 2 @ KARAD	07-01-25	8:30	07-01-25	11:44	low oil level indication	EO	400 KV
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	07-01-25	14:55	07-01-25	18:19	Suspected DC leakage observed	T	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 1	07-01-25	10:25	12-01-25	17:02	H/T for load management.	HT	400 KV
BUS COUPLER @ KARAD	07-01-25	17:15	07-01-25	19:30	Emergency outage to attend hot spot at 29B Y Ph isolator IPS clamp	EO	400 KV
JAIGAD - KARAD CKT - 1	07-01-25	22:19	08-01-25	9:06	overvoltage	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	07-01-25	22:03	08-01-25	8:43	overvoltage	HT	400 KV
MALEGAON (ZODGA) - BALAPUR CKT 2	07-01-25	9:23	07-01-25	12:29	Diagnostic testing, IR stack value measurement of LA and maintenance work	PO	220 KV
NAVI MUMBAI - 400KV B/R 1	07-01-25	13:06	07-01-25	18:44	Onload Commissioning works of 63MVAR Bus Reactor at Navi Mumbai GIS SS	PO	400 KV
PARLI - KARJAT CKT - 2	07-01-25	22:17	08-01-25	6:11	1) CB testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	PO	400 KV
VERSOVA - GHODBUNDER	07-01-25	9:10	07-01-25	16:19	Annual Maintenance of Circuit Breaker i.e. CB 552	PO	220 KV
ABHIJEET-WARDHA-1	08-01-25	13:11	08-01-25	15:37	Hot Line Work	PO	220 KV
AKOLA - WARDHA(PG) CKT - 1	08-01-25	12:18	08-01-25	20:41	To attend Hotspot		400 KV
BABHALESHWAR - PADGHE CKT- 1	08-01-25	3:28	08-01-25	6:48	distance protection	T	400 KV
CHANDRAPUR 2 - DHARIWAL CKT - 1	08-01-25	9:02	08-01-25	14:08	To attend Hotspot		400 KV
GADCHANDUR - GRACE	08-01-25	10:19	08-01-25	17:36	Replacement of faulty disc	PO	220 KV
KALMESHWAR-PANDHURNA	08-01-25	10:58	08-01-25	17:47	WORK AT PANDHURNA END	PO	220 KV
KALMESHWAR-PANDHURNA	08-01-25	11:24	08-01-25	17:47	For routine maintenance work	PO	220 KV
KALMESHWAR-PANDHURNA	08-01-25	10:58	08-01-25	17:47	1) Attending Damaged conductors of Yph and Bph of Bus Isolator by Hot line method by Hot line Unit,Nagpur. 2) Main Bus Isolator overhauling work		220 KV
KHAREPATAN -PAWAS LINE	08-01-25	9:06	08-01-25	17:58	For replacement of damaged insulator string if found and cold washing.	PO	220 KV
LAMBOTI - PANDHARPUR	08-01-25	10:26	08-01-25	19:32	Outage is required for String Replacement and Cold line cleaning	PO	220 KV

Transmission Line Outages/Trippings from 06.01.2025 to 12.01.2025							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MUDSHINGI- BELEWADI LINE	08-01-25	8:43	08-01-25	16:26	Insulator cleaning work	PO	220 KV
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	08-01-25	11:19	08-01-25	16:07	Outage is required for Quarterly Maintenance	PO	220 KV
URAN - APTA 2	08-01-25	16:00	08-01-25	17:10	Diagnostic Testing work(CT C & Tan delta and maintenance work)	PO	220 KV
100 MVA 220/132 KV ICT 2 @ NAGEWADI	08-01-25	11:09	08-01-25	15:05	DIAGNOSTIC TESTING OF ICT	PO	220 KV
220 KV BEED - MANJARSUMBHA	08-01-25	10:17	08-01-25	13:41	STRINGING WORK OF 132 KV SCDC LINE FROM 100 MW SOLAR PARK AT VILLAGE PANGADI OF CEMS JUNIPER TO 132 KV GHATANJI BETWEEN 136-137 OF EXISTING YAVATMAL RALEGAON LINE	PO	220 KV
220/132 KV 100 MVA ICT II @ SHAHADA	08-01-25	17:20	08-01-25	18:45	LOW OIL ALARTEM OF ICT	PO	220 KV
220/132 KV 100 MVA ICT 1 @ BUTIBORI	08-01-25	10:30	08-01-25	19:35	FOR REPLACEMENT OF HV Y PH FAULTY LA COUNTER	PO	220 KV
220/132 KV 200 MVA ICT 1 @ AMBAZARI	08-01-25	10:22	08-01-25	11:55	FOR ATTENDING HOT SPOT ON 220/132KV,200MVA, ICT 1, LV BUS 1 ISOLATOR B PH.	PO	220 KV
220/132 KV 200 MVA ICT 1 @ BEED	08-01-25	10:03	08-01-25	15:25	TO TOP UP OIL LEVELS AND QUARTERLY MAINTENANCE	PO	220 KV
220/33KV 50MVA PTR 2 @ MUMEWADI	08-01-25	7:00	09-01-25	18:21	TF OLTC overhauling work	PO	220 KV
220/33KV 100 MVA TF 2 @ VERSOVA (AEML)	08-01-25	9:43	09-01-25	13:45	1. Annual Maintenance of TR-2. 2. NGT Maintenance . 3. Attending Y phase bushing Oil leakages.	PO	220 KV
220kv Koradi-2 - Uppalwadi ckt 1	08-01-25	9:36	08-01-25	17:54	DAILY BASIS OUTAGE REQUIRED ON 220KV KORADI2- UWADI CKT 1 & 2 FOR SAFETY REASONS DUE TO CIVIL WORK FOR CONSTRUCTION AND HEIGHT RAISING OF DAMAGE POWER CABLE JOINT BOX JB 1 & JB2A AT 3X660 MW KTPS PREMISES	PO	220 KV
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	08-01-25	16:58	08-01-25	21:10	For tripping related testing work.	T	400 KV
400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	08-01-25	13:50	11-01-25	21:45	CB overhauling work will be attended by agency.	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	08-01-25	10:52	12-01-25	18:16	Diagnostic Testing of CTs ,CBs & Painting Work of R Y & B Ph Unit	PO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	08-01-25	11:31	08-01-25	19:22	H/T for load management.	HT	400 KV
BUS COUPLER @ PANDHARPUR	08-01-25	10:23	08-01-25	20:29	Outage is required for Quarterly Maintenance	PO	220 KV
DHARIWAL- CHANDRAPUR 2 CKT I	08-01-25	9:02			ATTENDING HOT SPOT IN R-PHASE OF LINE ISOLATOR CONNECTOR 171	PO	400 KV
JAIGAD - KARAD CKT - 2	08-01-25	21:48	09-01-25	8:57	overvoltage	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	08-01-25	21:48	09-01-25	9:10	overvoltage	HT	400 KV
MAIN BAY (406) OF 400KV-KORADI-II-KORADI-III-3 @ KORADI 3	08-01-25	9:43	08-01-25	17:54	Bay Outage	PO	400 KV
MAIN BAY (406) OF NANDED CKT - 1 @ CHANDRAPUR 2	08-01-25	14:15	08-01-25	18:17	Diagnostic testing & allied bay maintenance work	PO	400 KV
MAIN BUS - 1 @ AKOLA 2	08-01-25	13:04	08-01-25	20:18	Bus Outage	PO	400 KV
MAIN BUS - 1 @ AKOLA 2	08-01-25	13:04	08-01-25	20:18	BUS OUTAGE	PO	765 KV
MAIN BUS - 2 @ GHODBUNDER	08-01-25	9:28	08-01-25	18:22	1. Annual Maintenance of AIS Bus-2 2.Tan delta test of R-Y-B IVTs .	PO	220 KV
MIDC BUTIBORI -VIPL LINE-2	08-01-25	10:49	08-01-25	15:54	FOR DIAGONISTIC TESTING WORK	PO	220 KV
PARAS-BALAPUR IV	08-01-25	9:20	08-01-25	13:00	REPLACEMENT OF Y PHASE LA DUE TO HIGHER LCM AND LOWER IR VALUES AT 220 KV BALAPUR SUBSTATION.	PO	220 KV
PARLI-SOLAPUR (LAMBOTI)	08-01-25	13:23	08-01-25	18:56	Hardware tightening and cold line washing	PO	400 KV
SALSETTE BORIVLI - 1	08-01-25	9:15	08-01-25	9:48	Hanging rope removal from Gantry	PO	220 KV
TBC @ VERSOVA (AEML)	08-01-25	9:44	09-01-25	13:45	Safety purpose during annual maintenance of Bay-07 i.e.100MVA Transformer-2	PO	220 KV
TIE BAY (429) OF ICT - 1 @ KORADI - 2	08-01-25	10:38	08-01-25	12:21	DURING CHARGING OF ICT 1 TIE BAY429 , BREAKER TRIPPED ON PDR. AFTER INVESTIGATION R PHASE CLOSING COIL WIRE FOUND OPEN	T	400 KV
TOPWORTH - TIMBER MARKET	08-01-25	9:37	08-01-25	18:20	Tripped on distance protection from Timber market only	T	220 KV

Transmission Line Outages/Trippings from 06.01.2025 to 12.01.2025							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
TOPWORTH - Vile - bhagad	08-01-25	9:37	08-01-25	11:07	Tripped on distance protection from Villebagad only.	T	220 KV
URAN - APTA CKT - 1	08-01-25	11:00	08-01-25	14:00	1) Diagnostic Testing (CT C & Tan delta work) 2) R & M Work.	PO	220 KV
AMBAZARI-ABHIJEET	09-01-25	14:00	09-01-25	15:52	FOR CT TAND DELTA MEASUREMENT.	PO	220 KV
BABHALESHWAR - PADGHE CKT- 1	09-01-25	0:00	09-01-25	4:07	Replacement of flshovered disc Insulator string at location 55 Y phase observed in monkey patrolling.	EO	400 KV
JEJURI (400 KV)-JEJURI- II	09-01-25	14:58	09-01-25	18:28	For testing and maintenance work	PO	220 KV
JEJURI (400KV) - BARAMATI CKT	09-01-25	10:20	09-01-25	13:30	Relay testing work	PO	220 KV
KANDALGAON - KOYNA (POPHALI)	09-01-25	12:35	09-01-25	18:30	For cold washing of insulator strings, replacement of rusted hardware, outage tree cutting work and other line maintenance work.	PO	220 KV
KANDALGAON - PIRANGUT	09-01-25	10:12	09-01-25	12:13	Replacement of Damaged jumper between Y-ph CT and line isolator work to be carried out	PO	220 KV
NARSI - DEGLOOR	09-01-25	10:01	09-01-25	11:10	TRIPPED AT NARSI END DUE TO WHICH 132 KV NARSI SSN WENT INTO DARK.	T	132 KV
TALANDGE - SAWANTWADI	09-01-25	10:02	09-01-25	18:06	Insulator cleaning work	PO	220 KV
WAGHALA (NANDED2) - NARSI	09-01-25	10:01	09-01-25	11:10	Distance protection	T	132 KV
132KV NARSI (132KV)- KUNDALWADI(132KV) CKT	09-01-25	10:01	09-01-25	11:10	TRIPPED AT NARSI END DUE TO WHICH 132 KV NARSI SSN WENT INTO DARK.	T	132 KV
220 KV BALAPUR - MALKAPUR LINE	09-01-25	8:01	09-01-25	13:09	FOR MEASUREMENT OF TAN DELTA VALUE OF CC & CT.	PO	220 KV
220/33-33 KV 100 MVA PTR 2 @ BOISAR-II	09-01-25	18:50	10-01-25	20:40	Replacement of R,Y,B ph CT of TBC. (TBC element not in OMS hence PTR selected).	PO	220 KV
220KV TBC BAY	09-01-25	14:00	09-01-25	14:48	FOR MEASUREMENT OF TAN DELTA VALUE OF CT.	PO	220 KV
400/11.5KV STATION TRANSFORMER - 1 @ TIRORA	09-01-25	10:40	10-01-25	18:45	Annual Maintenance	PO	400 KV
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	09-01-25	21:31	10-01-25	5:50	To attend the Hotspot on 1) 220kV side B ph CT stud clamp (107 deg. C) 2) 220kV side B ph CT stud clamp D-isolator side (96 deg.C) 3) 220kV side R ph, T conductor between A & B isolator. (159 deg.C) 4) 400kV side R ph B bus PGI strip Rod (91 deg.C) 5) 400kV side Y ph B bus PGI strip Rod (86 deg.C)	EO	400 KV
400/220/33 KV 500 MVA ICT - 1 @ NANDED	09-01-25	10:50	09-01-25	18:50	Diagnostic testing & maintenance work	PO	400 KV
JAIGAD - KARAD CKT - 2	09-01-25	22:53	10-01-25	10:14	For voltage management	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	09-01-25	20:58	10-01-25	8:35	HT for voltage management	HT	400 KV
KHOPOLI - KARANJADE	09-01-25	17:50	09-01-25	20:29	Guard wire replacement in span 181-182	EO	110 KV
LONIKAND I - KOYNA STAGE-IV	09-01-25	11:35	09-01-25	18:41	INSULATOR REPLACEMENT WORK AGAINST SCHEME & COLD LINE WASHING WORK	PO	400 KV
MAIN BUS - 2 @ GHODBUNDER	09-01-25	9:05	09-01-25	16:30	1. Annual Maintenance of AIS Bus-2 2.Tan delta test of R-Y-B IVTs .	PO	220 KV
PT - 2 @ TALOJA	09-01-25	10:37	09-01-25	22:38	Replacement of Old PT Set due to ageing with New CVT set .	PO	220 KV
Pole-2 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	09-01-25	13:17	09-01-25	18:58	To attend Unbalance Level 2 alarm Rph	EO	500 KV
SALSETTE BORIVLI - 2	09-01-25	1:08	09-01-25	6:32	THIRD PARTY WORK IN VICINITY	PO	220 KV
STATION TF-3 @ KORADI 2	09-01-25	10:51	10-01-25	18:32	Installation, Testing & comissioning of dedicated metering CT & IVT	PO	400 KV
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	09-01-25	23:02	10-01-25	6:38	METRO WORK IN VICINITY	PO	220 KV
WALCHANDNAGAR-LONI DEOKAR	09-01-25	11:22	09-01-25	17:42	Cold line washing of insulator string	PO	220 KV
ABHIJEET-WARDHA-II	10-01-25	16:37	10-01-25	17:44	DUE TO LIZARD FAULT AS OBSERVED IN PANEL.	T	220 KV
AMBAZARI-ABHIJEET	10-01-25	16:37	10-01-25	17:44	DUE TO LIZARD FAULT AS OBSERVED IN PANEL.	T	220 KV
DASTURI-KANDALGAON LINE	10-01-25	15:30	10-01-25	19:45	For cold washing of insulator string and other line maintenance work.	PO	220 KV
GHATGHAR - BAPGAON	10-01-25	9:51	10-01-25	18:40	For Replacement of flashover Insulator string at loc no.302,262,295,294.	PO	220 KV
KALWA - COLOURCHEM	10-01-25	15:40	10-01-25	20:24	Tripped on distance protection.	T	220 KV
LOTEPARSHURAM- DASTURI LINE	10-01-25	11:04	10-01-25	15:11	For cold washing of insulator string , Outage tree cutting and other line maintenance work.	PO	220 KV
TALANDGE - SAWANTWADI	10-01-25	8:57	10-01-25	17:18	Insulator cleaning work	PO	220 KV
132 KV CHITEGAON - PAITHAN CKT	10-01-25	10:13	10-01-25	17:50	FOR CT TAN DELTA & CB OVERHAULING.	PO	220 KV

Transmission Line Outages/Trippings from 06.01.2025 to 12.01.2025							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV PARAS - MALKAPUR CKT	10-01-25	8:02	10-01-25	11:55	FOR MEASUREMENT OF TAN DELTA VALUE OF CC & CT.	PO	220 KV
220/100 KV 200 MVA ICT 2 @ KALWA	10-01-25	10:24	10-01-25	18:09	Diagnostic testing, and R&M work	PO	220 KV
220/132KV 200MVA ICT 6 @ EKLAHARE (GCR)	10-01-25	13:40	10-01-25	15:13	5 Nature of work to be carried out Whether included in quarterly/six monthly outage proposal 1) LV side Isolator alignment , jaw replacement	PO	220 KV
220/33KV 50MVA TF NO.1 @ SAYNE	10-01-25	11:03	10-01-25	15:28	Emergency outage as testing team available For diagnostic testing work such as CT C-Tan Delta, CB Timing CB CRM, Winding, Bushing C-Tan Delta, IR & PI measurement etc	EO	220 KV
220KV BUS SECTION BAY @ MALKAPUR	10-01-25	12:04	10-01-25	13:45	FOR MEASUREMENT OF TAN DELTA VALUE OF CT.	PO	220 KV
400/220 KV 500 MVA ICT - 5 @ PADGHE	10-01-25	13:02	10-01-25	16:58	1) For excavation of Gantry foundation and equipment foundation of new ICT -6 below ICT -5 interconnecting line . 2) In case of any emergency ICT -5 will be taken in service within 5min 3) As per instruction of Hon'ble DOP ICT -6 to be commission before 15Feb -25	PO	400 KV
AAREY - MSETCL BORIVALI CKT - 2	10-01-25	9:31			Annual Maintenance of Bay and all equipments	PO	220 KV
BUS REACTOR (50 MVAR) @ KORADI	10-01-25	10:30	10-01-25	18:03	SFRA / DFRA / BREAKER TESTING (CB CRM, DCRM, TIMING)	PO	400 KV
DHULE - SSNNL CKT - 1	10-01-25	8:11	10-01-25	18:54	CVT Testing work by M/s. ERDA Vadodara	PO	400 KV
JAIGAD - KARAD CKT - 2	10-01-25	23:37	11-01-25	9:19	For voltage management	HT	400 KV
KARAD - OGALEWADI CKT 1	10-01-25	10:47	10-01-25	15:23	Diagnostic Testing Work & Quarterly Maintenance Work	PO	220 KV
KUDUS - KALA CKT - 1	10-01-25	11:39	10-01-25	21:50	Construction of 400kV Bay Extension works(New Navsari 1 &2) are under progress at kala ss. The working area for GIB erection works is very near toSF6 Air bushings and CVT/LA drooper of kala-kudus 1 line and comes under induction zone area	PO	400 KV
LONIDEOKAR TAP ON WALCHANDNAGAR-BHIGWAN CKT	10-01-25	11:45	10-01-25	22:25	Cold line washing of Insulator String	PO	220 KV
LONIKAND I - KOYNA STAGE-IV	10-01-25	12:47	10-01-25	19:25	INSULATOR REPLACEMENT WORK AGAINST SCHEME & COLD LINE WASHING WORK	PO	400 KV
MAHAPE - STT GLOBAL GIS	10-01-25	7:21	10-01-25	13:14	For Replacement of 220kV Bus PT Set.(R & B Ph PT).	PO	220 KV
MAIN BUS - 2 @ AKOLA 2	10-01-25	11:35	10-01-25	19:35	Bay Outage	PO	400 KV
MAIN BUS PT @ MAHAPE	10-01-25	7:31	10-01-25	13:14	Replacement of 220kV Bus PT Set.(R & B Ph PT).	PO	220 KV
MAIN BUS SECTION-2 @ MAHAPE	10-01-25	7:31	10-01-25	13:14	For Replacement of 220kV Bus PT Set.(R & B Ph PT).	PO	220 KV
SALSETTE BORIVLI - 2	10-01-25	23:30	11-01-25	5:58	THIRD PARTY WORK IN VICINITY	PO	220 KV
TBC @ MAHAPE	10-01-25	7:31	10-01-25	13:14	For Replacement of 220kV Bus PT Set.(R & B Ph PT).	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 4	10-01-25	23:07	10-01-25	8:01	METRO WORK IN VICINITY	PO	220 KV
TROMBAY DHARAVI - 6	10-01-25	17:35	10-01-25	18:54	REMOVING HANGING OBJECT	EO	220 KV
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	10-01-25	11:45	10-01-25	12:49	For SF6 purity sensor installation	PO	220 KV
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	10-01-25	13:14	10-01-25	15:32	For SF6 purity sensor installation	PO	220 KV
ALEPHATA-PARGAON(KATHAPUR)	11-01-25	11:02	11-01-25	18:48	Load management	HT	220 KV
HINJAWADI I- CHINCHWAD	11-01-25	8:55	11-01-25	21:11	Load management.	HT	220 KV
KHARGHAR - SONKHAR	11-01-25	20:09	11-01-25	23:02	R-Ph LA Replacement work due to High LCM Value	PO	220 KV
TILLARI - AMONA LINE	11-01-25	10:18	11-01-25	18:17	Replacement of old polymer insulator	PO	220 KV
200 MVA 220/132 KV ICT - III @ CHALISGAON	11-01-25	11:26	11-01-25	12:05	Remove excess oil from OLTC conservator tank.	HT	220 KV
220/132 KV 150 MVA ICT-2 @BHENDA	11-01-25	11:06	11-01-25	14:10	For Quarterly Maintenance and Oil topup work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	11-01-25	10:52	11-01-25	19:30	Replacement of defective R phase HV bus to isolator jump by HOT line maintenance unit	EO	220 KV
220/132-110 KV 100MVA ICT 2 @ JATH	11-01-25	16:54	11-01-25	18:02	Re-Fitting & Maintenance of OTI Meter in order to avoid ICT Tripping	EO	220 KV
400/220/33 KV 315MVA ICT - 3 @ KHADKA	11-01-25	9:37	11-01-25	18:06	for Diagnostic testing work such as Bushing ,CT -Tan delta & Relay testing work	PO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	11-01-25	13:17	11-01-25	15:52	Load Management	HT	400 KV

Transmission Line Outages/Trippings from 06.01.2025 to 12.01.2025							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BORIVALI - BOISAR (PG)	11-01-25	6:05	11-01-25	12:07	Shifting of 220KV-BOISAR-BORIVALI-1 and 220KV-TARAPUR 3&4-BOISAR-1 on ERS tower (8 no.s) for erection of tower and stringing between 4 no.s of inline lattice tower	PO	220 KV
DHULE - SSNNL CKT - 2	11-01-25	8:38	11-01-25	17:46	CVT Testing work by M/s. ERDA Vadodara	PO	400 KV
GIS BUS - 1 @ WAGHIVALI	11-01-25	11:18	11-01-25	12:16	For SF6 purity sensor installation	PO	220 KV
GIS BUS - 2 @ WAGHIVALI	11-01-25	12:45	11-01-25	15:49	For SF6 purity sensor installation	PO	220 KV
KHADKA-AURANGABAD (WALUJ)	11-01-25	0:41	11-01-25	9:05	for voltage management	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	11-01-25	23:32	12-01-25	10:13	Over voltage.	HT	400 KV
KHARGHAR - TALEGAON (PG)	11-01-25	12:49	11-01-25	15:09	Distance Protection	T	400 KV
KHOPOLI - KARANJADE	11-01-25	10:28	11-01-25	17:46	ATTENDING LINE SIDE GOD	EO	110 KV
KOLSHET - KHARBAO	11-01-25	22:54	12-01-25	5:49	for safety purpose for erection of Monopole at loc no. 134 for Shifting/Height rising work of 220KV D/C Kolshet-Kamba-Wada Transmission Line for MMRDA.	PO	220 KV
LONIKAND I - KOYNA STAGE-IV	11-01-25	15:56	11-01-25	19:13	INSULATOR REPLACEMENT WORK AGAINST SCHEME & COLD LINE WASHING WORK	PO	400 KV
NEW KOYNA - POPHALI	11-01-25	12:19	11-01-25	19:06	Routine maint. Work	PO	220 KV
SAKI - SAHAR	11-01-25	0:53	11-01-25	5:03	Protection testing	PO	220 KV
TIFIL - NEXTRA GIS	11-01-25	10:23	11-01-25	14:15	For chemical cleaning of disc insulator strings at TL No. 6 to 11.	PO	220 KV
TIFIL - STT GLOBAL GIS	11-01-25	15:44	11-01-25	17:32	For chemical cleaning of disc insulator strings at TL No. 6 to 11.	PO	220 KV
220KV TATA Motors bay 1 (EHV Consumer Bay) TELCO-220 KV	12-01-25	7:29	12-01-25	14:43	Mainteanance work	EO	220 KV
BORIVALI - TARAPUR	12-01-25	6:22	13-01-25	2:20	For stringing of conductor in the span between loc no.207A to 208 and between loc no.210 to 211.	PO	220 KV
EKLAHARE (GCR) - AIROLI KNOW PARK	12-01-25	17:30	12-01-25	18:10	Distance Protection	T	220 KV
HINJAWADI I- CHINCHWAD	12-01-25	10:30	12-01-25	19:46	Load management.	HT	220 KV
KALWA - COLOURCHEM	12-01-25	15:47	12-01-25	16:38	Distance Protection	T	220 KV
URSE - TALEGAON (AMBI) CKT 1	12-01-25	12:27	12-01-25	18:11	For Chemical washing of insulator strings.	PO	220 KV
220/110 KV 250 MVA ICT - 1@VIKHROLI GIS	12-01-25	10:36	12-01-25	15:32	PROJECT WORK -CABLE LAYING WORK IN VICINITY	PO	220 KV
400/220KV 105 MVA SPARE ICT @ KHADKA	12-01-25	11:32			E/O required on 400/220KV,105MVA Spare ICT for Safety clearance purpose. The 400/132KV,200MVA ICT-2 dismantled for repairing purpose & winching is in progress which cross the spare ICT bay. Hence E/O required on 400/220KV,105MVA Spare ICT as sefty precaution for loading dismanteled ICT 2.	EO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	12-01-25	16:18	12-01-25	19:19	Distance Protection	T	400 KV
BORIVALI - BOISAR (PG)	12-01-25	6:15	13-01-25	2:52	For stringing of conductor in the span between loc no.207A to 208 and between loc no.210 to 211.	PO	220 KV
JAIGAD - KARAD CKT - 1	12-01-25	23:12	13-01-25	9:40	H/T for voltage management.	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	12-01-25	21:14	13-01-25	9:03	Overvoltage	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	12-01-25	21:14			Over voltage.	HT	400 KV
STATION TF 8B @ CHANDRAPUR SWITCHING	12-01-25	6:14	12-01-25	8:19	OBA board flashover at GENCO end.	T	400 KV
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	12-01-25	6:14	12-01-25	15:49	OBA board flashover at GENCO end.	T	400 KV
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	12-01-25	0:14	12-01-25	9:52	Taking Main 2 Differential relay in service	PO	220 KV