

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 06/Feb/2017 to 12/Feb/2017**

**Supply Position During Morning Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR      | TPCL Exch.  | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|------------|-------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |            |             |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW         | MW          | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 06/02/2017     | 12 Hrs | 5813        | 1126        | 308        | 7247        | 7700                   | 24         | 3110        | 187        | -860        | 17639                 | 0                  | 17639                    | 1241        | 503          | 20243            | 20243                   | 49.95        |
| 07/02/2017     | 9 Hrs  | 6213        | 1539        | 322        | 8074        | 7265                   | 182        | 3129        | 61         | -413        | 18529                 | 0                  | 18529                    | 1163        | 510          | 20615            | 20615                   | 49.96        |
| 08/02/2017     | 12 Hrs | 5708        | 1650        | 447        | 7805        | 7729                   | 70         | 3128        | 176        | -805        | 18103                 | 0                  | 18103                    | 1358        | 502          | 20768            | 20768                   | 49.97        |
| 09/02/2017     | 12 Hrs | 5733        | 1904        | 451        | 8088        | 7646                   | 50         | 2993        | 173        | -818        | 18132                 | 0                  | 18132                    | 1314        | 507          | 20771            | 20771                   | 49.99        |
| 10/02/2017     | 12 Hrs | 5472        | 1409        | 432        | 7313        | 8212                   | 131        | 3037        | 165        | -855        | 18003                 | 0                  | 18003                    | 1330        | 508          | 20696            | 20696                   | 49.97        |
| 11/02/2017     | 12 Hrs | 6229        | 1009        | 460        | 7698        | 7819                   | 43         | 3053        | 180        | -769        | 18024                 | 0                  | 18024                    | 1203        | 507          | 20503            | 20503                   | 50.02        |
| 12/02/2017     | 12 Hrs | 6118        | 1114        | 452        | 7684        | 7347                   | 77         | 3056        | 182        | -602        | 17744                 | 0                  | 17744                    | 885         | 505          | 19736            | 19736                   | 49.97        |
| <b>Maximum</b> |        | <b>6229</b> | <b>1904</b> | <b>460</b> | <b>8088</b> | <b>8212</b>            | <b>182</b> | <b>3129</b> | <b>187</b> | <b>-413</b> | <b>18529</b>          | <b>0</b>           | <b>18529</b>             | <b>1358</b> | <b>510</b>   | <b>20771</b>     | <b>20771</b>            | <b>50.02</b> |
| <b>Minimum</b> |        | <b>5472</b> | <b>1009</b> | <b>308</b> | <b>7247</b> | <b>7265</b>            | <b>24</b>  | <b>2993</b> | <b>61</b>  | <b>-860</b> | <b>17639</b>          | <b>0</b>           | <b>17639</b>             | <b>885</b>  | <b>502</b>   | <b>19736</b>     | <b>19736</b>            | <b>49.95</b> |
| <b>Average</b> |        | <b>5898</b> | <b>1393</b> | <b>410</b> | <b>7701</b> | <b>7674</b>            | <b>82</b>  | <b>3072</b> | <b>161</b> | <b>-732</b> | <b>18025</b>          | <b>0</b>           | <b>18025</b>             | <b>1213</b> | <b>506</b>   | <b>20476</b>     | <b>20476</b>            | <b>49.98</b> |

**Supply Position During Day Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR      | TPCL Exch.  | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|------------|-------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |            |             |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW         | MW          | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 06/02/2017     | 13 Hrs | 5838        | 1026        | 295        | 7159        | 7937                   | 28         | 3077        | 196        | -891        | 17737                 | 0                  | 17737                    | 1164        | 508          | 20300            | 20300                   | 49.99        |
| 07/02/2017     | 15 Hrs | 5510        | 1573        | 304        | 7387        | 7497                   | 26         | 3089        | 165        | -729        | 17667                 | 0                  | 17667                    | 1212        | 509          | 20117            | 20117                   | 49.92        |
| 08/02/2017     | 13 Hrs | 5701        | 1599        | 429        | 7729        | 7591                   | 48         | 3068        | 180        | -738        | 17878                 | 0                  | 17878                    | 1356        | 508          | 20480            | 20480                   | 49.95        |
| 09/02/2017     | 13 Hrs | 5775        | 1912        | 422        | 8109        | 7696                   | 20         | 3003        | 185        | -781        | 18232                 | 0                  | 18232                    | 1315        | 508          | 20836            | 20836                   | 49.97        |
| 10/02/2017     | 14 Hrs | 5388        | 1480        | 423        | 7291        | 7982                   | 109        | 3005        | 163        | -839        | 17711                 | 0                  | 17711                    | 1179        | 510          | 20239            | 20239                   | 50.03        |
| 11/02/2017     | 13 Hrs | 6248        | 863         | 430        | 7541        | 7607                   | 83         | 3051        | 182        | -707        | 17757                 | 0                  | 17757                    | 1203        | 507          | 20174            | 20174                   | 50.00        |
| 12/02/2017     | 13 Hrs | 6101        | 1043        | 426        | 7570        | 7402                   | 81         | 3046        | 182        | -545        | 17736                 | 0                  | 17736                    | 884         | 509          | 19674            | 19674                   | 50.00        |
| <b>Maximum</b> |        | <b>6248</b> | <b>1912</b> | <b>430</b> | <b>8109</b> | <b>7982</b>            | <b>109</b> | <b>3089</b> | <b>196</b> | <b>-545</b> | <b>18232</b>          | <b>0</b>           | <b>18232</b>             | <b>1356</b> | <b>510</b>   | <b>20836</b>     | <b>20836</b>            | <b>50.03</b> |
| <b>Minimum</b> |        | <b>5388</b> | <b>863</b>  | <b>295</b> | <b>7159</b> | <b>7402</b>            | <b>20</b>  | <b>3003</b> | <b>163</b> | <b>-891</b> | <b>17667</b>          | <b>0</b>           | <b>17667</b>             | <b>884</b>  | <b>507</b>   | <b>19674</b>     | <b>19674</b>            | <b>49.92</b> |
| <b>Average</b> |        | <b>5794</b> | <b>1357</b> | <b>390</b> | <b>7541</b> | <b>7673</b>            | <b>56</b>  | <b>3048</b> | <b>179</b> | <b>-747</b> | <b>17817</b>          | <b>0</b>           | <b>17817</b>             | <b>1188</b> | <b>508</b>   | <b>20260</b>     | <b>20260</b>            | <b>49.98</b> |

## Supply Position During Evening Peak (MW)

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |            |             |          |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW         | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 06/02/2017     | 19 Hrs | 5636        | 613        | 325        | 6574        | 6711                   | 185        | 3008        | 1        | -938         | 15541                 | 0                  | 15541                    | 1032        | 386          | 17897            | 17897                   | 49.94        |
| 07/02/2017     | 19 Hrs | 5468        | 778        | 298        | 6544        | 6857                   | 143        | 3109        | 0        | -964         | 15689                 | 0                  | 15689                    | 1058        | 418          | 18129            | 18129                   | 49.92        |
| 08/02/2017     | 20 Hrs | 5206        | 941        | 447        | 6594        | 6710                   | 304        | 3052        | 0        | -1087        | 15573                 | 0                  | 15573                    | 955         | 451          | 18066            | 18066                   | 49.98        |
| 09/02/2017     | 19 Hrs | 5557        | 846        | 448        | 6851        | 6979                   | 123        | 3042        | 0        | -918         | 16077                 | 0                  | 16077                    | 1062        | 511          | 18568            | 18568                   | 49.96        |
| 10/02/2017     | 19 Hrs | 5810        | 321        | 442        | 6573        | 6580                   | 186        | 3053        | 0        | -1035        | 15357                 | 0                  | 15357                    | 1040        | 386          | 17818            | 17818                   | 50.02        |
| 11/02/2017     | 19 Hrs | 5810        | 316        | 452        | 6578        | 6500                   | 507        | 3029        | 1        | -1027        | 15588                 | 0                  | 15588                    | 849         | 386          | 17850            | 17850                   | 50.00        |
| 12/02/2017     | 19 Hrs | 5628        | 423        | 450        | 6501        | 6235                   | 130        | 2948        | 0        | -792         | 15022                 | 0                  | 15022                    | 683         | 387          | 16884            | 16884                   | 49.99        |
| <b>Maximum</b> |        | <b>5810</b> | <b>941</b> | <b>452</b> | <b>6851</b> | <b>6979</b>            | <b>507</b> | <b>3109</b> | <b>1</b> | <b>-792</b>  | <b>16077</b>          | <b>0</b>           | <b>16077</b>             | <b>1062</b> | <b>511</b>   | <b>18568</b>     | <b>18568</b>            | <b>50.02</b> |
| <b>Minimum</b> |        | <b>5206</b> | <b>316</b> | <b>298</b> | <b>6501</b> | <b>6235</b>            | <b>123</b> | <b>2948</b> | <b>0</b> | <b>-1087</b> | <b>15022</b>          | <b>0</b>           | <b>15022</b>             | <b>683</b>  | <b>386</b>   | <b>16884</b>     | <b>16884</b>            | <b>49.92</b> |
| <b>Average</b> |        | <b>5588</b> | <b>605</b> | <b>409</b> | <b>6602</b> | <b>6653</b>            | <b>225</b> | <b>3034</b> | <b>0</b> | <b>-966</b>  | <b>15550</b>          | <b>0</b>           | <b>15550</b>             | <b>954</b>  | <b>418</b>   | <b>17887</b>     | <b>17887</b>            | <b>49.97</b> |

## Supply Position During Night Off Peak (MW)

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR    | TPCL Exch.  | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.  | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|------------|-------------|----------|-------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |            |             |          |             |                       |                    |                          |            |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW         | MW          | MW       | MW          | MW                    | MW                 | MW                       | MW         | MW           | MW               | MW                      | Hzs          |
| 06/02/2017     | 4 Hrs  | 4788        | 126        | 324        | 5238        | 5476                   | 528        | 2827        | 0        | -280        | 13789                 | 0                  | 13789                    | 678        | 387          | 15134            | 15134                   | 49.97        |
| 07/02/2017     | 3 Hrs  | 5300        | 174        | 326        | 5800        | 5342                   | 273        | 2849        | 0        | -278        | 13986                 | 0                  | 13986                    | 697        | 387          | 15348            | 15348                   | 49.97        |
| 08/02/2017     | 4 Hrs  | 5278        | 138        | 479        | 5895        | 5488                   | 153        | 3101        | 0        | -333        | 14304                 | 0                  | 14304                    | 631        | 387          | 15655            | 15655                   | 49.99        |
| 09/02/2017     | 3 Hrs  | 5344        | 133        | 467        | 5944        | 5784                   | 149        | 2978        | 0        | -409        | 14446                 | 0                  | 14446                    | 632        | 388          | 15875            | 15875                   | 49.98        |
| 10/02/2017     | 23 Hrs | 5024        | 296        | 458        | 5778        | 6031                   | 190        | 2786        | 0        | -942        | 13843                 | 0                  | 13843                    | 698        | 386          | 15869            | 15869                   | 50.02        |
| 11/02/2017     | 3 Hrs  | 5011        | 138        | 464        | 5613        | 5954                   | 164        | 2843        | 0        | -443        | 14131                 | 0                  | 14131                    | 630        | 387          | 15591            | 15591                   | 50.02        |
| 12/02/2017     | 23 Hrs | 4914        | 136        | 464        | 5514        | 5537                   | 422        | 2791        | 0        | -854        | 13410                 | 0                  | 13410                    | 635        | 388          | 15287            | 15287                   | 50.05        |
| <b>Maximum</b> |        | <b>5344</b> | <b>296</b> | <b>479</b> | <b>5944</b> | <b>6031</b>            | <b>528</b> | <b>3101</b> | <b>0</b> | <b>-278</b> | <b>14446</b>          | <b>0</b>           | <b>14446</b>             | <b>698</b> | <b>388</b>   | <b>15875</b>     | <b>15875</b>            | <b>50.05</b> |
| <b>Minimum</b> |        | <b>4788</b> | <b>126</b> | <b>324</b> | <b>5238</b> | <b>5342</b>            | <b>149</b> | <b>2786</b> | <b>0</b> | <b>-942</b> | <b>13410</b>          | <b>0</b>           | <b>13410</b>             | <b>630</b> | <b>386</b>   | <b>15134</b>     | <b>15134</b>            | <b>49.97</b> |
| <b>Average</b> |        | <b>5094</b> | <b>163</b> | <b>426</b> | <b>5683</b> | <b>5659</b>            | <b>268</b> | <b>2882</b> | <b>0</b> | <b>-506</b> | <b>13987</b>          | <b>0</b>           | <b>13987</b>             | <b>657</b> | <b>387</b>   | <b>15537</b>     | <b>15537</b>            | <b>50.00</b> |

## Details of Supply Position (MUs)

| Date           | MSGENCO        |               |               |                | Pench (MS)   | Central Sector Receipt | Central Sector Share | WIND           | CPP           | SOLAR        | TPCL Gen.     | R-INFRA Gen.  | TPCL Exch.     | Energy Requirement |               |                |
|----------------|----------------|---------------|---------------|----------------|--------------|------------------------|----------------------|----------------|---------------|--------------|---------------|---------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS           | Total          |              |                        |                      |                |               |              |               |               |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus           | Mus            | Mus          | Mus                    | Mus                  | Mus            | Mus           | Mus          | Mus           | Mus           | Mus            | Mus                | Mus           | Mus            |
| 06/02/2017     | 132.982        | 14.182        | 7.555         | 154.719        | 0.414        | 160.931                | 158.641              | 4.758          | 71.556        | 1.362        | 22.600        | 10.587        | -16.334        | 379.657            | 49.521        | 429.178        |
| 07/02/2017     | 133.716        | 20.241        | 7.568         | 161.525        | 0.621        | 158.091                | 155.935              | 3.335          | 73.130        | 1.314        | 23.103        | 10.967        | -15.534        | 384.488            | 49.604        | 434.092        |
| 08/02/2017     | 132.389        | 23.584        | 10.735        | 166.708        | 0.353        | 158.544                | 157.316              | 3.845          | 73.725        | 1.258        | 23.243        | 11.289        | -16.388        | 387.694            | 50.920        | 438.614        |
| 09/02/2017     | 133.292        | 20.479        | 10.816        | 164.587        | 0.488        | 164.762                | 163.556              | 3.145          | 72.339        | 1.208        | 22.963        | 11.100        | -17.020        | 389.022            | 51.084        | 440.106        |
| 10/02/2017     | 130.240        | 16.360        | 10.746        | 157.346        | 0.438        | 166.475                | 165.869              | 4.266          | 71.737        | 1.141        | 22.795        | 10.699        | -17.866        | 382.661            | 51.358        | 434.019        |
| 11/02/2017     | 136.904        | 11.043        | 10.957        | 158.904        | 0.367        | 161.899                | 160.889              | 6.126          | 71.306        | 1.188        | 21.239        | 10.437        | -16.434        | 382.989            | 48.110        | 431.099        |
| 12/02/2017     | 135.297        | 11.527        | 10.918        | 157.742        | 0.285        | 153.360                | 152.510              | 3.648          | 71.787        | 1.241        | 18.025        | 10.646        | -13.139        | 374.639            | 41.810        | 416.449        |
| <b>Maximum</b> | <b>136.904</b> | <b>23.584</b> | <b>10.957</b> | <b>166.708</b> | <b>0.621</b> | <b>166.475</b>         | <b>165.869</b>       | <b>136.904</b> | <b>73.725</b> | <b>1.362</b> | <b>23.243</b> | <b>11.289</b> | <b>-13.139</b> | <b>389.022</b>     | <b>51.358</b> | <b>440.106</b> |
| <b>Minimum</b> | <b>130.240</b> | <b>11.043</b> | <b>7.555</b>  | <b>154.719</b> | <b>0.285</b> | <b>153.360</b>         | <b>152.510</b>       | <b>130.240</b> | <b>71.306</b> | <b>1.141</b> | <b>18.025</b> | <b>10.437</b> | <b>-17.866</b> | <b>374.639</b>     | <b>41.810</b> | <b>416.449</b> |
| <b>Average</b> | <b>133.546</b> | <b>16.774</b> | <b>9.899</b>  | <b>160.219</b> | <b>0.424</b> | <b>160.580</b>         | <b>159.245</b>       | <b>133.546</b> | <b>72.226</b> | <b>1.245</b> | <b>21.995</b> | <b>10.818</b> | <b>-16.102</b> | <b>383.021</b>     | <b>48.915</b> | <b>431.937</b> |

## Details of Koyna Water Consumption (in TMC)

---

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 06/02/2017 | 0.189       | 1.200         | 21.960  |
| 07/02/2017 | 0.326       | 1.526         | 21.634  |
| 08/02/2017 | 0.400       | 1.926         | 21.234  |
| 09/02/2017 | 0.330       | 2.256         | 20.904  |
| 10/02/2017 | 0.256       | 2.512         | 20.648  |
| 11/02/2017 | 0.140       | 2.652         | 20.508  |
| 12/02/2017 | 0.143       | 2.795         | 20.365  |

**State Load Despatch Center, Airoli (MSETCL)**  
**Central Sector Share/Drawal from 06/Feb/2017 to 12/Feb/2017**

| Date         | DAY      | Central Sector Share |         | Total Interstate Bilateral Purchase |         | Total Share     |         | Total Drawal    |         | Overdrawal(+) / UnderDrawal(-) |         |
|--------------|----------|----------------------|---------|-------------------------------------|---------|-----------------|---------|-----------------|---------|--------------------------------|---------|
|              |          | MUs                  | Avg. MW | MUs                                 | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW | MUs                            | Avg. MW |
|              |          | 1                    |         | 2                                   |         | 1+2=3           |         | 4               |         | 3-4=5                          |         |
| 06/02/2017   | MONDAY   | 120.823              | 6572    | 37.818                              | 1576    | 158.641         | 6610    | 160.931         | 6705    | 2.290                          | 95      |
| 07/02/2017   | TUESDAY  | 119.867              | 6461    | 36.068                              | 1503    | 155.935         | 6497    | 158.091         | 6587    | 2.156                          | 90      |
| 08/02/2017   | WEDNESDA | 121.488              | 6519    | 35.828                              | 1493    | 157.316         | 6555    | 158.544         | 6606    | 1.228                          | 51      |
| 09/02/2017   | THURSDAY | 124.609              | 6776    | 38.947                              | 1623    | 163.556         | 6815    | 164.762         | 6865    | 1.206                          | 50      |
| 10/02/2017   | FRIDAY   | 121.070              | 6866    | 44.799                              | 1867    | 165.869         | 6911    | 166.475         | 6936    | 0.606                          | 25      |
| 11/02/2017   | SATURDAY | 116.011              | 6659    | 44.878                              | 1870    | 160.889         | 6704    | 161.899         | 6746    | 1.010                          | 42      |
| 12/02/2017   | SUNDAY   | 109.339              | 6311    | 43.171                              | 1799    | 152.510         | 6355    | 153.360         | 6390    | 0.850                          | 35      |
| <b>Total</b> |          | <b>833.207</b>       |         | <b>281.509</b>                      |         | <b>1114.716</b> |         | <b>1124.062</b> |         | <b>9.346</b>                   |         |

| GENERATING UNITS OUTAGES FOR THE WEEK FROM 06/02/2017 TO 12/02/2017 |                    |          |              |              |             |            |                                                                                                                                                                  |
|---------------------------------------------------------------------|--------------------|----------|--------------|--------------|-------------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Generator                                                           | Generating Unit    | Capacity | Tripped Date | Tripped Time | Synch. Date | Synch Time | Reason                                                                                                                                                           |
| PLANNED OUTAGES                                                     |                    |          |              |              |             |            |                                                                                                                                                                  |
| IPP                                                                 | Tata Trombay 6     | 500MW    | 15/Jul/2015  | 17.08        |             | Continued. | Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)                                                                                         |
| MSPGCL                                                              | Paras Unit 3       | 250MW    | 25/Oct/2016  | 08.54        |             | Continued. | Stator Fault, continued under AOH.26/10/2016 00.00hrs                                                                                                            |
| MSPGCL                                                              | Chandrapur Unit 7  | 500MW    | 25/Jan/2017  | 19.32        |             | Continued. | Capital Overhaul                                                                                                                                                 |
| FORCED OUTAGES                                                      |                    |          |              |              |             |            |                                                                                                                                                                  |
| RGPL                                                                | Dabhol Dabhol 1B   | 230MW    | 28/May/2013  | 22.02        |             | Continued. | Gas Shortage.                                                                                                                                                    |
| RGPL                                                                | Dabhol Dabhol 1X   | 230MW    | 27/Jun/2013  | 21.46        |             | Continued. | Gas Shortage                                                                                                                                                     |
| RGPL                                                                | Dabhol Dabhol 1A   | 230MW    | 27/Jun/2013  | 21.47        |             | Continued. | Gas Shortage                                                                                                                                                     |
| IPP                                                                 | Dhariwal           | 300MW    | 28/May/2014  | 02.27        |             | Continued. | No schedule                                                                                                                                                      |
| MSPGCL                                                              | Koradi Unit 6      | 210MW    | 20/Mar/2015  | 01.02        |             | Continued. | EE R&M LE Work                                                                                                                                                   |
| MSPGCL                                                              | Parli Unit 4       | 210MW    | 01/Apr/2016  | 00.00        |             | Continued. | Economic shutdown                                                                                                                                                |
| MSPGCL                                                              | Parli Unit 5       | 210MW    | 01/Apr/2016  | 00.00        |             | Continued. | Economic shutdown                                                                                                                                                |
| IPP                                                                 | WPCL U-1           | 135MW    | 16/Feb/2016  | 17.09        |             | Continued. | Change Over , No Schedule                                                                                                                                        |
| IPP                                                                 | WPCL U-2           | 135MW    | 29/Feb/2016  | 21.46        |             | Continued. | Change over against Unit III                                                                                                                                     |
| MSPGCL                                                              | Bhusawal Unit 2    | 210MW    | 14/Jun/2016  | 19.35        |             | Continued. | Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)                                                                               |
| IPP                                                                 | RPL(AMT) U-3       | 270MW    | 29/Jun/2016  | 03.01        |             | Continued. | Zero Shedule By MSEDCL.                                                                                                                                          |
| MSPGCL                                                              | Uran Unit 8        | 108MW    | 14/Aug/2016  | 07.56        |             | Continued. | Maintenance work                                                                                                                                                 |
| RGPL                                                                | Dabhol 2A          | 230MW    | 24/Aug/2016  | 13.31        |             | Continued. | Change Over.                                                                                                                                                     |
| MSPGCL                                                              | Koradi Unit 5      | 200MW    | 05/Sep/2016  | 00.21        |             | Continued. | ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work |
| MSPGCL                                                              | Bhusawal Unit 3    | 210MW    | 16/Sep/2016  | 00.02        |             | Continued. | Zero Schedule by MSEDCL                                                                                                                                          |
| IPP                                                                 | Adani U-1          | 660MW    | 06/Nov/2016  | 11.10        |             | Continued. | Coal Shortage                                                                                                                                                    |
| IPP                                                                 | RPL(AMT) U-5       | 270MW    | 15/Nov/2016  | 20.00        |             | Continued. | Zero schedule                                                                                                                                                    |
| IPP                                                                 | RPL(AMT) U-2       | 270MW    | 16/Nov/2016  | 22.36        |             | Continued. | Zero Schedule By MSEDCL.                                                                                                                                         |
| IPP                                                                 | RPL(AMT) U-4       | 270MW    | 16/Nov/2016  | 21.03        |             | Continued. | Zero Schedule By MSEDCL.                                                                                                                                         |
| IPP                                                                 | JSW (J) U1         |          | 16/Nov/2016  | 14.38        |             | Continued. | Due To CW Duct Leakage.                                                                                                                                          |
| IPP                                                                 | RPL(AMT) U-1       | 270MW    | 17/Nov/2016  | 17.23        |             | Continued. | Zero Schedule.                                                                                                                                                   |
| MSPGCL                                                              | Parli Unit 8       | 250MW    | 18/Nov/2016  | 16.23        |             | Continued. | w/dn for balance work.                                                                                                                                           |
| IPP                                                                 | JSW (J) U2         | 300MW    | 01/Dec/2016  | 00.00        |             | Continued. | No Schedule.                                                                                                                                                     |
| IPP                                                                 | VIPL U-1           | 300MW    | 03/Jan/2017  | 00.45        |             | Continued. | Turbine bearing temprature high.                                                                                                                                 |
| MSPGCL                                                              | Uran Unit 5        | 108MW    | 26/Jan/2017  | 09.35        | 07/Feb/2017 | 10.07      | Gas shortage                                                                                                                                                     |
| MSPGCL                                                              | Koradi Unit-9      | 660MW    | 28/Jan/2017  | 23.08        | 06/Feb/2017 | 07.00      | Debrish Filter Jamming.                                                                                                                                          |
| IPP                                                                 | Adani U-4          | 660MW    | 31/Jan/2017  | 23.57        |             | Continued. | COAL PROBLEM.                                                                                                                                                    |
| MSPGCL                                                              | Nasik Unit 4       | 210MW    | 31/Jan/2017  | 02.55        |             | Continued. | WITHDRAW UNDER ZERO SCHEDULE.                                                                                                                                    |
| MSPGCL                                                              | Chandrapur Unit 6  | 500MW    | 03/Feb/2017  | 20.25        | 10/Feb/2017 | 23.21      | GTR Y Phase DGA Report poor.                                                                                                                                     |
| MSPGCL                                                              | Chandrapur Unit 8  | 500MW    | 05/Feb/2017  | 00.13        | 06/Feb/2017 | 16.29      | Boiler Tube Leakage                                                                                                                                              |
| IPP                                                                 | PGPL U2            | 126MW    | 05/Feb/2017  | 17.15        | 06/Feb/2017 | 04.51      | No Schedule.                                                                                                                                                     |
| IPP                                                                 | PGPL U1            | 126MW    | 05/Feb/2017  | 17.15        | 06/Feb/2017 | 04.00      | No Schedule.                                                                                                                                                     |
| IPP                                                                 | PGPL U2            | 126MW    | 06/Feb/2017  | 17.48        | 07/Feb/2017 | 04.48      | No Schedule                                                                                                                                                      |
| IPP                                                                 | PGPL U1            | 126MW    | 06/Feb/2017  | 17.45        | 07/Feb/2017 | 03.59      | No Schedule                                                                                                                                                      |
| IPP                                                                 | PGPL U2            | 126MW    | 07/Feb/2017  | 17.30        |             | Continued. | No Schedule                                                                                                                                                      |
| MSPGCL                                                              | Parli Unit 6       | 250MW    | 07/Feb/2017  | 19.50        | 07/Feb/2017 | 22.55      | Flame Failure                                                                                                                                                    |
| MSPGCL                                                              | Koradi Unit 10     | 660MW    | 07/Feb/2017  | 00.10        |             | Continued. | Work Of PG Test.                                                                                                                                                 |
| IPP                                                                 | PGPL U1            | 126MW    | 07/Feb/2017  | 17.30        |             | Continued. | No Schedule                                                                                                                                                      |
| MSPGCL                                                              | Uran Unit 5        | 108MW    | 07/Feb/2017  | 11.38        | 07/Feb/2017 | 23.38      | Boiler feed sation shut off valve leakage                                                                                                                        |
| MSPGCL                                                              | Bhusawal Unit 5    | 500MW    | 07/Feb/2017  | 12.12        | 10/Feb/2017 | 10.57      | Bottom ash gate problem                                                                                                                                          |
| MSPGCL                                                              | Paras Unit 4       | 250MW    | 08/Feb/2017  | 18.01        | 08/Feb/2017 | 20.50      | TRIPPED, LOSS OF FUEL.                                                                                                                                           |
| MSPGCL                                                              | Nasik Unit 3       | 210MW    | 08/Feb/2017  | 19.50        | 08/Feb/2017 | 22.25      | CONTROL VALVE PROBLEM.                                                                                                                                           |
| IPP                                                                 | WPCL U-4           | 135MW    | 08/Feb/2017  | 12.35        | 11/Feb/2017 | 23.23      | ID FAN VIBRATION HIGH.                                                                                                                                           |
| MSPGCL                                                              | Khaparkheda Unit 4 | 210MW    | 09/Feb/2017  | 13.52        | 11/Feb/2017 | 14.48      | Boiler Tube Leakage                                                                                                                                              |
| MSPGCL                                                              | Chandrapur Unit 6  | 500MW    | 10/Feb/2017  | 23.25        | 11/Feb/2017 | 07.16      | Reverse Power Prot. Operated.                                                                                                                                    |
| MSPGCL                                                              | Bhusawal Unit 5    | 500MW    | 10/Feb/2017  | 11.25        | 10/Feb/2017 | 13.19      | Main Steam Temp.Low.                                                                                                                                             |
| MSPGCL                                                              | Chandrapur Unit 6  | 500MW    | 11/Feb/2017  | 15.36        |             | Continued. | Control Oil Pressure Low                                                                                                                                         |
| MSPGCL                                                              | Khaparkheda Unit 3 | 210MW    | 11/Feb/2017  | 07.02        | 12/Feb/2017 | 16.34      | Boiler Tube Leakage                                                                                                                                              |
| MSPGCL                                                              | Parli Unit 6       | 250MW    | 11/Feb/2017  | 19.40        | 11/Feb/2017 | 21.46      | Furnace Pressure High                                                                                                                                            |
| MSPGCL                                                              | Chandrapur Unit 9  | 500MW    | 12/Feb/2017  | 19.55        | 13/Feb/2017 | 00.40      | PA Fan problem                                                                                                                                                   |

**LINE OUTAGES AND RIPPING FOR THE WEEK FROM 06/02/2017 TO 12/02/2017**

| Voltage | Name of Line                            | Tripping Date | Tripping Time | Synch Date  | Synch Time | Reason                                                                                 |
|---------|-----------------------------------------|---------------|---------------|-------------|------------|----------------------------------------------------------------------------------------|
| 400 KV  | Karad -kolhapur-I                       | 05/Feb/2017   | 16.35         | 06/Feb/2017 | 09.26      | Over Voltage                                                                           |
| 400 KV  | Karad - Jaigad - II                     | 05/Feb/2017   | 16.36         | 06/Feb/2017 | 09.28      | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar II                    | 05/Feb/2017   | 17.13         | 06/Feb/2017 | 07.10      | Over Voltage                                                                           |
| 400 KV  | Bhusawal-Aurangabad                     | 05/Feb/2017   | 18.01         | 06/Feb/2017 | 06.06      | Over Voltage                                                                           |
| 400 KV  | Girwali-Solapur (Lamboti)               | 06/Feb/2017   | 16.44         | 06/Feb/2017 | 17.01      | Taking Reactor Out, Cold Welding Work.                                                 |
| 400 KV  | Karad -kolhapur-II                      | 06/Feb/2017   | 17.30         | 07/Feb/2017 | 08.52      | Over Voltage                                                                           |
| 400 KV  | Karad-Jaigad - I                        | 06/Feb/2017   | 17.40         | 07/Feb/2017 | 08.50      | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar II                    | 06/Feb/2017   | 19.13         | 07/Feb/2017 | 06.03      | Over Voltage                                                                           |
| 400 KV  | Bhusawal-Aurangabad                     | 06/Feb/2017   | 19.57         | 07/Feb/2017 | 06.07      | Over Voltage                                                                           |
| 400 KV  | Bus Coupler @ New Koyna                 | 07/Feb/2017   | 10.31         | 07/Feb/2017 | 16.58      | Testing Work                                                                           |
| 400 KV  | Solapur - Parli(PG) I                   | 07/Feb/2017   | 17.15         | 07/Feb/2017 | 18.02      | Take a line reactor but Tripped line charge with out reactor                           |
| 400 KV  | Karad - Jaigad - II                     | 07/Feb/2017   | 18.06         | 08/Feb/2017 | 08.19      | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar II                    | 07/Feb/2017   | 18.18         | 08/Feb/2017 | 07.11      | Over Voltage                                                                           |
| 400 KV  | Bhusawal-Aurangabad                     | 07/Feb/2017   | 18.33         | 08/Feb/2017 | 06.58      | Over Voltage                                                                           |
| 400 KV  | Karad -kolhapur-I                       | 07/Feb/2017   | 22.04         | 08/Feb/2017 | 08.17      | Over Voltage                                                                           |
| 400 KV  | Cahndrapur II - Dhariwal II             | 08/Feb/2017   | 09.31         | 08/Feb/2017 | 13.24      | Routine Maintenance Work                                                               |
| 400 KV  | Kolhapur(M)-Kolhapur(GIS) ckt1          | 08/Feb/2017   | 09.40         | 08/Feb/2017 | 18.19      | To attend Insulator String                                                             |
| 400 KV  | Main Bus - II @ Kalwa                   | 08/Feb/2017   | 12.23         | 08/Feb/2017 | 12.35      | Bus Bar Protection Operated                                                            |
| 400 KV  | Padghe - Kalwa-II                       | 08/Feb/2017   | 12.23         | 08/Feb/2017 | 12.42      | Bus Bar Protection Operated                                                            |
| 400 KV  | Kalwa - Kharghar                        | 08/Feb/2017   | 12.23         | 08/Feb/2017 | 12.50      | Bus Bar Protection Operated                                                            |
| 400 KV  | Chandrapur2-Parali 2 ckt1               | 08/Feb/2017   | 13.39         | 08/Feb/2017 | 19.14      | REACTOR COLD WELDING WORK FOR OIL LEAKAGES FROM MANHOLE PLATE AN                       |
| 400 KV  | Karad -kolhapur-II                      | 08/Feb/2017   | 16.36         | 09/Feb/2017 | 08.57      | Over Voltage                                                                           |
| 400 KV  | Karad-Jaigad - I                        | 08/Feb/2017   | 16.37         | 09/Feb/2017 | 09.10      | Over Voltage                                                                           |
| 400 KV  | Bhusawal-Aurangabad                     | 08/Feb/2017   | 19.23         | 09/Feb/2017 | 06.06      | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar I                     | 08/Feb/2017   | 20.19         | 09/Feb/2017 | 07.48      | Over Voltage                                                                           |
| 400 KV  | Padghe - Kalwa- I                       | 09/Feb/2017   | 06.40         | 10/Feb/2017 | 22.10      | Old Rusted Conductor Replacement Work.                                                 |
| 400 KV  | Padgha Tarapur II                       | 09/Feb/2017   | 10.35         | 11/Feb/2017 | 11.29      | Overhauling of CB(Shifted on TBC @ Padgha End)                                         |
| 400 KV  | Kolhapur Solapur(PG) I                  | 09/Feb/2017   | 17.03         | 09/Feb/2017 | 18.56      | Attending Hot Spot                                                                     |
| 400 KV  | Bhusawal-Aurangabad                     | 09/Feb/2017   | 19.33         | 10/Feb/2017 | 06.35      | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar II                    | 09/Feb/2017   | 19.40         | 10/Feb/2017 | 06.57      | Over Voltage                                                                           |
| 400 KV  | Karad -kolhapur-I                       | 09/Feb/2017   | 20.27         | 10/Feb/2017 | 09.01      | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar II                    | 10/Feb/2017   | 09.44         | 11/Feb/2017 | 08.11      | Outage @ SSP End.RFC @ 19.26.                                                          |
| 400 KV  | Karad -kolhapur-II                      | 10/Feb/2017   | 16.43         | 11/Feb/2017 | 08.14      | Over Voltage                                                                           |
| 400 KV  | Karad-Jaigad - I                        | 10/Feb/2017   | 16.44         | 11/Feb/2017 | 08.16      | Over Voltage                                                                           |
| 400 KV  | Bhusawal-Aurangabad                     | 10/Feb/2017   | 18.05         | 11/Feb/2017 | 06.51      | Over Voltage                                                                           |
| 400 KV  | Padghe - Kalwa-II                       | 11/Feb/2017   | 07.15         | 11/Feb/2017 | 10.23      | On TBC.                                                                                |
| 400 KV  | Ektuni-Bableshtar ckt 1                 | 11/Feb/2017   | 11.59         | 11/Feb/2017 | 20.53      | Isolator Alignment Work.                                                               |
| 400 KV  | Karad - Jaigad - II                     | 11/Feb/2017   | 16.39         | 12/Feb/2017 | 09.38      | Over Voltage                                                                           |
| 400 KV  | Karad -kolhapur-I                       | 11/Feb/2017   | 16.41         | 12/Feb/2017 | 09.35      | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar II                    | 11/Feb/2017   | 17.15         | 12/Feb/2017 | 06.43      | Over Voltage                                                                           |
| 400 KV  | Bhusawal-Aurangabad                     | 11/Feb/2017   | 18.27         | 12/Feb/2017 | 06.35      | Over Voltage                                                                           |
| 400 KV  | Padghe - Kalwa-II                       | 12/Feb/2017   | 09.45         | 12/Feb/2017 | 16.43      | For Old Rusted Conductor Replacement Work.                                             |
| 400 KV  | Karad -kolhapur-II                      | 12/Feb/2017   | 16.07         |             | Continued. | Over Voltage                                                                           |
| 400 KV  | Karad - Jaigad - II                     | 12/Feb/2017   | 16.08         |             | Continued. | Over Voltage                                                                           |
| 400 KV  | Dhule Sar'Sarovar II                    | 12/Feb/2017   | 17.36         |             | Continued. | Over Voltage                                                                           |
| 400 KV  | Bhusawal-Aurangabad                     | 12/Feb/2017   | 20.00         |             | Continued. | Over Voltage                                                                           |
| 220 KV  | Chandrapur GCR - Warora - I             | 05/Apr/2015   | 09.13         |             | Continued. | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-ener  |
| 220 KV  | Chandrapur GCR - Wani                   | 05/Apr/2015   | 09.15         |             | Continued. | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-ener  |
| 220 KV  | Chandrapur MIDC - GEPL Ckt I            | 20/Dec/2016   | 18.36         |             | Continued. | Energy Bill Ending At GEPL End.                                                        |
| 220 KV  | Mudshingi - Chikodi                     | 03/Feb/2017   | 05.17         | 07/Feb/2017 | 20.00      | Distance protection(Line charged from Mudshingi end only at 22.10Hrs Dt. 04-02-2017. B |
| 220 KV  | Pedambe-Pophali                         | 06/Feb/2017   | 11.05         | 06/Feb/2017 | 11.55      | Oil Top Up At Pedambe.                                                                 |
| 220 KV  | Bhugaon- Wardha                         | 06/Feb/2017   | 13.09         | 06/Feb/2017 | 13.23      | Tripped At Wardha End.                                                                 |
| 220 KV  | Kadegaon-Miraj                          | 07/Feb/2017   | 09.06         | 07/Feb/2017 | 18.38      | Faulty String Replacement work                                                         |
| 220 KV  | Apta - Hoc                              | 07/Feb/2017   | 10.26         | 07/Feb/2017 | 17.30      | Testing Work                                                                           |
| 220 KV  | Vita - Ghatnandre                       | 07/Feb/2017   | 11.00         | 07/Feb/2017 | 13.09      | Annual Maintenance Work                                                                |
| 220 KV  | 220KV Borivali (M) - Borivali (T) ckt I | 07/Feb/2017   | 12.48         | 07/Feb/2017 | 18.43      | Testing Work                                                                           |
| 220 KV  | Karad - Vita Ckt- I                     | 07/Feb/2017   | 16.26         | 07/Feb/2017 | 18.27      | Testing Work                                                                           |
| 220 KV  | Kalwa - Airol Knowledge Park            | 08/Feb/2017   | 09.20         | 08/Feb/2017 | 19.33      | Routine Maintenance Work                                                               |
| 220 KV  | Parli New Tps - Beed Ckt 1              | 08/Feb/2017   | 10.15         | 08/Feb/2017 | 15.39      | Routine Maintenance Work                                                               |
| 220 KV  | Koradi-Ambazari-II                      | 08/Feb/2017   | 10.23         | 08/Feb/2017 | 16.36      | Attending Hot Spot                                                                     |
| 220 KV  | Talandage(400kv) - Five Star Midc       | 08/Feb/2017   | 10.25         | 08/Feb/2017 | 12.35      | Repl. of Insulator String                                                              |
| 220 KV  | Bhandara-Bhandara Rty Tss 1             | 08/Feb/2017   | 10.30         | 08/Feb/2017 | 15.04      | DAIGNOSTIC TESTING WORK CARRYING OUT SIGNATURE TEST.                                   |
| 220 KV  | REL Borivali MSETCL Borivali Line-2     | 08/Feb/2017   | 11.25         | 08/Feb/2017 | 16.20      | Testing Work                                                                           |
| 220 KV  | Chinchwad- Parvati                      | 08/Feb/2017   | 11.55         |             | Continued. | Construction Work                                                                      |
| 220 KV  | Solapur (Pg) South Solapur I            | 08/Feb/2017   | 12.03         | 08/Feb/2017 | 15.52      | Line Signature Test                                                                    |
| 220 KV  | Bhandara-Bhandara Rty Tss 2             | 08/Feb/2017   | 15.20         | 08/Feb/2017 | 18.08      | DAIGNOSTIC TESTING WORK CARRYING OUT SIGNATURE TEST.                                   |
| 220 KV  | Solapur (Pg) South Solapur II           | 08/Feb/2017   | 16.06         | 08/Feb/2017 | 18.47      | Line Signature Test                                                                    |
| 220 KV  | Pophali - Pedambe II                    | 09/Feb/2017   | 06.25         | 09/Feb/2017 | 19.20      | R Phase CT Replacement Work.                                                           |
| 220 KV  | Telco- Chinchwad                        | 09/Feb/2017   | 07.48         | 09/Feb/2017 | 14.16      | Conductor Stringing Work.                                                              |
| 220 KV  | Bhugaon-WardhaPG (Deoli)                | 09/Feb/2017   | 09.33         | 09/Feb/2017 | 18.30      | Insulator Replacement Work                                                             |
| 220 KV  | Valve-Jamde                             | 09/Feb/2017   | 11.10         | 09/Feb/2017 | 12.46      | Relay Testing Work.                                                                    |
| 220 KV  | Pohali-Nerle                            | 09/Feb/2017   | 11.59         | 10/Feb/2017 | 17.10      | Distance Protection                                                                    |
| 220 KV  | Karad - Dasgaon                         | 09/Feb/2017   | 12.41         | 09/Feb/2017 | 15.14      | Distance Protection                                                                    |
| 220 KV  | Karad(400kv) - Ogalewadi Ckt 2          | 09/Feb/2017   | 12.41         | 09/Feb/2017 | 13.35      | Distance Protection                                                                    |
| 220 KV  | Ranjangaon-Lonikand                     | 09/Feb/2017   | 15.13         | 09/Feb/2017 | 18.35      | Testing Work                                                                           |
| 220 KV  | Jejuri ( 400 Kv)-Jejuri- I              | 09/Feb/2017   | 19.31         | 09/Feb/2017 | 22.24      | C T Tan Delta Measurement.                                                             |
| 220 KV  | Purti-Bhugaon                           | 10/Feb/2017   | 10.01         | 10/Feb/2017 | 14.51      | Gantry Structure STN to DTN Work @ Bhugaon.                                            |
| 220 KV  | IPCL - SPCL                             | 10/Feb/2017   | 10.05         | 10/Feb/2017 | 16.55      | Maintenance Work.                                                                      |
| 220 KV  | 512 Khadki- Century Enka                | 10/Feb/2017   | 10.22         | 10/Feb/2017 | 19.17      | Scada Work.                                                                            |
| 220 KV  | Gorai MSETCL Borivali Line-1            | 10/Feb/2017   | 12.32         | 10/Feb/2017 | 15.46      | Relay Testing Work.                                                                    |
| 220 KV  | Pophali - Pedambe II                    | 10/Feb/2017   | 14.25         | 10/Feb/2017 | 16.45      | Bus Isolator Burnt Clamp Replacement of Nerale Line.                                   |
| 220 KV  | Pophali - New Koyna                     | 10/Feb/2017   | 14.30         | 10/Feb/2017 | 1630       | Bus Isolator Burnt Clamp Replacement of Nerale Line.                                   |
| 220 KV  | Bus Section II @ Pophali                | 10/Feb/2017   | 14.50         | 10/Feb/2017 | 16.35      | Bus Isolator Burnt Clamp Replacement of Nerale Line.                                   |
| 220 KV  | Gorai MSETCL Borivali Line-2            | 10/Feb/2017   | 15.50         | 10/Feb/2017 | 18.02      | Relay Testing Work.                                                                    |
| 220 KV  | Eklahara(Gcr)(Nasik)- Bableshtar 2      | 11/Feb/2017   | 05.49         | 11/Feb/2017 | 06.16      | PDR Trip.                                                                              |
| 220 KV  | Karad(400kv) -Nigade                    | 11/Feb/2017   | 10.25         | 11/Feb/2017 | 13.43      | Signature Analysis Test.                                                               |
| 220 KV  | Chakan-Chinchwad                        | 11/Feb/2017   | 12.05         | 11/Feb/2017 | 17.24      | Relay Retrofitting Work by Testing                                                     |
| 220 KV  | Tata Borivil MSETCL Borivil 5           | 11/Feb/2017   | 12.20         | 11/Feb/2017 | 17.00      | Line Maintenance work                                                                  |
| 220 KV  | Karad(400kv) - Wathar                   | 11/Feb/2017   | 13.58         | 11/Feb/2017 | 15.19      | Line Signature Analysis.                                                               |
| 220 KV  | Ranjangaon-Lonikand                     | 11/Feb/2017   | 14.35         | 11/Feb/2017 | 17.11      | Distance Protection                                                                    |
| 220 KV  | Karad -Mudshingi Ckt- IV                | 11/Feb/2017   | 15.22         | 11/Feb/2017 | 17.12      | Line Signature Analysis.                                                               |

| Voltage | Name of Line               | Tripping Date | Tripping Time | Synch Date  | Synch Time | Reason                        |
|---------|----------------------------|---------------|---------------|-------------|------------|-------------------------------|
| 220 KV  | Jejuri- Ismt- Lonand       | 11/Feb/2017   | 17.34         | 11/Feb/2017 | 20.11      | Diagnostic Testing Work.      |
| 220 KV  | TPC Borivali Aarey Line 1  | 12/Feb/2017   | 07.32         | 13/Feb/2017 | 00.51      | Maintenance Work.             |
| 220 KV  | Trombay Salsette 1 Backbay | 12/Feb/2017   | 08.15         | 12/Feb/2017 | 19.30      | B Phase CVT Repalcement Work. |
| 220 KV  | Kalwa-Salsette-VI          | 12/Feb/2017   | 10.31         | 12/Feb/2017 | 14.45      | Tree Trimming.                |