

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 11/Feb/2019 to 17/Feb/2019
Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/02/2019	11 Hrs	5711	376	295	6382	6313	264	4566	781	-997	17309	0	17309	1079	380	19765	19765	50.00
12/02/2019	11 Hrs	5973	434	303	6710	6090	569	4684	674	-1053	17674	0	17674	1070	487	20284	20284	50.05
13/02/2019	11 Hrs	5835	497	189	6521	6235	567	4644	696	-1071	17592	0	17592	1134	499	20296	20296	50.03
14/02/2019	12 Hrs	5091	1668	291	7050	6805	262	4035	868	-958	18062	0	18062	1287	496	20803	20803	50.04
15/02/2019	12 Hrs	6531	377	304	7212	6310	228	3949	818	-1171	17346	0	17346	1136	375	20028	20028	50.02
16/02/2019	11 Hrs	6235	587	308	7130	6106	239	3995	838	-962	17346	0	17346	965	497	19770	19770	50.03
17/02/2019	11 Hrs	6413	439	307	7159	6228	234	3840	867	-581	17747	0	17747	875	502	19705	19705	50.01
Maximum		6531	1668	308	7212	6805	569	4684	868	-581	18062	0	18062	1287	502	20803	20803	50.05
Minimum		5091	376	189	6382	6090	228	3840	674	-1171	17309	0	17309	875	375	19705	19705	50.00
Average		5970	625	285	6881	6298	338	4245	792	-970	17582	0	17582	1078	462	20093	20093	50.03

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/02/2019	13 Hrs	5899	335	286	6520	5787	244	4397	874	-1021	16801	0	16801	1054	373	19249	19249	50.01
12/02/2019	13 Hrs	5942	448	283	6673	5746	300	4393	737	-1021	16828	0	16828	1111	454	19414	19414	49.98
13/02/2019	13 Hrs	5841	382	286	6509	5968	284	4413	804	-1058	16920	0	16920	1118	501	19597	19597	50.03
14/02/2019	13 Hrs	5268	1161	287	6716	6469	274	4013	911	-918	17465	0	17465	1287	500	20170	20170	50.01
15/02/2019	13 Hrs	6518	392	292	7202	5921	343	3636	861	-1175	16788	0	16788	1079	373	19415	19415	50.00
16/02/2019	13 Hrs	6137	450	289	6876	5566	309	3696	931	-943	16435	0	16435	950	500	18828	18828	49.95
17/02/2019	13 Hrs	6435	377	288	7100	5811	288	3680	1047	-852	17074	0	17074	716	376	19018	19018	50.02
Maximum		6518	1161	292	7202	6469	343	4413	1047	-852	17465	0	17465	1287	501	20170	20170	50.03
Minimum		5268	335	283	6509	5566	244	3636	737	-1175	16435	0	16435	716	373	18828	18828	49.95
Average		6006	506	287	6799	5895	292	4033	881	-998	16902	0	16902	1045	440	19384	19384	50.00

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 11/Feb/2019 to 17/Feb/2019
Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/02/2019	20 Hrs	5629	204	297	6130	5316	90	4444	0	-963	15017	0	15017	1030	374	17384	17384	50.02
12/02/2019	20 Hrs	6029	133	293	6455	5171	311	4600	0	-946	15591	0	15591	1034	500	18071	18071	50.01
13/02/2019	20 Hrs	5932	337	154	6423	5641	362	4297	0	-836	15887	0	15887	1162	495	18380	18380	49.93
14/02/2019	20 Hrs	5843	158	297	6298	5549	530	4096	0	-983	15490	0	15490	1118	374	17964	17964	50.00
15/02/2019	20 Hrs	5652	263	301	6216	5061	872	3430	0	-995	14584	0	14584	1059	375	17013	17013	49.99
16/02/2019	20 Hrs	6009	187	306	6502	5043	825	3676	0	-905	15141	0	15141	991	373	17410	17410	49.97
17/02/2019	20 Hrs	5494	277	296	6067	5395	610	3412	0	-810	14674	0	14674	798	372	16654	16654	50.01
Maximum		6029	337	306	6502	5641	872	4600	0	-810	15887	0	15887	1162	500	18380	18380	50.02
Minimum		5494	133	154	6067	5043	90	3412	0	-995	14584	0	14584	798	372	16654	16654	49.93
Average		5798	223	278	6299	5311	514	3994	0	-920	15198	0	15198	1027	409	17554	17554	49.99

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/02/2019	3 Hrs	4916	82	319	5317	3543	474	3191	0	-204	12321	0	12321	626	373	13524	13524	50.02
12/02/2019	4 Hrs	5042	205	315	5562	3842	435	3498	0	-282	13055	0	13055	659	374	14370	14370	49.96
13/02/2019	3 Hrs	5030	95	300	5425	4491	479	3536	0	-422	13509	0	13509	665	372	14968	14968	49.98
14/02/2019	4 Hrs	4798	267	286	5351	4713	428	3555	0	-396	13651	0	13651	669	374	15090	15090	49.91
15/02/2019	3 Hrs	5178	89	316	5583	4732	463	3514	0	-437	13855	0	13855	672	374	15338	15338	50.00
16/02/2019	3 Hrs	5396	74	318	5788	4541	733	2991	0	-548	13505	0	13505	665	196	14914	14914	49.97
17/02/2019	4 Hrs	5411	250	316	5977	4818	137	3026	0	-345	13613	0	13613	621	373	14952	14952	49.97
Maximum		5411	267	319	5977	4818	733	3555	0	-204	13855	0	13855	672	374	15338	15338	50.02
Minimum		4798	74	286	5317	3543	137	2991	0	-548	12321	0	12321	621	196	13524	13524	49.91
Average		5110	152	310	5572	4383	450	3330	0	-376	13358	0	13358	654	348	14737	14737	49.97

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 11/Feb/2019 to 17/Feb/2019

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus										Mus	Mus	Mus
11/02/2019	130.683	6.249	7.311	144.243	0.000	119.018	117.715	7.041	96.969	5.948	21.187	9.269	-16.647	356.572	47.103	403.675
12/02/2019	135.992	7.410	6.778	150.180	0.000	123.012	121.436	8.906	100.279	5.224	22.050	10.549	-17.651	369.950	50.248	420.198
13/02/2019	134.249	8.480	6.269	148.998	0.037	130.933	130.715	10.599	97.728	5.462	22.386	10.344	-19.333	374.387	52.065	426.452
14/02/2019	126.645	15.719	7.034	149.398	0.000	138.218	136.374	10.305	93.193	6.124	23.646	10.120	-18.285	378.953	52.051	431.004
15/02/2019	140.756	5.959	7.371	154.086	0.000	128.810	128.381	14.249	84.066	5.919	21.906	9.080	-20.100	367.030	51.086	418.116
16/02/2019	140.186	6.400	7.361	153.947	0.000	128.327	128.067	11.703	83.435	6.543	20.187	8.874	-17.980	365.975	47.039	413.014
17/02/2019	139.850	6.023	7.319	153.192	0.000	127.470	125.998	7.074	82.462	7.322	17.178	9.343	-14.392	363.128	40.913	404.041
Maximum	140.756	15.719	7.371	154.086	0.037	138.218	136.374	140.756	100.279	7.322	23.646	10.549	-14.392	378.953	52.065	431.004
Minimum	126.645	5.959	6.269	144.243	0.000	119.018	117.715	126.645	82.462	5.224	17.178	8.874	-20.100	356.572	40.913	403.675
Average	135.480	8.034	7.063	150.578	0.005	127.970	126.955	135.480	91.162	6.077	21.220	9.654	-17.770	367.999	48.644	416.643

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
11/02/2019	0.057	1.003	40.237
12/02/2019	0.080	1.083	40.157
13/02/2019	0.123	1.206	40.034
14/02/2019	0.261	1.467	39.773
15/02/2019	0.059	1.526	39.714
16/02/2019	0.065	1.591	39.649
17/02/2019	0.066	1.657	39.583

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 11/Feb/2019 to 17/Feb/2019

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
11/02/2019	MONDAY	102.277	4889	15.438	643	117.715	4905	119.018	4959	1.303	54
12/02/2019	TUESDAY	105.314	5044	16.122	672	121.436	5060	123.012	5126	1.576	66
13/02/2019	WEDNESDAY	109.587	5425	21.128	880	130.715	5446	130.933	5456	0.218	9
14/02/2019	THURSDAY	112.284	5658	24.090	1004	136.374	5682	138.218	5759	1.844	77
15/02/2019	FRIDAY	103.886	5325	24.494	1021	128.381	5349	128.810	5367	0.429	18
16/02/2019	SATURDAY	108.423	5316	19.644	819	128.067	5336	128.327	5347	0.260	11
17/02/2019	SUNDAY	106.228	5230	19.770	824	125.998	5250	127.470	5311	1.472	61
Total		747.999		140.687		888.686		895.788		7.102	

Generating Unit Outages for the week 11 Feb -2019 to 17 Feb-2019							
Sr No	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
1	PLANNED	SWPGL U-3	1-Nov-18	0.28		Continued.	Annual Overhaul
2	FORCED	Trombay 6	15-Jul-15	17:08		Continued.	Economic shutdown
3	FORCED	SWPGL U-1	16-Feb-16	17.09		Continued.	No PPA.
4	FORCED	Parli Unit 4	1-Apr-16	0		Continued.	Economic shutdown
5	FORCED	Parli Unit 5	1-Apr-16	0		Continued.	Economic shutdown
6	FORCED	PGPL U1	7-Feb-17	17.3		Continued.	No Schedule
7	FORCED	PGPL U2	7-Feb-17	17.3		Continued.	No Schedule
8	FORCED	Uran Unit 7	20-Jul-18	12.53		Continued.	Failure.
9	FORCED	IEPL Unit 1	28-Aug-18	21.26		Continued.	Poor Coal Receipt
10	FORCED	Uran Unit 8	8-Sep-18	22.08		Continued.	Withdrawn Due To B0 & U-7
11	FORCED	Uran Unit B0	8-Sep-18	12.19		Continued.	T/F Shifting Work.
12	FORCED	Paras Unit 3	15-Sep-18	0.55		Continued.	Stator Earth Fault
13	FORCED	RPL(AMT) U-4	20-Sep-18	0.01		Continued.	Zero Schedule.
14	FORCED	Koyna Unit 1	26-Nov-18	0		Continued.	Oil Cooler Leakage.
15	FORCED	SWPGL U-2	27-Nov-18	0		Continued.	No Schedule.
16	FORCED	Parli Unit 7	12-Dec-18	0		Continued.	Zero Schedule.
17	FORCED	Parli Unit 6	12-Dec-18	0		Continued.	Zero Schedule.
18	FORCED	RPL(AMT) U-3	14-Dec-18	16.3		Continued.	Zero Schedule.
19	FORCED	Bhusawal Unit 3	14-Dec-18	3		Continued.	Zero Schedule.
20	FORCED	SWPGL U-4	15-Dec-18	0		Continued.	No Schedule
21	FORCED	RPL(AMT) U-2	27-Dec-18	19.3		Continued.	Zero Schedule.
22	FORCED	RPL(AMT) U-5	28-Dec-18	19.3		Continued.	Zero Schedule.
23	FORCED	VIPL U-1	29-Dec-18	0.3		Continued.	Coal Shortage
24	FORCED	Nasik Unit 3	9-Jan-19	19.3		Continued.	Zero Schedule
25	FORCED	Parli Unit 8	12-Jan-19	12		Continued.	Zero Schedule by MSEDCL
26	FORCED	Dhariwal	12-Jan-19	10.15		Continued.	Coal Shortage
27	FORCED	VIPL U-2	17-Jan-19	0.15		Continued.	Coal Shortage
28	FORCED	Koradi Unit 7	19-Jan-19	18.21		Continued.	Poor Coal Receipt
29	FORCED	RPL(AMT) U-1	27-Jan-19	2.17		Continued.	Withdrawn On RSD.
30	FORCED	Koradi Unit 6	3-Feb-19	22.09	14-Feb-19	7.46	Boiler Tube Leakage
31	FORCED	Adani U-5	3-Feb-19	10.08	11-Feb-19	4.37	Bottom ASH Hopper leakage
32	FORCED	Nasik Unit 4	8-Feb-19	5.18		Continued.	Zero schedule
33	FORCED	Chandrapur Unit 5	9-Feb-19	12.33	15-Feb-19	2.2	Air Heater Basket Replacement Work.
34	FORCED	Paras Unit 4	10-Feb-19	4.55	14-Feb-19	4.36	Air heater problem
35	FORCED	Uran Unit 5	12-Feb-19	13.36	12-Feb-19	15.17	Electronic card failure.
36	FORCED	Uran Unit 5	13-Feb-19	18.58	13-Feb-19	21.3	Generator Protection operated
37	FORCED	Adani U-5	13-Feb-19	14.52	17-Feb-19	16.47	Due To APH-B Gearbox Problem.
38	FORCED	Uran Unit 5	13-Feb-19	8.26	13-Feb-19	9.55	Generator Protection operated
39	FORCED	Koradi Unit 9	14-Feb-19	5.31	14-Feb-19	11.43	Main Steam Temperature High Protection.
40	FORCED	Chandrapur Unit 6	14-Feb-19	5.23	14-Feb-19	15.09	Flash Over At UAT 6C.
41	FORCED	JSW (J) U1	15-Feb-19	14.34		Continued.	Condenser problem
42	FORCED	AEML Unit 2	15-Feb-19	23.38	16-Feb-19	3.51	Generator Elect. Fault
43	FORCED	Koyna Unit 7	15-Feb-19	7.25	15-Feb-19	13	Cooling water Bus Replacement work

List of Transmission line Trippings/Outages for the week 11 Feb- 2019 to 17 Feb -2019

Sr. No.	Voltage Level	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
1	132 KV	HT	Mansar Pench	22-Jan-19	18.4		Continued.	After Completion of Outage.
2	132 KV	HT	Kanhan-Pench	22-Jan-19	18.44		Continued.	After Completion of Outage.
3	132 KV	Tripped	Hingoli 2- Akhada Balapur	11-Feb-19	16.35	11-Feb-19	16.55	Distance Protection
4	132 KV	PO	Harangul-Latur(Koyana) Ckt-I	13-Feb-19	11.06	13-Feb-19	15.43	Diagnostic Testing Work.
5	132 KV	Tripped	Ujani - Ausa	13-Feb-19	13.35	13-Feb-19	16.07	Distance Protection
6	132 KV	PO	Ranjangaon-Whirlpool	14-Feb-19	10.05	14-Feb-19	19.38	Construction work
7	220 KV	PO	Chandrapur GCR - Warora - I	5-Apr-15	9.13		Continued.	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
8	220 KV	PO	Chandrapur GCR - Wani	5-Apr-15	9.15		Continued.	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
9	220 KV	PO	Talandage - Chikodi	1-Jun-17	0.01		Continued.	No Schedule
10	220 KV	PO	Mudshingi - Chikodi	1-Jun-17	0.06		Continued.	No Schedule.
11	220 KV	HT	Gadchandur-Ultratech I	3-Apr-18	22.12	13-Feb-19	18.5	Replacement Of Metering CT AT UTCL End (Form 100/1 To 50/1) Request By Discom.
12	220 KV	HT	BOISAR BORIVALI	24-Jul-18	13.18		Continued.	To Control Line Loading.
13	220 KV	PO	Pusad-Ghatodi	5-Feb-19	9.37	16-Feb-19	13.28	REP. OF RCC STRUCTURES ISOLATOR REP UNDER LES ETC.
14	220 KV	PO	Half Bus section-I @ Yavatmal	11-Feb-19	9.04	11-Feb-19	18.2	Isolator Replacement Work.
15	220 KV	PO	Padegaon-Sawangi	11-Feb-19	9.11	11-Feb-19	19.47	String Replacement Work At Various Location.
16	220 KV	PO	Karad(400kv) - Wathar	11-Feb-19	10.23	11-Feb-19	17.35	Cold Washing.
17	220 KV	PO	Mumewadi -Halkarni II	11-Feb-19	10.3	11-Feb-19	13.51	Location No 187 String Flashover.
18	220 KV	PO	Vita-Khanapur(Mahuli Tap)	11-Feb-19	10:30	11-Feb-19	20:45	Breaker Overhauling work
19	220 KV	PO	ACCIL - Apta	11-Feb-19	11.05	11-Feb-19	18.28	Diagnostic & Routine Maintenance Work.
20	220 KV	PO	220/132kv 100mva Vijai Ptr No 1 @Baramati	11-Feb-19	11.5	11-Feb-19	17.2	Relay Testing Work.
21	220 KV	HT	Miraj - Ichalkaranji II	11-Feb-19	12.52	11-Feb-19	15.36	For Availing Main Bus-2 Outage.
22	220 KV	PO	Main Bus Section @ Ichalkaranji II	11-Feb-19	13.02	11-Feb-19	14.5	Relay Replacement Work.
23	220 KV	EO	220/33kv 125 MVA Transformer 1 @Gorai R/S	11-Feb-19	14.49	11-Feb-19	16.02	Attending Low Oil Level ON HV Cable Box.
24	220 KV	Tripped	Mudshingi-Belewadi	11-Feb-19	15.04	11-Feb-19	17.05	Distance Protection
25	220 KV	Tripped	Talandge-Hamidwada	11-Feb-19	15.04	11-Feb-19	16.36	Distance Protection
26	220 KV	PO	220KV Sawangi- Bhokardan	12-Feb-19	8.43	12-Feb-19	17.55	In view of outage on sawangi padegaon CKT.
27	220 KV	PO	Padegaon-Sawangi	12-Feb-19	8.56	12-Feb-19	17.52	Insulator string replacement work.
28	220 KV	PO	satara MIDC- Malharpeth	12-Feb-19	10.15	12-Feb-19	5:16	Quarterly Maintainance Work
29	220 KV	PO	220/132-110kv 200mva Ptr 1 @Oglewadi	12-Feb-19	10.4	12-Feb-19	16.17	C.B timing CRM testing work.
30	220 KV	EO	Alkud Miraj	12-Feb-19	10.58	12-Feb-19	15.3	Y PH CT oil leakage.
31	220 KV	PO	Yeatmal- Pusad	12-Feb-19	12.06	12-Feb-19	15	Jumper removal work.
32	220 KV	PO	Nagothane - ACCIL	12-Feb-19	12.22	12-Feb-19	17.55	Diagnostic testing.
33	220 KV	PO	Paranda-Barshi	12-Feb-19	14.15	12-Feb-19	17	Line Maintenance work
34	220 KV	PO	220/132kv 100MVA ICT II @Satara Midc	12-Feb-19	14.2	12-Feb-19	16.55	Quarterly Maintainance Work

List of Transmission line Trippings/Outages for the week 11 Feb- 2019 to 17 Feb -2019

Sr. No.	Voltage Level	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
35	220 KV	PO	Apta - Tambati	13-Feb-19	7.08	13-Feb-19	17.07	Routine Maintenance Work &Diagnostic Testing Work.
36	220 KV	PO	Boisar-Viraj	13-Feb-19	8.05	13-Feb-19	13.3	Diagnostic Testing Work.
37	220 KV	EO	220/33 Kv 100 Mva Areva Ptr 1 @Jamde	13-Feb-19	8.48	13-Feb-19	14.25	HV BPH CT Oil Leakage.
38	220 KV	PO	220/100 Kv 200 Mva Cgl lct @Pal-Dombivali	13-Feb-19	9.3	13-Feb-19	21.3	Diagnostic Testing Work.
39	220 KV	PO	Karad(400kv) -Mudshingi Ckt 2-Tak	13-Feb-19	10.02	13-Feb-19	12.51	Quarterly Maintainance Work
40	220 KV	PO	Bhugaon-WardhaPG (Deoli)	13-Feb-19	10.04	13-Feb-19	17.29	Testing Work
41	220 KV	PO	PARLY (PG) - OLD GCR PARLI	13-Feb-19	10.17	13-Feb-19	19.28	CT Replacement Work.
42	220 KV	PO	220/132KV 200MVA ICT-II @ Miraj	13-Feb-19	10.2	13-Feb-19	17.2	Diagnostic Testing Work.
43	220 KV	PO	Beed-Manjarsumba	13-Feb-19	10.25	13-Feb-19	14.05	Quarterly Maintainance Work
44	220 KV	PO	khaparkheda-Khaparkheda(new)-I	13-Feb-19	10.58	13-Feb-19	15.43	Testing Work
45	220 KV	PO	220/132 Kv 200 Mva Vijai lct 2 @Bale (Solapur 2)	13-Feb-19	10:36	13-Feb-19	12:41	Quarterly Maintainance Work
46	220 KV	PO	Dhamangaon New- Tss -I	13-Feb-19	11.34	13-Feb-19	18.17	R PH Metering PT Replacement Work.
47	220 KV	PO	220/66 Kv 150 Mva Emco lct 2 @Gadchandur	13-Feb-19	11.35		Continued.	LV Bushing Replacement Work For 10 Days
48	220 KV	PO	220/132 Kv 100 Mva lct 1 @South Solapur (Kumbhari)	13-Feb-19	12	13-Feb-19	15.45	Quarterly Maintainance Work
49	220 KV	EO	Trombay - Kalwa	13-Feb-19	12.08	13-Feb-19	12.28	Bird Nest Removal.
50	220 KV	Tripped	Pophali - Kdph	13-Feb-19	13.05	13-Feb-19	13.45	R PH E/F 1.32KA.
51	220 KV	PO	Beed-Patoda Ckt 1	13-Feb-19	14.12	13-Feb-19	16.3	Diagnostic Testing Work.
52	220 KV	PO	220/132 Kv 200 Mva Bbl lct 1 @Kalmeshwar	13-Feb-19	14.28	13-Feb-19	16.22	Attending Oil Leakage
53	220 KV	PO	ACCIL - Apta	13-Feb-19	17.33	13-Feb-19	19.26	Diagnostic Testing Work.
54	220 KV	PO	220/132 Kv 100 Mva Emco lct @Shahada	13-Feb-19	17.4	13-Feb-19	21.08	For Cold Welding To Attending Oil Leakage.
55	220 KV	PO	Gadchandur-Ultratech II	13-Feb-19	18		Continued.	Metering C.T.Replacement Work.
56	220 KV	PO	Sadawaghapur Karad Ckt 2	14-Feb-19	10	14-Feb-19	18.3	Diagnostic testing work
57	220 KV	PO	Peth- Mudshingi -I	14-Feb-19	10.14	14-Feb-19	11.55	Attending Oil Leakage
58	220 KV	HT	Chakan-Chinchwad	14-Feb-19	11.19	14-Feb-19	14.48	Load management for outage on chakan
59	220 KV	PO	220/132 Kv 200 Mva Cgl Ptr No 5 @Parvati	14-Feb-19	11:15	14-Feb-19	12:25	For oil top
60	220 KV	PO	Ranjangaon-Lonikand	14-Feb-19	15	14-Feb-19	19.07	Annual Maintenance Work
61	220 KV	PO	220/132 Kv 200mva Cgl Ptr No 3 @Chinchwad	15-Feb-19	1.15	15-Feb-19	2.55	Bus Bar configuration work
62	220 KV	PO	220/132 KV ICT II @ Kopergaon	15-Feb-19	9.3	15-Feb-19	13.1	Testing Work
63	220 KV	PO	220/100 Kv 100 MVA ICT II @Vasai-Ii	15-Feb-19	9.57	15-Feb-19	19.23	MOG Inspection and OLTC Overhauling
64	220 KV	PO	Karad(400kv) -Mudshingi Ckt 2-	15-Feb-19	10.1	15-Feb-19	15.55	Replacement of Y Phase Faulty Tension
65	220 KV	PO	220/132 kv 200 Mva ICT-II @Boisar-Ii	15-Feb-19	10.42	15-Feb-19	18.11	OLTC Overhauling
66	220 KV	PO	karad - Dasgaon	15-Feb-19	11.1	15-Feb-19	13.29	Testing Work

List of Transmission line Trippings/Outages for the week 11 Feb- 2019 to 17 Feb -2019

Sr. No.	Voltage Level	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
67	220 KV	PO	Chitegaon-Shendra Ckt-I	15-Feb-19	12.12	15-Feb-19	17.47	Routine Maintenance Work
68	220 KV	PO	220/132kv 200mva Vijai Ptr 2 @Lonand	15-Feb-19	12.55	15-Feb-19	15.3	Testing Work
69	220 KV	PO	Yeotmal- Pusad	15-Feb-19	13.37	15-Feb-19	19.22	Isolator Replacement
70	220 KV	PO	Chandrapur Main Bus II	15-Feb-19	14.15		Continued.	Isolator alignment work and Bay Maintenance work
71	220 KV	Tripped	Warora - Wardha	15-Feb-19	18.26	15-Feb-19	19.25	Bus Section I Tripped at Wardha
72	220 KV	Tripped	Abhijeet-Wardha-I	15-Feb-19	18.26	15-Feb-19	19.3	Bus Section I Tripped at Wardha
73	220 KV	Tripped	Wardha - Wardha Rly Tss 2	15-Feb-19	18.26	15-Feb-19	20.41	Bus Section I Tripped at Wardha
74	220 KV	Tripped	Bhugaon- Wardha	15-Feb-19	18.26	15-Feb-19	18.54	Bus Section I Tripped at Wardha
75	220 KV	Tripped	Abhijeet-Wardha-li	15-Feb-19	6:14		Continued.	Distance Protection Zone 1 Sparking observed on CT
76	220 KV	Tripped	Wardha - Wardharlytss1	15-Feb-19	18.26	15-Feb-19	19	Bus Section I Tripped at Wardha
77	220 KV	Tripped	Nagothane - Posco	16-Feb-19	8.01	16-Feb-19	9.47	BPH E/F & AR SUCCESSFUL AT NAGOTHANE END.
78	220 KV	PO	220/132 Kv 200 Mva Vijay Ict 2 @Malegaon	16-Feb-19	9.46		Continued.	OIL FILTREAION WORK.
79	220 KV	PO	Malharpeth - Karad(400kv)	16-Feb-19	10.03	16-Feb-19	14.48	Testing Work
80	220 KV	PO	220/100 Kv 200MVA ICT-I @Padghe	16-Feb-19	10.16	16-Feb-19	19.21	DIAGNOSTIC TESTING WORK.
81	220 KV	PO	220/132kv 200mva Vijai Ptr 1 @Lonand	16-Feb-19	10.55	16-Feb-19	12.12	132KV BUS BAR SCHEME WIRING AND TESTING WORK.
82	220 KV	PO	Bableshwar Ahamadnagar-li	16-Feb-19	11.08	16-Feb-19	14.28	CT TESTING WORK.
83	220 KV	HT	Sahara-Urse	16-Feb-19	12.19	16-Feb-19	14.51	manage load for availing emergency outage on 220kv talegaon (ambi)-talegaon (pg)-2.
84	220 KV	Tripped	Vankuswade - Kdph	16-Feb-19	13.45	16-Feb-19	14.15	Distance Protection
85	220 KV	PO	220/132kv 115mva Bhel Ptr 3 @Lonand	16-Feb-19	15.03	16-Feb-19	15.45	132KV BUS BAR SCHEME WIRING AND TESTING WORK.
86	220 KV	PO	Pigasus-Hinjewadi-II	16-Feb-19	16	16-Feb-19	18.58	Half yearly maintenance work
87	220 KV	PO	Kalwa-TIFIL	17-Feb-19	9.14		Continued.	For Tapping to Kharghar-Borivali-II(For Load
88	220 KV	PO	Kharghar-Borivali ckt II	17-Feb-19	9.2	17-Feb-19	14.51	For Tapping to Kharghar-Borivali-II(For Load Management on Kalwa ICT)
89	220 KV	PO	TALEGAON - TALEGAON ambi (PG)-I	17-Feb-19	10.09	17-Feb-19	15.23	Copper Palm replacement by Aluminium Palm
90	220 KV	PO	Arey - TPC Borivali	18-Feb-19	0.34		Continued.	Safety During Metro Work.
91	220 KV	PO	REL Borivali Aarey Line	18-Feb-19	0.57		Continued.	Safety During Metro Work.
92	400 KV	PO	Karad Solapur (PG)	3-May-17	11:49		Continued.	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
93	400 KV	Tripped	400/220/33 Kv 315 Mva ICT 1	15-Nov-18	10.07		Continued.	Differential Protection Declared Faulty.
94	400 KV	PO	Dhule Sar'Sarovar I	7-Feb-19	8.55		Continued.	Relay Testing Work(RFC 19.48Hrs)
95	400 KV	HT	Bhusawal-Aurangabad	10-Feb-19	17.38	11-Feb-19	9.05	Over Voltage
96	400 KV	HT	Karad-Jaigad - I	10-Feb-19	18.07	13-Feb-19	9.3	Over Voltage
97	400 KV	HT	Lonikand I - Koyna stage-IV	10-Feb-19	21.07	11-Feb-19	9	Over Voltage
98	400 KV	Tripped	Padghe - Kalwa- I	11-Feb-19	3.27	11-Feb-19	10.19	Over Voltage
99	400 KV	PO	400/220 KV 300 MVA ICT- I @Koradi	11-Feb-19	9.05	11-Feb-19	21.01	Cold Welding & Painting.
100	400 KV	PO	Akola II - RPL(Rattanindia) Ckt I	11-Feb-19	9.34	11-Feb-19	16.23	Routine Maintenance Work

List of Transmission line Trippings/Outages for the week 11 Feb- 2019 to 17 Feb -2019								
Sr. No.	Voltage Level	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
101	400 KV	EO	400/220 Kv 315 Mva Ict -2 @New Koyna	11-Feb-19	9.59	11-Feb-19	14.22	Replacement Of Buchholz Relay.
102	400 KV	PO	Kala Kudus Ckt-II	11-Feb-19	9.59	11-Feb-19	20.53	Insulator Replacement Work.
103	400 KV	PO	Dabhol Nagothane I	11-Feb-19	10.2	13-Feb-19	20.14	Cold Welding & String Replacement Work.During Opening R-Phase Pole Burst
104	400 KV	HT	Khadka-Aurangabad (Waluj)	11-Feb-19	16.24	12-Feb-19	7.38	Over Voltage
105	400 KV	PO	Kala Kudus Ckt-II	12-Feb-19	7.55	12-Feb-19	19.29	Line Maintenance work at kala end.
106	400 KV	PO	400/220 KV 300 MVA ICT- I @Koradi	12-Feb-19	8.59	12-Feb-19	19.34	Painting work.
107	400 KV	PO	Deepnagar Waluj 1	12-Feb-19	10.34	12-Feb-19	17.58	Replacement of dead end and mid span joint.
108	400 KV	PO	400/220/33 Kv 500 MVA ICT-III @Girwali	12-Feb-19	10:14	12-Feb-19	21:50	For erection of support structure of RRS scheme
109	400 KV	HT	Khadka-Aurangabad (Waluj)	12-Feb-19	18.16	13-Feb-19	7.04	Over Voltage
110	400 KV	PO	Deepnagar - Aurangabad	13-Feb-19	7.06	13-Feb-19	17.54	Replacement Of Dead End And MID Span Joint And Replacement Of Faulty Insulator String.
111	400 KV	PO	400/220/33 Kv 315 Mva Ict 2 @Koradi	13-Feb-19	9.06	13-Feb-19	20.32	RELAY TESTING WORK
112	400 KV	PO	Girwali- Lonikand 2	13-Feb-19	10.47	13-Feb-19	11.46	Work At Lonikand 2 End.
113	400 KV	HT	Girwali- Lonikand 2	13-Feb-19	16.41	13-Feb-19	17.12	To Take L/R In Service At Lonikand End.
114	400 KV	HT	Bhusawal-Aurangabad	13-Feb-19	18	14-Feb-19	7.27	Over Voltage
115	400 KV	EO	Padghe - Kalwa-II	14-Feb-19	5.59	14-Feb-19	9.16	Hot Spot On isolator.
116	400 KV	PO	Deepnagar - Aurangabad	14-Feb-19	7.51	14-Feb-19	18.53	Replacement work
117	400 KV	HT	Koradi-Bhusawal	14-Feb-19	8.12	14-Feb-19	19.12	Safety Purpose
118	400 KV	PO	400/220/33 Kv 315 Mva Ict 2 @Koradi	14-Feb-19	9.08	14-Feb-19	18.1	Painting cold welding & relay testing
119	400 KV	PO	400/220 KV 315MVA ICT II @	14-Feb-19	9.11	14-Feb-19	21.25	Testing Work
120	400 KV	PO	Warora -IEPL	14-Feb-19	9.31	14-Feb-19	18.14	Diagnostic Testing Work
121	400 KV	PO	400/220 Kv 315 Mva Ict 1	14-Feb-19	11.4	14-Feb-19	14.15	Conservator tank maint.work
122	400 KV	EO	New Koyna - Dabhol - li	14-Feb-19	14.3	15-Feb-19	20.25	String Replacement Work
123	400 KV	HT	Khadka-Aurangabad (Waluj)	14-Feb-19	19.5	15-Feb-19	7.13	Over Voltage
124	400 KV	Tripped	Chandrapur - Parli	14-Feb-19	20.02	15-Feb-19	6.17	Distance Protection
125	400 KV	PO	Deepnagar - Aurangabad	15-Feb-19	7.24	15-Feb-19	15.46	Replacement of Mid Span Joint
126	400 KV	PO	400/220/33 Kv 315 Mva Ict 2 @Koradi	15-Feb-19	8.55	15-Feb-19	18.44	Painting work
127	400 KV	Tripped	Chandrapur - Parli	15-Feb-19	18.53	16-Feb-19	12.22	Distance Protection B Phase E/F Z1
128	400 KV	HT	Bhusawal-Aurangabad	15-Feb-19	19.02	18-Feb-19	7.27	Over Voltage
129	400 KV	HT	Karad-Jaigad - I	15-Feb-19	20.04	16-Feb-19	9.14	Over Voltage
130	400 KV	PO	New Koyna - Dabhol - li	16-Feb-19	8.55	17-Feb-19	21.33	PM & TESTING WORK RFC 20.30 HRS.
131	400 KV	PO	400/220/33 Kv 315 Mva Ict 2 @Koradi	16-Feb-19	8.56	16-Feb-19	18.48	FOR PAINTING COLD WELDING & RELAY TESTING WORK.
132	400 KV	HT	Padghe - Nagothane - I	16-Feb-19	23.02	17-Feb-19	11.38	Over Voltage
133	400 KV	HT	Lonikand I - Koyna stage-IV	16-Feb-19	23.39	17-Feb-19	9.4	Over Voltage
134	400 KV	HT	Padghe - Nagothane - II	17-Feb-19	22		Continued.	Over Voltage
135	400 KV	HT	Lonikand I - Koyna stage-IV	17-Feb-19	23.29		Continued.	Over Voltage
136	765 KV	PO	Koradi III - Tirora - I	15-Feb-19	11.52	15-Feb-19	19.2	Annual Maintenance Work