

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 08/Apr/2024 to 14/Apr/2024

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-04-2024	12 Hrs	6808	348	277	7432	10066	180	6099	2218	-2149	23339	0	23339	900	497	27392	27392	49.95
09-04-2024	12 Hrs	6575	246	264	7084	9836	145	6137	2180	-2139	22754	0	22754	691	307	26380	26380	49.98
10-04-2024	12 Hrs	6116	520	272	6908	9678	227	5918	2260	-2227	22272	0	22272	950	463	26404	26404	49.95
11-04-2024	12 Hrs	5579	356	270	6204	9640	217	5987	2056	-2045	21600	0	21600	746	319	25170	25170	49.98
12-04-2024	11 Hrs	6451	369	278	7098	9295	455	5747	1852	-2188	21788	0	21788	789	291	25527	25527	50.05
13-04-2024	11 Hrs	6485	222	140	6847	8758	155	5441	1993	-1893	20831	0	20831	829	308	24331	24331	49.93
14-04-2024	12 Hrs	6945	268	283	7496	8451	180	4945	2135	-1622	21127	0	21127	664	313	24184	24184	50.03
Maximum		6945	520	283	7496	10066	455	6137	2260	-1622	23339	0	23339	950	497	27392	27392	50.05
Minimum		5579	222	140	6204	8451	145	4945	1852	-2227	20831	0	20831	664	291	24184	24184	49.93
Average		6423	333	255	7010	9389	223	5753	2099	-2038	21959	0	21959	796	357	25627	25627	49.98

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-04-2024	17 Hrs	6842	532	277	7652	10755	277	6945	854	-2229	23737	0	23737	862	500	27844	27844	50.02
09-04-2024	16 Hrs	6933	484	268	7684	9678	287	6847	1071	-1970	23124	0	23124	786	481	26834	26834	49.96
10-04-2024	16 Hrs	7118	786	272	8176	9975	312	6557	1275	-2267	23535	0	23535	919	446	27660	27660	49.98
11-04-2024	16 Hrs	6409	226	273	6908	9797	493	6194	1088	-2142	21859	0	21859	817	291	25588	25588	49.98
12-04-2024	15 Hrs	6640	609	273	7522	9050	552	5879	1484	-2089	21933	0	21933	941	338	25766	25766	49.95
13-04-2024	16 Hrs	7157	286	134	7577	8312	693	5531	1309	-1884	21055	0	21055	883	332	24637	24637	50.07
14-04-2024	16 Hrs	7290	298	275	7864	8265	199	5628	1369	-1563	21284	0	21284	760	383	24468	24468	50.02
Maximum		7290	786	277	8176	10755	693	6945	1484	-1563	23737	0	23737	941	500	27844	27844	50.07
Minimum		6409	226	134	6908	8265	199	5531	854	-2267	21055	0	21055	760	291	24468	24468	49.95
Average		6913	460	253	7626	9405	402	6226	1207	-2021	22361	0	22361	853	396	26114	26114	50.00

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-04-2024	20 Hrs	7429	732	284	8446	9624	302	6952	0	-1614	23200	0	23200	1169	481	26974	26974	50.00
09-04-2024	20 Hrs	6680	492	281	7454	7488	710	6868	0	-1684	20393	0	20393	902	496	23918	23918	49.95
10-04-2024	20 Hrs	7415	788	282	8486	8478	528	7259	0	-1840	22414	0	22414	987	479	26216	26216	50.01
11-04-2024	20 Hrs	6953	306	283	7542	7854	639	6971	0	-1841	20696	0	20696	786	356	24148	24148	49.99
12-04-2024	20 Hrs	7328	632	281	8241	7628	470	6802	0	-1807	20854	0	20854	954	299	24394	24394	50.00
13-04-2024	20 Hrs	7556	362	141	8059	8391	1117	6243	0	-1498	21838	0	21838	1000	430	25240	25240	49.96
14-04-2024	20 Hrs	7891	432	283	8606	8527	277	5880	0	-1613	21208	0	21208	753	383	24427	24427	49.96
Maximum		7891	788	284	8606	9624	1117	7259	0	-1498	23200	0	23200	1169	496	26974	26974	50.01
Minimum		6680	306	141	7454	7488	277	5880	0	-1841	20393	0	20393	753	299	23918	23918	49.95
Average		7322	535	262	8119	8284	578	6711	0	-1700	21515	0	21515	936	418	25045	25045	49.98

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-04-2024	4 Hrs	6603	190	295	7088	7756	1032	7005	0	-1278	21257	0	21257	631	386	23898	23898	50.01
09-04-2024	23 Hrs	6743	386	285	7414	7707	845	6726	0	-1759	20508	0	20508	838	419	23950	23950	49.96
10-04-2024	3 Hrs	6847	176	288	7312	7465	476	7075	0	-1406	20569	0	20569	674	391	23392	23392	49.97
11-04-2024	4 Hrs	7027	166	291	7484	7230	310	6966	0	-1187	20447	0	20447	832	329	23152	23152	49.99
12-04-2024	4 Hrs	7235	165	290	7690	7098	332	7002	0	-1229	20543	0	20543	621	452	23195	23195	50.01
13-04-2024	5 Hrs	7301	155	145	7601	6615	249	6416	0	-1105	19410	0	19410	695	422	21998	21998	49.93
14-04-2024	4 Hrs	7749	242	297	8288	7626	328	5957	0	-1239	20628	0	20628	654	327	23180	23180	50.01
Maximum		7749	386	297	8288	7756	1032	7075	0	-1105	21257	0	21257	838	452	23950	23950	50.01
Minimum		6603	155	145	7088	6615	249	5957	0	-1759	19410	0	19410	621	327	21998	21998	49.93
Average		7072	212	270	7554	7357	510	6735	0	-1315	20480	0	20480	706	389	23252	23252	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
08-04-2024	165.500	8.730	6.874	181.104	0.074	220.127	222.386	12.164	163.356	16.316	20.146	10.608	-42.050	539.970	72.804	623.821
09-04-2024	164.911	6.642	6.710	178.263	0.183	210.275	215.691	12.214	160.605	15.008	17.848	9.511	-41.382	524.644	68.741	603.724
10-04-2024	165.879	9.379	6.743	182.001	0.084	206.400	209.817	11.447	161.805	16.076	20.152	10.176	-43.837	522.967	74.165	608.057
11-04-2024	158.398	5.568	6.789	170.755	0.197	200.648	205.690	11.333	160.119	13.918	18.934	8.468	-40.518	505.579	67.920	584.175
12-04-2024	165.093	7.778	6.779	179.650	0.133	193.970	201.147	12.180	155.476	13.873	19.556	8.655	-41.466	503.037	69.677	583.360
13-04-2024	168.243	6.200	3.472	177.915	0.216	191.345	198.228	10.985	143.256	15.661	19.085	8.679	-37.892	490.691	65.657	566.927
14-04-2024	182.030	8.543	6.877	197.450	0.212	189.272	194.243	6.852	135.898	15.891	16.626	9.418	-34.619	500.288	60.663	571.407
Maximum	182.030	9.379	6.877	197.450	0.216	220.127	222.386	182.030	163.356	16.316	20.152	10.608	-34.619	539.970	74.165	623.821
Minimum	158.398	5.568	3.472	170.755	0.074	189.272	194.243	158.398	135.898	13.873	16.626	8.468	-43.837	490.691	60.663	566.927
Average	167.151	7.549	6.321	181.020	0.157	201.720	206.743	167.151	154.359	15.249	18.907	9.359	-40.252	512.454	68.518	591.639

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
08-04-2024	0.101	1.315	27.489
09-04-2024	0.062	1.377	27.427
10-04-2024	0.109	1.486	27.318
11-04-2024	0.040	1.527	27.277
12-04-2024	0.095	1.621	27.183
13-04-2024	0.063	1.684	27.120
14-04-2024	0.117	1.801	27.003

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 08/Apr/2024 to 14/Apr/2024

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
08-04-2024	MONDAY	104.453	9148	117.933	4914	222.386	9266	220.127	9172	-2.259	-94
09-04-2024	TUESDAY	135.455	8907	80.236	3343	215.691	8987	210.275	8761	-5.416	-226
10-04-2024	WEDNESDAY	105.895	8638	103.922	4330	209.817	8742	206.400	8600	-3.417	-142
11-04-2024	THURSDAY	102.244	8467	103.446	4310	205.690	8570	200.648	8360	-5.042	-210
12-04-2024	FRIDAY	103.095	8283	98.052	4085	201.147	8381	193.970	8082	-7.177	-299
13-04-2024	SATURDAY	108.728	8170	89.500	3729	198.228	8260	191.345	7973	-6.883	-287
14-04-2024	SUNDAY	103.868	8003	90.375	3766	194.243	8093	189.272	7886	-4.971	-207
Total		763.739		683.463		1447.202		1412.037		-35.165	

Generator Unit Outages/Trippings from 08.04.2024 to 14.04.2024						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	NOPPA
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	NOPPA
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	NOPPA
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	NOPPA
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	12-11-2022	13:23		Continued.	Major overhaul.	PLANNED
Koyna Unit 11	10-07-2023	09:40		Continued.	Capital Overhaul	PLANNED
Bhusawal Unit 5	05-04-2024	23:23	08-04-2024	06:14	Boiler Tube Leakage	FORCED
JPL Unit 2	06-04-2024	17:00	10-04-2024	13:39	Due to the Bottom Ash system failure .	FORCED
Koradi Unit-10	06-04-2024	17:26	12-04-2024	23:57	Boiler Tube Leakage	FORCED
Khaparkheda Unit 4	06-04-2024	20:53	08-04-2024	05:51	Furnace Pressure High	FORCED
Uran Unit 6	07-04-2024	06:57		Continued.	Zero Schedule(Due to open cycle can be taken on bar as per MSEDCL requirement)	ZEROSCH/R SD
Chandrapur Unit 7	08-04-2024	12:00	10-04-2024	08:12	Excessively high DM makeup	FORCED
JSW (J) U4	08-04-2024	17:00	08-04-2024	19:42	Boiler feed pump problem	FORCED
Nasik Unit 3	10-04-2024	09:55	13-04-2024	18:35	Generator Protection operated	FORCED
Koradi Unit 8	11-04-2024	07:50	11-04-2024	13:14	Main Steam Temperature High.	FORCED
RPL(AMT) U-1	12-04-2024	05:30		Continued.	Bottom ash evacuation problem	FORCED
Ghatghar Unit-2	12-04-2024	21:45	13-04-2024	22:45	GM Link Fault	FORCED
Uran Unit 7	13-04-2024	00:10	13-04-2024	22:08	Filter replacement work, B1 boiler HP feed station valves repairing work.	FORCED
Chandrapur Unit 5	13-04-2024	00:31		Continued.	Excessively high DM consumption due to FD 47 and boiler side leakages.	FORCED
Chandrapur Unit 3	13-04-2024	02:52	14-04-2024	01:50	PA Fan problem	FORCED
Khaparkheda Unit 3	13-04-2024	03:22	13-04-2024	16:24	Air heater problem	FORCED
Adani U-3	13-04-2024	04:57		Continued.	APH-A inlet bellow leakage	FORCED
Ghatghar Unit-1	13-04-2024	15:00		Continued.	GM Link Fault	FORCED
JPL Unit 2	13-04-2024	15:20	13-04-2024	16:38	C&I network failure	FORCED
JPL Unit 2	14-04-2024	08:49		Continued.	Low net sales realization.	ZEROSCH/R SD

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAIN BAY (707) OF TIRORA CKT - 2 @ KORADI 3	08-04-2024	09:40	08-04-2024	12:33	DGA Test of Current Transformer at Koradi-III SS.	PO	765 KV
TIE BAY (708) OF AKOLA CKT - 1 & TIRODA CKT - 2 @ KORADI - 3	08-04-2024	16:41	08-04-2024	18:02	DGA Test of Current Transformer at Koradi-III SS.	PO	765 KV
AKOLA II - EKTUNI CKT - 2	09-04-2024	15:36	09-04-2024	17:35	Distance Protection	T	765 KV
TIE BAY OF 765KV/21KV TIRODA-GT-	09-04-2024	13:49	09-04-2024	18:20	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
MAIN BAY (709) OF AKOLA CKT - 1	10-04-2024	09:58	10-04-2024	11:57	DGA Test of Current Transformer at	PO	765 KV
MAIN BAY (710) OF TIRORA CKT - 1 @ KORADI 3	10-04-2024	16:41	10-04-2024	19:38	DGA Test of Current Transformer at Koradi-III SS.	PO	765 KV
MAIN BAY (707) OF KORADI CKT - 1 @ TIRORA	11-04-2024	09:18	11-04-2024	14:30	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
MAIN BAY (712) OF AKOLA CKT - 2 @ KORADI 3	12-04-2024	16:17	12-04-2024	18:01	DGA Test of Current Transformer at Koradi-III SS.	PO	765 KV
TIE BAY (711) OF AKOLA CKT - 2 & TIRODA CKT - 1 @ KORADI - 3	12-04-2024	09:57	12-04-2024	15:14	DGA Test of Current Transformer at Koradi-III SS.	PO	765 KV
TIE BAY (705) OF KORADI 3 CKT - 2 & BUS REACTOR @ TIRORA	13-04-2024	09:16	13-04-2024	13:40	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
765/400kV 1500MVA ICT @ AKOLA 2	14-04-2024	10:17	15-04-2024	03:41	Insulation Coating of 33KV Tertiary yard	PO	765 KV
TIE BAY (423) OF STATION TF - 1 @ KORADI 2	03-04-2024	11:26	08-04-2024	16:56	Overhauling of Circuit breaker	PO	400 KV
JAIGAD - NEW KOYNA CKT - 2	08-04-2024	21:33	10-04-2024	04:56	Tripped on distance protection.	T	400 KV
LONIKAND I - TALEGAON (PGCIL)	08-04-2024	09:31	08-04-2024	09:56	W/I:- Direct carrier Failure; Main-I Carrier failure ; R/I:- 96 optd	T	400 KV
200 MVA 220/132 KV ICT - 5 @ KHADKA	08-04-2024	08:55	08-04-2024	12:35	FOR REPLACEMENT OF REGULATOR ASSEMBLY WITH N2 GAS CYLINDER OF NIFPS SYSTEM BY AGENCY	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	08-04-2024	09:31	08-04-2024	17:46	Tripped on differential protection	T	400 KV
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	08-04-2024	12:35	08-04-2024	21:38	After completion of Oil filtration the Diagnostic Testing of 167 MVA, 400/220/33 kV R PH Unit of ICT-3 is to be carried out.	PO	400 KV
400/220/33KV 315MVA ICT - 2 @ LONIKAND	08-04-2024	09:31	08-04-2024	10:16	W/I:- NIL; R/I:- 96 optd; 86A, B, C, D Optd	T	400 KV
BUS COUPLER @ LONIKAND-1	08-04-2024	09:31	08-04-2024	10:03	W/I:- Zone-I trip R/I:- 96 optd	T	400 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
DEEPNAGAR - AURANGABAD (WALUJ)	08-04-2024	13:21	08-04-2024	18:35	Replacement of Faulty Disc Insulator Strings by Long Rod Porcelain Strings	PO	400 KV
LONIKAND - JEJURI CKT - 2	08-04-2024	09:31	08-04-2024	10:12	W/I:- NIL ; R/I:- 96 optd	T	400 KV
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	08-04-2024	09:31	08-04-2024	10:06	W/I:- NIL ; R/I:- 96 optd	T	400 KV
NEW KOYNA - STAGE IV CKT - 2	08-04-2024	11:15	08-04-2024	21:24	Diagnostic testing & Relay testing work , Routine maint. Work	PO	400 KV
PADGHE - NAGOTHANE CKT - 1	09-04-2024	02:22	09-04-2024	19:44	Due to repeated autoreclosing at both end.	HT	400 KV
PADGHE - NAGOTHANE CKT - 2	09-04-2024	01:22	09-04-2024	19:58	Tripped On Distance Protection	T	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	09-04-2024	12:02	09-04-2024	18:04	Replacement of Faulty Disc Insulator Strings by Long Rod Porcelain Strings	PO	400 KV
AKOLA - WARDHA(PG) CKT - 1	10-04-2024	22:20	10-04-2024	23:03	AT A E= Y PH-E, IF=8.90KA,D=39.4KM, Z1, DT RECEIVED, ATW E= Y PH-E,IF=3.15KA, D=127KM.	HT	400 KV
CHANDRAPUR - KHAPERKHEDA	10-04-2024	10:58	10-04-2024	17:14	CT Diagnostic Testing Work	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ PARLI	10-04-2024	18:44	10-04-2024	20:51	220 kV Bus bar 1 operated at Parly ss	T	400 KV
BUSBAR PROTECTION @ PARLI	10-04-2024	20:25	10-04-2024	20:33	Primary suspect for abnormal currents in 220kv girwali- kurunda line was ct cables laid from ct mb to relay panel.	HT	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	10-04-2024	11:25	10-04-2024	18:14	Replacement of Faulty Disc Insulator Strings by Long Rod Porcelain Strings	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ PARLI	11-04-2024	16:35	11-04-2024	21:12	Tripped due to 220 kV main bus 1 operated	T	400 KV
DHULE- - BABLESHWAR CKT - 1	11-04-2024	13:28	11-04-2024	19:50	Routine Line Maintenance work;Distance main I and II relay testing	PO	400 KV
PARLI - KUMBHARGAON (NANDED) CKT - 1	11-04-2024	17:35	11-04-2024	22:33	Tripped on distance protection	T	400 KV
TIE BAY (420) OF 400/21KV GT-3 @ TIRORA	11-04-2024	15:17	11-04-2024	17:00	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV
220 KV DHULE(400KV) - MALEGAON CKT	12-04-2024	16:10	12-04-2024	20:20	Outage at Malegaon end.	PO	400 KV
PADGHE - KALWA CKT - 1	12-04-2024	13:58			1.B Bus PG Isolator replacement work under LES Scheme. 2. 400kV Kalwa-I in service through TBC. 3.CB Diagonostic Testing Work.	PO	400 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA 2	12-04-2024	11:08	12-04-2024	20:41	Line isolator 29 D & Auxiliary isolator 29 C overhauling & alignment work.	PO	400 KV
400/220/33 KV 500 MVA ICT - 2 @ DHULE	12-04-2024	17:30	12-04-2024	22:26	1) CTR make NIFPS system Rph,Yph & Bph unit servicing & maintenance.2) Rph,Yph & Bph unit NIFPS system TCIV valve replacement with dampers.3) Faulty conservator MOG replacement of Yph unit.4) Pre-monsoon Maintenance.	PO	400 KV
AKOLA-NANDGAONPETH (RPL-AMT)	12-04-2024	11:33	12-04-2024	18:30	Spacer Nut bolt tightening ,jumper nut bolt tightening, fixing of corona ring,vibration damper and earthwire vibration damper at loc no Bph 17,18,20,21,28,29,30,Rph32,34,Bph 35,36,38,39 46-47 R ph and 41 Yph	PO	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	12-04-2024	11:08	12-04-2024	18:09	Replacement of Faulty Disc Insulator Strings by Long Rod Porcelain Strings	PO	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	12-04-2024	11:08	12-04-2024	18:09	1) Diagnostic Testing and Routine Maintenance Work. 2) Line Maintenance Work and replacement of Insulators.	PO	400 KV
DHULE- - BABLESHWAR CKT - 2	12-04-2024	10:40	12-04-2024	19:56	Routine Line maintenance work	PO	400 KV
TBC @ KALWA	12-04-2024	06:51	13-04-2024	23:06	1)Old CT- 3 nos replacement work with new CT (3000-1500-750/1A) due to HTLS of 400kV RS Kalwa. 2) CT structure modification at both side. 3) IPS tube modification for CT clamp fitting. 4) Mk box wiring work & cabling work.	PO	400 KV
PARLI - KUMBHARGAON(NANDED) CKT - 2	13-04-2024	17:12	13-04-2024	22:29	(1) Reactor B/U testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work	PO	400 KV
400/11.5KV STATION TRANSFORMER - 3 @ TIRORA	13-04-2024	14:38	13-04-2024	17:47	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ DHULE	13-04-2024	16:59	13-04-2024	22:10	Checking and rectification of Fire detector trip indication	PO	400 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	13-04-2024	07:55	13-04-2024	16:51	For Pre-monsoon Maintenance work, Also Tan delta testing of Bushings, Windings & MV Side CTs. Also SFRA & Winding Resistance measurement testing work. Also both HV & MV Bay maintenance work to be carried out.	PO	400 KV
400KV RPL-AKOLA 2 CKT 2	13-04-2024	02:41	13-04-2024	19:27	Tripped on R, B phase	T	400 KV
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	13-04-2024	15:48	13-04-2024	19:53	Work by PGCIL		400 KV
MAIN BAY (408) OF WARDHA(PG) CKT - 1 @ AKOLA	13-04-2024	03:32	13-04-2024	04:20	408 Main Bay is tripped on PDR	T	400 KV
MAIN BUS - 2 @ PADGHE	13-04-2024	12:40			1.Replacement of Hanger Assembly of B Bus PG Isolator of Kalwa-1 by hot line method. 2. All feeders on B Bus will be in service.	PO	400 KV
TIE BAY (426) OF WARORA CKT - 2 @ CHANDRAPUR 2	13-04-2024	09:50	13-04-2024	14:11	Diagnostic testing and allied bay Maintenance work	PO	400 KV
JAIGAD - KARAD CKT - 1	14-04-2024	12:45	14-04-2024	22:50	Tripped on distance protection.	T	400 KV
220KV GIS DCHI - COLOURCHEM	07-04-2024	20:10	08-04-2024	05:50	For Retrofitting of Line differential Relay at both end by testing team, Kalwa.	PO	220 KV
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	07-04-2024	23:33	08-04-2024	06:36	Replacement of old disc insulator with porcelain long rod insulator strings, replacement of the cross arm at loc no 209 Y ph. Suspension nut bolt tightening work.	PO	220 KV
220/33-33KV 100MVA TF NO. - 1 @ ICHALKARANJI - II	08-04-2024	09:01	08-04-2024	17:01	1) QMW & hotspot attending work. 2) Civil Fire Protection wall plaster work. 3) Diag Testing work.	PO	220 KV
MUMEWADI -HALKARNI 1 LINE	08-04-2024	09:32	08-04-2024	15:42	Quarterly Maintenance	PO	220 KV
WARORA - WARDHA	08-04-2024	07:11	08-04-2024	07:40	DAIGNOSTIC TESTING WORK	PO	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV GIRWALI - MURUD CKT	08-04-2024	10:24	08-04-2024	11:32	1) TO SHIFT 220 KV MURUD LINE ON 220 KV TBC 2. 2) SHUTDOWN IS REQUIRED FOR ISOLATOR OPERATION. AFTER OPERATION OF ISOLATORS, LINE WILL SHIFTED ON TBC 2. 3) ABB MAKE OWN LINE CB OVERHAULING WORK IS PROPOSED. 4) 220 KV MURUD LINE WILL BE ON TBC 2 FROM 08.04.2024 TO 10.04.2024.	PO	220 KV
220/132 KV 200 MVA ICT 1	08-04-2024	10:31	08-04-2024	17:24	FOR TAN DELTA AND DFR TESTING WORK BY MOBILE TESTING UNIT AKOLA	PO	220 KV
220/132-110 KV 200MVA ICT - 3 @ OGLEWADI	08-04-2024	10:45	12-04-2024	22:10	Oil Filtration Work	PO	220 KV
220/132-110KV 100MVA PTR 1@WATHAR	08-04-2024	09:20	08-04-2024	18:30	Quarterly maintenance work	PO	220 KV
220/33 kv 50 MVA CGL PTR 1 @ MUDSHINGI	08-04-2024	08:15	08-04-2024	18:56	"Quarterly maint work & transformer painting work." "	PO	220 KV
MHAISAL - ALKUD	08-04-2024	18:46	09-04-2024	03:01	Polymer Replacement Work	PO	220 KV
NAGOTHANE - MSL	08-04-2024	10:45	08-04-2024	23:37	Relay Retrofitting work at 400kv Nagothane Substation.	PO	220 KV
TALANDAGE - FIVE STAR MIDC 2	08-04-2024	10:49	08-04-2024	23:59	Retrofitting of faulty Distance Relay.		220 KV
VERSOVA - GHODBUNDER	08-04-2024	09:35	08-04-2024	14:47	Preventive maintenance of circuit breaker	PO	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
WARORA-BHUGAON CKT - 2	08-04-2024	07:53	08-04-2024	16:40	FOR FIXING OF BIRD DIVERTER ON EARTHWIRE BETWEEN LOC NO. 1 TO 40 BY AGENCY M/S. TRAFOTECH SYSTEM PVT. LTD. MUMBAI	PO	220 KV
220 KV PARLI (OLD GCR)- GIRWALI (400 KV) CKT 4	09-04-2024	15:44	09-04-2024	19:14	Distance Protection	T	220 KV
BOISAR - VERSOVA	09-04-2024	22:53			Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.		220 KV
BUTIBORI-ABHIJEET	09-04-2024	02:05	09-04-2024	08:55	Distance Protection	T	220 KV
MUDSHINGI- BELEWADI LINE	09-04-2024	10:32	09-04-2024	14:23	For replacement of flashover string at loc. No 94 BPh	PO	220 KV
132 KV NAGEWADI (220 KV) - JALNA (220 KV) CKT 2	09-04-2024	17:50	09-04-2024	18:44	polythene removal work		220 KV
220 KV UMRED - TOPWORTH CKT	09-04-2024	21:46	09-04-2024	22:25	Distance Protection	T	220 KV
220/100 KV 200 MVA ICT 2 @ BORIVALI	09-04-2024	04:51	09-04-2024	08:25	Tripped on O/C protection.	T	220 KV
220/132 100MVA ICT-2 @ AMRAPUR	09-04-2024	13:15	10-04-2024	15:50	ICT II & Outage is required to carry out oil filtration work by M/s OM NSG Enterprises oil filtration agency	PO	220 KV
220/132 KV 100 MVA ICT 1 @ PUSAD	09-04-2024	11:06	09-04-2024	15:33	To attend oil leakage	PO	220 KV
220KV WARORA(400KV)-WARORA CKT 2	09-04-2024	07:54	09-04-2024	14:21	For fixing of Bird diverter on E/W	PO	220 KV
BALAPUR-AKOLA I	09-04-2024	16:34	09-04-2024	20:21	Distance Protection	T	220 KV
DAHANU - VERSOVA	09-04-2024	22:49			Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.	PO	220 KV
KARAD - DASGAON	09-04-2024	10:28	09-04-2024	17:11	Bay Maintenance work at 220kV Dasgaon S/stn	PO	220 KV
NERLE - DASGAON	09-04-2024	09:40	09-04-2024	16:13	Quarterly bay Maintenance Work at 220kV Dasgaon Substation	PO	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
ADLABS - PEDAMBE	10-04-2024	08:40	10-04-2024	19:40	Twin Jumpering work at 220kV Adlab substation end.	PO	220 KV
IPCL - SPCL	10-04-2024	10:44	10-04-2024	17:50	Installation of Multifunction meter (MFM) at 220KV IPCL end.	PO	220 KV
KANDALGAON - ONGC PANVEL	10-04-2024	15:37	10-04-2024	19:07	Routine line maintenance work.	PO	220 KV
TALANDGE - ICHALKARANJI 1	10-04-2024	19:01	10-04-2024	20:54	Crossarm Erection of Tower at Loc. No. 1 of 110KV Tilwani - Rukadi line	PO	220 KV
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	10-04-2024	09:05	10-04-2024	12:00	Quarterly Maintenance	PO	220 KV
220KV HARANGUL ICL CKT	10-04-2024	18:40	11-04-2024	14:19	Distance Protection	T	220 KV
220KV YAWATMAL- WARDHA(DEOLI) PG CKT 2	10-04-2024	08:54	10-04-2024	15:30	Maintenance work	PO	220 KV
KARAD - DASGAON	10-04-2024	11:01	10-04-2024	15:19	Bay Maintenance Work at 220kv Dasgaon Stn	PO	220 KV
KARAD - WATHAR	10-04-2024	11:01	10-04-2024	20:29	For back filling work of 220kV Narrow base multi tower Loc No.200A of new 220kV Karad-Koyna line	PO	220 KV
WAGHIVALI - DHARAVI 7	10-04-2024	02:25	10-04-2024	05:30	METRO PROJECT WORK BY MMRDA	PO	220 KV
WAGHIVALI - DHARAVI 8	10-04-2024	02:25	10-04-2024	05:30	METRO PROJECT WORK IN VICINITY BY MMRDA	PO	220 KV
WARORA-BHUGAON CKT - 1	10-04-2024	11:21	10-04-2024	18:15	Fixing of bird diverter on r, y & b-ph conductor between loc no. 1 to 40 by agency m/s. trafotech system pvt. ltd. mumbai.	HT	220 KV
WARORA-BHUGAON CKT - 2	10-04-2024	11:21	10-04-2024	18:17	Fixing of bird diverter on r, y & b-ph conductor between loc no. 1 to 40 by agency m/s. trafotech system pvt. ltd. mumbai.	HT	220 KV
100 MVA 220/132 KV ICT 1	11-04-2024	11:43	11-04-2024	14:13	Tan delta testing work	PO	220 KV
220 KV GIRWALI (400 KV) -PARLI U-8 CKT	11-04-2024	15:33	11-04-2024	23:10	G - Z1, R PH, 0.6 KM, 14 KA. U8 - 6 KA, 18 KM.bkr overhauling work.	HT	220 KV
220 KV PARLI -U-8 - PARBHANI CKT	11-04-2024	16:35	11-04-2024	16:55	Distance Protection	T	220 KV
220/100 KV 200 MVA ICT 4 @ APTA	11-04-2024	10:40	11-04-2024	16:14	1. CTR NIFPS reinstallation and preventive maintenance work 2. Bay maintenance work	PO	220 KV
220/132KV 100MVA ICT 3 @ PANDHARPUR	11-04-2024	09:09	11-04-2024	15:15	220 KV side CB Overhauling work.	PO	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/22-22 KV 100 MVA PTR 3 @ MULUND	11-04-2024	09:12	11-04-2024	17:07	1) PTR No. 3 is 50MVA on 220kV Bus-1. 2) Outage on 50MVA PTR No. 3 outage availed on 10.04.2024 to 11.04.2024 for EHV CB Pole overhauling. 3) On 11.04.2024 it is proposed to carry out 29 A ISOLATOR HV SIDE MAINTAINANCE WORK for which Jumper Opening & closing work from 220kV Bus-1 by Hot line unit kalwa is required.	PO	220 KV
220KV KURUNDA -GIRWALI CKT	11-04-2024	10:35	11-04-2024	10:59	Ckt is shifted to tbc by handtripping due to isolator bkr. bkr overhauling work.	T	220 KV
BABLESHWAR -BHENDA	11-04-2024	17:21	11-04-2024	20:05	Replacement of the disc insulator with porcelain long rod under scheme	PO	220 KV
DAHANU - GHODBUNDER CKT - 2	11-04-2024	22:11	12-04-2024	04:15	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Removal of Jumpers 192A (Virar) 2. Bunching between LS & SS Lines - Virar & Vasai area.	PO	220 KV
NERLE - DASGAON	11-04-2024	09:59	11-04-2024	17:29	For bay maintenance activities	PO	220 KV
PARLI (OLD GCR) - PARLI (PG) CKT 2	11-04-2024	16:45	12-04-2024	03:44	D/P R-E Z1 10.29KM 8.473KA AR LOCK OUT.	T	220 KV
WAGHIVALI - DHARAVI 7	11-04-2024	01:58	11-04-2024	04:38	Project Work - in vicinity of line to carry girder launching of Metro 2B (D N Nagar to Mandale) by using crane at S G Barve, Kurla East crossing by MMRDA Metro Team.	PO	220 KV
WAGHIVALI - DHARAVI 8	11-04-2024	01:58	11-04-2024	04:38	Project Work - in vicinity of lines to carry girder launching of Metro 2B (D N Nagar to Mandale) by using crane at S G Barve, Kurla East crossing by MMRDA Metro Team.	PO	220 KV
WARORA-BHUGAON CKT - 1	11-04-2024	07:27	11-04-2024	17:27	For fixing of Bird diverter	PO	220 KV
WARORA-BHUGAON CKT - 2	11-04-2024	07:27	11-04-2024	17:28	For fixing of Bird diverter	PO	220 KV
DONDAICHA(220)-AMALNER(220)	12-04-2024	17:35	12-04-2024	19:27	Distance protection	T	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KALWA - SIEMENS	12-04-2024	12:57	12-04-2024	14:56	Siemens end GIS Bushing Clamp Replacement work for R,Y& B-Phase to minimise the formation of hotspots	PO	220 KV
PADGHE - KAMBA 1	12-04-2024	08:07	12-04-2024	23:48	Work of Replacement of old C & R panel by new C & R panel	PO	220 KV
SIEMENS - RELIANCE GIS	12-04-2024	15:04	12-04-2024	16:25	Siemens end GIS Bushing Clamp Replacement work for R,Y& B-Phase to minimise the formation of hotspots	PO	220 KV
220 KV GIRWALI - MURUD CKT	12-04-2024	19:38	12-04-2024	19:54	Distance protection	T	220 KV
220 KV PARTUR - NAGEWADI CKT 2	12-04-2024	16:55	12-04-2024	17:23	Distance protection	T	220 KV
220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II	12-04-2024	09:01	12-04-2024	17:26	1) Quarterly bay maintenance work 2) Diag Testing Work 3) Attending Hotspot work.	PO	220 KV
220/132 KV 200 MVA ICT 3	12-04-2024	09:29	12-04-2024	14:08	Repeat measurement tan delta value of HV B-ph bushing.	PO	220 KV
220/132 KV 200 MVA ICT 1 @ MALEGAON	12-04-2024	09:03	12-04-2024	19:07	Tan delta testing of ICT and allied bay equipment, pre monsoon routine maintenance, NIFPS maintenance and repairing by M/S CTR	PO	220 KV
220/22 KV 50 MVA PTR 1 @ PADGHE	12-04-2024	11:35	12-04-2024	20:36	1. Diagnostic Testing Work 2. Bay maintenance work	PO	220 KV
220/33 KV 100 MVA PTR 3	12-04-2024	10:02	12-04-2024	19:42	Replacement of RYB CT.	PO	220 KV
220/33 KV 100 MVA PTR 4	12-04-2024	12:09	12-04-2024	16:08	For Crane movement	PO	220 KV
220/33 KV 50 MVA PTR 1 @ KHARGHAR	12-04-2024	16:02	12-04-2024	21:04	R.M.Work and Diagnostic testing work	PO	220 KV
220/33 KV 50 MVA PTR 2 @ KHARGHAR	12-04-2024	10:28	12-04-2024	15:50	R.M.Work	PO	220 KV
220/33-33KV 100MVA PTR 1	12-04-2024	10:43	12-04-2024	18:20	Replacement Work of HV B Ph CT	PO	220 KV
220KV MALEGAON - DHULE	12-04-2024	16:13	12-04-2024	20:20	For Bay Maintenance & Diagnostic Testing work	PO	220 KV
220KV WARORA(400KV)- WARORA CKT 1	12-04-2024	07:32	12-04-2024	18:37	Fixing of bird diverter on R, Y and B-Ph conductor between Loc no. 1 to 40.	PO	220 KV
220KV WARORA(400KV)-WARORA CKT 2	12-04-2024	07:32	12-04-2024	18:37	Fixing of bird diverter on R, Y and B-Ph conductor between Loc no. 1 to 40.	PO	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
CHAKAN-BHOSARI 1	12-04-2024	21:25	13-04-2024	05:39	For replacement of flashover string at Loc No. 53 (R Phase DSN), Double Jumping work at Loc No. 2, 3, 4, 4A, 5, from Loc no 51 to 60 cold line washing work	PO	220 KV
KARAD -MUDSHINGI CKT 2-TAK	12-04-2024	16:41	12-04-2024	18:16	Tripped on distance protection from Karad end only	T	220 KV
MAHAPE - RELIANCE GIS	12-04-2024	07:23	12-04-2024	11:04	Reliance end GIS Bushing Clamp Replacement work for R,Y& B-Phase to minimise the formation of recursive hotspots	PO	220 KV
MHAISAL - ALKUD	12-04-2024	17:42	13-04-2024	01:15	Polymer Replacement Work	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 4	12-04-2024	02:06	12-04-2024	05:04	Loc 23 to 26 insulator cleaning and loc 23B insulator replacement.	PO	220 KV
WAGHIVALI - DHARAVI 7	12-04-2024	01:56	12-04-2024	05:51	METRO WORK BY MMRDA	PO	220 KV
WAGHIVALI - DHARAVI 8	12-04-2024	01:53	12-04-2024	05:25	METRO WORK BY MMRDA	PO	220 KV
ADLABS - PEDAMBE	13-04-2024	19:57	14-04-2024	02:50	Line tripped on distance protection.	T	220 KV
APTA - PRINT HOUSE LINE	13-04-2024	08:48	14-04-2024	16:12	Errction of new inline ND+3 Tower for height rasing at Taloja MIDC road between Loc no. 638 to 639. Work includes stringing, complete erection. Etc	PO	220 KV
JEJURI (400 KV)-JEJURI- I	13-04-2024	16:34	14-04-2024	04:27	Retrofitting of Distance Protection Relay by M/s GE.	PO	220 KV
MIRAJ - MHAISHAL	13-04-2024	18:03	13-04-2024	23:11	Polymer Replacement Work & Back up relay retrofitting work at 220kV Miraj S/stn	PO	220 KV
PARLI NEW TPS - BEED CKT 1	13-04-2024	16:38	14-04-2024	04:25	RELAY REPL.	PO	220 KV
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA CKT 1	13-04-2024	11:39	13-04-2024	16:15	Line Maintenance work	PO	220 KV
220/132 KV 150 MVA ICT 2 @ SATANA	13-04-2024	11:22	13-04-2024	15:27	For Oil leakage attending work	PO	220 KV
220/132 KV 200 MVA ICT 1 @ RAYMOND	13-04-2024	16:04	13-04-2024	17:25	1.Diagnostic Testing of ICT and other equipment's 2.Complete bay maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ RAYMOND	13-04-2024	09:12	13-04-2024	15:00	1.Diagnostic Testing of ICT and other equipment's 2.Complete Bay maintenance work	PO	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220KV BADNERA -220KV AVAADA(DHAMANGAON) SOLAR CKT	13-04-2024	09:42	13-04-2024	10:37	To attend Hot Spot	PO	220 KV
220KV BADNERA -NER CKT	13-04-2024	04:01	13-04-2024	04:25	Distance Protection	T	220 KV
220KV KARJAT-AHMEDNAGAR-CKT-1	13-04-2024	10:47	13-04-2024	15:48	Replacement of R ph flashover insu. String at loc 82 (Line was Auto reclosed on dt 08.04.2024)	PO	220 KV
220KV WARORA(400KV)- WARORA CKT 1	13-04-2024	11:55	13-04-2024	18:22	For fixing of Bird Diverter on Conductor	PO	220 KV
220KV WARORA(400KV)-WARORA CKT 2	13-04-2024	11:56	13-04-2024	18:21	For fixing of Bird Diverter on Conductor	PO	220 KV
BHAVEGHAR - ROMA	13-04-2024	15:08	13-04-2024	19:47	Insulator replacement work identified in PID.	PO	220 KV
CHEMBUR (AEML) - NERUL (M)	13-04-2024	18:06	13-04-2024	23:45	Tripped only at Chembur AEML end.	T	220 KV
MALEGAON - SAYNE	13-04-2024	12:23	13-04-2024	1445	For Bay Maintenance work	PO	220 KV
POPHALI - KDPH	13-04-2024	14:45	13-04-2024	18:40	For installation of OPGW from tower loc no. 1 to 11 of 220kV KDPH LILO line.	PO	220 KV
TROMBAY (M) - CHEMBUR CKT - 3	13-04-2024	18:06	13-04-2024	21:23	Tripped only at trombay end.	T	220 KV
220 / 110 / 33kV 315 MVA ICT 6 @ CARNAC	14-04-2024	09:46	14-04-2024	18:38	Routine Mainetannce and Premonsoon Checks	PO	220 KV
BOISAR II - BOISAR (PG) CKT - 1	14-04-2024	09:48	14-04-2024	17:24	Work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	PO	220 KV
COLOURCHEM - TEMGHAR	14-04-2024	09:29	14-04-2024	19:37	To replace old rusted D'Shackle of Insulator strings at TL No. 24	PO	220 KV
COLOURCHEM - TEMGHAR	14-04-2024	09:29	14-04-2024	19:37	For Separation of combine jumper of 220kV Bus PT & 220kV TBC on main bus and maintenance of 220kV TBC main bus isolator.	PO	220 KV
220 / 110 / 33kV 250MVA ICT 9 @ DHARAVI	14-04-2024	08:46	14-04-2024	17:01	R/M, PM checks, device trials, LT cable box inspection	PO	220 KV

Transmission Line Outages/Trippings from 08.04.2024 to 14.04.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV BAMBHORI - DEEPNAGAR CKT	14-04-2024	11:42	14-04-2024	16:13	B= R PH DIST PRTN 1.684 KA 62.02 KM TL 70 .8 KM , D = 6.28 KM R PH Z1 10.6 KA	T	220 KV
AUXILARY BUS @ COLOURCHEM	14-04-2024	09:29	14-04-2024	19:00	For Separation of combine jumper of 220kV Bus PT & 220kV TBC on main bus and maintenance of 220kV TBC main bus isolator.	PO	220 KV
POPHALI - KDPH	14-04-2024	09:00	14-04-2024	17:35	For installation of OPGW from tower loc no. 1 to 11 of 220kV KDPH LILO line.	PO	220 KV
PT BAY @ COLOURCHEM	14-04-2024	09:29	14-04-2024	19:00	For Separation of combine jumper of 220kV Bus PT & 220kV TBC on main bus and maintenance of 220kV TBC main bus isolator.	PO	220 KV
DHARANI - NEPANAGAR	14-04-2024	01:10	14-04-2024	02:10	Tripped on distance protection.	T	132 KV
UMARKHED-GUNJ	14-04-2024	14:22	14-04-2024	16:08	FOR REMOVING TARPAULIN HANGING ON LINE CONDUCTOR		132 KV
BHIVPURI - AMBERNATH CKT - 1	09-04-2024	05:51	09-04-2024	14:28	Connection of Bus From Line Side GOD to CT	PO	110 KV
AMBERNATH - KALYAN CKT - 1	12-04-2024	08:03	12-04-2024	16:38	Insulator replacement	PO	110 KV
KALYAN KALWA SALSETTE 1	13-04-2024	10:08	13-04-2024	18:43	Making loop connection & cross jumpering at loc. 78 Kalwa end for taking line in service at Salsette end.	PO	110 KV
BUS-3 @ KHOPOLI	14-04-2024	06:05	14-04-2024	09:30	110 KV Khopoli-Bokarpada Breaker Main Bus III side jumper connection after breaker O/H	PO	110 KV
KALYAN KALWA SALSETTE 2	14-04-2024	10:14	14-04-2024	14:50	PROJECT WORK-LOOP CLOSING AT LOC-43	PO	110 KV
KOLSHET - BMC - BORIVALI (T) - BORIVALI (M)	14-04-2024	08:08	14-04-2024	20:22	BMC END WORK	PO	110 KV