

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 11/May/2015 to 17/May/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/05/2015	12 Hrs	4942	2050	276	7268	6050	206	4260	180	-1455	16509	152	16661	1330	509	19803	19955	50.00
12/05/2015	11 Hrs	5035	1800	272	7107	5274	202	4503	152	-1387	15851	57	15908	1269	505	19012	19069	49.95
13/05/2015	12 Hrs	5555	1863	272	7690	5208	123	4813	151	-1468	16517	159	16676	1262	504	19751	19910	49.97
14/05/2015	12 Hrs	4959	1869	276	7104	4444	55	4328	116	-1460	14587	52	14639	1314	510	17871	17923	49.98
15/05/2015	11 Hrs	5438	1387	274	7099	4668	57	4394	118	-1441	14895	50	14945	1176	516	18028	18078	49.94
16/05/2015	11 Hrs	5566	1887	269	7722	4998	70	4217	141	-1429	15719	47	15766	1063	512	18723	18770	49.97
17/05/2015	12 Hrs	5681	1137	273	7091	4855	299	4205	180	-972	15658	52	15710	848	517	17995	18047	50.03
Maximum		5681	2050	276	7722	6050	299	4813	180	-972	16517	159	16676	1330	517	19803	19955	50
Minimum		4942	1137	269	7091	4444	55	4205	116	-1468	14587	47	14639	848	504	17871	17923	50
Average		5311	1713	273	7297	5071	145	4389	148	-1373	15677	47	15758	1180	510	18740	18822	50

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/05/2015	16 Hrs	4699	2006	277	6982	5940	293	4264	114	-1470	16123	916	17039	1349	509	19451	20367	49.91
12/05/2015	16 Hrs	5215	1740	272	7227	5687	190	4922	97	-1415	16708	56	16764	1361	512	19996	20052	49.93
13/05/2015	15 Hrs	5755	1525	269	7549	5292	326	4856	97	-1527	16593	112	16705	1208	515	19843	19955	49.97
14/05/2015	16 Hrs	5002	1889	280	7171	4765	31	4456	85	-1502	15006	48	15054	1300	510	18318	18366	49.81
15/05/2015	13 Hrs	5249	1515	274	7038	4801	30	4042	105	-1609	14407	50	14457	1190	518	17724	17774	49.99
16/05/2015	13 Hrs	5517	1834	270	7621	5262	51	4201	167	-1537	15765	47	15812	1110	515	18927	18974	49.94
17/05/2015	15 Hrs	5629	1289	273	7191	4737	498	4245	130	-1115	15686	44	15730	845	518	18164	18208	50.02
Maximum		5755	2006	280	7621	5940	498	4922	167	-1115	16708	916	17039	1361	518	19996	20367	50
Minimum		4699	1289	269	6982	4737	30	4042	85	-1609	14407	44	14457	845	509	17724	17774	50
Average		5295	1685	274	7254	5212	203	4427	114	-1454	15755	44	15937	1195	514	18918	19099	50

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/05/2015	20 Hrs	4937	1368	275	6580	4717	766	3843	0	-1285	14621	67	14688	1125	519	17550	17617	49.98
12/05/2015	21 Hrs	5252	541	274	6067	4826	432	4887	0	-1183	15029	47	15076	1127	517	17856	17903	49.93
13/05/2015	21 Hrs	4900	798	276	5974	4259	539	4169	0	-1415	13526	47	13573	1048	380	16369	16416	49.98
14/05/2015	21 Hrs	5230	1306	275	6811	4501	472	4223	0	-1379	14628	49	14677	986	519	17512	17561	49.94
15/05/2015	21 Hrs	5433	1529	275	7237	4530	159	3464	0	-1364	14026	49	14075	1021	517	16928	16977	49.98
16/05/2015	20 Hrs	5299	1189	274	6762	4731	553	4033	0	-1331	14748	44	14792	1023	516	17618	17662	49.95
17/05/2015	21 Hrs	5163	432	276	5871	4422	1268	4110	0	-1217	14454	47	14501	884	378	16933	16980	49.99
Maximum		5433	1529	276	7237	4826	1268	4887	0	-1183	15029	67	15076	1127	519	17856	17903	50
Minimum		4900	432	274	5871	4259	159	3464	0	-1415	13526	44	13573	884	378	16369	16416	50
Average		5173	1023	275	6472	4569	598	4104	0	-1311	14433	44	14483	1031	478	17252	17302	50

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
11/05/2015	5 Hrs	4880	114	288	5282	4438	733	4214	0	-749	13918	67	13985	826	519	16012	16079	50.03
12/05/2015	5 Hrs	4749	117	291	5157	4832	442	4270	0	-1078	13623	48	13671	667	381	15749	15797	50.00
13/05/2015	24 Hrs	4825	474	278	5577	4071	630	4530	0	-1455	13353	47	13400	938	380	16126	16173	49.94
14/05/2015	5 Hrs	4872	126	277	5275	3967	592	3587	0	-914	12507	47	12554	708	519	14648	14695	50.00
15/05/2015	6 Hrs	5377	297	283	5957	4379	399	4361	0	-1068	14028	50	14078	660	395	16151	16201	49.98
16/05/2015	4 Hrs	5425	126	277	5828	4366	167	4139	0	-1105	13395	47	13442	667	464	15631	15678	50.01
17/05/2015	5 Hrs	5444	93	280	5817	4196	732	4057	0	-862	13940	49	13989	835	520	16157	16206	49.97
Maximum		5444	474	291	5957	4832	733	4530	0	-749	14028	67	14078	938	520	16157	16206	50
Minimum		4749	93	277	5157	3967	167	3587	0	-1455	12507	47	12554	660	380	14648	14695	50
Average		5082	192	282	5556	4321	528	4165	0	-1033	13538	47	13588	757	454	15782	15833	50

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
11/05/2015	118.255	23.237	6.698	148.190	0.046	124.310	118.429	13.946	100.426	1.277	25.061	12.349	-29.023	359.125	66.434	425.559
12/05/2015	120.074	18.995	6.699	145.768	0.248	120.095	119.066	9.628	110.593	1.183	24.350	11.778	-30.220	357.047	66.346	423.393
13/05/2015	125.803	18.897	6.687	151.387	0.054	110.260	109.854	12.061	111.167	1.050	23.167	11.408	-31.686	354.239	66.257	420.496
14/05/2015	118.489	25.801	6.649	150.939	0.092	105.175	105.106	6.517	99.354	0.884	24.238	12.295	-30.172	332.697	66.710	399.407
15/05/2015	130.155	24.737	6.667	161.559	0.221	104.617	103.591	5.440	96.887	0.931	23.814	12.186	-30.987	338.451	66.986	405.437
16/05/2015	130.535	25.512	6.622	162.669	0.102	110.378	105.905	5.563	100.785	1.175	22.050	11.705	-31.551	349.019	65.304	414.323
17/05/2015	130.950	14.837	6.655	152.442	0.157	107.507	106.033	15.426	99.009	1.206	20.428	11.639	-24.937	350.656	57.004	407.660
Maximum	130.950	25.801	6.699	162.669	0.248	124.310	119.066	130.950	111.167	1.277	25.061	12.349	-24.937	359.125	66.986	425.559
Minimum	118.255	14.837	6.622	145.768	0.046	104.617	103.591	118.255	96.887	0.884	20.428	11.408	-31.686	332.697	57.004	399.407
Average	124.894	21.717	6.668	153.279	0.131	111.763	109.712	124.894	102.603	1.101	20.428	11.909	-29.797	348.748	65.006	413.754

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
11/05/2015	0.443	3.856	7.483
12/05/2015	0.353	4.209	7.130
13/05/2015	0.334	4.543	6.796
14/05/2015	0.492	5.035	6.304
15/05/2015	0.463	5.498	5.841
16/05/2015	0.515	6.013	5.326
17/05/2015	0.278	6.291	5.048

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 11/May/2015 to 17/May/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
11/05/2015	MONDAY	98.936	4915	19.493	812	118.429	4935	124.310	5180	5.881	245
12/05/2015	TUESDAY	101.077	4943	17.989	750	119.066	4961	120.095	5004	1.029	43
13/05/2015	WEDNESDA	91.204	4559	18.650	777	109.854	4577	110.260	4594	0.406	17
14/05/2015	THURSDAY	85.442	4360	19.664	819	105.106	4379	105.175	4382	0.069	3
15/05/2015	FRIDAY	83.839	4297	19.752	823	103.591	4316	104.617	4359	1.026	43
16/05/2015	SATURDAY	91.484	4398	14.421	601	105.905	4413	110.378	4599	4.473	186
17/05/2015	SUNDAY	88.913	4401	17.120	713	106.033	4418	107.507	4479	1.474	61
Total		640.897		127.087		767.984		782.342		14.358	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 11/05/2015 TO 17/05/2015

Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	1:02		Continued.	Renovation and Modification work
MSPGCL	Parli Unit 4		13/Apr/2015	11:27		Continued.	Turbine vibration high. Continued to AOH w.e.f.01.05.2015
FORCED OUTAGES							
IPP	Dhariwal	300MW	28/May/2014	2:27		Continued.	PA Fan Vibration Problem
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12:43		Continued.	Economic shutdown
IPP	RPL(AMT)U1	270MW	21/Mar/2015	23:28		Continued.	Turbine vibration high.
IPP	Tata Trombay 6	500MW	06/Apr/2015	16:27		Continued.	Economic shut down.
MSPGCL	Parli Unit 4	210MW	13/Apr/2015	11:27		Continued.	Turbine vibration high.
MSPGCL	Bhusawal Unit 3	210MW	20/Apr/2015	0:00		Continued.	no buyer as per msdcl reqirment
MSPGCL	Parli Unit 3	210MW	03/May/2015	20:51	15/May/2015	6:50	Sparking on Slipring.
IPP	Adani U-2	660MW	06/May/2015	4:23	11/May/2015	21:00	FRS MOV Bonnet leakage.
MSPGCL	Khaparkheda Unit 3	210MW	08/May/2015	17:41	11/May/2015	18:24	Flame Failure
MSPGCL	Khaparkheda Unit 5	500MW	10/May/2015	2:27	13/May/2015	9:35	Boiler Tube Leakage
IPP	Adani U-3	660MW	11/May/2015	0:52		Continued.	Main Steam Drain MIY Bonnet Leakage.
MSPGCL	Nasik Unit 4	210MW	11/May/2015	4:30	12/May/2015	4:00	Gland Cooler Leakage.
MSPGCL	Koradi Unit 5	200MW	11/May/2015	4:20	12/May/2015	13:16	I D Fan Bearing Temp.High.
IPP	WPCL U-4	135MW	11/May/2015	18:19	12/May/2015	4:40	220kv warora circuit 1 & 2 Tripped.
IPP	WPCL U-3	135MW	11/May/2015	18:19	11/May/2015	22:32	220kv warora circuit 1 & 2 Tripped.
IPP	WPCL U-2	135MW	11/May/2015	18:19	12/May/2015	12:31	220kv warora circuit 1 & 2 Tripped.
IPP	WPCL U-1	135MW	11/May/2015	18:19	12/May/2015	0:46	220kv warora circuit 1 & 2 Tripped.
MSPGCL	Chandrapur Unit 4	210MW	12/May/2015	9:18	15/May/2015	15:40	Boiler Tube Leakage
MSPGCL	Khaparkheda Unit 3	210MW	13/May/2015	9:15	14/May/2015	9:15	Turbine Pressure High
IPP	Tata Trombay 7B	60MW	14/May/2015	1:58	14/May/2015	10:50	AVR Problem
MSPGCL	Paras Unit 3	250MW	14/May/2015	16:43	14/May/2015	19:11	Furnace Pressure High
IPP	JSW (J) U1	300MW	14/May/2015	19:16		Continued.	Turbine Bearing Problem
MSPGCL	Bhusawal Unit 5	500MW	14/May/2015	5:58	14/May/2015	9:53	Stator Earth Fault
MSPGCL	Chandrapur Unit 3	210MW	16/May/2015	15:40		Continued.	Bottam hash hopper work

LINE OUTAGES FOR THE WEEK FROM 11/05/2015 TO 17/05/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
765 KV	Koradi-III - Akola-II ckt-I	12/May/2015	16:32	12/May/2015	18:54	Distance Protection
500 KV	Chandrapur - Padghe Hvdc Pole 2	15/May/2015	18:19	15/May/2015	19:42	Smothering Reactor Oil Pressure Low.
400 KV	Akola II - RPL(Rattanindia) Ckt I	07/Apr/2015	0:27		Continued.	"R" Phase Metering PT Burst.
400 KV	Babhaleshwar-Taptitanda ckt-I	01/May/2015	12:16	15/May/2015	20:27	Over Voltage
400 KV	Wardha (PG)-Warora II	04/May/2015	20:47	16/May/2015	19:37	CB under lockout at Wardha PG end.
400 KV	Padghe - Kalwa- I	10/May/2015	9:45	11/May/2015	11:38	29B Isolator Maintenance Work.
400 KV	karad -kolhapur-II	10/May/2015	16:24	11/May/2015	8:30	Over Voltage
400 KV	Kolhapur Mapusa I	10/May/2015	16:40	11/May/2015	8:46	Over Voltage
400 KV	Bhusawal-Aurangabad	10/May/2015	17:45	11/May/2015	6:04	Over Voltage
400 KV	Dhule Sar'Sarovar I	10/May/2015	17:55	11/May/2015	6:51	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	11/May/2015	9:50	11/May/2015	12:54	PID Work.
400 KV	karad -kolhapur-I	11/May/2015	17:13	12/May/2015	7:58	Over Voltage
400 KV	Kolhapur Mapusa II	11/May/2015	17:19	12/May/2015	8:27	Over Voltage
400 KV	Bhusawal-Aurangabad	11/May/2015	21:42	12/May/2015	6:27	Over Voltage
400 KV	Bhusawal-Aurangabad	12/May/2015	9:25	12/May/2015	13:52	Annual Maintenance Work
400 KV	Akola Wardha II	12/May/2015	9:39	12/May/2015	16:48	Testing Work
400 KV	Kolhapur Solapur (PG) II	12/May/2015	12:00	12/May/2015	14:25	Annual Maintenance Work
400 KV	Kolhapur Mapusa I	12/May/2015	14:53	12/May/2015	21:47	Distance Protection
400 KV	karad -kolhapur-II	12/May/2015	18:06	13/May/2015	8:22	Over Voltage
400 KV	Dhule Sar'Sarovar I	12/May/2015	18:18	13/May/2015	7:03	Over Voltage
400 KV	Kolhapur Mapusa I	13/May/2015	3:39	13/May/2015	7:08	Over Voltage
400 KV	Babhaleshwar - Padghe-II	13/May/2015	11:03	13/May/2015	8:08	Distance Protection
400 KV	Koradi-Bhusawal	13/May/2015	11:03	13/May/2015	12:39	Distance Protection
400 KV	Khadka- Deepnagar Ckt 2	14/May/2015	0:34	14/May/2015	11:09	DT received from Deepnagar end
400 KV	Kalwa - Talegaon(PG)	14/May/2015	1:13	14/May/2015	7:56	To attend Hot Spot
400 KV	Girwali- Lonikand 2	14/May/2015	9:18	14/May/2015	19:20	Bay maint.work
400 KV	Talegaon PG - Aurangabad - II	14/May/2015	10:07	14/May/2015	13:11	Heavy sparking in CB at Talegaon
400 KV	karad -kolhapur-II	14/May/2015	16:39	15/May/2015	7:14	Over Voltage
400 KV	Kolhapur Mapusa II	14/May/2015	17:11	15/May/2015	6:59	Over Voltage
400 KV	Karad - Lonikand 1	14/May/2015	17:15	14/May/2015	17:36	Distance Protection
400 KV	Dhule Sar'Sarovar I	14/May/2015	18:15	15/May/2015	7:31	Over Voltage
400 KV	Padghe - Kalwa- I	15/May/2015	1:38	15/May/2015	7:56	To attend Hot Spot
400 KV	Bus Coupler @ Padgha	15/May/2015	9:31	15/May/2015	20:18	C T Replacement Work.
400 KV	karad -kolhapur-II	15/May/2015	16:15	16/May/2015	7:28	Over Voltage
400 KV	Kolhapur Mapusa I	15/May/2015	16:19	16/May/2015	6:37	Over Voltage
400 KV	Dabhol Nagothane II	15/May/2015	16:42	15/May/2015	22:48	Distance Protection
400 KV	Chandrapur II- Warora ckt II	15/May/2015	16:58	15/May/2015	20:31	Attending Hot Spot
400 KV	Bhusawal-Aurangabad	15/May/2015	17:23	16/May/2015	7:44	Over Voltage
400 KV	Dhule Sar'Sarovar II	15/May/2015	17:46	17/May/2015	8:49	Over Voltage
400 KV	Babhaleshwar-Taptitanda ckt-II	15/May/2015	19:55	16/May/2015	13:21	Distance Protection
400 KV	Babhaleshwar- Aurangabad (Waluj)	16/May/2015	16:31	17/May/2015	9:07	CT Leakage,CT Replacement Work @ Babhaleshwar End.
400 KV	Dabhol Nagothane II	16/May/2015	16:42	16/May/2015	22:48	Distance Protection
400 KV	karad -kolhapur-II	16/May/2015	17:47	17/May/2015	7:01	Over Voltage
400 KV	Kolhapur Mapusa I	16/May/2015	18:02	17/May/2015	16:01	Over Voltage
400 KV	Babhaleshwar-Taptitanda ckt-I	17/May/2015	9:30	17/May/2015	12:17	To Control Padghe-BBLR Loading
400 KV	Main Bus I @ Kalwa	17/May/2015	10:03	17/May/2015	22:09	Scissor of ICT-III R Ph & Padgha B Ph With Overhaul
400 KV	Babhaleshwar- Aurangabad (Waluj)	17/May/2015	15:06	17/May/2015	21:18	Attending Hot Spot
400 KV	Dabhol Nagothane II	17/May/2015	16:00	17/May/2015	17:18	AR Successful At Nagothane End.
400 KV	Kolhapur Mapusa II	17/May/2015	16:09		Continued.	Over Voltage
400 KV	Kolhapur Mapusa I	17/May/2015	16:19	17/May/2015	6:37	Over Voltage
400 KV	karad -kolhapur-I	17/May/2015	16:45		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar I	17/May/2015	17:17		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	17/May/2015	17:53		Continued.	Over Voltage
220 KV	Sahara-Urse	03/Mar/2015	11:06		Continued.	Tower erection work (90Days)
220 KV	Chandrapur Gcr - Warora - I	05/Apr/2015	9:13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.

220 KV	Chandrapur Gcr - Wani	05/Apr/2015	9:15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Eklahara-(Ocr)-Navasari I	05/May/2015	23:09		Continued.	To control Load on Bus section at Nasik GCR
220 KV	Niwali - Pawas Line	11/May/2015	9:44	11/May/2015	17:30	Routine Maintenance Work
220 KV	Talandge(400kv)- Sawantwadi(Insul	11/May/2015	10:16	11/May/2015	17:30	Line Maintenance work
220 KV	V Warora - Warorarltyss1	11/May/2015	18:11	11/May/2015	19:21	Distance Protection
220 KV	Wpcl-Warora 1	11/May/2015	18:14	11/May/2015	19:30	Distance Protection
220 KV	Wpcl-Warora 2	11/May/2015	18:19	11/May/2015	19:20	Distance Protection
220 KV	Parvati - Hybrid Pass	12/May/2015	8:44	13/May/2015	0:32	load control at cinchwad
220 KV	Kalwa - Borivali	12/May/2015	9:02	12/May/2015	12:15	shifted on TBC & Timing work
220 KV	Hinjawadi I- Chinchwad	12/May/2015	9:14	12/May/2015	17:34	load control at cinchwad-urse
220 KV	Talandge(400kv)- Sawantwadi(Insul	12/May/2015	9:19	12/May/2015	16:33	Annual Maintenance Work
220 KV	Nerul - Sonkhkar	13/May/2015	6:08	13/May/2015	8:53	To attend Hot Spot
220 KV	Deepnagar Khadaka 1	13/May/2015	9:25	13/May/2015	17:52	To attend Hot Spot
220 KV	Eklahara(Gcr)(Nasik)- Bableswhar 2	13/May/2015	9:42	13/May/2015	18:42	OPGW replacement work
220 KV	Karad - Vita Ckt- II	13/May/2015	10:03	13/May/2015	15:02	Replacement of Wavetrap Jumper
220 KV	Bhandara-Bhandara Rly Tss 2	13/May/2015	10:55	13/May/2015	17:16	Stringing of E/W
220 KV	Theur-Jejuri	13/May/2015	13:12	14/May/2015	9:02	Distance Protection
220 KV	Parli 3 (Oldgcr)-Harangul Ckt 2	13/May/2015	18:10	13/May/2015	22:17	To attend Hot Spot
220 KV	Nasik - Raymond	13/May/2015	20:18	14/May/2015	2:06	Bus Bar Prot.operated at Raymond
220 KV	Raymond-TKES	13/May/2015	20:18	14/May/2015	20:08	Bus Bar Protection Operated
220 KV	Main Bus @ Raymond	13/May/2015	20:18	14/May/2015	2:06	Wavetrap burst
220 KV	Khaparkheda-Kaulewada-II	14/May/2015	9:42	14/May/2015	13:50	Routine Maintenance Work
220 KV	Lonand-Baramati	14/May/2015	10:00	14/May/2015	18:20	To attend Conductor Damage
220 KV	Akola-Paras Ckt No-I	14/May/2015	10:17	14/May/2015	16:05	Tan Delta Measurment of CTs
220 KV	Talandage - Sawantwadi I	14/May/2015	13:34	14/May/2015	17:37	Insulator Cleaning work
220 KV	Uran - Jnpt	14/May/2015	10:41	14/May/2015	16:46	Premansoon maint.work
220 KV	Pedhambe - Oni	14/May/2015	11:23	14/May/2015	17:30	Insulator Cleaning work
220 KV	Uran - Kharghar I	14/May/2015	11:40	14/May/2015	19:55	Breaker O/H work(Taken on TBC)
220 KV	Telco- Chinchwad	14/May/2015	13:42	14/May/2015	20:23	Jumper work at C.P.Tower
220 KV	Amalner - Bambhori	14/May/2015	13:21	14/May/2015	14:43	line signature test
220 KV	Dhule-Chalisagaon	14/May/2015	15:18	14/May/2015	15:54	CT Ratio change at Chalisgaon end
220 KV	Jejuri-Phursungi 1	14/May/2015	15:39	14/May/2015	17:42	To attend Hot Spot
220 KV	Dhule-Chalisagaon	14/May/2015	17:51	14/May/2015	21:36	Heavy sparking on Isolator
220 KV	Nerul - Sonkhkar	15/May/2015	6:00	15/May/2015	10:29	ction-I Outage for Jumper Replacement,Hot Sopt At
220 KV	Dhule - Malegaon	15/May/2015	6:24	15/May/2015	13:50	LILO Arrangement for Saysne S/S.
220 KV	Dahanu Versova	15/May/2015	8:01	15/May/2015	9:37	Attending Hot Spot
220 KV	Uran - Kharghar 2	15/May/2015	9:25	16/May/2015	18:11	Taken on TBC for Breaker Overhauling Work.
220 KV	Nasik - Raymond	15/May/2015	11:00	15/May/2015	15:03	Replacement of R Ph CT Wavetrap Jumper.
220 KV	Boisar(M) - Ghodbunder	15/May/2015	14:17	15/May/2015	17:44	Distance Protection
220 KV	Mahad - Pedambe	15/May/2015	15:57	15/May/2015	17:20	Distance Protection
220 KV	Bhira Dharavi 7	15/May/2015	16:14	15/May/2015	16:39	Distance Protection
220 KV	Eklahara(Gcr)(Nasik)- Bableswhar-I	16/May/2015	8:27	16/May/2015	18:33	A/R Out Only for PID Work.
220 KV	Eklahara(Gcr)(Nasik)- Bableswhar 2	16/May/2015	8:27	16/May/2015	18:33	A/R Out Only for PID Work.
220 KV	Theur-Phursungi	16/May/2015	8:45	16/May/2015	16:25	Half yearly maintenance work
220 KV	Apta - Kalwa	16/May/2015	9:11	16/May/2015	15:13	A/R Out Only for PID Work.
220 KV	Kalwa - Taloja	16/May/2015	9:12	16/May/2015	15:14	A/R Out Only for PID Work.
220 KV	Beed-Patoda Ckt 1	16/May/2015	9:15	16/May/2015	14:00	Measurment of Tan Delta of CT.
220 KV	Pedambe-Nerle	16/May/2015	11:25	16/May/2015	11:40	Distance Protection
220 KV	Beed-Patoda Ckt 2	16/May/2015	14:56	16/May/2015	18:31	Measurment of Tan Delta of CT.
220 KV	Kharghar - Nerul	17/May/2015	4:47	18/May/2015	4:35	Erection of W/T and CC.
220 KV	Padgha - Temghar I	17/May/2015	6:36	18/May/2015	0:16	A Bus Outage at Padgha End.
220 KV	Padgha-Temghar-II	17/May/2015	6:36	18/May/2015	0:18	A Bus Outage at Padgha End.
220 KV	Adlabs - Pedambe	17/May/2015	7:22	17/May/2015	8:20	Distance Protection
220 KV	Padghe - Kamba	17/May/2015	23:55	18/May/2015	1:55	Load Trimming Operated.
220 KV	Mudshingi-Wathar	18/May/2015	0:33		Continued.	R Phase CT Burst.

132 KV	Khadka - Savda	11/May/2015	4:02	11/May/2015	4:12	B Ph to Ground.
132 KV	Dhule- Nardane	11/May/2015	11:16	11/May/2015	16:31	Distance Protection
132 KV	Waghala(Nanded2) - Ardhapur	14/May/2015	19:26	15/May/2015	1:07	Y Phase LA Burst
132 KV	Viraj - Jindal	15/May/2015	10:55	15/May/2015	17:39	Bus Red Hot Sopt Attending Work.
132 KV	Boisar li - Viraj	15/May/2015	11:55	15/May/2015	13:27	Bus Red Hot Sopt Attending Work.
132 KV	Bambhori(220) Jalgaon(O)	16/May/2015	14:35	16/May/2015	16:38	Distanace Protection Operated Z-I R Ph.