

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 08/May/2017 to 14/May/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/05/2017	12 Hrs	6017	286	432	6735	7910	174	4757	231	-1720	18087	0	18087	1354	235	21396	21396	49.96
09/05/2017	12 Hrs	6614	136	420	7170	7027	250	5539	240	-1758	18468	0	18468	1112	387	21725	21725	49.97
10/05/2017	12 Hrs	6905	142	253	7300	7016	192	5084	235	-1446	18381	0	18381	1187	488	21502	21502	49.96
11/05/2017	12 Hrs	6735	476	264	7475	7092	311	4748	213	-1605	18234	0	18234	1274	389	21502	21502	49.86
12/05/2017	12 Hrs	6630	275	264	7169	7208	164	4865	234	-1511	18129	0	18129	1321	500	21461	21461	49.89
13/05/2017	12 Hrs	6470	152	298	6920	7393	54	4129	219	-1439	17276	0	17276	1006	416	20137	20137	49.89
14/05/2017	12 Hrs	6646	143	420	7209	6662	275	3937	229	-1327	16985	0	16985	722	389	19423	19423	49.95
Maximum		6905	476	432	7475	7910	311	5539	240	-1327	18468	0	18468	1354	500	21725	21725	49.97
Minimum		6017	136	253	6735	6662	54	3937	213	-1758	16985	0	16985	722	235	19423	19423	49.86
Average		6574	230	336	7140	7187	203	4723	229	-1544	17937	0	17937	1139	401	21021	21021	49.93

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/05/2017	16 Hrs	6460	155	431	7046	7696	590	4959	140	-1765	18666	0	18666	1302	238	21971	21971	49.95
09/05/2017	15 Hrs	6729	121	421	7271	7106	385	5601	181	-1782	18762	0	18762	1110	388	22042	22042	49.91
10/05/2017	16 Hrs	7376	196	142	7714	6730	300	5353	142	-1498	18741	0	18741	1202	491	21932	21932	49.97
11/05/2017	16 Hrs	7041	122	276	7439	7480	337	4779	138	-1625	18548	0	18548	1294	446	21913	21913	49.88
12/05/2017	15 Hrs	6562	331	264	7157	7142	198	4903	169	-1584	17985	0	17985	1315	502	21386	21386	49.82
13/05/2017	16 Hrs	6317	228	405	6950	7605	367	3993	130	-1438	17607	0	17607	1070	505	20620	20620	49.96
14/05/2017	17 Hrs	6697	241	421	7359	6645	1009	4006	76	-1339	17756	0	17756	729	389	20213	20213	50.00
Maximum		7376	331	431	7714	7696	1009	5601	181	-1339	18762	0	18762	1315	505	22042	22042	50.00
Minimum		6317	121	142	6950	6645	198	3993	76	-1782	17607	0	17607	729	238	20213	20213	49.82
Average		6740	199	337	7277	7201	455	4799	139	-1576	18295	0	18295	1146	423	21440	21440	49.93

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/05/2017	20 Hrs	6016	269	433	6718	5458	1211	4659	0	-1674	16372	0	16372	979	255	19280	19280	49.96
09/05/2017	20 Hrs	6514	241	146	6901	5146	966	5335	0	-1651	16697	0	16697	933	402	19683	19683	49.96
10/05/2017	21 Hrs	7148	269	147	7564	4886	816	5533	0	-1573	17226	0	17226	878	389	20066	20066	49.97
11/05/2017	21 Hrs	6926	148	292	7366	5375	814	4614	0	-1556	16613	0	16613	926	389	19484	19484	49.93
12/05/2017	20 Hrs	6295	189	269	6753	5817	212	4428	0	-1476	15734	0	15734	1114	389	18713	18713	49.86
13/05/2017	20 Hrs	6334	193	427	6954	5649	777	4123	0	-1491	16012	0	16012	883	389	18775	18775	49.94
14/05/2017	21 Hrs	6473	178	433	7084	5262	1045	4112	0	-1380	16123	0	16123	767	389	18659	18659	49.95
Maximum		7148	269	433	7564	5817	1211	5533	0	-1380	17226	0	17226	1114	402	20066	20066	49.97
Minimum		6016	148	146	6718	4886	212	4112	0	-1674	15734	0	15734	767	255	18659	18659	49.86
Average		6529	212	307	7049	5370	834	4686	0	-1543	16397	0	16397	926	372	19237	19237	49.94

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/05/2017	1 Hrs	5302	101	441	5844	4863	761	4774	0	-1639	14603	0	14603	771	195	17208	17208	49.98
09/05/2017	1 Hrs	5935	100	444	6479	4942	777	5032	0	-1728	15502	0	15502	724	238	18192	18192	49.93
10/05/2017	1 Hrs	6194	74	175	6443	4908	768	4810	0	-1591	15338	0	15338	698	389	18016	18016	49.98
11/05/2017	2 Hrs	6583	206	175	6964	4825	820	4574	0	-1405	15778	0	15778	697	388	18268	18268	49.95
12/05/2017	24 Hrs	6289	80	291	6660	4536	328	4583	0	-1666	14441	0	14441	764	388	17259	17259	49.91
13/05/2017	1 Hrs	6011	94	297	6402	5077	365	4541	0	-1574	14811	0	14811	714	389	17488	17488	49.91
14/05/2017	1 Hrs	6193	98	428	6719	5146	591	4222	0	-1472	15206	0	15206	835	389	17902	17902	49.95
Maximum		6583	206	444	6964	5146	820	5032	0	-1405	15778	0	15778	835	389	18268	18268	49.98
Minimum		5302	74	175	5844	4536	328	4222	0	-1728	14441	0	14441	697	195	17208	17208	49.91
Average		6072	108	322	6502	4900	630	4648	0	-1582	15097	0	15097	743	339	17762	17762	49.94

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
08/05/2017	140.967	4.716	10.462	156.145	0.243	147.323	148.531	16.390	113.942	1.637	23.292	5.387	-37.561	397.876	66.240	464.116
09/05/2017	157.053	4.048	8.663	169.764	0.412	135.184	134.811	14.021	128.880	1.650	21.075	9.240	-36.381	413.118	66.696	479.814
10/05/2017	162.655	3.545	4.684	170.884	0.373	138.306	141.736	12.765	125.489	1.678	21.989	10.125	-33.149	415.976	65.264	481.240
11/05/2017	164.203	4.435	6.173	174.811	0.445	142.335	147.564	12.746	114.461	1.631	22.231	9.606	-35.462	410.522	67.297	477.819
12/05/2017	156.832	4.276	6.653	167.761	0.498	144.400	147.059	8.952	111.204	1.543	23.593	10.261	-34.155	399.705	68.009	467.714
13/05/2017	153.297	3.694	9.457	166.448	0.539	145.533	147.170	10.374	101.477	1.546	19.899	9.860	-32.944	392.434	62.703	455.137
14/05/2017	155.902	3.602	10.366	169.870	0.431	137.297	138.018	16.393	97.846	1.493	17.758	9.330	-30.858	392.041	57.943	449.984
Maximum	164.203	4.716	10.462	174.811	0.539	147.323	148.531	164.203	128.880	1.678	23.593	10.261	-30.858	415.976	68.009	481.240
Minimum	140.967	3.545	4.684	156.145	0.243	135.184	134.811	140.967	97.846	1.493	17.758	5.387	-37.561	392.041	57.943	449.984
Average	155.844	4.045	8.065	167.955	0.420	141.483	143.556	155.844	113.328	1.597	21.405	9.116	-34.359	403.096	64.879	467.975

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
08/05/2017	0.030	0.269	1.384
09/05/2017	0.028	0.297	1.356
10/05/2017	0.026	0.323	1.330
11/05/2017	0.027	0.350	1.303
12/05/2017	0.027	0.377	1.276
13/05/2017	0.028	0.405	1.248
14/05/2017	0.030	0.435	1.218

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 08/May/2017 to 14/May/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
08/05/2017	MONDAY	92.659	6133	55.872	2328	148.531	6189	147.323	6138	-1.208	-50
09/05/2017	TUESDAY	99.987	5582	34.824	1451	134.811	5617	135.184	5633	0.373	16
10/05/2017	WEDNESDA	103.047	5867	38.689	1612	141.736	5906	138.306	5763	-3.430	-143
11/05/2017	THURSDAY	108.239	6109	39.325	1639	147.564	6148	142.335	5931	-5.229	-218
12/05/2017	FRIDAY	110.902	6091	36.157	1507	147.059	6127	144.400	6017	-2.659	-111
13/05/2017	SATURDAY	104.064	6089	43.106	1796	147.170	6132	145.533	6064	-1.637	-68
14/05/2017	SUNDAY	102.226	5715	35.792	1491	138.018	5751	137.297	5721	-0.721	-30
Total		721.123		283.766		1004.889		990.378		-14.511	

Unit outages and trippings for the week 08/May/2017-14/May/2017

Sr.No.	Outage Type	Name	Trip Date	Trip Time	Synchronisation Date	Synchronisation Time	Reason
1	PLANNED	Trombay 6	15/Jul/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul
2	PLANNED	Chandrapur Unit 7	25/Jan/2017	19.32		Continued.	Turbine Problem, continued under COH
3	FORCED	Dabhol 1B	28/May/2013	22:02		Continued.	Gas Shortage.
4	FORCED	Dabhol 1A	27/Jun/2013	21.47		Continued.	Gas Shortage
5	FORCED	Dabhol 1X	27/Jun/2013	21.46		Continued.	Gas Shortage
6	FORCED	Koradi Unit 6	09/Jul/2015	00.00		Continued.	EE R&M LE Work
7	FORCED	SWPGL U-1	16/Feb/2016	17.09		Continued.	No PPA.
8	FORCED	SWPGL U-2	29/Feb/2016	21.46		Continued.	No PPA
9	FORCED	Parli Unit 5	01/Apr/2016	00.00		Continued.	Economic shutdown
10	FORCED	Parli Unit 4	01/Apr/2016	00.00		Continued.	Economic shutdown
11	FORCED	Bhusawal Unit 2	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
12	FORCED	Uran Unit 8	14/Aug/2016	07.56		Continued.	Maintenance work
13	FORCED	Dabhol 2A	24/Aug/2016	13.31		Continued.	Change Over.
14	FORCED	Koradi Unit 5	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
15	FORCED	PGPL U2	07/Feb/2017	17.30		Continued.	No Schedule
16	FORCED	PGPL U1	07/Feb/2017	17.30		Continued.	No Schedule
17	FORCED	RPL(AMT) U-5	15/Apr/2017	08.59		Continued.	Coal Shortage
18	FORCED	RPL(AMT) U-4	15/Apr/2017	12.08		Continued.	Coal Shortage
19	FORCED	Parli Unit 8	25/Apr/2017	07.52	11/May/2017	12.23	Turbine bearing Vabration high
20	FORCED	SWPGL U-3	25/Apr/2017	00.01	09/May/2017	23.21	ESP.
21	FORCED	Koradi Unit 10	03/May/2017	00.08	09/May/2017	02.41	Boiler Tube Leakage
22	FORCED	Khaparkheda Unit 5	06/May/2017	06.29	08/May/2017	05.13	Boiler Tube Leakage
23	FORCED	REL Unit 1	06/May/2017	20.17	09/May/2017	00.30	Boiler Tube Leakage
24	FORCED	Chandrapur Unit 5	07/May/2017	21.25	08/May/2017	01.34	Loss of fuel
25	FORCED	Koyna Unit 5	08/May/2017	08.20	14/May/2017	14.35	installation & commissioning of numerical relay.
26	FORCED	Bhusawal Unit 3	08/May/2017	20.07	10/May/2017	12.01	Boiler Tube Leakage
27	FORCED	Koradi Unit 9	08/May/2017	03.44	08/May/2017	07.39	M.S.Teamp High
28	FORCED	Uran Unit 5	09/May/2017	17.23	09/May/2017	20.40	Due to damper discrepency
29	FORCED	Uran Unit A0	09/May/2017	17.23	10/May/2017	02.17	Due to damper discrepency
30	FORCED	SWPGL U-4	09/May/2017	05.10	14/May/2017	22.36	ESP PROBLEM.
31	FORCED	Uran Unit 6	09/May/2017	17.23	13/May/2017	00.25	Due to damper discrepency
32	FORCED	Nasik Unit 5	10/May/2017	01.15	10/May/2017	06.35	Generator Elect. Fault
33	FORCED	Uran Unit A0	10/May/2017	12.00	11/May/2017	05.00	Turbine bearing Vabration high
34	FORCED	Uran Unit 5	10/May/2017	12.00	11/May/2017	01.10	Turbine bearing Vabration high
35	FORCED	JSW (J) U3	11/May/2017	16.25	11/May/2017	19.15	ID Fan Problem
36	FORCED	JSW (J) U2	11/May/2017	05.35		Continued.	No Schedule.
37	FORCED	Koradi Unit 10	12/May/2017	13.17	13/May/2017	11.43	CHP Bunkering Problem.
38	FORCED	Parli Unit 8	12/May/2017	20.10	13/May/2017	09.21	FD Fan Vibration High.
39	FORCED	Parli Unit 8	12/May/2017	10.25	12/May/2017	14.48	PA Fan problem
40	FORCED	Khaparkheda Unit 3	12/May/2017	20.04	12/May/2017	23.06	Fumace Pressure High
41	FORCED	Uran Unit 6	13/May/2017	00.52	13/May/2017	01.32	Damper Discrepency.
42	FORCED	Parli Unit 8	13/May/2017	18.01	14/May/2017	01.04	M.S.Temp Low
43	FORCED	Khaparkheda Unit 3	13/May/2017	02.08	13/May/2017	08.57	Fumace Pressure High

Line outages and trippings 08/May/2017-14/May/2017

Voltage Level	Name	Trip Date	Trip Time	Synchronisation Date	Synchronisation Time	Reason
765 KV	Koradi III - Akola II- ckt-II	08/May/2017	18.40	08/May/2017	20.51	Attending Hot Spot
500 KV	Chandrapur - Padghe Hvdc Pole 2	07/May/2017	16.26	08/May/2017	01.23	Insulator replacement
500 KV	Chandrapur - Padghe Hvdc Pole 1	09/May/2017	05.10	09/May/2017	09.27	reduce voltage.
500 KV	Chandrapur - Padghe Hvdc Pole 1	11/May/2017	00.52	11/May/2017	07.52	Line Maintenance work
500 KV	HVDC Pole-I	13/May/2017	01.37	13/May/2017	06.45	Cold Washing Insulator String.
400 KV	Ektuni-Bableshtar ckt II	01/May/2017	22.55		Continued.	to control line load.
400 KV	Karad Solapur (PG)	03/May/2017	11.49		Continued.	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
400 KV	Kalwa - Talegaon(PG)	04/May/2017	01.26	08/May/2017	22.20	Distance Protection
400 KV	400/220KV 500MVA ICT-II@Taptitanda	05/May/2017	11.02	10/May/2017	21.59	R/M,Diagnostic Testing Work.
400 KV	Koradi Satpur	06/May/2017	23.18	08/May/2017	04.32	Tripped at Sarni end and later H/T from koradi end
400 KV	Karad - Lonikand 1	07/May/2017	17.35	08/May/2017	07.49	Distance Protection
400 KV	Dhule Sar'Sarovar II	07/May/2017	17.46	08/May/2017	06.48	Over Voltage
400 KV	Akola Wardha II	08/May/2017	08.45	08/May/2017	17.01	Testing Work
400 KV	400/220 KV 315 MVA ICT-I @ Nagothane	08/May/2017	11.02	08/May/2017	19.12	Routine Maintenance Work
400 KV	Akola Wardha II	08/May/2017	17.50	09/May/2017	14.21	Distance Protection
400 KV	Karad -kolhapur-II	08/May/2017	17.56	08/May/2017	18.03	Distance Protection
400 KV	Bhusawal-Aurangabad	08/May/2017	18.21	09/May/2017	05.49	Over Voltage
400 KV	400/220 Kv 315 MVA ICT -I @New Koyana	09/May/2017	11.32	09/May/2017	18.15	taken on tbc breaker overhauling work.
400 KV	Dhule Sar'Sarovar II	09/May/2017	18.59	10/May/2017	09.45	Over Voltage
400 KV	Chandrapur-II - Warora - I	10/May/2017	09.17	10/May/2017	14.39	Routine Maintenance Work
400 KV	Koradi-India Bulls	10/May/2017	10.52	10/May/2017	13.42	Attending Hot Spot
400 KV	400/220KV 315MVA ICT-III @ Kharghar	10/May/2017	10.57	10/May/2017	20.26	Testing Work
400 KV	Girwali- Lonikand 2	10/May/2017	16.59	10/May/2017	18.07	Distance Protection
400 KV	Dhule Sar'Sarovar I	10/May/2017	17.56	11/May/2017	07.57	Over Voltage
400 KV	Chandrapur II - Dhariwal -I	11/May/2017	06.55	11/May/2017	18.31	Line Maintenance work
400 KV	Kalwa - Kharghar	11/May/2017	08.48	11/May/2017	11.16	Attending Hot Spot
400 KV	Akola - Bhusawal	11/May/2017	09.44	11/May/2017	10.20	Distance Protection
400 KV	Karad - Jaigad - II	11/May/2017	16.27	11/May/2017	19.39	DP,ZONE-2,DISTANCE:-99.76KM, CURRENT B-E 3.345KAMP, B PHASE TO EARTH FAULT.
400 KV	Chandrapur - Parli	11/May/2017	18.05	11/May/2017	18.55	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	11/May/2017	20.33	12/May/2017	06.11	Over Voltage
400 KV	Chandrapur II - Dhariwal II	12/May/2017	06.48	12/May/2017	17.25	Line Maintenance work
400 KV	400/220/33 Kv 315 Mva Ict 1 @Dhule	12/May/2017	07.33	12/May/2017	12.22	Testing Work
400 KV	Nagothane - Dabhol-II	12/May/2017	10.05	12/May/2017	18.47	Attending Hot Spot
400 KV	Dhule Sar'Sarovar I	12/May/2017	14.27	13/May/2017	09.24	PMU Work @ SSNL End,RFG @ 17.22 Hrs.
400 KV	Jejuri- Koyanastage-IV	12/May/2017	18.38	13/May/2017	11.06	D/P,B Ph. to E Z-2.
400 KV	Padghe - Nagothane - I	12/May/2017	22.48	13/May/2017	15.54	Distance Protection
400 KV	Bhusawal-Aurangabad	13/May/2017	00.08	13/May/2017	05.57	Over Voltage
400 KV	Chandrapur-II - Nanded ckt I	13/May/2017	07.56	13/May/2017	14.21	Routine Maintenance Work
400 KV	Chandrapur II- Warora ckt II	13/May/2017	08.58	13/May/2017	13.55	Routine Maintenance Work
400 KV	Dhule Sar'Sarovar II	13/May/2017	09.58	13/May/2017	12.12	By WRDC outage
400 KV	Padghe - Kalwa-II	13/May/2017	10.48	13/May/2017	14.44	Emergency outage to attend INS. Decapping on local no 1136
400 KV	400/220KV 500MVA ICT-II@Taptitanda	13/May/2017	15.59	14/May/2017	12.30	Tripped on Buchholz.
400 KV	Lonikand 1 - Talegaon(Pgcil)	13/May/2017	17.07	13/May/2017	18.00	Taken on TBC for isolater hot spot attending work.
400 KV	Dabhol Nagothane I	13/May/2017	17.09	14/May/2017	20.56	Distance Protection
400 KV	400/220/33kv 315MVA ICT-I @Lonikand	13/May/2017	19.32	13/May/2017	19.56	Tripped on NDR.
400 KV	400/220/33 Kv 500 MVA ICT-II @Lonikand	13/May/2017	19.33	13/May/2017	20.08	Distance Protection
400 KV	Khadka-Aurangabad (Waluj)	13/May/2017	20.17	14/May/2017	06.18	Over Voltage
400 KV	Dhule Sar'Sarovar II	13/May/2017	22.07		Continued.	Over Voltage
400 KV	Padghe - Kalwa-II	13/May/2017	9.13	13/May/2017	10.00	Distance Protection
400 KV	Bhusawal-Aurangabad	14/May/2017	18.18		Continued.	Over Voltage
220 KV	220/100 Kv 200 MVA ICT III @Borivali	21/Sep/2014	09.16		Continued.	Failed on internal Fault(Now repaired and ready for commissioning)
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Deepnagar Bambhori	07/May/2017	17.47	08/May/2017	00.40	Distance Protection
220 KV	Deepnagar Amalner	07/May/2017	20.16	08/May/2017	03.04	Distance Protection
220 KV	Waluj - Jalna 1	08/May/2017	08.35		Continued.	make lilo arrangement for newly const.
220 KV	Niwali - Pawas Line	08/May/2017	09.32	08/May/2017	18.23	Routine Maintenance Work
220 KV	Loteparshuram- Dasturi Line	08/May/2017	09.45	08/May/2017	18.13	cold line washing of bus insulator string.
220 KV	Main Bus @ Lote	08/May/2017	09.55	08/May/2017	18.10	cold line washing of bus insulator string.
220 KV	New Koyana - Loteparshuram	08/May/2017	09.55	08/May/2017	18.10	cold line washing of bus insulator string.
220 KV	New Koyana - Niwali	08/May/2017	10.20	08/May/2017	18.22	Routine Maintenance Work
220 KV	220/132 Kv 200 Mva Bb Ict 2 @Chikhali	08/May/2017	11.26	08/May/2017	18.26	premonsoon maintenance work.
220 KV	220/132 KV 100MVA ICT-I @ Bhokar	08/May/2017	13.12	08/May/2017	19.31	Tan Delta Measurment of CTs
220 KV	Karad -Mudshingi Ckt- IV	08/May/2017	18.25	08/May/2017	18.30	Distance Protection
220 KV	Warora - Wardha	09/May/2017	07.42	09/May/2017	10.44	Replacement of cross ARM rafter member.
220 KV	Mahad - Pedambe	09/May/2017	09.15	09/May/2017	14.07	pre monsoon maintenance work.
220 KV	Sawantwadi-Bidri	09/May/2017	09.45	09/May/2017	19.23	cold line insulator washing work.
220 KV	Satara (MIDC)-Ajinkytara	09/May/2017	09.50	09/May/2017	12.40	Quarterly Maintenance Work
220 KV	220/132 Kv 200mva V/jay Ict 2 @Jalna	09/May/2017	10.15	09/May/2017	21.03	Line Maintenance work
220 KV	Kandalgaoon - Bhira	09/May/2017	12.30	09/May/2017	17.30	pre monsoon maintenance work.
220 KV	Deepnagar Bambhori	09/May/2017	13.30	09/May/2017	17.33	Routine Maintenance Work

220 KV	Lonikand-II- Kathapur	09/May/2017	14.09	09/May/2017	14.21	Distance Protection
220 KV	satara MIDC- Malharpeth	09/May/2017	15.40	09/May/2017	18.20	Quarterly Maintenance Work
220 KV	Bhokardan-Jafarabad	09/May/2017	16.40	09/May/2017	17.05	Distance Protection
220 KV	220/132 Kv 100 Mva Emco Ict 1 @Buttib	10/May/2017	07.08	10/May/2017	09.55	Attending Hot Spot
220 KV	Koradi II - Kawlewada	10/May/2017	07.47	10/May/2017	15.09	Attending Hot Spot
220 KV	Sawantwadi-Bidri	10/May/2017	08.36	10/May/2017	21.08	Insulator Cleaning Work.
220 KV	220/33kv 125 MVA Transformer 1 @REL Borivali	10/May/2017	08.48	10/May/2017	17.21	Routine Maintenance Work
220 KV	Ambazari-Amravati	10/May/2017	09.25	10/May/2017	18.08	Replacement of Damaged Disc Insulator.
220 KV	220/100 Kv 200 MVA ICT I @Kolshet	10/May/2017	09.39	10/May/2017	17.03	Attending Hot Spot
220 KV	Wardha-Yeotmal	10/May/2017	16.15	10/May/2017	17.26	PDR Operated.
220 KV	Kharepatan -Pawas Line	10/May/2017	16.29	10/May/2017	18.02	Insulator Washing.
220 KV	Gadchandur - Virur-I	10/May/2017	16.58	10/May/2017	17.05	Heavy Sparking on Line Isolator.
220 KV	220/22 Kv 50 Mva Bb Ptr 2 @Kalwa	10/May/2017	17.07	10/May/2017	18.01	Differential Protection Crow Fault.
220 KV	Gadchandur - Virur-I	10/May/2017	17.22	11/May/2017	07.14	PDR Operated.
220 KV	Parli 3 (Oldgr)-Harangul Ckt I	10/May/2017	18.41	10/May/2017	19.08	Distance Protection
220 KV	Mudshingi - Chikodi	11/May/2017	06.01	13/May/2017	00.01	No Schedule.
220 KV	Talandage - Chikodi	11/May/2017	06.06	13/May/2017	00.02	No Schedule.
220 KV	220/132 KV 100MVA ICT-I @ Walchand	11/May/2017	07.16	11/May/2017	15.10	Quarterly Maintenance Work
220 KV	Sawantwadi-Bidri	11/May/2017	09.30	11/May/2017	18.39	Cold Washing.
220 KV	512 Khadki- Century Enka	11/May/2017	10.21	11/May/2017	18.05	Routine Maintenance Work
220 KV	Osmanabad - Solapur (Bale)	11/May/2017	11.10	11/May/2017	18.35	Routine Maintenance Work
220 KV	Bableshtar-Alephata ckt I	11/May/2017	12.56	11/May/2017	18.25	Routine Maintenance Work
220 KV	220/132 KV 100MVA ICT-II @ Walchand	11/May/2017	15.27	11/May/2017	17.33	Routine Maintenance Work
220 KV	Phursungi-Parvati	11/May/2017	23.47	12/May/2017	00.26	Removing Bird Nest.
220 KV	220/132 Kv 200 MVA ICT III @Ambazari	12/May/2017	07.45	12/May/2017	12.24	Attending Hot Spot
220 KV	Mahad - Pedambe	12/May/2017	07.55	12/May/2017	17.55	Rusted D Shackel Replacement Work.
220 KV	220/100 Kv 200 Mva Alstom Ict 2 @Apta	12/May/2017	08.34	12/May/2017	17.15	Testing Work
220 KV	Purti-Bhugaon	12/May/2017	08.55	12/May/2017	19.37	Replacement of Damaged Disc Insulator Strings.
220 KV	220/33kv 125 MVA Transformer 2 @REL Borivali	12/May/2017	10.00	12/May/2017	15.58	Annual Maintenance Work
220 KV	Wada - Bhavghar	12/May/2017	10.07	12/May/2017	12.10	Testing Work
220 KV	220/132 Kv 100 Mva Ict 1 @Phaltan Mid	12/May/2017	10.28	12/May/2017	15.51	LA Replacement Work.
220 KV	Padghe - Nalasaopara	12/May/2017	10.34	12/May/2017	16.58	Outage.
220 KV	Karad(400kv) - Wathar	12/May/2017	10.55	12/May/2017	17.35	Insulator String Replacement.
220 KV	Waluj-Padegaon I	12/May/2017	10.57	12/May/2017	20.22	Attending Hot Spot
220 KV	Deepnagar Khadaka 2	12/May/2017	13.55	12/May/2017	20.12	Attending Hot Spot
220 KV	Parli 3 (Oldgr)-Harangul Ckt I	12/May/2017	16.33	12/May/2017	16.41	While Downloading DR.
220 KV	220kv Halkarni- Tillari	12/May/2017	16.35	12/May/2017	18.23	Line is Tripped from Tillari End Only,Breaker Problem.
220 KV	Tillari Amona	12/May/2017	16.40	13/May/2017	02.20	R Ph. CC Burst @ Tillari.
220 KV	Mahalakshmi Amona	12/May/2017	16.40	12/May/2017	17.45	Breaker Trip from Amona End.
220 KV	Halkarni-Mahalaxmiline	12/May/2017	16.40	12/May/2017	17.45	Distance Protection
220 KV	Taloja li - QCIL-II	12/May/2017	19.15	12/May/2017	20.24	Distance Protection
220 KV	Pophali - Kdph	12/May/2017	19.18	12/May/2017	21.50	Distance Protection
220 KV	Kharghar-PGPL	12/May/2017	19.45	13/May/2017	7.47	Distance Protection
220 KV	Mudshingi - Chikodi	13/May/2017	06.00	13/May/2017	18.00	No schedule
220 KV	Talandage - Chikodi	13/May/2017	06.05	13/May/2017	18.13	No schedule
220 KV	220/100 Kv 200 MVA ICT-IV@Kalwa	13/May/2017	06.11	13/May/2017	17.15	Routine Maintenance Work
220 KV	Pigasus-Hinjewadi-II	13/May/2017	08.06	13/May/2017	17.03	Outage.
220 KV	220/132 Kv 100 Mva Emco Ict 2 @Donda	13/May/2017	08.47	13/May/2017	11.52	Overhauling of CTR Make OLTC of ICT-II.
220 KV	Koradi-Ambazari-II	13/May/2017	09.45	13/May/2017	12.59	Attending Hot Spot
220 KV	220/132 Kv 200 Mva Cgl Ict 1 @Raymond (Nasik 2)	13/May/2017	09.50	13/May/2017	14.32	Annual Maintenance Work
220 KV	Karad -Mudshingi Ckt- IV	13/May/2017	09.50	13/May/2017	18.16	Outage.
220 KV	Adlabs - Pedambe	13/May/2017	10.25	13/May/2017	18.10	Line Maintenance work
220 KV	Karad(400kv) - Wathar	13/May/2017	10.35	13/May/2017	18.20	Outage.
220 KV	GIS Bhandup - Borivali	13/May/2017	11.09	13/May/2017	20.31	Distance Protection
220 KV	Lamboti - Solapur li(Bale) Ckt- I	13/May/2017	14.02	13/May/2017	14.35	Distance Protection
220 KV	Kharghar-Borivali ckt II	13/May/2017	15.53	13/May/2017	20.10	H/T for outage work
220 KV	Pophali - Kdph	13/May/2017	15.55	13/May/2017	22.10	Distance Protection
220 KV	New Koyna - Loteparshuram	13/May/2017	16.35	13/May/2017	21.07	Broken conductor indication hence H/T.
220 KV	Loteparshuram- Dasturi Line	13/May/2017	17.03	13/May/2017	17.30	Distance Protection
220 KV	Phursungi-Parvati	13/May/2017	20.12	13/May/2017	20.59	Distance Protection
220 KV	Gadchandur - Grace	13/May/2017	23.44	14/May/2017	05.23	Earth Conductor Broken.
220 KV	Gadchandur - Virur-I	13/May/2017	23.44	14/May/2017	05.12	Over Current Protection
220 KV	Gadchandur - Virur-I	13/May/2017	23.44	14/May/2017	05.14	Earth Conductor Broken.
220 KV	Bhira Dharavi 7	14/May/2017	06.00	14/May/2017	19.55	Routine Maintenance Work
220 KV	Mudshingi - Chikodi	14/May/2017	06.00	14/May/2017	18.05	No Schedule
220 KV	Talandage - Chikodi	14/May/2017	06.05	14/May/2017	18.07	No Schedule
220 KV	Trombay - Kalwa	14/May/2017	09.04	14/May/2017	14.13	Routine Maintenance Work
220 KV	Niwali - Pawas Line	14/May/2017	09.25	14/May/2017	19.15	Routine Maintenance Work
220 KV	Umred-Kanhan 2	14/May/2017	13.27	14/May/2017	14.23	Distance Protection
220 KV	Phursungi-Parvati	14/May/2017	14.50	14/May/2017	16.27	Removing broken poliet string on M/C Tower
220 KV	Jejuri-Phursungi 1	14/May/2017	14.52	14/May/2017	16.32	outage on parvati-phursungi due to M/C Tower
220 KV	Talandage - Chikodi	15/May/2017	06.02		Continued.	No Schedule
220 KV	Mudshingi Chikodi	15/May/2017	06.05		Continued.	No Schedule
132 KV	Malegaon-Mangrulpir	08/May/2017	10.30	08/May/2017	14.07	erection of ht pole and bunching work.
132 KV	Paras-Warwat Bakal	08/May/2017	20.38	08/May/2017	20.55	Distance Protection
132 KV	Lalkhed-Durgwada	09/May/2017	19.00	09/May/2017	19.35	Distance Protection
132 KV	Jintur - Yeldari	10/May/2017	04.05	10/May/2017	04.25	Backup Protection
132 KV	Kardha-Asgaon	10/May/2017	20.19	10/May/2017	20.58	Distance Protection
132 KV	Hingna-li-Khapari	12/May/2017	14.47	12/May/2017	17.31	Distance Protection
132 KV	Harangul - Nilanga	12/May/2017	16.33	12/May/2017	16.41	LTS Operated @ 220KV Harangul.
132 KV	Harangul-Jagruiti sugar	12/May/2017	16.39	12/May/2017	17.08	LTS Operated @ 220KV Harangul.

132 KV	Elichpur - Hingoli	13/May/2017	09.32	13/May/2017	09.50	Distance Protection
132 KV	Gorakshan Tap On Akola-Paras Ckt-I	13/May/2017	13.04	13/May/2017	13.32	Backup Protection
132 KV	Paras-Malkapur	13/May/2017	13.04	13/May/2017	17.50	Distance Protection
132 KV	Warwat Bakal-Khamgaon	13/May/2017	13.04	13/May/2017	13.20	Backup Protection
132 KV	Akola-Paras Ckt-II	13/May/2017	13.04	13/May/2017	13.37	Backup Protection
132 KV	Deepnagar- Nimbhora	14/May/2017	13.54	14/May/2017	14.06	Distance Protection
132 KV	Elichpur - Hingoli	14/May/2017	16.14	14/May/2017	16.28	Distance Protection
132 KV	Yawal - Chopda	14/May/2017	16.17	14/May/2017	17.22	Distance Protection
110 KV	Khopoli Lodhivali Chembur	12/May/2017	19.36	12/May/2017	19.48	Distance Protection