

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 08/May/2023 to 14/May/2023

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-05-2023	12 Hrs	6613	188	237	7038	10276	248	4267	2132	-2274	21210	0	21210	714	501	25176	25176	49.93
09-05-2023	12 Hrs	6821	146	228	7194	10055	124	4963	1956	-2304	21513	0	21513	690	494	25476	25476	49.90
10-05-2023	12 Hrs	7204	386	215	7804	10391	178	4072	2172	-2349	21804	0	21804	750	498	25866	25866	50.04
11-05-2023	12 Hrs	7350	238	211	7799	10571	116	4455	2199	-2374	22287	0	22287	804	500	26444	26444	49.93
12-05-2023	12 Hrs	7098	747	214	8059	10115	364	4461	2223	-2487	22256	0	22256	716	478	26416	26416	49.95
13-05-2023	12 Hrs	6500	453	210	7163	10082	791	4348	2194	-2052	22058	0	22058	835	489	25902	25902	49.93
14-05-2023	12 Hrs	6324	212	218	6754	9519	985	4401	2278	-1839	21668	0	21668	554	320	24811	24811	49.97
Maximum		7350	747	237	8059	10571	985	4963	2278	-1839	22287	0	22287	835	501	26444	26444	50.04
Minimum		6324	146	210	6754	9519	116	4072	1956	-2487	21210	0	21210	554	320	24811	24811	49.90
Average		6844	338	219	7402	10144	401	4424	2165	-2240	21828	0	21828	723	469	25727	25727	49.95

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-05-2023	15 Hrs	6639	528	227	7394	10754	236	4510	1702	-2255	21863	0	21863	711	502	25808	25808	49.94
09-05-2023	16 Hrs	7050	462	226	7738	9994	321	5061	1181	-2322	21490	0	21490	728	501	25524	25524	50.01
10-05-2023	16 Hrs	7291	262	217	7770	10515	210	4919	1347	-2378	21912	0	21912	789	496	26046	26046	50.01
11-05-2023	16 Hrs	7557	527	213	8297	10548	216	5045	1401	-2395	22652	0	22652	941	500	26948	26948	50.02
12-05-2023	16 Hrs	7619	594	213	8426	10081	453	4763	1455	-2506	22204	0	22204	816	501	26495	26495	49.98
13-05-2023	15 Hrs	7201	229	213	7643	10229	959	4430	1882	-2345	22338	0	22338	669	458	26270	26270	49.91
14-05-2023	16 Hrs	7262	154	214	7630	9417	1472	4437	1464	-2076	21905	0	21905	555	289	25264	25264	50.02
Maximum		7619	594	227	8426	10754	1472	5061	1882	-2076	22652	0	22652	941	502	26948	26948	50.02
Minimum		6639	154	213	7394	9417	210	4430	1181	-2506	21490	0	21490	555	289	25264	25264	49.91
Average		7231	394	218	7842	10220	552	4738	1490	-2325	22052	0	22052	744	464	26051	26051	49.98

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-05-2023	20 Hrs	6845	1790	257	8892	8262	815	5323	0	-1533	21278	0	21278	1128	499	24918	24918	49.95
09-05-2023	20 Hrs	7192	1994	311	9498	8028	369	5326	0	-1546	21203	0	21203	1209	489	24918	24918	49.95
10-05-2023	21 Hrs	7446	1738	229	9414	8064	513	5984	0	-1661	21851	0	21851	1209	475	25658	25658	50.00
11-05-2023	20 Hrs	7586	1962	232	9780	7983	488	6264	0	-1702	22347	0	22347	1201	471	26187	26187	50.04
12-05-2023	20 Hrs	7821	1308	226	9355	7660	1084	6088	0	-1818	21893	0	21893	1195	389	25771	25771	49.96
13-05-2023	21 Hrs	7624	361	238	8223	8414	2065	5344	0	-1805	21773	0	21773	942	352	25340	25340	49.99
14-05-2023	22 Hrs	7584	374	241	8200	8219	1682	5131	0	-1617	21175	0	21175	854	443	24529	24529	50.03
Maximum		7821	1994	311	9780	8414	2065	6264	0	-1533	22347	0	22347	1209	499	26187	26187	50.04
Minimum		6845	361	226	8200	7660	369	5131	0	-1818	21175	0	21175	854	352	24529	24529	49.95
Average		7443	1361	248	9051	8090	1002	5637	0	-1669	21646	0	21646	1105	445	25332	25332	49.99

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08-05-2023	4 Hrs	6920	284	275	7480	7941	543	4948	0	-1406	19189	0	19189	562	379	21852	21852	50.07
09-05-2023	4 Hrs	6817	1638	269	8724	7068	392	5207	0	-1336	19712	0	19712	627	476	22494	22494	49.99
10-05-2023	4 Hrs	7274	1300	261	8834	7660	471	5084	0	-1445	20275	0	20275	674	478	23202	23202	50.00
11-05-2023	8 Hrs	7622	307	244	8173	8608	341	5281	630	-1841	20734	0	20734	569	314	23916	23916	50.05
12-05-2023	8 Hrs	7544	325	250	8119	8730	836	4815	596	-1758	20889	0	20889	569	316	23981	23981	50.02
13-05-2023	8 Hrs	7157	325	253	7735	8857	1174	4441	657	-1718	20715	0	20715	518	306	23688	23688	49.97
14-05-2023	8 Hrs	7242	280	260	7782	7915	1465	4654	661	-1546	20519	0	20519	544	307	23329	23329	50.05
Maximum		7622	1638	275	8834	8857	1465	5281	661	-1336	20889	0	20889	674	478	23981	23981	50.07
Minimum		6817	280	244	7480	7068	341	4441	0	-1841	19189	0	19189	518	306	21852	21852	49.97
Average		7225	637	259	8121	8111	746	4919	363	-1579	20290	0	20290	580	368	23209	23209	50.02

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
08-05-2023	163.547	17.069	6.137	186.753	0.000	216.305	217.346	10.083	116.382	15.738	18.663	10.658	-42.389	492.250	71.710	574.582
09-05-2023	166.943	26.576	6.334	199.853	0.017	205.677	204.596	8.731	122.151	14.388	19.889	11.096	-42.395	497.882	73.380	581.785
10-05-2023	175.936	22.702	5.835	204.473	0.019	212.269	211.503	7.981	121.981	16.383	20.797	11.219	-44.506	508.128	76.522	595.103
11-05-2023	180.873	20.546	5.586	207.005	0.000	214.119	215.018	9.851	130.911	16.783	20.812	10.861	-46.428	521.750	78.101	610.342
12-05-2023	179.903	19.439	5.613	204.955	0.030	210.453	213.118	20.069	127.364	16.946	20.688	10.133	-46.624	522.614	77.445	610.608
13-05-2023	173.663	12.877	5.625	192.165	0.000	215.029	210.524	33.484	120.583	17.142	18.687	9.771	-44.675	523.417	73.133	606.861
14-05-2023	172.491	8.197	5.680	186.368	0.000	205.044	207.765	37.810	119.057	17.345	15.943	8.014	-41.760	513.888	65.717	589.581
Maximum	180.873	26.576	6.334	207.005	0.030	216.305	217.346	180.873	130.911	17.345	20.812	11.219	-41.760	523.417	78.101	610.608
Minimum	163.547	8.197	5.586	186.368	0.000	205.044	204.596	163.547	116.382	14.388	15.943	8.014	-46.624	492.250	65.717	574.582
Average	173.337	18.201	5.830	197.367	0.009	211.271	211.410	173.337	122.633	16.389	19.354	10.250	-44.111	511.418	73.715	595.552

**Details of Koyna Water Consumption
(in TMC)**

Date	For the Day	For the Month	Balance
08-05-2023	0.309	2.902	7.482
09-05-2023	0.547	3.448	6.935
10-05-2023	0.445	3.894	6.490
11-05-2023	0.367	4.261	6.123
12-05-2023	0.343	4.604	5.780
13-05-2023	0.182	4.786	5.598
14-05-2023	0.079	4.864	5.519

**State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 08/May/2023 to 14/May/2023**

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
08-05-2023	MONDAY	107.358	8946	109.988	4583	217.346	9056	216.305	9013	-1.041	-43
09-05-2023	TUESDAY	105.618	8426	98.978	4124	204.596	8525	205.677	8570	1.081	45
10-05-2023	WEDNESDAY	109.769	8711	101.734	4239	211.503	8813	212.269	8845	0.766	32
11-05-2023	THURSDAY	83.326	8827	131.692	5487	215.018	8959	214.119	8922	-0.899	-37
12-05-2023	FRIDAY	109.108	8776	104.010	4334	213.118	8880	210.453	8769	-2.665	-111
13-05-2023	SATURDAY	95.003	8656	115.521	4813	210.524	8772	215.029	8960	4.505	188
14-05-2023	SUNDAY	88.992	8538	118.773	4949	207.765	8657	205.044	8544	-2.721	-113
Total		699.174		780.696		1479.870		1478.896		-0.974	

Generator Unit Outages/Trippings from 08.05.2023 to 14.05.2023						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Ghatghar Unit-1	20-04-2022	00:35		Continued.	Stator Earth Fault	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	12-11-2022	13:23		Continued.	Material replacement work.	FORCED
Ghatghar Unit-2	08-02-2023	07:02		Continued.	Stator Earth Fault	FORCED
Nasik Unit 3	17-04-2023	21:27	13-05-2023	22:11	Boiler Tube Leakage	FORCED
Uran Unit 6	20-04-2023	19:15	09-05-2023	19:02	No Schedule.	FORCED
Adani U-2	29-04-2023	08:21	10-05-2023	15:09	Zero Schedule.	FORCED
JSW (J) U4	01-05-2023	09:29	11-05-2023	00:34	NO SCHEDULE	FORCED
RPL(AMT) U-4	01-05-2023	15:30	18-05-2023	20:17	Coal Shortage	FORCED
Koyna STG-IV Unit-3	02-05-2023	22:10	09-05-2023	22:45	Thrust Bearing Pad Temperature very high	FORCED
Bhusawal Unit 4	06-05-2023	22:37	09-05-2023	12:07	Boiler Tube Leakage	FORCED
Chandrapur Unit 8	07-05-2023	12:29	10-05-2023	06:00	Boiler Tube Leakage	FORCED
Koyna Unit 9	09-05-2023	04:25	09-05-2023	05:35	TRIPPED DUE TO HEAVY RAIN AND LIGHTENING	FORCED
Uran Unit 6	10-05-2023	02:00		Continued.	Zero Schedule.	FORCED
Khaparkheda Unit 3	10-05-2023	08:11	11-05-2023	00:24	Air heater problem	FORCED
Koyna STG-IV Unit-3	11-05-2023	00:53	11-05-2023	18:40	Thrust bearing pad temperature very high	FORCED
Parli Unit 7	13-05-2023	01:13	13-05-2023	04:12	Furnace Pressure High	FORCED
Nasik Unit 5	13-05-2023	22:53	20-05-2023	22:25	Unit-05 subjected to Case IV Phase III Tolling immediately from 22:53 Hrs dt.13.05.2023	FORCED

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAIN BAY (707) OF KORADI CKT - 1 @ TIRORA	08-05-2023	09:53	09-05-2023	20:33	For bay(707-52) breaker SF6 gas leakage attending work.	PO	765 KV
TIE BAY (702) OF 765/21KV GT-4 and 765/400KV ICT (HV Side) @ TIRORA	11-05-2023	11:42	12-05-2023	21:03	For bay(702-52) breaker SF6 gas leakage attending work.	PO	765 KV
TIE BAY (705) OF KORADI 3 CKT - 2 & BUS REACTOR @ TIRORA	13-05-2023	11:41	16-05-2023	21:55	For bay(705-52) breaker SF6 gas leakage attending work.	PO	765 KV
CHANDRAPUR - PADGHE HVDC POLE 1	11-05-2023	22:28	11-05-2023	00:05	Emergency Shutdown of HVDC Pole-1 Non-base Filter Z11-Z3/Z4 for attending Hotspots at various locations in all the three phase,respective images are also attached	EO	500 KV
CHANDRAPUR - PADGHE HVDC POLE 2	11-05-2023	00:30	11-05-2023	02:35	Emergency Shutdown of HVDC Pole-2 Non BASE FILTER Z21-Z3/Z4 for attending Hotspots at various locations in Z21-Z3/Z4, Respective images are also attached	EO	500 KV
DHULE - DHULE(BDTCL) CKT - 1	08-05-2023	08:25	08-05-2023	19:26	Line Bays Equipment annual maintenance & Testing	PO	400 KV
LONIKAND - JEJURI CKT - 1	08-05-2023	08:37	12-05-2023	20:15	400kV CB O/H work by shifting on TBC	PO	400 KV
MAIN BAY (411) of THAPTITANDA @ DEEPNAGAR	08-05-2023	09:43	10-05-2023	22:52	For servicing & overhauling of 400kV AREVA make THAPTITANDA Line Main C.B. Mechanism	PO	400 KV
CHANDRAPUR - BHADRAVATI CKT - 2	09-05-2023	08:25	10-05-2023	18:54	Group Relay (Self-resetting) retrofitting works at GCR end. Line TLM Works.	PO	400 KV
AKOLA - KHADKA (BHUSAWAL)	09-05-2023	07:30	09-05-2023	18:29	String replacement work on 400 kV Akola- Bhusawal Line will be carried out by engaging agency which are detected punctured in PID testing.	PO	400 KV
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	09-05-2023	07:05	09-05-2023	16:11	Diagnostic testing & allied bay maintenance work	PO	400 KV
DHULE - DHULE(BDTCL) CKT - 2	09-05-2023	10:06	09-05-2023	19:37	-	PO	400 KV
DHULE - KHANDWA CKT - 1	10-05-2023	15:21	10-05-2023	17:13	Tripped on distance protection	T	400 KV
400/220/20 KV 300 MVA ICT - 1 @ KORADI	10-05-2023	08:29	10-05-2023	15:18	For taking NIFPS trials by M/s CTR Pune. Old 220KV PT will be remove from circuit due to non avilability of Tan delta point.Bus PT extended through PT selector switch relay.	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	10-05-2023	14:40	11-05-2023	01:24	1) ICT-III spare unit taken out of service by removing connection of RRS scheme. (HV, IV and tertiary) 2) ICT-III Yph unit taken into service by making connection/termination with Yph. (HV, IV and tertiary)	PO	400 KV
AKOLA - KHADKA (BHUSAWAL)	10-05-2023	06:18	10-05-2023	19:13	String replacement work on 400 kV Akola- Bhusawal Line will be carried out by engaging agency which are detected punctured in PID testing.	PO	400 KV
DHULE- - BABLESHWAR CKT - 1	10-05-2023	09:30	10-05-2023	10:16	Routine Line maintenance and Insulator cleaning work	PO	400 KV
DHULE- - BABLESHWAR CKT - 1	10-05-2023	13:22	10-05-2023	20:39	Planned outage previously taken back due to loading condition	HT	400 KV
MAIN BAY (403) OF ICT - 1 @ KARJAT	10-05-2023	15:10	10-05-2023	20:50	Diagnostic testing and bay maintenance	PO	400 KV
TIE BAY (402) OF BUS REACTOR AND ICT - 1 @ KARJAT	10-05-2023	15:10	10-05-2023	20:50	diagnostic testing and bay maintenance work	PO	400 KV

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400/220 KV 315MVA ICT - 1 @ KARAD	11-05-2023	16:19	11-05-2023	19:40	Attending hot spot at R ph 220 kV LV side 29 A isolator jaw Temp-160 Degree	EO	400 KV
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	11-05-2023	00:15	11-05-2023	04:58	Resolving FDR Trip(Fire Detector Trip) indication on NIFPS(Nitrogen Injection Fire Protection System) of Rph Unit	EO	400 KV
400KV 125 MVAR BUS REACTOR@400KV DHULE SS	11-05-2023	11:13	11-05-2023	12:44	Pre-Monsoon activity	PO	400 KV
AKOLA - KHADKA (BHUSAWAL)	11-05-2023	08:46	11-05-2023	19:53	String replacement work on 400 kV Akola- Bhusawal Line will be carried out by engaging agency which are detected punctured in PID testing.	PO	400 KV
DEEPNAGAR - THAPTI TANDA	11-05-2023	14:42	11-05-2023	21:42	tripped while charging from outage	T	400 KV
DEEPNAGAR - THAPTI TANDA	11-05-2023	21:58	12-05-2023	04:15	Distance Protection	T	400 KV
DEEPNAGAR - THAPTI TANDA	11-05-2023	07:07	11-05-2023	14:39	FOR REPLACEMENT OF FAULTY STRING S OBSERVED IN PID.	PO	400 KV
DHULE - - BABLESHWAR CKT - 1	11-05-2023	13:18	11-05-2023	21:08	Routine Line maintenance and Insulator cleaning work	PO	400 KV
MAIN BAY (417) OF 500 MVA ICT - 1 @ DEEPNAGAR	11-05-2023	13:16	13-05-2023	18:12	For servicing & overhauling of 400kV AREVA make 501 MVA ICT & 1 MAIN C.B. Mechanism	PO	400 KV
MAIN BUS - 1 @ JEJURI	11-05-2023	10:44	11-05-2023	20:39	Jumping work from 400 kV Main Bus-1 to RRS isolator 407 Bay	PO	400 KV
MAIN BUS - 2 @ KUMBHARGAON (NANDED)	11-05-2023	11:55	12-05-2023	22:32	400 KV MAIN BUS-2 (BUS BAR PROTECTION OUT ONLY) FOR TESTING OF BUSBAR PROTECTION SCHEME ALONG WITH TRIP TRAILS IN R/O 400KV, 125MVAR BUS SHUNT REACTOR AT 400KV SUBSTATION.	PO	400 KV
PARLI - KUMBHARGAON (NANDED) CKT - 1	11-05-2023	16:25	11-05-2023	17:19	DC positive extended, accidentally	T	400 KV
TIE BAY - 411 OF PARLI (GIRWALI) CKT-1 @ NANDED	11-05-2023	10:55	12-05-2023	23:22	For shifting of CT ,CB, etc wiring from TIE bay 411 to Main Bay 412.	PO	400 KV
BABHALESHWAR - PADGHE CKT- 1	12-05-2023	23:45	13-05-2023	06:26	Cold line washing of dust polluted Disc insulator strings at Naneghat section and Samrudhii Highway crossing towers.	PO	400 KV
CHANDRAPUR - BHADRAVATI CKT - 3	12-05-2023	07:42	12-05-2023	20:25	Group Relay (Self-resetting) retrofitting works at GCR end. Line TLM Works.	PO	400 KV
220 KV KORADI (400 KV) - BUTIBORI CKT	12-05-2023	08:12	17-05-2023	13:50	loop in loop out arrangement for 220 kv abhijeet- ambazari & koradi - butibori tss ckt. 1) removing of cp jumper at loc no.09 & 17. 2) at location no 17 loop in loop out arrangement to be done 3) at location no 09 loop in loop out arrangement to be done.	HT	400 KV
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	12-05-2023	10:27	12-05-2023	16:59	Routine maintenance along with isolator maintenance work.	PO	400 KV
400/220KV 167 MVA SPARE ICT @ DHULE	12-05-2023	10:40	12-05-2023	18:25	Pre-monsoon Activities	PO	400 KV
AKOLA - KHADKA (BHUSAWAL)	12-05-2023	08:11	12-05-2023	18:52	String replacement work on 400 kV Akola- Bhusawal Line will be carried out by engaging agency which are detected punctured in PID testing.	PO	400 KV

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	12-05-2023	19:13	12-05-2023	22:30	For attending hotspot observed at Y phase stub bus to IPS connecting jump & Y-phase BPI no 2 IPS to IPS connecting jump of 400 KV Bus-coupler at 400 kV Talandge.	EO	400 KV
KHADKA - BABLESHWAR	12-05-2023	13:28	12-05-2023	14:15	Tripped on Distance protection.	T	400 KV
MAIN BUS - 2 @ KUMBHARGAON (NANDED)	12-05-2023	08:36	12-05-2023	22:26	FOR ALLIED JUMPERING OF MAINBUS ISOLATOR AND DROPPERS CONNECTING AND ERECTION OF IPS TUBES FOR 400kV, 125MVAR Bus Shunt Reactor.	PO	400 KV
BABHALESHWAR - PADGHE CKT - 2	13-05-2023	23:19	14-05-2023	06:15	Cold line washing of dust polluted Disc Insulator strings at Naneghat section and Samruddhi Highway crossing towers.	PO	400 KV
CHANDRAPUR-PARLI CKT-3	13-05-2023	08:07	13-05-2023	19:04	1. Measurement of tandelta of CT and CVT. 2. Bay routine maintenance work.	PO	400 KV
AKOLA - KHADKA (BHUSAWAL)	13-05-2023	06:32	14-05-2023	05:09	String replacement work on 400 kV Akola- Bhusawal Line will be carried out by engaging agency which are detected punctured in PID testing.	PO	400 KV
BABHALESHWAR - PADGHE CKT - 2	14-05-2023	11:00	14-05-2023	17:56	Routine Line maintenance and Insulator cleaning work	PO	400 KV
KOLHAPUR - SOLAPUR (PG) CKT - 2	14-05-2023	12:35	14-05-2023	21:23	Tripped on distance protection	T	400 KV
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	14-05-2023	03:10	14-05-2023	09:38	Distance protection operated	T	400 KV
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	14-05-2023	14:45	14-05-2023	16:12	Earth wire tightening work		400 KV
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	14-05-2023	08:45	14-05-2023	17:59	1. Measurement of tandelta of CVT. 2. Bay routine maintenance work.	PO	400 KV
PARLI - KARJAT CKT - 2	14-05-2023	19:14	14-05-2023	23:11	(1) Reactor testing work. (2) Bay maintenance work.	PO	400 KV
TROMBAY DHARAVI - 6	07-05-2023	23:57	08-05-2023	05:29	Shifting of Conductors of 220kV Trombay Dharavi 6 to new Tower No 26A & 26B for Line diversion at Sejal Shakti	PO	220 KV
BIDRI - SAWANTWADI	08-05-2023	08:53	08-05-2023	19:14	For cold washing of line insulators.	PO	220 KV
EKLAHARE (GCR) - AIROLI KNOW PARK	08-05-2023	12:52	08-05-2023	16:04	HT for Load Management	HT	220 KV
MIRAJ - ICHALKARANJI	08-05-2023	15:57	08-05-2023	23:59	1) 220KV Miraj Circuit Kept off for attending work on 220KV Talandage Circuit-2 2) Bay relay testing work work.	PO	220 KV
NAGOTHANE - SPCL	08-05-2023	10:05	09-05-2023	19:07	ABB MAKE CB MECHANISM OVERHAULING WORK.	PO	220 KV
SADAWAGHAPUR KARAD CKT 2	08-05-2023	09:12	08-05-2023	19:14	Replacement work of Y & B Phase CT's due to massive oil leakage & higher tan delta values.	PO	220 KV
TALANDGE - ICHALKARANJI 2	08-05-2023	16:01	08-05-2023	23:52	1) For Quarterly bay maintenance work. 2) Faulty string insulator disc replacement work. 3) Diag Testing work. 4) Attending hotspots	PO	220 KV
TALANDGE - SAWANTWADI	08-05-2023	21:05	09-05-2023	04:38	TRIPPED ON DIST.PROTECTION	T	220 KV
220/132 KV 100 MVA ICT 2 @ RANJANGAON	08-05-2023	10:06	08-05-2023	18:47	for replacement of LV Bay CT having high tan delta	PO	220 KV
220/132-110KV 100MVA PTR 1@WATHAR	08-05-2023	10:08	08-05-2023	18:33	For OLTC drive mechanism overhauling work by M/S ER & Annual Diagonstic testing work by TCC Team. Premonsoon maint	PO	220 KV

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/33 kV 50 MVA CGL PTR 1 @ MUDSHINGI	08-05-2023	10:02	08-05-2023	18:31	Diagnostic testing & Quarterly maintenance work	PO	220 KV
220/33KV 100MVA PTR 2 @ 5 STAR MIDC, KAGAL	08-05-2023	11:10	08-05-2023	13:30	for chemical washing of insulator strings, oil leakage attending work etc.	PO	220 KV
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	08-05-2023	12:47	08-05-2023	13:21	Distance Protection	T	220 KV
GOREGAON - AAREY CKT - 1	08-05-2023	10:31	08-05-2023	17:45	Shifting of existing 220kV AIS Bay no. 1 to New GIS Bay no. 17 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.	PO	220 KV
TROMBAY DHARAVI - 6	08-05-2023	23:11	09-05-2023	04:21	Shifting of Conductors of 220kV Trombay Dharavi 6 to new Tower No 26A & 26B for Line diversion at Sejal Shakti	PO	220 KV
BHUGAON - WARDHA (PG)	09-05-2023	19:29	09-05-2023	21:04	To control OD -792MW.	HT	220 KV
BIDRI - SAWANTWADI	09-05-2023	13:54	09-05-2023	16:43	B-ph to Y-ph Tripped	T	220 KV
220/132 KV 200 MVA PTR NO 6 @ PARVATI	09-05-2023	09:15	09-05-2023	14:30	Half Yearly Maint. and CT Tan Delta	PO	220 KV
KARAD -MUDSHINGI CKT 2-TAK	09-05-2023	13:41	09-05-2023	17:00	Replacement of B-phase CT of Karad-II ckt due to higher tan-delta values	EO	220 KV
KARAD -NIGADE	09-05-2023	08:55	09-05-2023	17:36	Distance Protection	T	220 KV
NARANGWADI - SOLAPUR PG CKT - 1	09-05-2023	14:28	09-05-2023	19:11	Replacement of flash over disc insulator at location 98.	HT	220 KV
NERLE- POPHALI	09-05-2023	05:21	09-05-2023	16:15	TRIPPED ON DISTANCE PROTECTION	T	220 KV
NIWALI - PAWAS LINE	09-05-2023	02:24	09-05-2023	15:20	TRIPPED ON DISTANCE PROTECTION	T	220 KV
PALGHAR - NALASOPARA	09-05-2023	01:06	09-05-2023	07:03	For replacement of heavily rusted old Disc insulator string with porcelain long rod insulator at location no. 85,86,93,94,95,97,98 &100	EO	220 KV
POPHALI - KDPH	09-05-2023	05:07	09-05-2023	06:20	TRIPPED ON DISTANCE PROTECTION	T	220 KV
URAN - APTA CKT - 1	09-05-2023	11:24	09-05-2023	16:36	Repairing of damaged bottom phase conductor between Loc no. 4 to 5 (Railway crossing)	EO	220 KV
VITA WAIPHALE	09-05-2023	09:50	09-05-2023	19:57	Quarterly maintenance work at 220kV Waiphale S/Stn. also cold washing of insulator	PO	220 KV
BIDRI - SAWANTWADI	10-05-2023	08:42	10-05-2023	19:17	For cold washing of line insulators.	PO	220 KV
GHATODI-NANDED	10-05-2023	11:41	10-05-2023	18:05	Commissioning of auxiliary relay for a/r and distance relay testing.	HT	220 KV
IPCL - SPCL	10-05-2023	09:40	11-05-2023	16:33	ABB MAKE CB OVERHAULING WORK.	PO	220 KV
KALMESHWAR-PANDHURNA	10-05-2023	12:52	10-05-2023	18:52	Routine Maint. Work	PO	220 KV
220 KV BALAPUR - MALKAPUR LINE	10-05-2023	11:47	10-05-2023	15:41	M=DIST PROTN OPTD.Z1,Y- B,1.1KA,1.0KA.	T	220 KV
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	10-05-2023	08:49	10-05-2023	16:53	1. stringing between loc ap1a to ap1b for circuit -ii 2. 220kv bays reorientation of 220kv pandharkawda circuit-I and 220kv Chandrapur line at 220kv wani s/stn.	HT	220 KV
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA CKT 2	10-05-2023	12:14	10-05-2023	15:31	Attending mechanical problem of cgl make cb.	HT	220 KV
220 KV PARAS - MALKAPUR CKT	10-05-2023	11:29	10-05-2023	12:42	Replacement of damage insulator string at loc. loc. no 95 r-ph , 76 b-ph pilot disc of 220kv paras & malkapur line under EHV line maintenance sub division, khamgaon.	HT	220 KV
220/132 100MVA ICT-1 @ AMRAPUR	10-05-2023	08:28	10-05-2023	12:57	Outage for Pre-masoon maintenance work	PO	220 KV
220/132 KV 100 MVA ICT - 1 @KALWAN	10-05-2023	08:25	10-05-2023	12:52	Pre monsoon maintenance works	PO	220 KV
220/132 KV 200 MVA ICT - 1 @ HARANGUL	10-05-2023	07:08	10-05-2023	14:02	Premansoon maint work and auxillary protection trails.	HT	220 KV

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132-110/11KV 200MVA ICT 3 @ MIRAJ	10-05-2023	11:00	10-05-2023	16:41	R Ph HV LA's support insulator replacement work.	PO	220 KV
220/132KV 100MVA ICT 3 @ PANDHARPUR	10-05-2023	10:53	10-05-2023	14:30	Outage is required for Quarterly Maintenance	PO	220 KV
220KV MALEGAON - DHULE	10-05-2023	17:33	10-05-2023	21:35	outage/AR out for fixing of repair sleeve at loc no 45Bph &,attending red hot at R-Phase towards MLG at loc no 112 (Temp 72°C) & tightening of other various cutpoints.	PO	220 KV
250 MVA ICT-5 @ TROMBAY	10-05-2023	06:44	10-05-2023	06:55	for removal of Mesh and Bird nest from gantries at Trombay B	PO	220 KV
BHALVANI - VARKUTI	10-05-2023	10:13	10-05-2023	12:43	Outage is required for Quarterly Maintenance	PO	220 KV
BORIVALI - BOISAR II LINE	10-05-2023	06:08	10-05-2023	06:33	Bird nest removal from R-Ph Wave Trap TOp Gantry.	PO	220 KV
MAIN BUS @ JEUR	10-05-2023	12:05	10-05-2023	18:30	Outage is required for Quarterly Maintenance	PO	220 KV
TROMBAY CARNAC - 5	10-05-2023	06:07	10-05-2023	06:30	For removal of Mesh and Bird nest from gantries at Trombay generating station	PO	220 KV
VITA WAIPHALE	10-05-2023	09:14	10-05-2023	18:15	Quarterly maintenance work at 220kV Waiphale S/Stn. also cold washing of insulator	PO	220 KV
WALCHANDNAGAR-LONI DEOKAR	10-05-2023	09:30	10-05-2023	16:50	The work of cold line insulator string cleaning at bird fault proven locations.	PO	220 KV
AMBAZARI-KALMESHWAR	11-05-2023	09:37	11-05-2023	14:39	FOR REP OF FALSHED OVER INSULATOR AT VARIOUS LOCATIONS STRING & JUMPER REPLACEMENT WORK.	PO	220 KV
BIDRI - SAWANTWADI	11-05-2023	08:36	11-05-2023	19:28	For cold washing of line insulators.	PO	220 KV
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 2	11-05-2023	12:23	11-05-2023	15:54	Diagonestic testing work (CT Tandelta) & routine maint. work	PO	220 KV
EKLAHARE (GCR) - AIROLI KNOW PARK	11-05-2023	06:08	11-05-2023	06:49	Distance Protection	T	220 KV
GHATODI-NANDED	11-05-2023	12:34	11-05-2023	16:46	N- B-PH, Z1, 4.6KA,19.65KMS	T	220 KV
MHAISHAL- JATH	11-05-2023	09:06	11-05-2023	17:30	Cold washing of Insulator	PO	220 KV
URAN - APTA 3	11-05-2023	12:01	11-05-2023	17:18	"Main Bus 1, Q1 Isolator Maintaince Work by Agency. Apta end R& M Work & Lines Maintenace work"	PO	220 KV
WARORA - HINGANGHAT	11-05-2023	08:51	11-05-2023	17:31	1) REPLACEMENT OF DAMGAED/ BOLTED CLAMP JUMPERS OF CT, CC, LA, WAVETRAPH BY AGENCY. 2) DIAGNOSTIC TESTING WORK.	PO	220 KV
200 MVA 220/132 KV ICT 1 @ GIRWALI	11-05-2023	20:32	11-05-2023	21:44	132KV BUS BAR PROTECTION OPERATED DUE TO BURSTING OF R PH CT OF 132/33KV 50MVA PTR2.	T	220 KV
200 MVA 220/132 KV ICT 2 @ GIRWALI	11-05-2023	20:32	11-05-2023	21:21	132KV BUS BAR PROTECTION OPERATED DUE TO BURSTING OF R PH CT OF 132/33KV 50MVA PTR2	T	220 KV
200 MVA 220/132 KV ICT 3 @ GIRWALI	11-05-2023	20:32	11-05-2023	21:26	132KV BUS BAR PROTECTION OPERATED DUE TO BURSTING OF R PH CT OF 132/33KV 50MVA PTR2	T	220 KV
220 KV GIRWALI - MURUD CKT	11-05-2023	13:19	11-05-2023	17:50	REPLACEMENT OF LA	PO	220 KV
220 KV PARTUR - NAGEWADI CKT 1	11-05-2023	13:26	11-05-2023	15:45	N- B-PH, 3.16KA, 30.46KMS P- B-PH, 2.41KA, 35.40KMS, AR OPTD	T	220 KV
220/132 KV 100 MVA ICT 3 @ RANJANGAON	11-05-2023	14:15	11-05-2023	15:55	For ICT-3 HV side Backup relay (67) checking, solving issue & testing work.	PO	220 KV

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132kV 100MVA ICT -1 @ LONI DEOKAR	11-05-2023	09:05	11-05-2023	12:50	Pre Monsoon maintenance	PO	220 KV
220/132kV 100MVA ICT -2 @ LONI DEOKAR	11-05-2023	14:05	11-05-2023	15:36	Pre monsoon maintenance	PO	220 KV
220/22 KV 50 MVA PTR 1 @ CHAKAN	11-05-2023	11:02	11-05-2023	18:36	For attending oil leakages at HV-LV Bushing turrets and Transformer body.	PO	220 KV
220/33 KV 100 MVA PTR 2 @ NIGADE	11-05-2023	08:52	11-05-2023	19:00	Replacement work of HV Side CT	PO	220 KV
BHIGWAN - WALCHAND NAGAR	11-05-2023	09:20	11-05-2023	16:19	The work of cold line insulator string cleaning at bird fault proven locations.	PO	220 KV
CHAKAN - CHINCHWAD 2	11-05-2023	14:12	11-05-2023	17:39	1) Replacement of faulty strings identified in PID scanning . Loc No-21(R-Ph tension (C&wad) 30 (Y-Ph tension (Chakan) 2) Stringing of earth wire between loc no-23-25. 3) Replacement of damaged conductor at loc at loc no-20-21 (B ph).	PO	220 KV
KORADI-AMBAZARI-I	11-05-2023	14:27	11-05-2023	18:41	REPLACEMENT OF FLASHOVER INSULATOR STRING.		220 KV
MAIN BUS - 1 @ URAN	11-05-2023	10:30	11-05-2023	19:12	Insulator Replacement,work	PO	220 KV
NERLE - DASGAON	11-05-2023	11:00	11-05-2023	13:00	Hot spot attending work of B ph CT jumper	PO	220 KV
NEW KOYNA - PEDAMBE	11-05-2023	09:08	11-05-2023	18:42	Hotspot attending work, Routine maint. Work ,C.T. and delta Work	PO	220 KV
ABHIJEET-WARDHA-II	12-05-2023	12:25	12-05-2023	14:53	Distance Protection.	T	220 KV
ADLABS - PEDAMBE	12-05-2023	11:35	12-05-2023	18:50	For cold washing of insulator string.	PO	220 KV
AMBAZARI-ABHIJEET	12-05-2023	08:38	17-05-2023	14:07	Loop in loop out arrangement for 220 kv abhijeet- ambazari & koradi - butibori tss ckt. 1) removing of cp jumper at loc no.09 & 17. 2) at location no 17 loop in loop out arrangement to be done 3) at location no 09 loop in loop out arrangement to be done.	HT	220 KV
BIDRI - SAWANTWADI	12-05-2023	08:35	12-05-2023	19:21	Cold washing of insulators.	PO	220 KV
KHAPARKHEDA-AMBAZARI-I	12-05-2023	09:27	12-05-2023	16:01	For Yearly Diagnostic Testing Work.	PO	220 KV
TALANDAGE - FIVE STAR MIDC 1	12-05-2023	09:21	12-05-2023	17:35	For disc insulator string cleaning by chemical method.	PO	220 KV
TEMGHAR - KALWA	12-05-2023	09:21	12-05-2023	14:27	(131 Degree C) Hot spot attending work on Bus Isolator Bph Jaw Circuit Breaker side after shifting the line on TBC.	EO	220 KV
WARDHA-D-GAON NEW	12-05-2023	08:13	12-05-2023	14:58	Replacement Of Flash Over Disc.	PO	220 KV
220 KV BALAPUR - MALKAPUR LINE	12-05-2023	12:30	12-05-2023	15:01	Replacement Of Flash Over Disc.	PO	220 KV
220/110 kV 200 MVA ICT 3 @ MUDSHINGI	12-05-2023	09:05	12-05-2023	18:17	For Diagnostic testing of Transformer & HV LV CT	PO	220 KV
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	12-05-2023	09:22	12-05-2023	13:02	Oil leakage from prv	EO	220 KV
220/33KV 50MVA TF NO.2 @ SAYNE	12-05-2023	12:05	12-05-2023	15:20	premonsoon & quarterly maintenance work	PO	220 KV
MAIN BUS SECTION - 1 @ KOLSHET	12-05-2023	05:58	12-05-2023	07:34	To remove Bird nest from R-Ph gantry structure above Bus suspension insulator of 220KV Gantry (220KV Bus section-1 which includes 220KV Roma- Kolshet line, 200MVA ICT-1, 220KV PT-1)	EO	220 KV
PT BAY NO.1 @ BHOSARI	12-05-2023	09:09	12-05-2023	18:30	Replacement of 220kV PTs of PT Bay -1	PO	220 KV

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
TROMBAY - SALSETTE CKT - 1	12-05-2023	22:44	13-05-2023	18:19	Shifting of conductors at loc. 82 to tower body and final make off with loops through at loc. 82 and 83 (Bhandup Village). Removal of cross jumpers at loc. 93, making loops through (both sides) at 93. TS 1 will go in service at Sal Saki 7 bay at Salsette	PO	220 KV
TROMBAY CARNAC - 6	12-05-2023	06:52	12-05-2023	07:37	Removal of bird nest from 1st & 2nd H-Gantry	PO	220 KV
TROMBAY MSETCL TIE - 2	12-05-2023	06:25	12-05-2023	06:46	Removal of bird nest from 1st & 2nd H-Gantry	PO	220 KV
CHINCHWAD- PARVATI	13-05-2023	10:40	13-05-2023	13:55	Replacement of faulty insulator string identified in line tripping patrolling at Loc no-40A -R ph .	PO	220 KV
GANGAPUR-VALVE	13-05-2023	07:20	13-05-2023	09:58	For attending hot spot on C.B. B Ph.		220 KV
MIRAJ - MHAISHAL	13-05-2023	14:40	13-05-2023	15:31	Removing Tarpaulin entangled on Conductor at Loc 125-126	EO	220 KV
TALANDGE - SAWANTWADI	13-05-2023	09:28	13-05-2023	18:25	For Cold washing of Line insulators.	PO	220 KV
220/100 KV 200 MVA ICT 2 @ PADGHE	13-05-2023	10:45	13-05-2023	18:26	For checking and attending oil leakage from top inspection wiindwo and tarret.	PO	220 KV
220/132 KV 200 MVA ICT - 2 @ HARANGUL	13-05-2023	08:24	13-05-2023	12:13	Ict-2 LV CB overhauling work by agency.	PO	220 KV
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	13-05-2023	09:53	13-05-2023	18:49	Attending R ph C.T. red hot (temp 160), Premonsoon work.	PO	220 KV
GHODBUNDER - MSETCL BOISAR	13-05-2023	10:34	13-05-2023	13:09	Line will be shifted on TBC for:Hot spot attending work 1) At Yph T between 220kV A & B Iso.- Temp : 1200C. 2) At 220kV CB jumper (Bph) at Stub Bus T: Temp: 1250C	EO	220 KV
KALWA SALSETTE - 3	13-05-2023	08:51	13-05-2023	13:15	To attend 220 kv Kalwa -salsette-03 line trip circuit faulty at kalwa end .	EO	220 KV
KALWA SALSETTE - 3	13-05-2023	02:27	13-05-2023	06:42	Removal of conductors in span 82-11 at Bhandup village	PO	220 KV
POPHALI - KDPH	13-05-2023	21:58	14-05-2023	22:45	Tripped on distance protection	T	220 KV
SALSETTE - SAKI -7	13-05-2023	06:56	14-05-2023	17:44	Removal of cross jumpers and closing of loops at loc. 93 (Salsette yard)	PO	220 KV
TROMBAY SALSETTE LINE-2	13-05-2023	18:56	14-05-2023	17:44	Shifting of TS 2 conductors at loc. 82 and stringing of new conductors in span 82-83 at Bhandup village. Trombay Salsette 2 will go in service as Trombay Saki line.	PO	220 KV
VANKUSWADE - AJINKYATARA	13-05-2023	12:53	13-05-2023	17:53	Pre Monsoon maintenance work	PO	220 KV
220 / 110 / 33kV 315 MVA ICT 6 @ CARNAC	14-05-2023	09:24	14-05-2023	13:09	R/M	PO	220 KV
TALANDGE - MUDSHINGI CKT - 2	14-05-2023	16:52	14-05-2023	20:22	Emergency Outage	HT	220 KV
220/110/33KV 250 MVA ICT-5 @ MAHALAXMI GIS (T)	14-05-2023	11:00	14-05-2023	14:39	R/M & Testing	PO	220 KV
SOLAPUR 2(BALE)-NALDURG	12-05-2023	11:37	12-05-2023	21:50	TRIPPED ON DISTANCE PROTECTION	T	132 KV
BHIVPURI - AMBERNATH CKT - 1	08-05-2023	05:58	08-05-2023	09:50	R/M AND TESTING	PO	110 KV
BHIRA (T) - KHOPOLI 2	10-05-2023	06:18	10-05-2023	11:02	Project Work - Augmentation of OPGW communication link from 6 Core to 48 Core of Bhira Karanjade Link	PO	110 KV
BHIRA (T) - KHOPOLI 2	11-05-2023	05:42	11-05-2023	11:16	Project Work - Augmentation of OPGW communication link from 6 Core to 48 Core of Bhira Karanjade Link	PO	110 KV

Transmission Line Outages/Trippings from 08.05.2023 to 14.05.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BHIRA (T) - KHOPOLI 2	12-05-2023	05:50	12-05-2023	12:35	Project Work - Augmentation of OPGW communication link from 6 Core to 48 Core of Bhira Karanjade Link	PO	110 KV
BHIRA (T) - KHOPOLI 2	14-05-2023	06:14	14-05-2023	14:25	Project Work - Augmentation of OPGW communication link from 6 Core to 48 Core of Bhira Karanjade Link	PO	110 KV
KHOPOLI - KARANJADE	14-05-2023	14:36	14-05-2023	17:30	REMOVAL OF BIRD NEST	PO	110 KV