

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 12/Jun/2023 to 18/Jun/2023

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12-06-2023	12 Hrs	6628	234	174	7036	9484	2025	4734	2211	-2552	22441	0	22441	681	482	26654	26654	49.96
13-06-2023	12 Hrs	6512	234	180	6926	9176	2370	4685	2179	-2559	22289	0	22289	681	482	26498	26498	50.03
14-06-2023	12 Hrs	5960	220	189	6370	9311	2531	4996	2117	-2573	22265	0	22265	707	462	26494	26494	50.01
15-06-2023	12 Hrs	6672	166	187	7024	9339	2340	4336	2180	-2605	22133	0	22133	636	465	26320	26320	49.96
16-06-2023	11 Hrs	6805	246	185	7236	8278	3030	4045	2040	-2650	21474	0	21474	594	376	25599	25599	50.04
17-06-2023	12 Hrs	7182	365	185	7732	8081	2505	4803	2129	-2300	22486	0	22486	695	488	26433	26433	49.89
18-06-2023	12 Hrs	7145	231	191	7567	8469	1981	4666	2106	-1870	22486	0	22486	615	314	25718	25718	50.02
Maximum		7182	365	191	7732	9484	3030	4996	2211	-1870	22486	0	22486	707	488	26654	26654	50.04
Minimum		5960	166	174	6370	8081	1981	4045	2040	-2650	21474	0	21474	594	314	25599	25599	49.89
Average		6701	242	184	7127	8877	2397	4609	2137	-2444	22225	0	22225	658	438	26245	26245	49.99

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12-06-2023	16 Hrs	6815	126	169	7110	9498	2113	5465	1361	-2514	22537	0	22537	939	490	26976	26976	50.06
13-06-2023	16 Hrs	6828	150	174	7152	9265	2339	5541	1415	-2469	22778	0	22778	923	476	27110	27110	49.95
14-06-2023	16 Hrs	6230	152	170	6552	9261	2827	5746	1423	-2580	22753	0	22753	807	432	27048	27048	49.96
15-06-2023	16 Hrs	6844	152	179	7174	9206	2463	5211	1474	-2394	22631	0	22631	897	501	26926	26926	49.97
16-06-2023	16 Hrs	7068	156	176	7400	7379	2680	5245	1441	-2370	21287	0	21287	948	462	25555	25555	50.02
17-06-2023	16 Hrs	7363	190	183	7736	8378	2414	5815	1384	-2118	23144	0	23144	974	464	27165	27165	49.96
18-06-2023	16 Hrs	7106	183	191	7480	8661	2396	5309	1319	-1876	22841	0	22841	548	499	26212	26212	50.07
Maximum		7363	190	191	7736	9498	2827	5815	1474	-1876	23144	0	23144	974	501	27165	27165	50.07
Minimum		6230	126	169	6552	7379	2113	5211	1319	-2580	21287	0	21287	548	432	25555	25555	49.95
Average		6893	158	177	7229	8807	2462	5476	1402	-2332	22567	0	22567	862	475	26713	26713	50.00

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12-06-2023	21 Hrs	6979	418	191	7588	8234	2111	6438	0	-2028	21862	0	21862	899	323	25594	25594	50.00
13-06-2023	21 Hrs	6851	234	190	7274	7152	2574	6241	0	-1646	21151	0	21151	1116	488	24846	24846	50.03
14-06-2023	21 Hrs	6388	866	191	7444	7630	2284	6325	0	-1782	21421	0	21421	1049	448	25180	25180	49.95
15-06-2023	21 Hrs	7267	696	194	8156	7337	1925	6323	0	-1618	21639	557	22196	1136	502	25379	25936	49.96
16-06-2023	20 Hrs	7223	268	191	7682	7713	2244	5955	0	-1877	21221	0	21221	1063	377	25034	25034	50.07
17-06-2023	20 Hrs	7255	263	197	7715	8145	2495	5869	0	-1790	21948	0	21948	992	410	25626	25626	50.04
18-06-2023	21 Hrs	7197	233	200	7630	7065	2262	5954	0	-1587	20857	0	20857	865	438	24214	24214	49.97
Maximum		7267	866	200	8156	8234	2574	6438	0	-1587	21948	557	22196	1136	502	25626	25936	50.07
Minimum		6388	233	190	7274	7065	1925	5869	0	-2028	20857	0	20857	865	323	24214	24214	49.95
Average		7023	425	193	7642	7611	2271	6158	0	-1761	21443	80	21522	1017	427	25125	25204	50.00

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12-06-2023	5 Hrs	6885	192	210	7288	8673	1235	5920	0	-1572	21207	0	21207	668	295	24078	24078	49.98
13-06-2023	5 Hrs	6790	218	203	7212	9546	1525	5701	0	-1607	22015	0	22015	699	306	24988	24988	50.00
14-06-2023	4 Hrs	6825	212	206	7244	8762	1637	5917	0	-1729	21520	0	21520	601	295	24456	24456	50.00
15-06-2023	4 Hrs	6823	214	206	7242	8648	1748	5936	0	-1695	21546	0	21546	627	292	24493	24493	49.94
16-06-2023	4 Hrs	7288	484	205	7977	7771	1764	6261	0	-1391	22039	0	22039	989	317	25079	25079	50.01
17-06-2023	4 Hrs	7300	314	204	7818	7775	1873	5984	0	-1403	21697	0	21697	979	291	24720	24720	50.05
18-06-2023	8 Hrs	7137	303	207	7647	8210	1869	5269	597	-1706	21461	0	21461	487	352	24431	24431	50.01
Maximum		7300	484	210	7977	9546	1873	6261	597	-1391	22039	0	22039	989	352	25079	25079	50.05
Minimum		6790	192	203	7212	7771	1235	5269	0	-1729	21207	0	21207	487	291	24078	24078	49.94
Average		7007	277	206	7490	8484	1664	5855	85	-1586	21641	0	21641	721	307	24607	24607	50.00

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
12-06-2023	163.487	6.333	4.526	174.346	0.054	210.554	206.831	42.186	137.827	16.882	19.291	8.864	-49.304	521.789	77.459	609.950
13-06-2023	160.808	6.517	4.555	171.880	0.068	213.871	213.367	50.942	132.369	16.442	20.161	9.556	-48.326	526.612	78.043	615.221
14-06-2023	152.591	8.027	4.618	165.236	0.082	209.226	208.040	56.677	135.470	16.350	18.430	9.747	-49.561	522.732	77.738	611.136
15-06-2023	164.382	8.616	4.666	177.664	0.098	205.523	203.088	48.499	134.801	16.986	19.953	10.410	-47.353	525.271	77.716	613.836
16-06-2023	170.905	8.948	4.677	184.530	0.272	187.574	184.623	54.629	129.766	16.815	21.134	9.695	-46.962	515.553	77.791	604.143
17-06-2023	174.479	8.368	4.740	187.587	0.110	189.516	184.466	53.966	134.942	16.474	21.684	9.556	-43.387	528.673	74.627	613.725
18-06-2023	169.102	6.720	4.812	180.634	0.113	193.494	191.909	52.843	128.737	15.892	18.281	9.454	-39.765	521.617	67.500	599.335
Maximum	174.479	8.948	4.812	187.587	0.272	213.871	213.367	174.479	137.827	16.986	21.684	10.410	-39.765	528.673	78.043	615.221
Minimum	152.591	6.333	4.526	165.236	0.054	187.574	184.466	152.591	128.737	15.892	18.281	8.864	-49.561	515.553	67.500	599.335
Average	165.108	7.647	4.656	177.411	0.114	201.394	198.903	165.108	133.416	16.549	19.848	9.612	-46.380	523.178	75.839	609.621

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
12-06-2023	0.066	3.655	63.845
13-06-2023	0.059	3.714	63.786
14-06-2023	0.080	3.793	63.707
15-06-2023	0.110	3.903	63.597
16-06-2023	0.097	4.001	63.499
17-06-2023	0.086	4.087	63.413
18-06-2023	0.039	4.126	63.374

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 12/Jun/2023 to 18/Jun/2023

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
12-06-2023	MONDAY	81.801	8493	125.030	5210	206.831	8618	210.554	8773	3.723	155
13-06-2023	TUESDAY	69.747	8747	143.620	5984	213.367	8890	213.871	8911	0.504	21
14-06-2023	WEDNESDAY	58.935	8519	149.105	6213	208.040	8668	209.226	8718	1.186	49
15-06-2023	THURSDAY	67.101	8326	135.987	5666	203.088	8462	205.523	8563	2.435	101
16-06-2023	FRIDAY	43.931	7552	140.692	5862	184.623	7693	187.574	7816	2.951	123
17-06-2023	SATURDAY	44.101	7546	140.365	5849	184.466	7686	189.516	7897	5.050	210
18-06-2023	SUNDAY	46.744	7851	145.165	6049	191.909	7996	193.494	8062	1.585	66
Total		412.360		979.964		1392.324		1409.758		17.434	

Generator Unit Outages/Trippings from 12.06.2023 to 18.06.2023						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	4:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Ghatghar Unit-1	20-04-2022	0:35		Continued.	Stator Earth Fault	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	12-11-2022	13:23		Continued.	Major overhauled.	FORCED
Chandrapur Unit 5	22-05-2023	19:00		Continued.	Stator Earth Fault	FORCED
Uran Unit 6	01-06-2023	19:57	13-07-2023	19:34	No Schedule	FORCED
Koyna STG-IV Unit-1	05-06-2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4 & 5.	FORCED
Koyna STG-IV Unit-3	07-06-2023	15:30	11-07-2023	15:35	Due to water shortage.	FORCED
Koyna STG-IV Unit-2	07-06-2023	15:30	12-07-2023	18:00	Due to water shortage.	FORCED
Koyna STG-IV Unit-4	08-06-2023	10:45	11-07-2023	15:35	Water Shortage	FORCED
Nasik Unit 3	08-06-2023	11:40	04-07-2023	16:35	Tolling Agreement with IEPL synchronised at 9:19 Hrs	FORCED
Paras Unit 4	11-06-2023	13:46	15-06-2023	13:17	Boiler Tube Leakage	FORCED
Chandrapur Unit 4	11-06-2023	18:51	14-06-2023	18:30	SUSPECTED BTL AT AB-4 ELEVATION	FORCED
RPL(AMT) U-3	13-06-2023	0:01		Continued.	Annual Overhaul	PLANNED
Bhusawal Unit 3	13-06-2023	3:15	15-06-2023	14:50	ID Fan Problem	FORCED
Trombay 7B	13-06-2023	23:10	16-06-2023	17:05	Gas shortage	FORCED
Trombay 7A	13-06-2023	23:24	16-06-2023	12:44	Gas shortage	FORCED
Chandrapur Unit 6	14-06-2023	4:25	14-06-2023	9:24	Stator Earth Fault	FORCED

Chandrapur Unit 6	14-06-2023	9:25	14-06-2023	10:48	Drum level low	FORCED
Chandrapur Unit 7	14-06-2023	11:48	14-06-2023	22:21	Air heater problem	FORCED
RPL(AMT) U-5	16-06-2023	6:45	21-06-2023	18:22	Ash Conveyer problem	FORCED
Paras Unit 3	16-06-2023	22:49	17-06-2023	2:00	HPCF pump no 2 pressure low Turbine tripped.	FORCED
Parli Unit 8	18-06-2023	23:55	15-07-2023	23:45	Annual Overhaul	PLANNED

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
CHANDRAPUR - PADGHE HVDC POLE 1	13-06-2023	0:30	14-06-2023	5:42	Emergency Shutdown of HVDC Pole 1 for premonsoon maintenance work.	EO	500 KV
CHANDRAPUR - PADGHE HVDC POLE 1	14-06-2023	0:30	14-06-2023	5:42	Emergency Shutdown of HVDC Pole 1 for premonsoon maintenance work.	HT	500 KV
CHANDRAPUR - PADGHE HVDC POLE 2	16-06-2023	23:03	17-06-2023	3:09	Emergency outage for Pre-monsoon Maint. work	HT	500 KV
400 KV KARAD - SOLAPUR (PG) LR	05-06-2023	10:58	14-06-2023	16:07	Overhauling of 400 kV CGL make SF CB by	PO	400 KV
PADGHE - NAGOTHANE CKT - 2	08-06-2023	13:08	13-06-2023	18:37	Work of shifting/height raising of various	PO	400 KV
LONIKAND I - TALEGAON (PGCIL)	12-06-2023	9:54	16-06-2023	22:02	400kV CB O/H work by shifting on TBC and 29-A PG Isolator mechanimc box replacement and trials	PO	400 KV
220 KV CHANDRAPUR GCR (400 KV) GRACE CKT	12-06-2023	14:07	12-06-2023	18:56	Routine Maintenance Work.	PO	400 KV
400/220 KV 315MVA ICT - 1 @ KARAD	12-06-2023	8:34	12-06-2023	18:05	For alignment of 220 kV Bus-I Isolator by opening jumps from Bus-I with the help of Hot Line Unit,Ogalewadi as there is hotspot in Y ph Isolator jaw towards Bus side. Temp-160 degree.	PO	400 KV
400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	12-06-2023	21:28	13-06-2023	23:59	To attend hotspot of 400 kV Bushing -B ph (Temp 160 ċC)	EO	400 KV
BUS REACTOR (50 MVar) @ KORADI	12-06-2023	9:22	12-06-2023	19:25	Bushings TAN Delta	PO	400 KV
JEJURI - KARAD	12-06-2023	20:10	14-06-2023	19:32	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad	PO	400 KV
TBC 2 @ CHANDRAPUR	12-06-2023	8:48	22-06-2023	14:15	Replacement of problematic old BHEL make 400kV quad break CB of TBC-2 bay with new siemens ltd make 400kV Quad CB.	PO	400 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
DHULE - KHANDWA CKT - 1	13-06-2023	9:08	16-06-2023	2:49	MTAMC Project work Main-I Dist Protn, REF & Master trip relay Gr-A & B replacement work	PO	400 KV
NAGOTHANE - DABHOL CKT - 1	13-06-2023	9:45	13-06-2023	11:47	bus 1 and bus -2 tripped at 400kv nagothane s/stn	T	400 KV
NAGOTHANE - DABHOL CKT - 1	13-06-2023	11:49	14-06-2023	13:50	LINE H/T DUE TO HEAVY SPARKING ON Y PHASE CT AT NAGOTHANE END	HT	400 KV
NAGOTHANE - DABHOL CKT - 2	13-06-2023	9:45	14-06-2023	12:57	bus 1 and bus -2 tripped at 400kv nagothane s/stn	T	400 KV
PADGHE - NAGOTHANE CKT - 1	13-06-2023	9:45	13-06-2023	10:13	bus 1 and bus -2 tripped at 400kv nagothane s/stn	T	400 KV
220 KV CHANDRAPUR 2 - TADALI CKT	13-06-2023	7:39	13-06-2023	13:53	To attend damaged/ broken strand of conductor	PO	400 KV
220KV CHANDRAPUR MIDC- CHANDRAPUR 2(400KV) CKT	13-06-2023	7:29	13-06-2023	14:11	Replacement of Broken Disc Insulator	PO	400 KV
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	13-06-2023	9:45	13-06-2023	10:36	bus 1 and bus -2 tripped at 400kv nagothane s/stn	T	400 KV
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	13-06-2023	9:45	13-06-2023	10:20	bus 1 and bus -2 tripped at 400kv nagothane s/stn	T	400 KV
400/220/33 KV 167 MVA SPARE ICT @ WALUJ	13-06-2023	11:50	13-06-2023	18:14	Installation of SCADA interfacing control box of CTR fire fighting system panel.	PO	400 KV
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	13-06-2023	9:45	13-06-2023	18:45	bus 1 and bus -2 tripped at 400kv nagothane s/stn	T	400 KV
JAIGAD - KARAD CKT - 1	13-06-2023	9:08	13-06-2023	13:35	BAY EQUIPMENT WASHING	PO	400 KV
PARLI - KUMBHARGAON(NANDED) CKT - 2	14-06-2023	12:17	15-06-2023	3:24	(1) Distance relay testing work. (2) Bay maintenance work. (3) Hardware tightning and fitting work.	PO	400 KV
220 KV CHANDRAPUR 2 - BALLARSHAH CKT	14-06-2023	8:06	14-06-2023	17:07	Safety purpose for attending R ph damaged strands of 220kv chandrapur 2 - chandrapur GCR.	PO	400 KV
220 KV CHANDRAPUR GCR - CHANDRAPUR 2 CKT	14-06-2023	8:03	14-06-2023	17:05	Attending R ph Damaged/Broken strand of conductor work.	PO	400 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
AURANGABAD(MS) - PUNE (GIS) CKT - 2	14-06-2023	12:55	24-06-2023	18:00	TO CONTROL LINE LOADING	HT	400 KV
KHADKA - BABLESHWAR	14-06-2023	13:14	14-06-2023	17:21	For routine bay maintenance works.	PO	400 KV
PADGHE - NAGOTHANE CKT - 1	15-06-2023	11:17	20-06-2023	20:30	1. Stringing of 6 Nos of spans between location nos 310-313. 2. Dismantling of 2 nos of Lattice towers	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	15-06-2023	8:23	15-06-2023	22:50	1. Measurement of tandelta of CT, bushing & winding. 2. Premonsoon maintenance work. 3. Bay routine maintenance work.	PO	400 KV
PADGHE - PADGHE HVDC CKT- 1	15-06-2023	17:00	15-06-2023	17:09	400kV HVDC-1 CB tripped at 400kV Padghe Stn only on 17.00Hrs on PDR	T	400 KV
DHULE - KHANDWA CKT - 2	16-06-2023	13:18	18-06-2023	21:34	MTAMC Project work Main-I Dist Protn, REF & Master trip relay Gr-A & B relay replacement work	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	17-06-2023	14:17	17-06-2023	18:22	Pre-monsoon maintenance activity	PO	400 KV
400/220/33KV 315MVA ICT - 2 @ LONIKAND	17-06-2023	9:37	17-06-2023	12:51	Pre-monsoon maintenance activity	PO	400 KV
400/220/33KV 500 MVA ICT - 1 @ KUDUS	17-06-2023	14:56	17-06-2023	18:43	Tripped on NDR	T	400 KV
KHADKA-AURANGABAD (WALUJ)	17-06-2023	10:05	17-06-2023	16:00	For routine bay maintenance works.	PO	400 KV
BABHALESHWAR - PADGHE CKT - 2	18-06-2023	22:08	19-06-2023	6:06	Routine Line maintenance and Insulator cleaning work	PO	400 KV
PADGHE - KALWA CKT - 1	18-06-2023	15:53	18-06-2023	19:27	To replace the decapped insulator string at loc no -1040 B Phase(DSN)	EO	400 KV
LONIKAND I - KOYNA STAGE-IV	18-06-2023	8:26	18-06-2023	19:02	Repairing of damaged conductor between Loc.No.21-22 (Y Phase)	EO	400 KV
AAREY - AEML SAKI CKT - 1	28-05-2023	17:23	13-06-2023	14:36	Tripped on Differential protection.	T	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAHAD-KALAMBANI(TSS)	10-06-2023	19:32	12-06-2023	13:08	1) Erection of 06 nos cross-arm on 02 nos monopole. 2) Stringing of 03 nos conductor on new erected monopole. 3) Stringing of 03 nos conductor both sides of 02 nos erected monopole. 4) Dismantling of old conductor and tower (02 nos)	PO	220 KV
BORIVALI - TARAPUR	11-06-2023	14:47	12-06-2023	3:17	Bus fault at Borivali s/s due to bad whether	T	220 KV
BARAMATI - KURKUMBH	12-06-2023	10:10	12-06-2023	10:35	To remove bird nest from gantry in switchyard.	PO	220 KV
BORIVALI - TARAPUR	12-06-2023	13:03	12-06-2023	23:50	Distance Protection	T	220 KV
GADCHANDUR - GRACE	12-06-2023	7:52	12-06-2023	13:50	Routine Maintenance Work.	PO	220 KV
TALANDAGE - FIVE STAR MIDC 1	12-06-2023	10:06	12-06-2023	13:29	For hotspot attending work (220KV Bus isolator)	PO	220 KV
100 MVA 220/132 KV ICT - II @ NARANGWADI	12-06-2023	10:50	12-06-2023	17:47	Pre-Monsoon Maintenance Work.	PO	220 KV
132 KV KANHAN-KANHAN RLY TSS 1	12-06-2023	12:30	12-06-2023	14:07	For Attending Overload Relay And Contactor Problem In CB.	PO	220 KV
220 KV AMRAVATI - KARANJA CKT	12-06-2023	11:05	12-06-2023	15:27	Distance & Back Up Protection Work.	PO	220 KV
220/132 KV 200MVA ICT 2 @ KURKUMBH	12-06-2023	11:00	12-06-2023	11:17	To remove bird nest on gantry in switchyard.	PO	220 KV
220/132-110/11KV 200MVA ICT 3 @ MIRAJ	12-06-2023	12:05	12-06-2023	17:01	Diagnostic testing & Quarterly maintenance work	PO	220 KV
220/132KV 200MVA ICT 1 @ KURKUMBH	12-06-2023	10:38	12-06-2023	10:50	To remove bird nest from gantry in switchyard.	PO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAIN BUS @ DASTURI	12-06-2023	14:00	12-06-2023	18:30	Replacement of damaged jumpers of Bus isolator towards 220KV Bus of Lote line & Kandalgaon line (Bph) at Dasturi S/s. Annual Maintenance of 220kv Bus & 220KV PT at 220/33kV Dasturi S/S.	PO	220 KV
MALEGAON - KALWAN CKT-2	12-06-2023	10:37	12-06-2023	13:25	An outage required for urgent tree cutting falling under Ckt-II under the vicinity of line fpr the preventive maintenance purpose	PO	220 KV
PALGHAR - NALASOPARA	12-06-2023	12:22	12-06-2023	18:28	Distance Protection	T	220 KV
TOPWORTH - Vile - bhagad	12-06-2023	12:15	12-06-2023	16:00	1.For replacement of 89 C isolator gear box 2. Dignostic testig work at Vilebhagad S/s end 3. Line maintenance work	PO	220 KV
TPC BORIVALI - AAREY	12-06-2023	12:16	12-06-2023	12:48	Through fault	T	220 KV
ABHIJEET-WARDHA-1	13-06-2023	8:14	13-06-2023	12:14	Testing work	PO	220 KV
BORIVALI - TARAPUR	13-06-2023	17:27	14-06-2023	13:14	Tripped on Distance Protection.	T	220 KV
KALMESHWAR-PANDHURNA	13-06-2023	8:45	13-06-2023	19:11	FOR LINE MAINTENANCE WORK	PO	220 KV
LOTEPARSHURAM- DASTURI LINE	13-06-2023	11:06	13-06-2023	16:45	Tripped on Distance Protection.	T	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PANDHARPUR - MALINAGAR	13-06-2023	16:36	13-06-2023	20:40	Outage is required for Date:- 12.06.2023; Cold line cleaning loc no. 1 to 30 Date:- 13.06.2023; Cold line cleaning loc no. 31 to 61 Date:- 14.06.2023; Cold line cleaning loc no. 62 to 118 For changing /replacement of faulty string at loc no LILO portion 60, 64, 67. Date:- 15.06.2023; Cold line cleaning LILO loc no. 1 to 30 Date:- 16.06.2023; Cold line cleaning LILO loc no. 31 to 60 Date:- 17.06.2023; Cold line cleaning LILO loc no. 61 to 62	PO	220 KV
PEDHAMBE ONI LINE	13-06-2023	8:20	13-06-2023	13:20	Pre-monsoon maintenance activities to be done.	PO	220 KV
PEDHAMBE ONI LINE	13-06-2023	8:20	13-06-2023	13:20	For cold washing of insulator strings & other maintenance work.	PO	220 KV
PUSAD - WARDHA (PG)	13-06-2023	12:24	16-06-2023	0:40	Urgent CB mechanism overhauling-- 1. Low SF6 Pressure alarm 2. Change Aux. Contact of CB	EO	220 KV
220/132KV 100MVA ICT 1 @ SATARA MIDC	13-06-2023	9:03	13-06-2023	16:41	Replacement work of LV CTs & testing of LTS scheme on HV Back up relay of 100MVA ICT-1	PO	220 KV
220/33 KV 50 MVA PTR 1 @ VIRAJ	13-06-2023	17:54	13-06-2023	20:03	Tripped due to R-ph LA Burst LV	T	220 KV
220/33KV 50MVA PTR 1 @ MIRAJ	13-06-2023	11:45	13-06-2023	17:19	For replacing chipped support insulator stack of TF HV side isolator	PO	220 KV
220KV PT-1 of BUS-1@ MULUND	13-06-2023	8:15	13-06-2023	16:04	PRE MANSOON ACTIVITY work & PAINTING WORK.	PO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220KV PT-2 of BUS-1@ MULUND	13-06-2023	16:10	13-06-2023	19:08	PRE MANSOON ACTIVITY work & PAINTING WORK.	PO	220 KV
BALE - SOLAPUR (PG)	13-06-2023	11:40	13-06-2023	13:05	220kV Bale Pgcil(solapur) line tripped due to the DT send, LBB operated.	T	220 KV
PARANDA - OSMANABAD	13-06-2023	8:29	13-06-2023	15:41	Quarterly Maintenance work	PO	220 KV
BHUGAON - WARDHA (PG)	14-06-2023	10:40	14-06-2023	17:35	For Amp of Line Bay	PO	220 KV
KHAPARKHEDA-KALMESHWAR	14-06-2023	10:01	14-06-2023	15:20	Replacement of F/O string at various location.	PO	220 KV
MAHALAXMI - AMONA	14-06-2023	10:37	14-06-2023	16:54	Maintenance work. For cold washing of 220 kV line bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments at 220kV Mahalaxmi ss.	PO	220 KV
OSMANABAD - SOLAPUR (BALE)	14-06-2023	10:48	14-06-2023	19:31	High tan delta CT replacement work.	PO	220 KV
OSMANABAD - SOLAPUR (BALE)	14-06-2023	10:48	14-06-2023	19:31	Outage is required for High tan delta CT replacement work	PO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PANDHARPUR - MALINAGAR	14-06-2023	10:46	14-06-2023	19:37	Outage is required for Date:- 12.06.2023; Cold line cleaning loc no. 1 to 30 Date:- 13.06.2023; Cold line cleaning loc no. 31 to 61 Date:- 14.06.2023; Cold line cleaning loc no. 62 to 118 For changing /replacement of faulty string at loc no LILO portion 60, 64, 67. Date:- 15.06.2023; Cold line cleaning LILO loc no. 1 to 30 Date:- 16.06.2023; Cold line cleaning LILO loc no. 31 to 60 Date:- 17.06.2023; Cold line cleaning LILO loc no. 61 to 62	PO	220 KV
220/100 KV 200 MVA ICT 1 @ PADGHE	14-06-2023	16:23	15-06-2023	19:25	200MVA 220/100kV ICT-1, frequent starting problem of differential relay RET670.	HT	220 KV
220/132 KV 200 MVA ICT 2	14-06-2023	8:05	14-06-2023	10:20	Monsoon & routine maintenance work.	PO	220 KV
220/132 KV 200 MVA ICT 1	14-06-2023	9:50	14-06-2023	17:30	Routine diagnostic testing of ICT work	PO	220 KV
220/132 KV 200 MVA ICT 1	14-06-2023	9:44	14-06-2023	15:45	LV side main circuit breaker overhauling work by agency, Tan delta and premonsoon maint work.	PO	220 KV
220/132 KV 200 MVA PTR NO 5 @ PARVATI	14-06-2023	10:51	14-06-2023	15:15	For safety purpose to replace 132 kV PT 01	EO	220 KV
220/132KV 100MVA ICT 3 @ PANDHARPUR	14-06-2023	16:52	14-06-2023	19:55	Outage is required for Auxillary Protection trails Testing	PO	220 KV
220/132KV 200MVA ICT 2 @ PANDHARPUR	14-06-2023	11:51	14-06-2023	15:53	Outage is required for Auxillary Protection trails Testing	PO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	14-06-2023	3:52	14-06-2023	4:15	Tripped from Nagar end only	T	220 KV
BUS COUPLER @ SOUTH SOLAPUR	14-06-2023	11:32	14-06-2023	13:05	Outage is required for Quarterly Maintenance	PO	220 KV
GOREGAON - VERSOVA CKT - 2	14-06-2023	9:45	14-06-2023	20:52	Attending the hotspots on line.	EO	220 KV
LAMBOTI - VAIRAG	14-06-2023	17:06	14-06-2023	19:41	Outage is required for Quarterly Maintenance	PO	220 KV
MAIN BUS @ VAIRAG	14-06-2023	17:06	14-06-2023	19:41	Outage is required for Quarterly Maintenance	PO	220 KV
TROMBAY CARNAC - 5	14-06-2023	23:56	15-06-2023	2:11	For Attending Hotspot of C Phase Dead end	PO	220 KV
AAREY - AEML SAKI CKT - 2	15-06-2023	9:03	16-06-2023	17:50	Attending the cable damage of R phase and B phase.	PO	220 KV
BHUGAON - WARDHA (PG)	15-06-2023	22:32	15-06-2023	23:43	H/T For OD Control	HT	220 KV
NANDED 2 (WAGHALA) - PARBHANI	15-06-2023	13:57	15-06-2023	17:25	For replacement of faulty abb make rel 670 distn proten relay with repaired abb make relay.	HT	220 KV
RANJANGAON-LONIKAND	15-06-2023	11:50	16-06-2023	20:35	220kV Circuit breaker overhauling work.	PO	220 KV
WARDHA - WARDHA (PG)	15-06-2023	22:36	16-06-2023	0:15	H/T For OD control	HT	220 KV
100 MVA 220/132 KV ICT - I @ JALKOT	15-06-2023	11:15	15-06-2023	15:20	LV back up prot optd.	HT	220 KV
220 / 11 KV 200 MVA GT @ BHIRA (T)	15-06-2023	6:09	15-06-2023	10:35	Pre-monsoon Checks and attending Oil leakage in Radiator Bank	PO	220 KV
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	15-06-2023	8:33	15-06-2023	10:58	Attending oil leakages of LV Y ph bushing	PO	220 KV
220/132 KV 100MVA ICT 2 @ BARAMATI	15-06-2023	10:30	15-06-2023	14:14	Preventive maintenance of NIFPS.	PO	220 KV
220/132 KV 200 MVA ICT 2	15-06-2023	9:27	15-06-2023	16:26	For routine diagnostic testing of ict and bay maintenance work.	HT	220 KV
220/22 KV 50 MVA PTR 1 @ CHAKAN	15-06-2023	10:37	15-06-2023	18:23	For attending oil leakages at HV Bushing turrets and Transformer body.	EO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/33 KV 50 MVA PTR 3 @ BUTIBORI	15-06-2023	10:27	15-06-2023	17:24	Diagnostic testing(tan delta & cap measurement) and premonsoon maintenance work.	HT	220 KV
220/33 KV 50 MVA TF I	15-06-2023	7:12	15-06-2023	10:58	For diagnostic testing & premonsoon maintenance work.	HT	220 KV
ALKUD - VITA	15-06-2023	15:26	15-06-2023	20:58	Jump Replacement work at Loc No.84 Y Ph	PO	220 KV
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	15-06-2023	14:30	15-06-2023	17:06	Distance Relay Testing work and Attending flashover at loc no 37 R ph	EO	220 KV
KARAD - VITA CKT- 1	15-06-2023	14:47	15-06-2023	19:01	Hotspot attending work at Y ph 29D isolator palm towards CB Side.	EO	220 KV
KHADKI- CENTURY ENKA	15-06-2023	10:20	15-06-2023	13:34	For attending CB ready signal in Distance relay is frequency getting low & high. Due to this problem in future chances of AR failure and Half yearly maintenance.	PO	220 KV
NANDED CITY-FLAGSHIP	15-06-2023	11:44	15-06-2023	18:14	Half yearly maint. & Testing work	PO	220 KV
NEW KOYNA - PEDAMBE	15-06-2023	9:15	15-06-2023	12:00	for attending unwound strands of Bph conductor jumper between brk to LS isolator	PO	220 KV
BUTIBORI-BUTIBORI RLY TSS	16-06-2023	10:09	16-06-2023	15:36	Diagnostic Testing work	PO	220 KV
DONDAICHA(220)-AMALNER(220)	16-06-2023	10:08	16-06-2023	14:28	Diagnostic Testing work	PO	220 KV
KANHAN-UMRED 1	16-06-2023	10:54	16-06-2023	18:53	Replacement of CT	PO	220 KV
MIRAJ - ICHALKARANJI	16-06-2023	17:06	16-06-2023	19:40	For attending hotspots at T.L 83 Rph & T.L.7 No Rph	PO	220 KV
220 KV DHULE(400 KV) - AMALNER	16-06-2023	17:51	16-06-2023	20:57	Replacement of damaged Wave Trap Jump and Testing work	PO	220 KV
220/132 KV 200 MVA ICT 1 @ MALEGAON	16-06-2023	8:50	16-06-2023	10:06	For premansoon maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ MALEGAON	16-06-2023	10:20	16-06-2023	11:01	For Premansoon Maintenance work	PO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132 KV 200 MVA ICT 1 @ BOISAR-II	16-06-2023	14:17	16-06-2023	16:06	Aux equipment polythene covering.	PO	220 KV
220/132KV 100MVA ICT 1 @ BARAMATI	16-06-2023	11:02	16-06-2023	13:30	Preventive maintenance of NIFPS.	PO	220 KV
220/132KV 100MVA PTR 2 @ KHAREPATAN	16-06-2023	9:43	16-06-2023	16:11	For replacement of higher tan delta LV CTs.	PO	220 KV
220/22 KV 50 MVA PTR 1 @ PAL-DOMBIVALI	16-06-2023	12:44	16-06-2023	15:10	Plastic paper wrapping & RM Work.	PO	220 KV
220/22 KV 50 MVA PTR 2 @ ANANDNAGAR	16-06-2023	8:28	16-06-2023	8:28	For premonsoon maintenance work	PO	220 KV
220/22 KV 50 MVA PTR 2 @ PAL-DOMBIVALI	16-06-2023	15:32	16-06-2023	17:45	Plastic paper wrapping & RM Work.	PO	220 KV
220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI	16-06-2023	10:00	16-06-2023	12:44	Plastic paper wrapping & RM Work.	PO	220 KV
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	16-06-2023	8:35	16-06-2023	9:27	For premonsoon maintenance work	PO	220 KV
220/22KV 50MVA PTR - 1 @ PALAVA	16-06-2023	9:20	16-06-2023	12:47	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.	PO	220 KV
220/22KV 50MVA PTR - 2 @ PALAVA	16-06-2023	13:47	16-06-2023	16:09	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.	PO	220 KV
220KV PT-2 of BUS-1@ MULUND	16-06-2023	8:44	16-06-2023	10:30	IR verification	PO	220 KV
AURANGABAD (WALUJ)-BHENDA	16-06-2023	8:48	16-06-2023	10:35	To attend Hot Spot	PO	220 KV
AURANGABAD (WALUJ)-BHENDA	16-06-2023	9:13	16-06-2023	10:05	For attending hotspot of R ϕ pole CB Top Plate.	PO	220 KV
KARAD - KADEGAON	16-06-2023	9:24	16-06-2023	16:52	Painting of MS rusted 220 kV Gantry Beam by applying Elastomeric Thermoplastic Graft co-Polymer Anticorrosive treatment to avoid corrosion to MS Gantry Beam	PO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
NERLE- POPHALI	16-06-2023	8:20	16-06-2023	17:18	For replacement of damaged conductor at loc no. 33B & Y ph Nerale side , R ph Pedhambe	PO	220 KV
PHALTAN MIDC - SWARAJ CO GEN	16-06-2023	10:10	16-06-2023	13:42	Diagnostic testing & Quarterly maintenance work.	PO	220 KV
DAHANU - VIRAJ	17-06-2023	14:13	17-06-2023	15:56	Pre-Monsoon Maintenance work.	PO	220 KV
GIS BHANDUP - BORIVALI	17-06-2023	9:26	17-06-2023	13:10	Relay Testing work	PO	220 KV
KANDALGAON - SONA ALLOYS	17-06-2023	11:06	17-06-2023	21:00	Outage tree cutting and other line maintenance work.	PO	220 KV
220/100 KV 100 MVA ICT 1 @ JAMBHUL	17-06-2023	9:23	17-06-2023	14:05	1)Premonsoon Maintenance Work, Plastic paper wrapping. 2)Measurement of ICT Neutral Earth Pit Resistance 3) ICT Cleaning Work	PO	220 KV
220/100 KV 125 MVA ICT 2 @ JAMBHUL	17-06-2023	14:11	17-06-2023	17:20	1)Premonsoon Maintenance Work, Plastic paper wrapping to auxiliary protections 2) Measurement of ICT Neutral Earth Pit Resistance. 3) ICT Cleaning Work	PO	220 KV
220/33 KV 50 MVA PTR 1 @ KHARGHAR	17-06-2023	10:45	17-06-2023	11:18	Pri monsoon Maintenance Work	PO	220 KV
220/33 KV 50 MVA PTR 2 @ KHARGHAR	17-06-2023	5:27	17-06-2023	6:12	PRE MONSOON MAINTENANCE	PO	220 KV
220/33 KV 50 MVA PTR 3 @ KHARGHAR	17-06-2023	4:19	17-06-2023	5:24	PRE MONSOON MAINTENANCE	PO	220 KV
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	17-06-2023	1:07	17-06-2023	1:59	Tripped on Distance Protection.	T	220 KV
BOISAR II - VIRAJ	17-06-2023	16:26	17-06-2023	17:54	Pre-Monsoon Maintenance work.	PO	220 KV
GOREGAON - AAREY CKT - 2	17-06-2023	18:14	10-07-2023	6:41	Shifting of existing 220kV AIS Bay no. 2 to New GIS Bay no. 19 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.	PO	220 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PARLI 3(OLD GCR)-PARLI NEWTPS CKT-2	17-06-2023	11:13	17-06-2023	14:05	Y&B Phase CT Leakage		220 KV
VSNL- KHADKI	17-06-2023	10:19	17-06-2023	12:20	For attending CB ready signal in Distance relay is frequently getting low and high.	PO	220 KV
WAGHIVALI - DHARAVI 7	17-06-2023	6:35	17-06-2023	9:31	Emergency tree trimming in span 96-97	PO	220 KV
CHIKHALI-JALNA I	18-06-2023	8:24	22-06-2023	0:25	Replacement of bend main 1st section leg of B type tower at Loc no.26.		220 KV
CHIKHALI-JALNA II	18-06-2023	8:24	22-06-2023	0:27	Replacement of bend main 1st section leg of B type tower at Loc no.26.		220 KV
KALWA - COLOURCHEM	18-06-2023	10:09	18-06-2023	15:08	Removing of Jumpers at Loc no.4 for making LILO of the line at 220KV GIS S/stn for power supply to DCHI under ORC.	PO	220 KV
220/132KV 200MVA ICT 1 @ JEUR	18-06-2023	14:35	18-06-2023	17:20	Outage is required for attending oil leakage from Yph LV CT	EO	220 KV
BHIRA - KARANJADE 8	18-06-2023	13:48	18-06-2023	17:28	PROJECT WORK-OPGW STRINING	PO	220 KV
MAIN BUS - 2 @ BOISAR II	18-06-2023	12:13	18-06-2023	14:21	1) Insulator string replacement. Pilot -1no & Tension-1no.	PO	220 KV
KANHAN-MANSAR	14-06-2023	10:50	14-06-2023	13:02	Routine Maint. Work	PO	132 KV
KALWA KALYAN	11-06-2023	21:56	12-06-2023	5:17	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
KALWA KALYAN	11-06-2023	21:56	12-06-2023	5:12	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
BHIRA (T) - DAVDI	12-06-2023	7:02	12-06-2023	18:18	FOR WORK IN VICINITY AT BHIRA	PO	110 KV
KALYAN KALWA SALSETTE 1	12-06-2023	21:17	13-06-2023	0:05	Removal of hanging object at loc.48	EO	110 KV

Transmission Line Outages/Trippings from 12.06.2023 to 18.06.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KALWA KALYAN	13-06-2023	22:15	14-06-2023	6:42	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
KALWA KALYAN	13-06-2023	0:13	13-06-2023	6:23	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
BHIRA (T) - DAVDI	14-06-2023	6:54	14-06-2023	12:12	Lightning spikes installation	PO	110 KV
KALWA KALYAN	14-06-2023	20:56	15-06-2023	6:28	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
KALWA KALYAN	15-06-2023	21:08	16-06-2023	6:24	Project work for Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
KALWA KALYAN	16-06-2023	21:00	17-06-2023	6:12	Project work of Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
KALYAN KALWA SALSETTE 1	16-06-2023	13:48	16-06-2023	16:39	Faulty OPGW replacement in span 107 to 109	PO	110 KV
KARANJADE - WAGHIVALI CKT - 1	17-06-2023	10:00	17-06-2023	12:15	For protection testing and trials	PO	110 KV
BHIRA (T) - KHOPOLI 2	18-06-2023	13:30	18-06-2023	15:30	PROJECT WORK-OPGW STRINING	PO	110 KV
KALWA KALYAN	18-06-2023	21:47	19-06-2023	5:20	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)	PO	110 KV
TATA BORIVLI MSETCL BORIVLI 2	18-06-2023	8:27	18-06-2023	10:01	FOR TREE TRIMMING	PO	110 KV