

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 10/Jun/2024 to 16/Jun/2024

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
10-06-2024	11 Hrs	4997	196	287	5480	8547	374	4976	1902	-2274	18489	0	18489	830	335	22444	22444	49.90
11-06-2024	11 Hrs	6260	121	288	6669	8537	681	4753	1520	-2308	19322	0	19322	874	381	23415	23415	49.99
12-06-2024	10 Hrs	6136	124	287	6547	8123	954	4745	1093	-2265	18677	0	18677	726	304	22492	22492	50.05
13-06-2024	10 Hrs	5491	118	140	5749	8233	1233	4518	1650	-2312	18540	0	18540	724	303	22410	22410	50.03
14-06-2024	12 Hrs	5070	351	286	5707	8395	1353	4524	2092	-2526	19004	0	19004	843	166	23080	23080	49.98
15-06-2024	12 Hrs	4811	250	278	5339	8355	867	4441	2240	-2345	18374	0	18374	851	221	22314	22314	49.97
16-06-2024	12 Hrs	5213	149	281	5643	7996	219	4394	2433	-1752	18438	0	18438	928	156	21769	21769	49.98
Maximum		6260	351	288	6669	8547	1353	4976	2433	-1752	19322	0	19322	928	381	23415	23415	50.05
Minimum		4811	118	140	5339	7996	219	4394	1093	-2526	18374	0	18374	724	156	21769	21769	49.90
Average		5425	187	264	5876	8312	812	4622	1847	-2255	18692	0	18692	825	267	22561	22561	49.99

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
10-06-2024	18 Hrs	6639	544	286	7469	7860	1289	4939	248	-2074	19177	0	19177	854	472	23131	23131	50.02
11-06-2024	16 Hrs	6600	122	281	7003	7536	1107	5103	894	-2167	18950	0	18950	956	467	23066	23066	50.01
12-06-2024	17 Hrs	6402	267	282	6951	8178	1349	4731	733	-2273	19135	0	19135	993	471	23406	23406	50.00
13-06-2024	15 Hrs	5834	117	283	6234	8361	1101	4584	1726	-2388	19105	0	19105	959	428	23393	23393	50.03
14-06-2024	15 Hrs	4978	143	291	5412	8846	1299	4538	1761	-2406	18933	0	18933	894	206	22956	22956	49.95
15-06-2024	17 Hrs	6429	256	108	6793	7697	1062	5211	922	-2034	19124	0	19124	1109	252	23046	23046	50.03
16-06-2024	17 Hrs	6072	230	283	6585	8239	417	5140	951	-1993	18836	0	18836	670	215	22217	22217	50.04
Maximum		6639	544	291	7469	8846	1349	5211	1761	-1993	19177	0	19177	1109	472	23406	23406	50.04
Minimum		4978	117	108	5412	7536	417	4538	248	-2406	18836	0	18836	670	206	22217	22217	49.95
Average		6136	240	259	6635	8102	1089	4892	1034	-2191	19037	0	19037	919	359	23031	23031	50.01

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
10-06-2024	20 Hrs	6839	950	289	8078	7461	1141	5950	0	-1647	20435	0	20435	1157	467	24254	24254	50.05
11-06-2024	20 Hrs	7171	328	285	7784	7451	978	5836	0	-1842	19661	0	19661	976	473	23498	23498	50.01
12-06-2024	20 Hrs	6954	573	285	7812	7905	1077	5822	0	-1832	20236	0	20236	1104	471	24191	24191	49.98
13-06-2024	20 Hrs	6894	383	289	7566	7535	1755	5425	0	-1890	19878	0	19878	998	407	23686	23686	49.98
14-06-2024	20 Hrs	6590	542	287	7419	7894	1335	5490	0	-2033	19589	0	19589	1033	238	23409	23409	49.95
15-06-2024	21 Hrs	6380	1297	272	7949	7169	1102	6225	0	-1730	20214	0	20214	1204	247	23896	23896	50.01
16-06-2024	21 Hrs	5701	1682	284	7667	6515	937	6236	0	-1574	19285	0	19285	1181	214	22750	22750	49.99
Maximum		7171	1682	289	8078	7905	1755	6236	0	-1574	20435	0	20435	1204	473	24254	24254	50.05
Minimum		5701	328	272	7419	6515	937	5425	0	-2033	19285	0	19285	976	214	22750	22750	49.95
Average		6647	822	284	7754	7419	1189	5855	0	-1793	19900	0	19900	1093	360	23669	23669	50.00

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
10-06-2024	4 Hrs	5203	169	295	5667	5808	876	5256	0	-1310	15920	0	15920	676	333	18616	18616	49.95
11-06-2024	4 Hrs	6097	187	295	6579	5938	1289	4849	0	-1186	17088	0	17088	709	452	19816	19816	50.02
12-06-2024	5 Hrs	6520	174	291	6985	6057	1365	4875	0	-1320	17574	0	17574	728	375	20385	20385	49.99
13-06-2024	5 Hrs	6507	196	143	6846	6932	1269	4877	0	-1414	18100	0	18100	730	390	21044	21044	50.00
14-06-2024	4 Hrs	6179	167	292	6638	6942	1452	4719	0	-1496	17855	0	17855	678	317	20746	20746	50.01
15-06-2024	4 Hrs	6117	164	289	6570	6772	1352	4864	0	-1556	17629	0	17629	757	246	20561	20561	49.95
16-06-2024	4 Hrs	5796	188	293	6277	6540	1093	5903	0	-1286	18138	0	18138	999	220	21032	21032	49.97
Maximum		6520	196	295	6985	6942	1452	5903	0	-1186	18138	0	18138	999	452	21044	21044	50.02
Minimum		5203	164	143	5667	5808	876	4719	0	-1556	15920	0	15920	676	220	18616	18616	49.95
Average		6060	178	271	6509	6427	1242	5049	0	-1367	17472	0	17472	754	333	20314	20314	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
10-06-2024	138.101	8.270	6.652	153.023	0.224	172.286	178.060	19.991	126.829	14.847	21.452	9.196	-41.607	433.757	72.255	517.624
11-06-2024	155.507	5.176	6.935	167.618	0.233	169.935	179.117	24.742	124.008	11.819	21.686	10.392	-42.106	444.294	74.181	530.197
12-06-2024	152.751	6.972	6.874	166.597	0.460	177.263	183.593	26.092	122.369	12.186	22.224	9.544	-45.246	447.520	77.014	536.275
13-06-2024	147.456	6.280	5.491	159.227	0.000	181.380	186.863	29.936	121.071	15.810	22.224	9.481	-45.839	449.768	77.544	539.129
14-06-2024	142.588	6.856	6.964	156.408	0.000	180.861	186.773	32.490	121.391	15.577	21.015	6.784	-47.002	447.853	74.801	534.526
15-06-2024	142.736	9.699	5.643	158.078	0.000	176.570	183.728	27.045	125.640	17.553	22.758	5.482	-44.603	448.659	72.843	533.126
16-06-2024	136.582	13.030	6.895	156.507	0.000	175.656	181.350	16.419	131.554	18.033	21.697	5.016	-39.525	447.349	66.238	524.882
Maximum	155.507	13.030	6.964	167.618	0.460	181.380	186.863	155.507	131.554	18.033	22.758	10.392	-39.525	449.768	77.544	539.129
Minimum	136.582	5.176	5.491	153.023	0.000	169.935	178.060	136.582	121.071	11.819	21.015	5.016	-47.002	433.757	66.238	517.624
Average	145.103	8.040	6.493	159.637	0.131	176.279	182.783	145.103	124.695	15.118	21.865	7.985	-43.704	445.600	73.554	530.823

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
10-06-2024	0.129	1.676	65.824
11-06-2024	0.058	1.733	65.767
12-06-2024	0.113	1.847	65.653
13-06-2024	0.079	1.926	65.574
14-06-2024	0.086	2.012	65.488
15-06-2024	0.147	2.159	65.341
16-06-2024	0.217	2.375	65.125

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 10/Jun/2024 to 16/Jun/2024

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
10-06-2024	MONDAY	89.968	7331	88.092	3671	178.060	7419	172.286	7179	-5.774	-241
11-06-2024	TUESDAY	92.218	7376	86.899	3621	179.117	7463	169.935	7081	-9.182	-383
12-06-2024	WEDNESDAY	91.744	7558	91.849	3827	183.593	7650	177.263	7386	-6.330	-264
13-06-2024	THURSDAY	91.273	7690	95.590	3983	186.863	7786	181.380	7558	-5.483	-228
14-06-2024	FRIDAY	88.312	7684	98.461	4103	186.773	7782	180.861	7536	-5.912	-246
15-06-2024	SATURDAY	86.924	7559	96.804	4033	183.728	7655	176.570	7357	-7.158	-298
16-06-2024	SUNDAY	110.246	7485	71.104	2963	181.350	7556	175.656	7319	-5.694	-237
Total		650.685		628.799		1279.484		1233.951		-45.533	

Generator Unit Outages/Trippings from 10.06.2024 to 16.06.2024						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	NOPPA
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	NOPPA
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	NOPPA
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	NOPPA
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Ghatghar Unit-2	26-05-2024	13:17		Continued.	Stator Earth Fault	FORCED
Paras Unit 4	05-06-2024	03:59		Continued.	Fire in GT	FORCED
Uran Unit 5	05-06-2024	17:00		Continued.	Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Uran Unit 6	06-06-2024	17:40		Continued.	Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Nasik Unit 4	06-06-2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	FORCED
Chandrapur Unit 6	08-06-2024	00:14	11-06-2024	02:05	Boiler Tube Leakage	FORCED
Parli Unit 7	08-06-2024	21:00		Continued.	Zero Schedule by MSEDCL.	ZEROSCH/R SD
Parli Unit 6	08-06-2024	21:13		Continued.	Zero Schedule by MSEDCL.	ZEROSCH/R SD
Parli Unit 8	09-06-2024	20:50		Continued.	Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Adani U-4	10-06-2024	16:16	17-06-2024	04:34	ZERO SCHEDULE BY MSEDCL	ZEROSCH/R SD
Uran Unit B0	10-06-2024	21:20	10-06-2024	23:23	Instrumentation and Control Problem.	FORCED
Bhusawal Unit 3	12-06-2024	16:15		Continued.	Zero schedule given by LM Cell Discom due to drop in demand	ZEROSCH/R SD
Uran Unit 8	13-06-2024	02:58	13-06-2024	11:17	attending B2 Boiler Super Heater vent leakage	FORCED
AEML Unit 1	14-06-2024	10:16		Continued.	Boiler Tube Leakage	FORCED
Chandrapur Unit 8	14-06-2024	12:25	16-06-2024	02:03	Abnormal Parameters which is created due to increase in leakage of FDV 9.	FORCED
Koyna Unit 2	15-06-2024	07:10		Continued.	Govrner renovation	PLANNED
Uran Unit 7	15-06-2024	12:34	15-06-2024	19:04	Black out at ONGC	FORCED
Chandrapur Unit 3	15-06-2024	22.16		Continued.	Boiler Tube Leakage	FORCED
Bhusawal Unit 4	16-06-2024	00:00		Continued.	Annual Overhaul	PLANNED
JPL Unit 1	16-06-2024	08:09	16-06-2024	12:53	Electrical protection	FORCED
Khaparkheda Unit 3	16-06-2024	16:56	17-06-2024	00:50	Bus Bar Differential Protection operated.	FORCED
Khaparkheda Unit 4	16-06-2024	16:56	17-06-2024	02:24	Bus Bar Differential Protection operated.	FORCED
Khaparkheda Unit 1	16-06-2024	16:56	17-06-2024	00:08	Bus Bar Differential Protection operated.	FORCED
Khaparkheda Unit 2	16-06-2024	17:01	17-06-2024	03:15	AC Supply failure.	FORCED

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
AKOLA II - EKTUNI CKT - 2	26-05-2024	18:11	12-06-2024	20:44	Tripped on distance protection.(Due to tower collapsed).	T	765 KV
765/400kV 1500 MVA ICT-1 @ TIRORA	13-06-2024	15:30	13-06-2024	19:20	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
MAIN BAY (709) OF 765/21KV GT-5 @TIRORA	14-06-2024	10:30	14-06-2024	13:24	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
765/400kV 1500MVA ICT-1 @	15-06-2024	09:47	15-06-2024	20:19	Six monthly changeover of R-Ph ICT to be	PO	765 KV
MAIN BAY (703) OF 765/21KV GT-4	15-06-2024	09:35	15-06-2024	12:14	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
CHANDRAPUR - PADGHE HVDC POLE 2	14-06-2024	22:31	15-06-2024	04:57	Wrapping of Polythene paper to Instrument relays of converter T/F		500 KV
400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	10-06-2024	10:46	10-06-2024	13:30	Pre-monsoon Maintenance Work.	PO	400 KV
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	10-06-2024	08:42	10-06-2024	17:00	Diagnostic testing & Relay testing work , Routine maint. Work	PO	400 KV
JAIGAD - KARAD CKT - 1	10-06-2024	03:46	10-06-2024	09:11	H/T for Voltage Management	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	10-06-2024	00:21	10-06-2024	09:20	H/T for Voltage Management	HT	400 KV
DHULE - KHANDWA CKT - 1	11-06-2024	02:45	11-06-2024	03:45	Tripped on distance protection from Dhule end only.	T	400 KV
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	11-06-2024	08:35	11-06-2024	20:47	1.Measurement of tandelta of Bushing & winding. 2.Measurement of tandelta & capacitance of CT. 3.Premonsoon maintenance work of ICT. 4. Bay routine maintenance work.	PO	400 KV
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	11-06-2024	16:16	11-06-2024	19:39	Hotspot on 220kV Yph LV Bushing clamp attending work	EO	400 KV
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	11-06-2024	16:00	11-06-2024	22:13	Hot-spot observed at R-phase, BPI no 1 (BPI between CB & CT) & B-phase, C bus isolator L clamp	EO	400 KV
400/220/33 KV 500 MVA ICT - 1 @ NANDED	11-06-2024	10:53	11-06-2024	16:47	ICT-1 Y & B Phase Oil Top up.	PO	400 KV
400/220KV 500MVA ICT 3 @ AKOLA	11-06-2024	19:20	12-06-2024	17:45	TRIPPED ON REF PROTECTION OPERATED	T	400 KV
400/220KV 500MVA ICT 3 @ AKOLA	11-06-2024	19:20	12-06-2024	17:45	REF Protection	T	400 KV
BUS COUPLER @ PARLI	11-06-2024	04:05	11-06-2024	13:27	Tripped but no indication appears.	T	400 KV
DABHOL - NEW KOYNA CKT - 1	11-06-2024	12:52	11-06-2024	13:55	tripped on distance protection	T	400 KV
SPARE LINE-1 BAY (401) @ TAPTITANDA	11-06-2024	13:42	11-06-2024	17:20	Outage required on all the three bays 401 , 402 , 403 for routine maintenance, testing work.	PO	400 KV
TIE BAY (402) of WALUJ @ TAPTITANDA	11-06-2024	13:42	11-06-2024	17:20	Outage required on all the three bays 401 , 402 , 403 for routine maintenance and testing work.	PO	400 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV KHAPARKHEDA (400KV) - AMBAZARI CKT	12-06-2024	11:04	12-06-2024	16:42	LINE ISOLATOR 29 D & AUXILLARY ISOLATOR 29 C OVERHAULING & ALIGNMENT WORK	PO	400 KV
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	12-06-2024	08:36	13-06-2024	20:58	1.MEASUREMENT OF TANDELTA OF BUSHING & WINDING. 2.MEASUREMENT OF TANDELTA & CAPACITANCE OF CT. 3.PREMONSOON MAINTENANCE WORK OF ICT. 4. BAY ROUTINE MAINTENANCE WORK	PO	400 KV
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	12-06-2024	08:06	12-06-2024	16:49	For the instalment of external cooling fans to enhance cooling in 400 kV, 125 MVAR, Bus Shunt Reactor.	PO	400 KV
80 MVAR BUS REACTOR @ PADGHE	12-06-2024	10:10	13-06-2024	18:30	1) Relay replacement work of Reactor 2) Bay maint work 3) Replacement of 29C bus PG isolator	PO	400 KV
TIE BAY (402) OF 400/21KV GT-1 and 765/400KV ICT (LV Side) @ TIRORA	12-06-2024	16:00	12-06-2024	17:35	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV
PADGHE - NAGOTHANE CKT - 2	13-06-2024	13:44	13-06-2024	19:45	For string replacement work	PO	400 KV
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	13-06-2024	10:11			For work in vicinity for erection of scaffolding for installation of LA�s on 220KV Bays at KVTL Vikhroli (These Bays used for feeding 220/110kV, 250MVA, ICT-1 & ICT-2 of TPC Vikhroli).	PO	400 KV
400220kv 167MVA SPARE ICT @ DEEPNAGAR	13-06-2024	17:06	13-06-2024	18:31	FOR REPLACEMENT OF NITROGEN GAS CYLINDER DUE TO LOW N2 PRESSURE ALARM APPEARS ON CTR NIFPS CUBICLE	PO	400 KV
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	13-06-2024	09:48	13-06-2024	18:40	For the instalment of external cooling fans to enhance cooling in 400 kV, 125 MVAR, Bus Shunt Reactor.	PO	400 KV
DEEPNAGAR - THAPTI TANDA	13-06-2024	06:22	13-06-2024	09:29	Replacement of R- Phase suspension type string insulator at location No. 90 due to flash over observed due to lightning and AR successful operated at both end on 07.06.2024.	PO	400 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
JEJURI - KARAD	13-06-2024	08:49	13-06-2024	13:14	For diagnostic testing work	PO	400 KV
LONIKAND I - KOYNA STAGE-IV	13-06-2024	14:22	13-06-2024	21:31	Diagnostic testing & Relay testing work , Routine maint. Work	PO	400 KV
MAIN BAY (419) OF 400/220/33kV 500MVA ICT-I @ LONIKAND 2	13-06-2024	06:18	13-06-2024	18:31	Diagnostic testing and Pre Monsoon Maintenance	PO	400 KV
MAIN BAY 415 OF BUS REACTOR 2@ TIRORA	13-06-2024	09:53	13-06-2024	11:40	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV
TIE BAY 418 OF ICT-1 @ LONIKAND 2	13-06-2024	06:18	13-06-2024	18:31	Diagnostic testing and Pre Mansoon Maintenance	PO	400 KV
CHANDRAPUR-PARLI CKT-3	14-06-2024	08:19	14-06-2024	15:53	1.Measurement of tandelta of Bushing of 50MVar Line shunt Reactor. 2.Premonsoon maintenance work of Reactor. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work.	PO	400 KV
PADGHE - NAGOTHANE CKT - 1	14-06-2024	12:35	14-06-2024	19:43	For string replacement work	PO	400 KV
400/220/20 KV 300 MVA ICT - 1 @ KORADI	14-06-2024	09:41	14-06-2024	14:17	For premonsson maintenance works	PO	400 KV
400/220/33 KV 315 MVA ICT - 2 @ KORADI	14-06-2024	14:51	14-06-2024	17:33	For premonsson maintenance works	PO	400 KV
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	14-06-2024	10:20	14-06-2024	16:53	Routine Maintenance and Diagnostic Testing Work.	PO	400 KV
KHADKA - BABLESHWAR	14-06-2024	14:08	14-06-2024	19:38	Routine Line maintenance work;LBB relay testing	PO	400 KV
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	15-06-2024	09:20	15-06-2024	16:42	HV CT tand Testing and bay maintenance work	PO	400 KV
400/220/33 KV 501MVA ICT - 5 @ BABHALESHWAR	15-06-2024	16:02	15-06-2024	21:15	DC Leakage	T	400 KV
BUS COUPLER @ KALWA	16-06-2024	06:42	16-06-2024	12:45	Bay maintenance and R &M work.	PO	400 KV
EKLAHARE (OCR) - NAVASARI CKT - 1	09-06-2024	23:20	10-06-2024	01:37	Tripped on distance protection from Nashik end only.	T	220 KV
EKLAHARE (OCR) - PADGHE	10-06-2024	08:42			H/T for load management	HT	220 KV
LOTEPARSHURAM- DASTURI LINE	10-06-2024	10:40	10-06-2024	11:00	Attending hot-spot on B ph CT palm towards CB of 220KV Dasturi line at 220KV Lote s/s. Also line isolator maintenance to be done.	PO	220 KV
PARLI NEW TPS - BEED CKT 1	10-06-2024	06:19	10-06-2024	10:45	B PH LA Burst Distance protection operated	T	220 KV
TALANDGE - MUDSHINGI CKT - 1	10-06-2024	10:10	10-06-2024	13:58	Diagnostic testing work		220 KV
100 MVA 220/132 KV ICT	10-06-2024	12:26	10-06-2024	17:34	Diagnostic testing work	PO	220 KV
220 KV CHANDRAPUR - 2 - CHANDRAPUR MIDC CKT	10-06-2024	08:11	10-06-2024	11:49	Diagnostic testing & Routine maintenance work	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV PARLI -U-8 - PARBHANI CKT	10-06-2024	14:35	11-06-2024	15:05	Distance protection	T	220 KV
220/132 KV 200MVA ICT 2 @ DHULE	10-06-2024	09:36	10-06-2024	12:13	CTR FD Trip alarm rectification work.		220 KV
220/33KV 100MVA PTR 2 @ 5 STAR MIDC, KAGAL	10-06-2024	10:35	10-06-2024	13:54	for premonsoon maintenance work	PO	220 KV
BADNERA - NANDGAON PETH	10-06-2024	17:00	10-06-2024	17:18	Distance protection	T	220 KV
MHAISAL - ALKUD	10-06-2024	18:07	11-06-2024	05:36	Wedge connector work	PO	220 KV
TALANDAGE - FIVE STAR MIDC 2	10-06-2024	10:35	10-06-2024	15:46	For R, Y, B ph STN strings replacement at tower loc no. 12 observed abnormal in PID testing.	PO	220 KV
TROMBAY DHARAVI - 5	10-06-2024	18:03	10-06-2024	23:17	ATTENDING HOT SPOT ON C PHASE CLAMP	EO	220 KV
220 KV VALVE-JAMDE CKT I	11-06-2024	13:06	11-06-2024	16:17	Testing work	PO	220 KV
BHUGAON - WARDHA (PG)	11-06-2024	17:21	11-06-2024	20:03	Distance Protection	T	220 KV
EKLAHARE (GCR) - AIROLI KNOW PARK	11-06-2024	21:35	12-06-2024	01:08	To re-connect jumpers of 220 kV AKP-Nashik line at TL No. 396 after erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333.	PO	220 KV
HALKARNI-MAHALAXMI LINE	11-06-2024	11:27	11-06-2024	16:03	Replacement of flshover string at loc. 309	PO	220 KV
JAMDE-DONDAICHA 2	11-06-2024	18:25	12-06-2024	08:21	Distance Protection	T	220 KV
JAMDE-DONDAICHA 2	11-06-2024	18:25	12-06-2024	08:21	D/P,RPH,2.4KM R PH	T	220 KV
WARORA - HINGANGHAT	11-06-2024	08:09	11-06-2024	11:22	Testing work	PO	220 KV
220 KV PARLI -U-8 - PARBHANI CKT	11-06-2024	14:35	11-06-2024	15:05	Distance Protection	T	220 KV
220/110kv 100MVA ICT - 3 @ PETH	11-06-2024	10:10	11-06-2024	12:03	Premonsoon maintenance work	PO	220 KV
220/33 KV 50MVA T/F - 2 @ MIRAJ	11-06-2024	09:05	11-06-2024	15:48	Replacement of differential relay	PO	220 KV
220/33KV 50MVA PTR 1 @ KATHAPUR	11-06-2024	09:22	11-06-2024	14:50	Attending LV Bph Bushing Hotspot and Diagnostic testing Work.	PO	220 KV
BALAPUR-AKOLA I	11-06-2024	17:48	11-06-2024	21:22	Tripped at Akola end on PDR	T	220 KV
BHAMBORI AMALNER	11-06-2024	12:04	11-06-2024	16:34	Testing and maintenance work	PO	220 KV
KORADI-KHAPERKHEDA	11-06-2024	09:34	11-06-2024	14:47	Replacement of Disc Insulator	PO	220 KV
KURKUMBH - SHIRSHUPHAL CKT	11-06-2024	11:27	11-06-2024	15:22	Outage is proposed for annual relay testing work and quarterly maintenance of line bay	PO	220 KV
MAIN BUS - 2 @ JEJURI	11-06-2024	10:42	11-06-2024	18:01	for alignment work of 29B isolator of 220 kV Lonand-1 & 2 line bay (gear box repairing work)and alignment work of 29B isolator of ICT 2 bay by taking main bay on TBC bay alternatively by external agency	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
NANDGAON PETH-AMRAVATI	11-06-2024	18:29	11-06-2024	20:46	Distance Protection	T	220 KV
NTT - BAPGAON	11-06-2024	21:35	12-06-2024	01:08	To re-connect jumpers of 220 kV AKP-Nashik line at TL No. 396 after erection of monopoles & shifting of line for height raising due to infringement of Vadodara-Mumbai Expressway SPUR in b/w Loc. no. 329 to 333.	PO	220 KV
GHATODI-NANDED	12-06-2024	12:44	12-06-2024	16:17	REPLACEMENT OF FLASHOVER STRING LOC. 13-RPH	PO	220 KV
HINGANGHAT - BHUGAON	12-06-2024	08:38	12-06-2024	14:19	DAIGONISTIC TESTING WORK AT BOTH END	PO	220 KV
KANHAN-SURYALAKSHMI	12-06-2024	07:59	12-06-2024	10:47	1) FOR TIGHTENING NUT BOLT OF RPH (76.5) AND B PH (48.4) JUMPER AT LN 07 2) FOR TIGHTENING NUT BOLT OF B PH (64.1) JUMPER AT LN 24	PO	220 KV
KHAPARKHEDA - BUTIBORI 3	12-06-2024	09:01	12-06-2024	16:45	STRINGING WORK BETWEEN LOC NO 103-LOC NO 104 OF 220KV KORADI II TO BUTIBORI III DC ON MC TL	PO	220 KV
KHAPARKHEDA- BUTIBORI	12-06-2024	09:06	12-06-2024	16:41	STRINGING WORK BETWEEN LOC NO 103-LOC NO 104 OF 220KV KORADI II TO BUTIBORI III DC ON MC TL	PO	220 KV
LONAND-BOTHE	12-06-2024	05:18	12-06-2024	06:04	Distance Protection	T	220 KV
LOTEPARSHURAM- DASTURI LINE	12-06-2024	14:11	12-06-2024	18:45	Attending hot-spot on B ph CT palm towards CB of 220KV Dasturi line at 220KV Lote s/s. Also line isolator maintenance to be done.	PO	220 KV
100 MVA 220/132 KV ICT - I @ JALKOT	12-06-2024	09:40	12-06-2024	12:45	PREMANSOON MAINTENANCE WORK	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
200 MVA 220/132 KV ICT - III @ CHALISGAON	12-06-2024	09:55	12-06-2024	13:48	PREMANSOON MAINTENANCE WORK	PO	220 KV
220 KV DHULE(400 KV) - AMALNER	12-06-2024	13:02	12-06-2024	14:27	TO ATTENDED RED HOT SPOT ON Y-PH CT(174 DEG) LINE SIDE		220 KV
220/100 KV 100 MVA ICT 1 @ KANDALGAON	12-06-2024	09:42	12-06-2024	12:55	125 MVA 220/100 Kv ICT No:01 Premansoon activites /Dignostic testing	PO	220 KV
220/100 KV 200 MVA ICT 1 @ PAL- DOMBIVALI	12-06-2024	10:17	12-06-2024	14:35	Pre-Monsoon work to be carried.	PO	220 KV
220/110 KV 100 MVA PTR 1 @ BIDRI	12-06-2024	10:20	12-06-2024	11:15	LV Bay Maintenance & Attending Hot spot on LV CB	PO	220 KV
220/132 KV 100 MVA ICT 1 @ BELWANDI	12-06-2024	09:38	12-06-2024	12:23	Pre-monsoon Maintenance Work	PO	220 KV
220/132 KV 100 MVA ICT 2 @ BELWANDI	12-06-2024	12:32	12-06-2024	14:06	Pre-monsoon Maintenance Work	PO	220 KV
220/132 KV 100 MVA ICT 2 @ GHATODI	12-06-2024	10:47	12-06-2024	17:39	PREMANSOON MAINTENANCE WORK	PO	220 KV
220/132 KV 200 MVA ICT 2	12-06-2024	12:14	12-06-2024	13:48	FOR PREMONSOON MAINTENANCE AND RM WORK OF BAY.	PO	220 KV
220/132 KV 200 MVA PTR NO 6 @ PARVATI	12-06-2024	10:29	12-06-2024	13:32	Half Yearly Maint Work	PO	220 KV
220/132KV 200MVA ICT 3 @ PANDHARPUR	12-06-2024	10:50	12-06-2024	11:39	Outage is required for Pre Monsoon maintenance	PO	220 KV
220KV PANDHARKAWDA - WANI CKT I	12-06-2024	09:20	12-06-2024	13:10	DAIGONISTIC TESTING WORK	PO	220 KV
220KV PANDHARKAWDA - WANI CKT II	12-06-2024	14:12	12-06-2024	18:06	DIAGNOSTIC TESTING (TAN DELTA, TIMING TEST ,CRM TEST	PO	220 KV
MAIN BUS @ KARKAMB	12-06-2024	10:55	12-06-2024	14:42	Outage is required for Quarterly Maintenance	PO	220 KV
OSMANABAD - PARLY (PG)	12-06-2024	12:05	12-06-2024	16:32	FOR REPLACEMENT OF FLASHOVER R PHASE STRING INSULATOR AT LOC NO.259	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
ABHIJEET-WARDHA-II	13-06-2024	10:52	13-06-2024	20:58	RETROFITTING OF DISTANCE RELAY OF 220KV ABHIJEET-WARDHA-2 CKT. (GE MAKE) DUE TO MALFUNCTIONING OF RELAY.	PO	220 KV
KANHAN-UMRED 1	13-06-2024	10:12	13-06-2024	13:19	FOR DIAGNOSTIC TESTING WORK AND ALLIED MAINTENANCE WORK.	PO	220 KV
NAGOTHANE - POSCO	13-06-2024	10:45	13-06-2024	14:56	Outage tree cutting work & Other line maintenance work.	PO	220 KV
PARGAON(KATHAPUR)-LONIKAND	13-06-2024	17:22	14-06-2024	00:19	Loc No 306 Bph, 321 Rph, 322 Bph flashover string replacement work.	PO	220 KV
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	13-06-2024	23:43	14-06-2024	06:24	Cold line washing of insulators.	PO	220 KV
220/100 KV 100 MVA ICT 1 @ JAMBHUL	13-06-2024	11:46	14-06-2024	13:30	Nitrogen Injection Pipeline reinstallation/ replacement work by M/s. CTR.	PO	220 KV
220/100 KV 100 MVA ICT 2 @ KANDALGAON	13-06-2024	09:45	13-06-2024	11:08	100 MVA 220/100 Kv ICT No:02 Premansoon activites /Dignostic testing	PO	220 KV
220/132 KV 200MVA ICT NO 1 @ THEUR	13-06-2024	06:15	13-06-2024	15:52	OLTC overhauling work	PO	220 KV
220/132kv 200MVA ICT-2 @ KOPARGAON	13-06-2024	11:42	13-06-2024	14:20	For TCIV valve of NIFPS (Nitrogen fire protection system) maintenance.	PO	220 KV
220KV WALUJ(400KV) -CHITEGAON CKT	13-06-2024	11:13	13-06-2024	14:57	DIAGNOSTIC TESTING AND ROUTINE MAINTENANCE WORK.	PO	220 KV
40MVA 220/6.6 KV STN T/F 3	13-06-2024	10:07	13-06-2024	19:04	DIAGNOSTIC MEASUREMENT WORK TO BE CARRIED OUT (CB CRM, TIMING & CT TAN DELTA & CAPACITANCE MEAS . WORK)	PO	220 KV
GOREGAON - VERSOVA CKT - 1	13-06-2024	09:32	13-06-2024	11:32	Pre-monsoon Maintenance work	PO	220 KV
GOREGAON - VERSOVA CKT - 2	13-06-2024	11:51	13-06-2024	16:25	Pre-monsoon Maintenance work	PO	220 KV
NERLE - DASGAON	13-06-2024	10:48	13-06-2024	15:24	For checking remote operation through new SAS of 220kV line & Bus Section CB	PO	220 KV
PHALTAN MIDC - CSSK BHAVANI NAGAR	13-06-2024	10:45	13-06-2024	17:22	1.Cable Replacement Work 2.Quarterly Maintenance Work 3.Relay Testing Work	PO	220 KV
TIFIL - KALWA	13-06-2024	08:55			For making 220kV Pawane-TIFIL line LILO for M/s NXTRA Data Ltd for the proposed 220kV GIS S/stn.	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
ADLABS - PEDAMBE	14-06-2024	06:50	14-06-2024	14:35	Outage tree cutting work at Loc.No.262-263,293-294,397-398 & Other line Maint. Works	PO	220 KV
VERSOVA - GORAI	14-06-2024	11:49			Pre-monsoon Maintenance work	PO	220 KV
WASHALA - GHATGHAR	14-06-2024	08:16	14-06-2024	14:00	1)Emergency Tree cutting maintenance work and 2) Emergency Tree monsoon maintenance work	PO	220 KV
YEOTMAL- PUSAD	14-06-2024	09:55	14-06-2024	17:43	Measurement of c & tan delta of line ct�s & cc. cb crm, timing, ir values etc. routine maintenance work.	HT	220 KV
220 KV GIRWALI (400 KV) -PARLI U-8 CKT	14-06-2024	06:23	14-06-2024	19:30	1. y phase ct replacement due to rising high tan delta values. 2. y phase la replacement due to high leakage current values as compared to previous results. 3. r phase cb to 29 d isolator jump replacement. 4. at present, the generation is stopped.	HT	220 KV
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	14-06-2024	09:28	14-06-2024	14:28	Replacement of HV Back up relay.	PO	220 KV
220/132 KV 100 MVA ICT 1	14-06-2024	10:00	14-06-2024	15:15	1)Replacement of LV B-phase CT.	PO	220 KV
220/132 KV 200 MVA PTR 4 @ PHURSUNGI	14-06-2024	18:04	14-06-2024	23:00	B ph LA of 132kV side is failed	T	220 KV
220/132 KV 200MVA ICT NO 2 @ THEUR	14-06-2024	06:15	14-06-2024	14:28	OLTC overhauling work	PO	220 KV
220/33KV 50MVA TF NO.1 @ SAYNE	14-06-2024	12:45	14-06-2024	15:10	For attending oil leakage of 33kV R-Ph & B-Ph CT. (Oil leakage observed recently from CT stud of R-Ph & B-Ph).	PO	220 KV
BHAVEGHAR - ROMA	14-06-2024	09:48	14-06-2024	14:06	Insulator replacement Work identified in PID.	PO	220 KV
KURKUMBH - SHIRSHUPHAL CKT	14-06-2024	10:17	14-06-2024	20:25	Replacement of Distance protection relay, diagnostic testing of bay equipments	PO	220 KV
LAMBOTI - TULJAPUR CKT - 1	14-06-2024	13:12	14-06-2024	16:58	Leakage attending work.	T	220 KV
LAMBOTI - TULJAPUR CKT - 2	14-06-2024	17:18	14-06-2024	18:13	Leakage attending work.	T	220 KV
TBC @220 KV NERUL	14-06-2024	09:01	14-06-2024	12:17	Pre-Monsoon Maintenance CB CRM Timing Auxiliary isolator maintenance work	PO	220 KV
KANDALGAON - ONGC PANVEL	15-06-2024	08:45	15-06-2024	11:20	Outage tree cutting work at various location and other line maintenance work.	PO	220 KV
KANDALGAON - PIRANGUT	15-06-2024	06:15	15-06-2024	10:57	For attending hot spot at various locations & double jumpering work.	PO	220 KV
NANDED 2 (WAGHALA) - PARBHANI	15-06-2024	10:20	15-06-2024	14:15	Replacement of Y Phase LA	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PETH- MUDSHINGI 1 LINE	15-06-2024	12:40	15-06-2024	15:52	Distance Protection	T	220 KV
100 MVA 220/132 KV ICT 1	15-06-2024	12:56	15-06-2024	14:32	Tan Delta testing	PO	220 KV
200 MVA 220/132 KV ICT - III @ CHALISGAON	15-06-2024	15:00	15-06-2024	15:24	To check physical Tap Position	PO	220 KV
220 / 110 / 33kv 250MVA AT 1 @ BACKBAY	15-06-2024	16:58	15-06-2024	17:25	110KV Bus Fault	T	220 KV
220 / 110 / 33kv 250MVA AT 2 @ BACKBAY	15-06-2024	16:58	16-06-2024	19:11	110KV Bus Fault	T	220 KV
220/132 KV 100 MVA ICT 2	15-06-2024	10:08	15-06-2024	14:19	Maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 1@ RANJANGAON	15-06-2024	10:30	15-06-2024	15:30	Replacement of LA of HV side Y-ph & LV side B-ph due to high LCM value. General Bay maintenance work.	PO	220 KV
220/22 KV 50 MVA PTR 2 @ LONIKAND	15-06-2024	14:24	15-06-2024	17:23	29D isolator alignment work	PO	220 KV
BUS COUPLER @ MAHALAXMI GIS (T)	15-06-2024	11:11	15-06-2024	13:46	Breaker testing.	PO	220 KV
HYBRID SWITCHGEAR (245kv) @ THEUR	15-06-2024	11:04	15-06-2024	13:10	To resolve problem of ingress of moisture appearing in B ph drive mechanism during rains by M/S CGL.	PO	220 KV
KARAD - DASGAON	15-06-2024	10:21	15-06-2024	15:00	Checking Remote Operation through new SAS for 220kV Line & Bus Section CB	PO	220 KV
NANDED CITY - GIS KONDHWA	15-06-2024	16:02			1. Double jumpering work due to Hotspot L.N.-84 2 R Phase L.N.-79-B&R Phase L.N.-70-B Phase L.N.-65-Y Phase L.N.-5-B Phase 2. fixing of vibration Damper at various missing locations	PO	220 KV
PANVEL TSS - KHANDESHWAR	15-06-2024	14:30			Making LILO of 220kV Khandeahwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioing of 220/33kV Timber Market GIS, Panvel	PO	220 KV
RANJANGAON - U TECH SUGAR CKT	15-06-2024	15:58	15-06-2024	18:30	For attending hot spot at various spot & genral bay maintenance work.	PO	220 KV
TATA BORIVLI MSETCL BORIVLI - 4	15-06-2024	10:12	15-06-2024	14:28	Protection testing & trials	PO	220 KV
TOPWORTH - KHANDESHWAR	15-06-2024	14:24			Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel	PO	220 KV
KALWA - MULUND 1	16-06-2024	13:02	16-06-2024	18:06	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 6 sets are to be installed)	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KALWA - BORIVALI	16-06-2024	18:40	16-06-2024	22:14	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 17 sets out of 33 sets are to be installed) Total Completed - 16 sets	PO	220 KV
KHAPARKHEDA- SURYALAKSHMI	16-06-2024	16:56	16-06-2024	18:49	Bus-1 BB Prot Optd	T	220 KV
PIRANGUT - HINJAWADI 2	16-06-2024	09:50	16-06-2024	13:43	Erection of monopole Loc No. 154 for height raising purpose and stringing of conductor at New Monopole Loc. No. 154-155	PO	220 KV
220 / 110 / 22kv 250MVA ICT 1 @ BORIVALI (TATA)	16-06-2024	09:32	16-06-2024	10:34	OSR canopy installation	PO	220 KV
220 / 110 / 33kv 250MVA ICT 3 @ BORIVALI (TATA)	16-06-2024	10:51	16-06-2024	11:41	OSR canopy installation	PO	220 KV
220 KV BUS COUPLER	16-06-2024	16:56	16-06-2024	18:40	Bus-1 BB Prot Optd	T	220 KV
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA CKT 2	16-06-2024	16:56	16-06-2024	18:17	Bus-1 Bus bar Protection operated	T	220 KV
220KV MAIN BUS 1 @ 220KV KHAPARKHEDA S/S	16-06-2024	16:56	16-06-2024	18:17	220 KV TBC Bay, Bus-1 isolator Yph jumpering by Hot line unit was in process .During restoration process , while moving hot line arrangement sudden rainfall started and Y phase earth fault occurred on 220 kv Bus1,through wet hot line ropes.	T	220 KV
220KV PANDHARKAWDA - WANI CKT li	16-06-2024	17:52	16-06-2024	18:42	Distance protection	T	220 KV
40 MVA 220/6.6 KV STN TF - 1 @KHAPARKHEDA	16-06-2024	16:56	16-06-2024	18:58	Bus-1 BB Prot Optd	T	220 KV
40MVA 220/6.6 KV STN T/F 3	16-06-2024	16:56	16-06-2024	19:58	Bus-1 BB Prot Optd	T	220 KV
BORIVALI - CTRLS CKT	16-06-2024	18:44	16-06-2024	22:12	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 15 sets out of 33 sets are to be installed)	PO	220 KV
KHAPERKHEDA - KALMESHVAR CKT	16-06-2024	16:56	16-06-2024	18:41	Bus-1 BB Prot Optd	T	220 KV
KHARGHAR - BORIVALI CKT - 2	16-06-2024	13:02	16-06-2024	16:12	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 66 sets are to be installed) Total completed - 6 sets	PO	220 KV
MAIN BUS SECTION - 1 @ POPHALI	16-06-2024	07:20	16-06-2024	18:12	220 KV Main Bus Section I outage Damaged conductor replacement work related to 220 kv main bus worksd main bus isolators allignment work	PO	220 KV

Transmission Line Outages/Trippings from 10.06.2024 to 16.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PADGHE - NALASOPARA - VASAI (T)	16-06-2024	12:56	16-06-2024	17:11	1) Insulator replacement Work identified in PID. 2) Diagnostic Testing and Pre-monsoon Maintenance Work at Vasai s/stn.	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	16-06-2024	10:46	16-06-2024	14:47	1)Work in vicinity of 220KV TC-7/KVTL-2 line at ash pond for daff installation activity. Activity will be carried out by environment team at Trombay generating station	PO	220 KV
KANHAN-MANSAR	12-06-2024	10:56	12-06-2024	13:20	For routine maintenance work	PO	132 KV
KANHAN-MANSAR	12-06-2024	10:56	12-06-2024	13:20	132KV Kanhan line Yph LA IR value to be taken due to high LA LCM value.Breaker timing,CRM and Routine Maintenance work		132 KV
DEEPNAGAR- NIMBHORA	13-06-2024	10:53	13-06-2024	14:14	D/P B-E Z1 30KM 3.3KA	T	132 KV
PADEGAON- WALUJ 1	13-06-2024	08:05	13-06-2024	12:45	AT P E=R PH, IF=2.3KA, D=66METER	T	132 KV
AMBERNATH - KALYAN CKT - 1	10-06-2024	06:45	10-06-2024	14:29	Insulator replacement	PO	110 KV
AMBERNATH - KALYAN CKT - 2	12-06-2024	06:32	12-06-2024	12:28	INSULATOR REPLACEMENT	PO	110 KV
BHIVPURI - AMBERNATH CKT - 1	13-06-2024	08:04	13-06-2024	09:20	Bird nest removal at loc. 166,173,175,182	PO	110 KV
TATA AMBERNATH MSETCL NERAL	13-06-2024	06:04	13-06-2024	07:50	Bird nest removal at loc. 176,177,178,180,181,183,184,185,186	PO	110 KV
TATA BHIVPURI MSETCL NERAL	13-06-2024	09:51	13-06-2024	16:42	110 KV BN line TBS GOD Stuck defect attaining work	PO	110 KV
TATA BHIVPURI MSETCL NERAL	14-06-2024	06:05	14-06-2024	13:14	R/M of TBS GOD and Testing	PO	110 KV
BORIVLI (T) - BORIVLI (M) - BMC - KOLSHET	16-06-2024	08:55	16-06-2024	19:59	Old OHIO Make polymer insulator replacement	PO	110 KV
KARANJADE - BHOKARPADA	16-06-2024	09:47	16-06-2024	12:34	For Bird nest removal at loc.161,183,191	PO	110 KV
KARANJADE - BHOKARPADA	16-06-2024	09:47			Bkr, CT, LS GOD, TBS GOD	PO	110 KV