

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 08/Aug/2016 to 14/Aug/2016

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/08/2016	10 Hrs	2786	1316	411	4513	4532	2053	2408	85	-1306	12285	0	12285	1069	402	15062	15062	49.99
09/08/2016	10 Hrs	2739	1140	402	4281	4534	2320	2799	83	-1359	12658	0	12658	1078	400	15495	15495	49.99
10/08/2016	11 Hrs	2711	477	285	3473	5626	2055	2896	80	-1515	12615	0	12615	1117	401	15648	15648	49.98
11/08/2016	11 Hrs	3119	413	290	3822	5267	1761	3108	92	-1243	12807	0	12807	1291	503	15844	15844	49.99
12/08/2016	9 Hrs	2959	1072	426	4457	5022	1459	3101	61	-789	13311	0	13311	1205	506	15811	15811	49.97
13/08/2016	11 Hrs	3221	760	416	4397	5024	1710	3040	87	-1160	13098	0	13098	1170	422	15850	15850	49.94
14/08/2016	10 Hrs	3487	474	282	4243	4890	1562	3100	102	-668	13229	0	13229	1014	507	15418	15418	50.00
Maximum		3487	1316	426	4513	5626	2320	3108	102	-668	13311	0	13311	1291	507	15850	15850	50.00
Minimum		2711	413	282	3473	4532	1459	2408	61	-1515	12285	0	12285	1014	400	15062	15062	49.94
Average		3003	807	359	4169	4985	1846	2922	84	-1149	12858	0	12858	1135	449	15590	15590	49.98

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/08/2016	13 Hrs	2487	844	396	3727	3997	2220	2409	95	-1357	11091	0	11091	1161	505	14114	14114	50.01
09/08/2016	13 Hrs	2766	651	403	3820	4264	2110	2717	140	-1464	11587	0	11587	1078	483	14612	14612	50.00
10/08/2016	13 Hrs	2733	138	287	3158	4661	2391	3017	119	-1584	11762	0	11762	1076	402	14824	14824	50.04
11/08/2016	13 Hrs	3050	264	282	3596	5748	1912	2793	139	-1580	12608	0	12608	1046	402	15636	15636	50.00
12/08/2016	13 Hrs	2917	285	408	3610	5260	1496	3101	135	-1534	12068	0	12068	1094	403	15099	15099	49.95
13/08/2016	13 Hrs	3177	295	416	3888	4951	1827	2776	111	-1302	12251	0	12251	1064	401	15018	15018	49.96
14/08/2016	13 Hrs	3284	283	275	3842	4615	1808	2707	130	-846	12256	0	12256	992	403	14497	14497	49.98
Maximum		3284	844	416	3888	5748	2391	3101	140	-846	12608	0	12608	1161	505	15636	15636	50.04
Minimum		2487	138	275	3158	3997	1496	2409	95	-1584	11091	0	11091	992	401	14114	14114	49.95
Average		2916	394	352	3663	4785	1966	2789	124	-1381	11946	0	11946	1073	428	14829	14829	49.99

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/08/2016	20 Hrs	2556	1537	392	4485	4532	1915	2868	0	-1077	12723	0	12723	1164	489	15453	15453	49.93
09/08/2016	20 Hrs	2973	1332	393	4698	4811	2087	2909	0	-1284	13221	0	13221	1063	401	15969	15969	49.98
10/08/2016	20 Hrs	2830	1611	280	4721	5150	2058	2716	0	-1273	13372	0	13372	1087	403	16135	16135	49.95
11/08/2016	20 Hrs	3193	1495	281	4969	4878	1756	2889	0	-1019	13473	0	13473	1255	506	16253	16253	49.94
12/08/2016	21 Hrs	2968	1188	424	4580	4674	1343	3062	0	-885	12774	0	12774	1282	507	15448	15448	49.95
13/08/2016	20 Hrs	3461	1724	399	5584	3840	1710	3364	0	-891	13607	0	13607	1253	491	16242	16242	49.85
14/08/2016	21 Hrs	3277	880	288	4445	4720	1647	2969	0	-798	12983	0	12983	1064	403	15248	15248	49.90
Maximum		3461	1724	424	5584	5150	2087	3364	0	-798	13607	0	13607	1282	507	16253	16253	49.98
Minimum		2556	880	280	4445	3840	1343	2716	0	-1284	12723	0	12723	1063	401	15248	15248	49.85
Average		3037	1395	351	4783	4658	1788	2968	0	-1032	13165	0	13165	1167	457	15821	15821	49.93

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
08/08/2016	4 Hrs	2613	955	397	3965	2686	1858	2383	0	-595	10297	0	10297	614	402	11908	11908	49.96
09/08/2016	4 Hrs	2506	1080	400	3986	2624	2362	2405	0	-648	10729	0	10729	639	402	12418	12418	50.00
10/08/2016	4 Hrs	2860	1262	280	4402	2495	2242	2391	0	-656	10874	0	10874	632	402	12564	12564	49.99
11/08/2016	4 Hrs	2816	423	290	3529	4250	1658	2548	0	-622	11363	0	11363	653	404	13042	13042	49.98
12/08/2016	4 Hrs	2778	332	399	3509	4478	1385	2597	0	-636	11333	0	11333	659	402	13030	13030	49.96
13/08/2016	3 Hrs	2790	395	414	3599	4094	917	3077	0	-721	10966	0	10966	651	403	12741	12741	49.97
14/08/2016	4 Hrs	2906	180	424	3510	4101	1555	2946	0	-694	11418	0	11418	618	402	13132	13132	49.99
Maximum		2906	1262	424	4402	4478	2362	3077	0	-595	11418	0	11418	659	404	13132	13132	50.00
Minimum		2506	180	280	3509	2495	917	2383	0	-721	10297	0	10297	614	402	11908	11908	49.96
Average		2753	661	372	3786	3533	1711	2621	0	-653	10997	0	10997	638	402	12691	12691	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
08/08/2016	62.560	30.072	9.674	102.306	0.252	87.613	86.271	48.820	59.139	0.784	22.960	10.079	-25.070	273.592	58.102	331.694
09/08/2016	65.766	28.086	9.143	102.995	0.247	92.461	92.039	52.391	61.586	0.986	22.824	9.841	-26.441	283.978	59.106	343.084
10/08/2016	67.737	19.435	6.814	93.986	0.165	103.356	103.388	50.044	64.214	0.781	23.421	9.712	-26.020	286.361	59.153	345.514
11/08/2016	71.652	14.182	7.103	92.937	0.221	111.156	111.198	42.247	67.472	0.990	24.128	10.425	-24.421	290.383	58.974	349.357
12/08/2016	69.952	14.515	9.775	94.242	0.199	109.668	109.185	33.164	72.118	0.973	25.478	10.732	-23.174	286.991	59.387	346.378
13/08/2016	74.741	15.678	9.885	100.304	0.142	104.378	106.610	35.817	72.549	0.818	24.197	10.559	-21.177	292.689	55.932	348.621
14/08/2016	77.529	8.747	7.841	94.117	0.116	105.779	106.522	39.388	69.568	1.005	21.914	10.307	-17.157	292.700	49.378	342.078
Maximum	77.529	30.072	9.885	102.995	0.252	111.156	111.198	77.529	72.549	1.005	25.478	10.732	-17.157	292.700	59.387	349.357
Minimum	62.560	8.747	6.814	92.937	0.116	87.613	86.271	62.560	59.139	0.781	21.914	9.712	-26.441	273.592	49.378	331.694
Average	69.991	18.674	8.605	97.270	0.192	102.059	102.173	69.991	66.664	0.905	23.560	10.236	-23.351	286.671	57.147	343.818

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
08/08/2016	0.000	0.484	61.975
09/08/2016	0.000	0.484	61.975
10/08/2016	0.100	0.584	61.875
11/08/2016	0.198	0.782	61.677
12/08/2016	0.214	0.996	61.463
13/08/2016	0.230	1.226	61.233
14/08/2016	0.090	1.316	61.143

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 08/Aug/2016 to 14/Aug/2016

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
08/08/2016	MONDAY	71.273	3580	14.998	625	86.271	3595	87.613	3651	1.342	56
09/08/2016	TUESDAY	81.328	3824	10.711	446	92.039	3835	92.461	3853	0.422	18
10/08/2016	WEDNESDA	82.791	4287	20.597	858	103.388	4308	103.356	4306	-0.032	-1
11/08/2016	THURSDAY	93.342	4615	17.856	744	111.198	4633	111.156	4632	-0.042	-2
12/08/2016	FRIDAY	93.479	4534	15.706	654	109.185	4549	109.668	4570	0.483	20
13/08/2016	SATURDAY	91.258	4427	15.352	640	106.610	4442	104.378	4349	-2.232	-93
14/08/2016	SUNDAY	91.170	4423	15.352	640	106.522	4438	105.779	4407	-0.743	-31
Total		604.640		110.573		715.213		714.411		-0.802	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 08/08/2016 TO 14/08/2016							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Koyna Unit 10	80MW	29/Dec/2015	08:00		Continued.	Annual Overhaul
MSPGCL	Khaparkheda Unit 1	210MW	25/Jun/2016	23.45		Continued.	Zero Schedule by MSEDCL from 00.00Hrs Dt.19-7-16 and A.O.H from 25/06/2016 to 18/07/2016
MSPGCL	Bhusawal Unit 4	500MW	01/Jul/2016	23.55	13/Aug/2016	07.01	A.O.H.(Zero Schedule from 01/07/2016 to 16/07/2016)
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	WPCL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	WPCL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
IPP	RPL(AMT) U-5	270MW	24/May/2016	00.05		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 7	108MW	24/May/2016	17.42		Continued.	Generation Bearing Vibration High.
MSPGCL	Koradi Unit 9	660MW	04/Jun/2016	14.45		Continued.	No concent to operate
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-2	270MW	18/Jun/2016	06.54		Continued.	Zero Shedule By MSEDCL.
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01		Continued.	Zero Shedule By MSEDCL.
IPP	RPL(AMT) U-4	270MW	30/Jun/2016	10.11		Continued.	Zero Schedule By MSEDCL.
MSPGCL	Bhusawal Unit 5	500MW	01/Jul/2016	23.59		Continued.	Zero Shedule By MSEDCL.
IPP	RPL(AMT) U-1	270MW	01/Jul/2016	18.40		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Koradi Unit 5	200MW	01/Jul/2016	02.23		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Koradi Unit 7	210MW	01/Jul/2016	04.43		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Khaparkheda Unit 2	210MW	05/Jul/2016	23.46		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Khaparkheda Unit 3	210MW	05/Jul/2016	23.52		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Bhusawal Unit 3	210MW	08/Jul/2016	23.57		Continued.	ID Fan Problem (Converted to Zero schedule by MSEDCL from 11-07-2016)
MSPGCL	Khaparkheda Unit 4	210MW	08/Jul/2016	03.07		Continued.	Zero Shedule By MSEDCL.
IPP	Adani U-4	660MW	13/Jul/2016	02.29			Zero Shedule By MSEDCL.
RGPPL	Dabhol 3B	230MW	18/Jul/2016	12.40		Continued.	Tripped.
RGPPL	Dabhol 2B	230MW	24/Jul/2016	17.13		Continued.	Change Over
IPP	JSW (J) U3	300MW	31/Jul/2016	19.29	10/Aug/2016	17.23	Generator Hydrogen leakage
MSPGCL	Nasik Unit 5	210MW	03/Aug/2016	17.30		Continued.	Zero shedule
IPP	Adani U-1	660MW	05/Aug/2016	11.44		Continued.	Zero Schedule from MSEDCL
MSPGCL	Chandrapur Unit 6	500MW	06/Aug/2016	21.54		Continued.	Boiler Tube Leakage
IPP	Adani U-5	660MW	06/Aug/2016	23.54		Continued.	Zero schedule given by MSDCL.
MSPGCL	Nasik Unit 3	210MW	08/Aug/2016	11.55	08/Aug/2016	21.48	due to Tripping of 6.6kv R3B Board
MSPGCL	Paras Unit 3	250MW	08/Aug/2016	00.01		Continued.	Zero schedule given by MSDCL.
MSPGCL	Uran Unit B0	120MW	09/Aug/2016	20.24	11/Aug/2016	23.23	Due To Gas Sortage.
MSPGCL	Uran Unit 8	108MW	09/Aug/2016	20.33	11/Aug/2016	20.18	Due To Gas Sortage.
MSPGCL	Chandrapur Unit 3	210MW	09/Aug/2016	00.08		Continued.	Zero Schedue
MSPGCL	Chandrapur Unit-8	500MW	10/Aug/2016	09.52	10/Aug/2016	13.40	Flame Failure
IPP	JSW (J) U3	300MW	10/Aug/2016	17.44	10/Aug/2016	19.29	Turbine Valve Problem.
MSPGCL	Chandrapur Unit 9	500MW	11/Aug/2016	22.11		Continued.	Oil Shortage.
MSPGCL	Nasik Unit 4	210MW	12/Aug/2016	06.50	13/Aug/2016	09.45	Boiler Tube Leakage
MSPGCL	Bhusawal Unit 4	500MW	13/Aug/2016	22.38	14/Aug/2016	03.22	Furnace Pressure High
MSPGCL	Bhusawal Unit 4	500MW	14/Aug/2016	21.28		Continued.	Zero schedule by MSEDCL
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.57		Continued.	Bearing vibration high

LINE OUTAGES FOR THE WEEK FROM 08/08/2016 TO 14/08/2016

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Bhusawal-Aurangabad	27/Jul/2016	13.09		Continued.	Over Voltage
400 KV	Karad-Jaigad - I	27/Jul/2016	21.07	10/Aug/2016	09.05	Over Voltage
400 KV	Ektuni-Bableshtarwar ckt II	01/Aug/2016	09.53		Continued.	To control Padgha-BBLSR L/L
400 KV	Chandrapur Bhadravati II	03/Aug/2016	01.59		Continued.	Over Voltage
400 KV	Kolhapur Solapur (PG) II	03/Aug/2016	15.49	08/Aug/2016	08.16	Over Voltage
400 KV	Bus Coupler @ Parly(Girwali)	05/Aug/2016	11.56	08/Aug/2016	18.26	Tripped without Indication,while charging trial failed at 18.08hrs on PDR problem
400 KV	Chandrapur-II - Nanded	07/Aug/2016	00.53	08/Aug/2016	14.52	Over Voltage
400 KV	Girwali-Solapur (Lamboti)	07/Aug/2016	09.23	08/Aug/2016	06.40	Line signature analysis and reactor cold welding work for oil leakage.
400 KV	Lonikand I - Koyana stage-IV	07/Aug/2016	13.17	08/Aug/2016	10.30	Over Voltage
400 KV	Dhule Khandwa II	07/Aug/2016	14.34	08/Aug/2016	07.45	To convert line reactor as bus reactor at khandwa end.
400 KV	Padghe - Kharghar	07/Aug/2016	17.07		Continued.	Shifted on TBC at kharghar end
400 KV	Kolhapur Solapur (PG) II	08/Aug/2016	12.10	10/Aug/2016	09.39	Over Voltage
400 KV	N.Koyana-Karad -Ckt I	08/Aug/2016	12.25	13/Aug/2016	10.22	Over Voltage
400 KV	Akola-Nandgaonpeth (RPL)	08/Aug/2016	13.14	08/Aug/2016	15.55	PID Testing by hot line
400 KV	Dhule Khandwa I	08/Aug/2016	13.20	12/Aug/2016	07.39	Over Voltage
400 KV	Padghe - Kharghar	08/Aug/2016	14.29	08/Aug/2016	17.22	Attending Hot Spot
400 KV	Chandrapur-II - Nanded	08/Aug/2016	14.52	08/Aug/2016	19.13	opportunity outage
400 KV	Chandrapur-II - Nanded	09/Aug/2016	03.37	09/Aug/2016	06.56	Over Voltage
400 KV	Waluj Talegaon(Pg) li	09/Aug/2016	10.36	09/Aug/2016	19.09	To Replace Faulty CVT.
400 KV	Kolhapur(M)-Kolhapur(GIS) ckt1	09/Aug/2016	11.51	09/Aug/2016	12.53	DT Recevie At Kolhapur
400 KV	karad -kolhapur-I	09/Aug/2016	14.48		Continued.	Over Voltage
400 KV	karad -kolhapur-I	09/Aug/2016	14.48	09/Aug/2016	15.31	Over Voltage
400 KV	Koradi-India Bulls	10/Aug/2016	08.12	10/Aug/2016	19.21	PID Testing Of Insulator String By Hot Line Method.
400 KV	Solapur - Parli(PG) II	10/Aug/2016	09.48	10/Aug/2016	19.46	Outage From Power Grid.
400 KV	Ektuni-Taptitanda II	10/Aug/2016	12.02	10/Aug/2016	19.53	Annual Maintenance Work
400 KV	Babhaleshtarwar - Padghe-II	10/Aug/2016	12.02	10/Aug/2016	21.34	Damaged Wavetrap Replacement.
400 KV	Padgha Tarapur II	10/Aug/2016	12.23	10/Aug/2016	16.44	Outage At Tarapur End.
400 KV	Kolhapur Solapur(PG) I	10/Aug/2016	16.04	11/Aug/2016	09.41	Over Voltage
400 KV	Karad - Jaigad - II	10/Aug/2016	17.33	11/Aug/2016	10.17	Over Voltage
400 KV	Kolhapur Solapur (PG) II	11/Aug/2016	03.00	11/Aug/2016	07.05	Over Voltage
400 KV	Kolhapur Solapur(PG) I	11/Aug/2016	16.13	12/Aug/2016	07.05	Over Voltage
400 KV	Padghe - Kalwa-II	12/Aug/2016	08.26	12/Aug/2016	13.01	While taking outage for PMU work Y Phase Breaker Pole is Stuck up at Kalwa end.
400 KV	Main Bus I @ Kalwa	12/Aug/2016	09.44	12/Aug/2016	10.19	Bus Bar Prot.Operated
400 KV	Kalwa - Talegaon(PG)	12/Aug/2016	09.44	12/Aug/2016	10.42	Bus Bar Protection Operated
400 KV	Kalwa - Kharghar	12/Aug/2016	09.44	12/Aug/2016	13.55	Bus Bar Protection Operated
400 KV	Akola Wardha I	12/Aug/2016	11.07	12/Aug/2016	16.35	Quarterly Maintenance Work
400 KV	Chandrapur-II - Warora - I	12/Aug/2016	11.40	12/Aug/2016	14.04	Repl.of Partially damage Corona Ring
400 KV	Kolhapur Solapur(PG) I	12/Aug/2016	16.48	13/Aug/2016	07.16	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	13/Aug/2016	00.05	13/Aug/2016	10.06	Over Voltage
400 KV	Karad - Jaigad - II	13/Aug/2016	13.02		Continued.	Over Voltage
400 KV	Kolhapur Solapur(PG) I	14/Aug/2016	00.42		Continued.	Over Voltage
400 KV	Dhule Khandwa II	14/Aug/2016	03.12	14/Aug/2016	08.56	Over Voltage
400 KV	Koradi-Bhusawal	14/Aug/2016	09.22	14/Aug/2016	19.45	Line signature test and faulty disc insulator replacement.
400 KV	Lonikand I - Koyana stage-IV	14/Aug/2016	22.03	16/Aug/2016	07.13	Over Voltage
400 KV	N.Koyana-Karad -Ckt I	15/Aug/2016	16.49		Continued.	Over Voltage
400 KV	karad -kolhapur-II	15/Aug/2016	17.04		Continued.	Over Voltage
400 KV	Aurangabad - Aurangabad(PG) I	15/Aug/2016	18.00		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	GIS Bhandup - Borivali	11/Jan/2016	07.42		Continued.	Tower Erection Work.
220 KV	Aurangabad (Waluj)-Bhenda	22/Jun/2016	23.02		Continued.	Hand Tripped.
220 KV	Kalwa-Salsette-IV	28/Jun/2016	18.17		Continued.	Distance Protection
220 KV	Bableshtarwar- Alephata	24/Jul/2016	07.57		Continued.	Load Diversion.
220 KV	Talandage(400kv) - Five Star Midc	08/Aug/2016	10.45	08/Aug/2016	17.00	Testing Work
220 KV	Adlabs - Pedambe	08/Aug/2016	11.15	08/Aug/2016	18.25	Routine Maintenance Work
220 KV	New Koyana - Pedambe	08/Aug/2016	13.53	08/Aug/2016	14.35	Distance Protection
220 KV	Pophali - New Koyana	08/Aug/2016	13.58	09/Aug/2016	11.40	Distance Protection
220 KV	New Koyana - Pedambe	08/Aug/2016	16.17	08/Aug/2016	16.30	Distance Protection
220 KV	New Koyana - Pedambe	09/Aug/2016	00.19	09/Aug/2016	19.25	conductor snap y phase
220 KV	Talandage(400kv) - Five Star Midc	09/Aug/2016	09.38	09/Aug/2016	20.51	Testing Work
220 KV	Baramati- Kalyani	09/Aug/2016	10.05	09/Aug/2016	13.20	Testing and Maintenance Work.

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Eklahare (Ocr)Nasik - Padghe 2	09/Aug/2016	10.49	09/Aug/2016	14.15	Attending Hot Spot
220 KV	Mururd - Tuljapur	09/Aug/2016	11.05	09/Aug/2016	16.42	Signature Analysis.
220 KV	Paranda-Barshi	09/Aug/2016	11.11	09/Aug/2016	13.56	Annual Maintenance Work
220 KV	Shivajinagar - Satana	09/Aug/2016	12.40	09/Aug/2016	19.06	Distance Protection
220 KV	satara MIDC- Malharpeth	09/Aug/2016	13.55	09/Aug/2016	16.20	Annual Maintenance Work
220 KV	Talandage(400kv) - Five Star Midc	10/Aug/2016	10.04	10/Aug/2016	14.25	Distance Relay Testing Work
220 KV	Ghatghar - Baggaon	10/Aug/2016	13.00	10/Aug/2016	15.50	Jumper Replacement Work.
220 KV	Kalwa - Borivali	10/Aug/2016	15.35	10/Aug/2016	16.10	Tripped on PDR
220 KV	Kalwa - Borivali	10/Aug/2016	20.56	12/Aug/2016	10.08	Shifted On TBC.
220 KV	Loteparshuram- Dasturi Line	11/Aug/2016	11.18	11/Aug/2016	16.08	Attending Hot Spot
220 KV	Telco- Chinchwad	11/Aug/2016	11.19	11/Aug/2016	18.10	Testing Work
220 KV	Dasturi-Kandalgaon Line	11/Aug/2016	11.45	11/Aug/2016	15.35	Attending Hot Spot
220 KV	Parli 3(Old Gcr)- Girwali Ckt 4	11/Aug/2016	11.58	11/Aug/2016	18.19	To Increase Y & B Ph.Phase to Phase Clearance,Line Signature Test.
220 KV	Pophali - Kdph	11/Aug/2016	12.05	12/Aug/2016	13.55	Y Ph Jumper Open Near Gantry.
220 KV	Shivajinagar - Satana	11/Aug/2016	22.17	12/Aug/2016	17.01	Distance Protection
220 KV	Karad(400kv) -Mudshingi Ckt 2-Tak	12/Aug/2016	06.31	12/Aug/2016	12.24	Distance Protection
220 KV	Mahad - Pedambe	12/Aug/2016	12.09	12/Aug/2016	14.30	Conductor replacement.
220 KV	Virur - Gadchiroli	12/Aug/2016	12.25	12/Aug/2016	16.26	Replacement of faulty Disc
220 KV	Mahad - Pedambe	12/Aug/2016	12.30	12/Aug/2016	14.30	Maintance work.
220 KV	Malharpeth - Karad(400kv)	12/Aug/2016	14.40	12/Aug/2016	16.31	Replacement of Line Isolator
220 KV	Nagothane-Wadkhal-I	13/Aug/2016	06.47	13/Aug/2016	13.52	Tripped
220 KV	Aurangabad (Waluj)-Bhenda	13/Aug/2016	08.37	14/Aug/2016	18.52	Stringing of 765 kv DC line (WRLDC work)
220 KV	Boisar Versova Line	13/Aug/2016	09.01	13/Aug/2016	15.28	Backup relay replacement.
220 KV	Tillari Amona	13/Aug/2016	09.35	13/Aug/2016	11.40	Annual Maintenance Work
220 KV	Shivajinagar - Satana	13/Aug/2016	15.07	13/Aug/2016	16.55	For Connecting Jumper.
220 KV	Gcr Chandrapur - Grace Ltd	13/Aug/2016	18.32	13/Aug/2016	19.32	Distance Protection
220 KV	Apta - Taloja	13/Aug/2016	21.51	14/Aug/2016	01.04	B Phase L A Burst @ Taloja end.
220 KV	Kalwa Salsette III	14/Aug/2016	10.13	14/Aug/2016	16.25	Providing additional polymer insulator string.
220 KV	Shivajinagar - Malegaon	15/Aug/2016	15.36		Continued.	Distance Protection
132 KV	Dhule(220kv) - Dhule(132 Kv) 1	11/Aug/2016	09.26	11/Aug/2016	12.48	Distance Protection
132 KV	Mul-Sindewahi	13/Aug/2016	00.38	13/Aug/2016	01.17	Distance Protection
132 KV	Mul-Sindewahi	13/Aug/2016	01.32	13/Aug/2016	14.55	Distance Protection
132 KV	Durgwada-Daryapur	13/Aug/2016	06.50	13/Aug/2016	07.25	Distance Protection
132 KV	Sppl - Sanaswadi	13/Aug/2016	10.37	13/Aug/2016	18.51	Attending Hot Spot