

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 09/Sep/2019 to 15/Sep/2019

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/09/2019	10 Hrs	3563	1119	0	4682	6280	2224	3610	363	-1738	15421	0	15421	733	373	18265	18265	49.96
10/09/2019	11 Hrs	3506	936	0	4442	6248	2134	3596	638	-1813	15245	0	15245	699	373	18130	18130	50.01
11/09/2019	10 Hrs	3387	1086	0	4473	6080	2026	3948	488	-1573	15442	0	15442	823	475	18313	18313	50.02
12/09/2019	9 Hrs	3295	597	0	3892	6674	1691	3963	247	-1254	15213	0	15213	772	472	17711	17711	49.95
13/09/2019	10 Hrs	3212	1110	120	4442	6281	1926	3639	377	-1809	14856	0	14856	663	373	17701	17701	50.01
14/09/2019	9 Hrs	3360	1051	120	4531	6455	1811	3602	253	-1277	15375	0	15375	693	373	17718	17718	50.01
15/09/2019	10 Hrs	3442	1348	120	4910	6237	1048	3460	340	-1230	14765	0	14765	573	374	16942	16942	50.03
Maximum		3563	1348	120	4910	6674	2224	3963	638	-1230	15442	0	15442	823	475	18313	18313	50.03
Minimum		3212	597	0	3892	6080	1048	3460	247	-1813	14765	0	14765	573	373	16942	16942	49.95
Average		3395	1035	51	4482	6322	1837	3688	387	-1528	15188	0	15188	708	402	17826	17826	50.00

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/09/2019	13 Hrs	3364	1119	0	4483	5694	2300	3361	458	-1858	14438	0	14438	747	373	17416	17416	49.95
10/09/2019	13 Hrs	3410	1051	0	4461	6298	1901	3504	570	-1791	14943	0	14943	753	375	17862	17862	49.92
11/09/2019	13 Hrs	3256	1044	0	4300	5886	2083	3592	371	-1906	14326	0	14326	769	375	17376	17376	49.97
12/09/2019	13 Hrs	2919	657	61	3637	5850	2350	3488	471	-1807	13989	0	13989	706	374	16876	16876	50.03
13/09/2019	13 Hrs	3257	964	129	4350	5413	2216	3539	587	-1992	14113	0	14113	687	374	17166	17166	49.96
14/09/2019	13 Hrs	3367	1067	120	4554	6072	1580	3501	457	-1812	14352	0	14352	689	375	17228	17228	50.03
15/09/2019	13 Hrs	3506	1046	120	4672	5427	1451	3440	466	-1371	14085	0	14085	581	374	16411	16411	50.01
Maximum		3506	1119	129	4672	6298	2350	3592	587	-1371	14943	0	14943	769	375	17862	17862	50.03
Minimum		2919	657	0	3637	5413	1451	3361	371	-1992	13989	0	13989	581	373	16411	16411	49.92
Average		3297	993	61	4351	5806	1983	3489	483	-1791	14321	0	14321	705	374	17191	17191	49.98

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/09/2019	20 Hrs	3552	1411	0	4963	5617	1881	3903	0	-1347	15017	0	15017	976	438	17778	17778	49.95
10/09/2019	20 Hrs	3640	988	0	4628	5614	1689	4105	0	-1191	14845	0	14845	1045	491	17572	17572	50.02
11/09/2019	19 Hrs	3234	1398	0	4632	5837	2106	3938	3	-1506	15010	0	15010	869	425	17810	17810	49.96
12/09/2019	20 Hrs	2879	839	90	3808	5192	2047	3744	0	-1177	13614	0	13614	793	374	15958	15958	50.03
13/09/2019	20 Hrs	3574	1154	119	4847	5531	1622	4014	0	-1426	14588	0	14588	912	468	17394	17394	50.03
14/09/2019	20 Hrs	3462	1439	122	5023	5615	1491	4063	0	-1343	14849	0	14849	904	481	17577	17577	50.04
15/09/2019	20 Hrs	3844	539	131	4514	5684	1342	4095	0	-903	14732	0	14732	895	482	17012	17012	50.01
Maximum		3844	1439	131	5023	5837	2106	4105	3	-903	15017	0	15017	1045	491	17810	17810	50.04
Minimum		2879	539	0	3808	5192	1342	3744	0	-1506	13614	0	13614	793	374	15958	15958	49.95
Average		3455	1110	66	4631	5584	1740	3980	0	-1270	14665	0	14665	913	451	17300	17300	50.01

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/09/2019	3 Hrs	3465	1211	0	4676	3537	1897	3321	0	-909	12522	0	12522	516	372	14319	14319	50.00
10/09/2019	4 Hrs	3292	1135	0	4427	3771	1649	3454	0	-868	12433	0	12433	531	373	14205	14205	50.01
11/09/2019	3 Hrs	3363	158	0	3521	5095	1529	3636	0	-907	12874	0	12874	555	374	14710	14710	49.96
12/09/2019	24 Hrs	2843	523	119	3485	4162	1784	3626	0	-1104	11953	0	11953	654	375	14086	14086	50.00
13/09/2019	3 Hrs	2780	400	119	3299	3658	1933	3457	0	-864	11483	0	11483	572	374	13293	13293	50.05
14/09/2019	3 Hrs	3336	947	120	4403	4059	1367	3495	0	-908	12416	0	12416	568	375	14267	14267	50.03
15/09/2019	3 Hrs	3264	1032	121	4417	4801	913	3490	0	-945	12676	0	12676	597	373	14591	14591	49.99
Maximum		3465	1211	121	4676	5095	1933	3636	0	-864	12874	0	12874	654	375	14710	14710	50.05
Minimum		2780	158	0	3299	3537	913	3321	0	-1104	11483	0	11483	516	372	13293	13293	49.96
Average		3192	772	68	4033	4155	1582	3497	0	-929	12337	0	12337	570	374	14210	14210	50.01

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
09/09/2019	81.672	29.181	0.000	110.853	0.743	120.739	121.074	49.109	84.284	3.559	17.280	9.318	-32.352	336.192	58.950	395.142
10/09/2019	82.820	22.717	0.000	105.537	1.213	127.864	127.125	43.292	87.575	4.516	17.311	9.492	-31.324	337.460	58.127	395.587
11/09/2019	79.706	20.108	0.039	99.853	1.238	136.281	136.230	43.763	89.447	3.442	17.791	9.726	-32.587	340.199	60.104	400.303
12/09/2019	71.065	13.505	1.652	86.222	1.260	126.584	126.028	46.967	88.127	3.632	16.912	9.353	-29.758	321.774	56.023	377.797
13/09/2019	76.397	18.660	2.910	97.967	1.266	124.203	124.345	45.251	86.676	3.819	16.414	9.144	-33.937	323.979	59.495	383.474
14/09/2019	80.736	21.028	2.973	104.737	1.264	130.839	130.080	38.544	87.394	3.475	16.446	9.296	-32.097	332.892	57.839	390.731
15/09/2019	84.883	21.970	2.987	109.840	1.267	129.043	129.627	28.496	87.409	3.145	15.358	9.150	-26.082	331.851	50.590	382.441
Maximum	84.883	29.181	2.987	110.853	1.267	136.281	136.230	84.883	89.447	4.516	17.791	9.726	-26.082	340.199	60.104	400.303
Minimum	71.065	13.505	0.000	86.222	0.743	120.739	121.074	71.065	84.284	3.145	15.358	9.144	-33.937	321.774	50.590	377.797
Average	79.611	21.024	1.509	102.144	1.179	127.936	127.787	79.611	87.273	3.655	16.787	9.354	-31.162	332.050	57.304	389.354

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
09/09/2019	0.534	2.069	58.191
10/09/2019	0.377	2.446	57.814
11/09/2019	0.352	2.798	57.462
12/09/2019	0.227	3.025	57.235
13/09/2019	0.325	3.350	56.910
14/09/2019	0.370	3.720	56.540
15/09/2019	0.377	4.097	56.163

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 09/Sep/2019 to 15/Sep/2019

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
09/09/2019	MONDAY	94.575	5018	26.499	1104	121.074	5045	120.739	5031	-0.335	-14
10/09/2019	TUESDAY	99.797	5270	27.328	1139	127.125	5297	127.864	5328	0.739	31
11/09/2019	WEDNESDA	110.802	5651	25.428	1060	136.230	5676	136.281	5678	0.051	2
12/09/2019	THURSDAY	101.187	5226	24.841	1035	126.028	5251	126.584	5274	0.556	23
13/09/2019	FRIDAY	96.128	5153	28.217	1176	124.345	5181	124.203	5175	-0.142	-6
14/09/2019	SATURDAY	104.350	5394	25.730	1072	130.080	5420	130.839	5452	0.759	32
15/09/2019	SUNDAY	109.459	5381	20.168	840	129.627	5401	129.043	5377	-0.584	-24
Total		716.298		178.211		894.509		895.553		1.044	

Generating Unit Outages for the week 9 September- 2019 to 15 Septembert -2019

Sr No	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
1	PLANNED	SWPGL U-3	01-Nov-18	0.28		Continued.	Annual Overhaul
2	PLANNED	Parli Unit 8	04-Jun-19	0		Continued.	Zero Schedule (converted to AOH from 25/06/2019)
3	PLANNED	Koyna STG- IV Unit - 1	18-Jul-19	14.3		Continued.	Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019 for 60 Days)
4	PLANNED	Chandrapur Unit 7	27-Jul-19	0		Continued.	Annual Overhaul
5	PLANNED	Khaparkheda Unit 2	13-Aug-19	15.01		Continued.	Flame Failure(Converted to AOH from 16-8-2019)
6	PLANNED	Paras Unit 4	25-Aug-19	0.45		Continued.	Annual Overhaul
7	PLANNED	Bhusawal Unit 5	25-Aug-19	0.13		Continued.	Capital Overhaul
8	PLANNED	Koradi Unit-8	25-Aug-19	0.01		Continued.	Annual Overhaul
9	FORCED	Trombay 6	15-Jul-15	17:08		Continued.	Economic shutdown
10	FORCED	SWPGL U-1	16-Feb-16	17.09		Continued.	No PPA.
11	FORCED	Parli Unit 4	01-Apr-16	0		Continued.	Economic shutdown
12	FORCED	Parli Unit 5	01-Apr-16	0		Continued.	Economic shutdown
13	FORCED	PGPL U1	07-Feb-17	17.3		Continued.	No Schedule
14	FORCED	PGPL U2	07-Feb-17	17.3		Continued.	No Schedule
15	FORCED	Uran Unit 7	20-Jul-18	12.53		Continued.	Compressor & Turbine Blade Failure.
16	FORCED	IEPL Unit 1	28-Aug-18	21.26		Continued.	No PPA
17	FORCED	SWPGL U-2	27-Nov-18	0		Continued.	No Schedule.
18	FORCED	SWPGL U-4	15-Dec-18	0		Continued.	No Schedule
19	FORCED	VIPL U-1	29-Dec-18	0.3		Continued.	Coal Shortage
20	FORCED	VIPL U-2	17-Jan-19	0.15		Continued.	Coal Shortage
21	FORCED	Dhariwal	01-Jul-19	0.01		Continued.	NO SCHEDULE
22	FORCED	Koyna Unit 10	05-Aug-19	20.05		Continued.	Stator Earth Fault
23	FORCED	Ghatghar Unit-1	13-Aug-19	21.3	09-Sep-19	17.4	Water Leakage
24	FORCED	Uran Unit 6	21-Aug-19	19.35	11-Sep-19	20.05	Gas shortage
25	FORCED	Koradi Unit 7	27-Aug-19	9.52		Continued.	Wet Coal.
26	FORCED	Chandrapur Unit 3	31-Aug-19	16.21		Continued.	Wet Coal.
27	FORCED	Bhusawal Unit 3	01-Sep-19	17.56		Continued.	Zero Schedule.
28	FORCED	RPL(AMT) U-1	01-Sep-19	9.11		Continued.	Generator Protection operated
29	FORCED	Adani U-3	01-Sep-19	0.51		Continued.	APH 3B Support bearing Abnormal Sound.
30	FORCED	Uran Unit B0	03-Sep-19	9.21	12-Sep-19	19.53	Gas shortage due to fire at ONGC.
31	FORCED	Trombay 7B	03-Sep-19	10.42		Continued.	Gas shortage due to fire at ONGC.
32	FORCED	Uran Unit 5	03-Sep-19	4.24		Continued.	boiler discrepancy.
33	FORCED	Koradi Unit 10	03-Sep-19	19	11-Sep-19	21.23	Boiler Tube Leakage
34	FORCED	Uran Unit A0	03-Sep-19	4.22		Continued.	HP feed water pump fault.
35	FORCED	Uran Unit 8	03-Sep-19	9.21	12-Sep-19	10.26	Gas shortage due to fire at ONGC.
36	FORCED	Trombay 7A	03-Sep-19	10.56		Continued.	Gas shortage due to fire at ONGC.
37	FORCED	Koradi Unit 6	06-Sep-19	15.41		Continued.	Zero Schedule
38	FORCED	Nasik Unit 3	07-Sep-19	15.3	13-Sep-19	7.2	Zero Schedule.
39	FORCED	Paras Unit 3	09-Sep-19	10.22	09-Sep-19	12.16	Furnace Pressure High
40	FORCED	Khaparkheda Unit 3	09-Sep-19	3.41	13-Sep-19	12.15	Reheater protection operated
41	FORCED	Nasik Unit 5	10-Sep-19	4.5	10-Sep-19	7.1	Furnace Pressure High
42	FORCED	Uran Unit 6	11-Sep-19	20.17	11-Sep-19	22.44	Flame Sensor Fault.
43	FORCED	Parli Unit 6	11-Sep-19	18.15	12-Sep-19	3.21	BFP Temperature Very High.
44	FORCED	Nasik Unit 4	12-Sep-19	0.01		Continued.	zero schedule.
45	FORCED	Nasik Unit 5	12-Sep-19	13.5	12-Sep-19	15.27	Flame Failure
46	FORCED	Nasik Unit 5	12-Sep-19	16.2		Continued.	HP control valve problem
47	FORCED	Uran Unit 6	12-Sep-19	6.53		Continued.	Tripped during supply changeover
48	FORCED	Paras Unit 3	12-Sep-19	0.01	18-Sep-19	2.09	Zero Schedule.
49	FORCED	Khaparkheda Unit 1	13-Sep-19	14.05		Continued.	Poor Coal
50	FORCED	Khaparkheda Unit 4	13-Sep-19	0.59	13-Sep-19	7.35	Furnace Pressure High

List of Transmission line Trippings/Outages for the week 9 September- 2019 to 15 Septembert -2019

Sr. No.	Voltage Level	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
1	220 KV	PO	Talandage - Chikodi	01-Jun-17	0.01		Continued.	No Schedule
2	220 KV	PO	Mudshingi - Chikodi	01-Jun-17	0.06		Continued.	No Schedule.
3	220 KV	HT	BOISAR BORIVALI	24-Jul-18	13.18		Continued.	To Control Line Loading(H/T from Boisar end)
4	220 KV	Tripped	Miraj - Tilwani	09-Aug-19	5.27		Continued.	Dist.Protection(Tower Bending Location no.28 29)
5	220 KV	Tripped	Talandge(400kv)- Ichalkaranji ckt-1	09-Sep-19	6.24	10-Sep-19	13.55	Distance Protection
6	220 KV	PO	Oni Kharepatan Line	09-Sep-19	11.27	09-Sep-19	17.43	Quarterly Maintenance Work
7	220 KV	PO	Talandge(400kv)- Ichalkaranji ckt-1	09-Sep-19	11.54	09-Sep-19	13.55	Repairing Conductor At TL No.43.
8	220 KV	EO	Mahad-Kandalgaon	10-Sep-19	7.1	10-Sep-19	13.2	Attending Hot Spot On Loc NO9
9	220 KV	Tripped	Kandalgaon - Koyna (Pophali)	10-Sep-19	7.22	11-Sep-19	0.3	Distance Protection
10	220 KV	PO	Badnera - Amravati	10-Sep-19	11.05	10-Sep-19	19.3	For Connection of ERS Tower.
11	220 KV	Tripped	220/100 Kv 100 Mva Emco Ict 1 @Tambati	10-Sep-19	11.55	10-Sep-19	14.32	Due To 220 KV Sectionaliser Tripping.
12	220 KV	Tripped	Tambati - Adlabs	10-Sep-19	11.55	10-Sep-19	18.34	As Wavetrap Burst At Adlab.
13	220 KV	Tripped	New Koyna - Pedambe	10-Sep-19	11.55	10-Sep-19	12.38	On Over Current At Pedambe End.
14	220 KV	Tripped	Ekalahara(Ocr)(Nashik)-Navasari II	10-Sep-19	12.39	10-Sep-19	13.23	Distance Protection
15	220 KV	Tripped	Mahad - Pedambe	10-Sep-19	15.06	10-Sep-19	15.27	Distance Protection
16	220 KV	Tripped	Mahad - Pedambe	10-Sep-19	15.4	10-Sep-19	21.45	Distance Protection
17	220 KV	Tripped	New Koyna - Pedambe	10-Sep-19	18.13	10-Sep-19	18.27	ON Back Up Protection. Tripped At Pedambe End only.
18	220 KV	EO	Koyna (Pophali) - Kdph	10-Sep-19	19.45	11-Sep-19	1	Attending Broken Conductor of Pophali Kandalgaon Line.
19	220 KV	EO	TALEGAON - TALEGAON ambi (PG)-I	11-Sep-19	0.38	11-Sep-19	3.12	Relay Replacement work
20	220 KV	PO	220/132KV 100MVA ICT-II@Belwandi	11-Sep-19	8.45	11-Sep-19	12.1	construction work.
21	220 KV	PO	Lamboti - Pandharpur li	11-Sep-19	10.22	11-Sep-19	20.2	Retrofitting Of Relay.
22	220 KV	PO	Gangapur-Valve	11-Sep-19	11.04	11-Sep-19	13.56	Routine Maintenance Work
23	220 KV	PO	Theur-Jejuri	11-Sep-19	11.55	11-Sep-19	16.24	Y-PH LA Replacement Work.
24	220 KV	Tripped	Gangapur-Valve	11-Sep-19	20.3	12-Sep-19	3.02	DUE TO JERK. BREAKER NOT TRIPPED AT VALVE END.
25	220 KV	Tripped	Wardha-Dhamangaon	11-Sep-19	21.26	11-Sep-19	23.11	Distance Protection
26	220 KV	PO	Kalwa Salsette III	12-Sep-19	7.3	12-Sep-19	8.37	TREE CUTTING.
27	220 KV	PO	Kalwa1- Airoli Knowledge Park	12-Sep-19	8.48	12-Sep-19	20.18	FOR ATTENDING RED HOT SPOT ON CREEK SIDE BUS.
28	220 KV	PO	Lonand-Baramati	13-Sep-19	9.5	13-Sep-19	13.48	Replacement of Flashover Suspension Insulator
29	220 KV	PO	Badnera - Nandgaonpeth	13-Sep-19	11.35		Continued.	Erection and stringing of new D+9 Tower for proposed Railway Wagon repair(Up to 18-9-19)
30	220 KV	PO	Koradi-Butibori Rly Tss	13-Sep-19	11.54	13-Sep-19	17.32	Testing Work
31	220 KV	EO	Pophali - Pedambe II	13-Sep-19	14	13-Sep-19	15.15	SF6 Gas Refilling work
32	220 KV	EO	Adlabs - Pedambe	13-Sep-19	15.45	13-Sep-19	23.18	Wavertrap R&Y phase Jumper replacement at Pedambe end
33	220 KV	PO	Kandalgaon - Koyna (Pophali)	14-Sep-19	8.35	14-Sep-19	11.55	Y-PH Breaker To CT Conductor Replacement.
34	220 KV	PO	Peth- Mudshingi -I	14-Sep-19	10.01	14-Sep-19	11.2	CT oil Leakage attending Work.
35	220 KV	PO	Pigasus-Hinjewadi-II	14-Sep-19	10.01	14-Sep-19	11.06	String Replacement Work.
36	220 KV	PO	Main Bus-I @ Hinjewadi-II	14-Sep-19	10.05	14-Sep-19	12.29	Annual Maintenance Work
37	220 KV	Tripped	Kolshet-Roma	14-Sep-19	21.45	14-Sep-19	7.55	Distance Protection
38	220 KV	Tripped	Malharpeth - Karad(400kv)	15-Sep-19	2.16	15-Sep-19	11.35	Distance Protection Wavetrap & L.A. Burst At Karad End.
39	220 KV	Tripped	Karad(400kv) -Mudshingi Ckt 2-Tak	15-Sep-19	2.16	15-Sep-19	2.48	Distance Protection Mudshingi End Only.

List of Transmission line Trippings/Outages for the week 9 September- 2019 to 15 Septembert -2019

Sr. No.	Voltage Level	Outage Type	Name	Trip Date	Trip Time	Sync Date	Sync Time	Reason
40	220 KV	Tripped	Karad - Vita Ckt- I	15-Sep-19	9.49	15-Sep-19	17.47	Distance Protection
41	220 KV	Tripped	Karad(400kv) - Wathar	15-Sep-19	19.37	15-Sep-19	23.3	Distance Protection
42	400 KV	PO	Karad Solapur (PG)	03-May-17	11:49		Continued.	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
43	400 KV	Tripped	400/220/33 Kv 315 Mva ICT 1 @Padghe	15-Nov-18	10.07		Continued.	Differential Protection Declared Faulty.
44	400 KV	HT	400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	12-Apr-19	17.1		Continued.	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
45	400 KV	PO	400/11.5/6.6 KV 70 MVA Station T/F @Khaparkheda	23-Aug-19	14.48	10-Sep-19	15.2	Routine Maintenance Work
46	400 KV	HT	Dhule Khandwa I	26-Aug-19	9.04	10-Sep-19	8.21	Over Voltage
47	400 KV	HT	Dhule Khandwa II	02-Sep-19	14.31	10-Sep-19	8.52	Control line loading of 400 KV SSP-Asoj.
48	400 KV	HT	Khadka-Aurangabad (Waluj)	04-Sep-19	17.19	13-Sep-19	10.34	Over Voltage
49	400 KV	PO	Bus Coupler @ Parly(Girwali)	09-Sep-19	11.46	09-Sep-19	16.05	Relay Testing And Maintenance Work.
50	400 KV	EO	Bus Coupler @ Karad	09-Sep-19	14.26	09-Sep-19	16.33	Attending Hot Spot
51	400 KV	HT	Karad - Jaigad - II	10-Sep-19	0.04	10-Sep-19	8.19	Over Voltage
52	400 KV	Tripped	Alkud-Kolhapur(Talandage)	10-Sep-19	2.26	10-Sep-19	7.44	Over Voltage
53	400 KV	Tripped	New Koyna - Koyna Stage IV-II	10-Sep-19	2.41	10-Sep-19	8.21	Over Voltage
54	400 KV	PO	Chandrapur-II - Warora - I	10-Sep-19	9.44	10-Sep-19	11.57	Scada & Protection Work.
55	400 KV	EO	Jaigad-New Koyna Ckt-I	10-Sep-19	15.26	10-Sep-19	18.23	Attending Hot Spot At New Koyna End.
56	400 KV	Tripped	400/220 Kv 315 Mva Ict -2 @New Koyna	10-Sep-19	18.32	12-Sep-19	19.04	Differential protection
57	400 KV	HT	Dhule Khandwa II	10-Sep-19	20.2		Continued.	Over Voltage
58	400 KV	PO	Girwali-Solapur (Lamboti)	11-Sep-19	9.47	11-Sep-19	17.4	Line & Bay maint Work.
59	400 KV	PO	Main Bus I @ Chandrapur Sw	11-Sep-19	10.25	11-Sep-19	21.24	Diagnostic Testing.Allied Bay Maint Work.
60	400 KV	PO	Deepnagar Taptitanda	11-Sep-19	11.35	11-Sep-19	16.23	Teed Protection relay Testing Work.
61	400 KV	PO	Kolhapur(M)-Kolhapur(GIS) cktII	12-Sep-19	9.44	12-Sep-19	20.11	Annual Maintenance Work
62	400 KV	PO	Main Bus II @ Chandrapur SW	12-Sep-19	10.22	12-Sep-19	14.38	DIGNOSTIC TESTING WORK.
63	400 KV	PO	Koradi III(Adani)-Koradi II ckt 2	12-Sep-19	11.36	12-Sep-19	16.51	TESTING OF HIGH TEED RELAY.
64	400 KV	HT	Dhule- Bableshtar - I	12-Sep-19	18.16	14-Sep-19	8.55	Over Voltage
65	400 KV	HT	Karad - Jaigad - II	12-Sep-19	23.5	13-Sep-19	9.31	Over Voltage
66	400 KV	PO	Koradi III(Adani)-Koradi II ckt 2	13-Sep-19	10.49	13-Sep-19	17.39	Testing Work
67	400 KV	PO	400/220/33 Kv 315 Mva ICT 2 @Padghe	13-Sep-19	11.17	13-Sep-19	20.5	R Phase LV Bushing Conductor stranded found broken
68	400 KV	PO	Koradi-Bhusawal	13-Sep-19	11.24	14-Sep-19	11.25	Line diversion work under ORC(RFC at 19.44Hrs)
69	400 KV	EO	Padghe - Nagothane - II	13-Sep-19	14.26	13-Sep-19	17.28	To attend Hot Spot
70	400 KV	HT	karad -kolhapur-I	14-Sep-19	9.54	15-Sep-19	11.08	Over Voltage
71	400 KV	PO	Koradi-Bhusawal	14-Sep-19	11.24	14-Sep-19	11.25	Line Diversion Work Under ORC.
72	400 KV	HT	Khadka-Aurangabad (Waluj)	14-Sep-19	16.43	15-Sep-19	9.44	Over Voltage
73	400 KV	Tripped	Koradi-Bhusawal	15-Sep-19	3.55	15-Sep-19	11.5	Over Voltage
74	400 KV	HT	Khadka-Aurangabad (Waluj)	15-Sep-19	15.34	16-Sep-19	8.51	Over Voltage
75	400 KV	Tripped	N.Koyna-Karad -Ckt I	15-Sep-19	22.23	16-Sep-19	9.05	Over Voltage
76	400 KV	HT	Khadka-Aurangabad (Waluj)	17-Sep-19	17.34		Continued.	Over Voltage
77	400 KV	Tripped	Deepnagar - Aurangabad	17-Sep-19	17.52		Continued.	Distance Protection
78	765 KV	PO	Koradi-III - Akola-II ckt-I	11-Sep-19	10.09	11-Sep-19	13.32	Bushing Erection Work For LR R-PH.