

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 05/Oct/2015 to 11/Oct/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05/10/2015	12 Hrs	4561	111	283	4955	5246	94	5413	88	-1441	14355	26	14381	1264	514	17574	17600	49.94
06/10/2015	12 Hrs	4908	231	276	5415	5690	764	4819	169	-1575	15282	33	15315	1173	518	18548	18581	49.94
07/10/2015	11 Hrs	5450	471	315	6236	5594	290	5116	165	-1570	15831	45	15876	1155	513	19069	19114	49.94
08/10/2015	12 Hrs	5734	658	430	6822	5209	122	5251	164	-1625	15943	52	15995	1259	510	19337	19389	49.95
09/10/2015	12 Hrs	5175	762	340	6277	5477	65	5385	143	-1623	15724	460	16184	1213	517	19077	19537	49.97
10/10/2015	12 Hrs	5321	1379	425	7125	5855	73	5049	170	-1600	16672	376	17048	1191	248	19711	20087	49.96
11/10/2015	12 Hrs	5661	748	426	6835	5575	20	5010	148	-1185	16403	271	16674	915	258	18761	19032	49.89
Maximum		5734	1379	430	7125	5855	764	5413	170	-1185	16672	460	17048	1264	518	19711	20087	50
Minimum		4561	111	276	4955	5209	20	4819	88	-1625	14355	26	14381	915	248	17574	17600	50
Average		5259	623	356	6238	5521	204	5149	150	-1517	15744	26	15925	1167	440	18868	19049	50

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05/10/2015	17 Hrs	4906	355	276	5537	4602	239	5523	35	-1535	14401	25	14426	1167	518	17621	17646	49.90
06/10/2015	15 Hrs	4845	69	270	5184	5688	797	4738	130	-1652	14885	23	14908	1147	517	18201	18224	49.88
07/10/2015	13 Hrs	5361	286	338	5985	5243	632	5116	177	-1646	15507	39	15546	1186	515	18854	18893	49.97
08/10/2015	16 Hrs	5433	714	414	6561	5291	175	5297	104	-1592	15836	46	15882	1321	503	19252	19298	49.91
09/10/2015	13 Hrs	5076	592	373	6041	5299	46	5349	172	-1643	15264	549	15813	1178	518	18603	19152	49.99
10/10/2015	16 Hrs	5284	1660	424	7368	5354	183	4938	78	-1602	16319	539	16858	1135	255	19311	19850	49.99
11/10/2015	14 Hrs	5585	929	425	6939	5268	39	4958	153	-1191	16166	565	16731	913	259	18529	19094	49.92
Maximum		5585	1660	425	7368	5688	797	5523	177	-1191	16319	565	16858	1321	518	19311	19850	50
Minimum		4845	69	270	5184	4602	39	4738	35	-1652	14401	23	14426	913	255	17621	17646	50
Average		5213	658	360	6231	5249	302	5131	121	-1552	15483	23	15738	1150	441	18624	18880	50

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05/10/2015	20 Hrs	4893	664	297	5854	4620	162	5490	0	-1302	14824	26	14850	1185	518	17829	17855	49.96
06/10/2015	20 Hrs	5339	467	270	6076	5373	390	4940	0	-1511	15268	26	15294	1098	516	18393	18419	50.01
07/10/2015	20 Hrs	5532	712	421	6665	5169	172	5159	0	-1532	15633	21	15654	1082	513	18760	18781	50.01
08/10/2015	20 Hrs	5580	594	422	6596	5012	95	5059	0	-1519	15243	56	15299	1156	514	18432	18488	50.01
09/10/2015	20 Hrs	4936	616	426	5978	5080	233	5294	0	-1537	15048	103	15151	1058	517	18160	18263	49.97
10/10/2015	20 Hrs	5635	534	410	6579	4832	340	5057	0	-1488	15320	73	15393	1170	257	18235	18308	49.96
11/10/2015	19 Hrs	5197	539	429	6165	4920	117	4932	0	-1264	14870	217	15087	858	242	17234	17451	49.94
Maximum		5635	712	429	6665	5373	390	5490	0	-1264	15633	217	15654	1185	518	18760	18781	50
Minimum		4893	467	270	5854	4620	95	4932	0	-1537	14824	21	14850	858	242	17234	17451	50
Average		5302	589	382	6273	5001	216	5133	0	-1450	15172	21	15247	1087	440	18149	18224	50

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
05/10/2015	4 Hrs	4006	110	310	4426	3443	174	5040	0	-395	12688	19	12707	909	517	14509	14528	49.97
06/10/2015	5 Hrs	4928	364	299	5591	3024	157	4996	0	-480	13288	24	13312	901	517	15186	15210	50.02
07/10/2015	4 Hrs	5233	69	294	5596	4084	294	4668	0	-840	13802	18	13820	805	395	15842	15860	50.03
08/10/2015	4 Hrs	5181	64	428	5673	3727	212	4964	0	-693	13883	20	13903	895	517	15988	16008	50.01
09/10/2015	5 Hrs	5254	71	430	5755	4263	73	4947	0	-786	14252	36	14288	909	398	16345	16381	49.96
10/10/2015	5 Hrs	4811	291	429	5531	4128	222	5261	0	-988	14154	35	14189	825	258	16225	16260	49.95
11/10/2015	5 Hrs	5479	82	430	5991	4077	164	5039	0	-929	14342	50	14392	861	259	16391	16441	49.94
Maximum		5479	364	430	5991	4263	294	5261	0	-395	14342	50	14392	909	517	16391	16441	50
Minimum		4006	64	294	4426	3024	73	4668	0	-988	12688	18	12707	805	258	14509	14528	50
Average		4985	150	374	5509	3821	185	4988	0	-730	13773	18	13802	872	409	15784	15813	50

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
05/10/2015	108.630	6.076	7.043	121.749	0.503	104.373	108.567	4.226	126.704	0.567	25.155	12.397	-26.210	331.409	63.762	395.171
06/10/2015	120.671	5.359	6.852	132.882	0.489	112.118	118.135	9.751	118.283	1.285	24.128	12.396	-29.217	345.102	65.741	410.843
07/10/2015	129.302	4.807	8.450	142.559	0.449	118.113	119.050	7.370	119.618	1.293	23.737	11.729	-31.802	357.152	67.268	424.420
08/10/2015	131.690	7.324	10.211	149.225	0.316	114.720	115.468	3.657	123.325	1.278	25.075	12.133	-31.355	360.850	68.562	429.412
09/10/2015	124.143	9.342	10.017	143.502	0.394	117.619	118.183	3.154	127.172	1.092	23.960	11.802	-32.249	360.292	68.011	428.303
10/10/2015	125.212	17.951	10.224	153.387	0.437	116.884	116.544	6.292	121.562	1.067	23.504	6.166	-33.568	365.627	63.239	428.866
11/10/2015	131.508	7.284	10.343	149.135	0.835	115.368	118.082	3.503	121.066	0.962	21.164	6.377	-27.917	362.117	55.173	417.290
Maximum	131.690	17.951	10.343	153.387	0.835	118.113	119.050	131.690	127.172	1.293	25.155	12.397	-26.210	365.627	68.562	429.412
Minimum	108.630	4.807	6.852	121.749	0.316	104.373	108.567	108.630	118.283	0.567	21.164	6.166	-33.568	331.409	55.173	395.171
Average	124.451	8.306	9.020	141.777	0.489	114.171	116.290	124.451	122.533	1.078	21.164	10.429	-30.331	354.650	64.537	419.186

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
05/10/2015	0.082	0.337	50.676
06/10/2015	0.078	0.415	50.598
07/10/2015	0.072	0.487	50.526
08/10/2015	0.129	0.616	50.397
09/10/2015	0.150	0.766	50.247
10/10/2015	0.375	1.141	49.872
11/10/2015	0.126	1.267	49.746

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 05/Oct/2015 to 11/Oct/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
05/10/2015	MONDAY	97.194	4512	11.373	474	108.567	4524	104.373	4349	-4.194	-175
06/10/2015	TUESDAY	101.260	4905	16.875	703	118.135	4922	112.118	4672	-6.017	-251
07/10/2015	WEDNESDA	101.208	4943	17.842	743	119.050	4960	118.113	4921	-0.937	-39
08/10/2015	THURSDAY	101.312	4797	14.156	590	115.468	4811	114.720	4780	-0.748	-31
09/10/2015	FRIDAY	98.709	4905	19.474	811	118.183	4924	117.619	4901	-0.564	-24
10/10/2015	SATURDAY	100.192	4840	16.352	681	116.544	4856	116.884	4870	0.340	14
11/10/2015	SUNDAY	98.733	4901	19.349	806	118.082	4920	115.368	4807	-2.714	-113
Total		698.608		115.421		814.029		799.195		-14.834	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 05/10/2015 TO 11/10/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
Cent_Sect	Tarapur 2	160MW	10/Sep/2015	12.55		Continued.	Refuelling work
MSPGCL	Koyna Koyna Unit 2	75MW	07/Oct/2015	07.30	08/Oct/2015	01.05	P M Work.
MSPGCL	Koyna Koyna Unit 3	75MW	08/Oct/2015	07.40	08/Oct/2015	19.00	Annual Maintenanace Work.
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 2A	230MW	06/Jun/2013	09.10		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3A	230MW	06/Jun/2013	08.28		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2X	230MW	15/Jul/2013	15.09		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2B	230MW	08/Aug/2013	15.03		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3X	230MW	29/Dec/2013	05.47		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3B	230MW	29/Dec/2013	06.14		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12.43		Continued.	Economic shutdown
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	RPL(AMT) U-5	270MW	03/Apr/2015	14.22		Continued.	turbine Shaft Vibration high.
MSPGCL	Uran Unit 7	108MW	17/Apr/2015	00.07		Continued.	Gas turbine problem
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12.58		Continued.	Water Shortage
IPP	WPCL U-2	135MW	16/Jun/2015	00.00		Continued.	No Schdule
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown
IPP	WPCL U-1	135MW	25/Aug/2015	19.18		Continued.	Maintenance work
IPP	Adani U-4	660MW	11/Sep/2015	20.49		Continued.	Abnormal sound in generater bearing
MSPGCL	Koradi Unit-8	660MW	18/Sep/2015	18.08	05/Oct/2015	04.32	ESP Problem
MSPGCL	Uran Unit 8	108MW	28/Sep/2015	23.11	07/Oct/2015	06.30	Gas shortage
MSPGCL	Uran Unit B0	120MW	28/Sep/2015	23.06	07/Oct/2015	14.49	Gas shortage
MSPGCL	Chandrapur Unit 5	500MW	30/Sep/2015	17.34	05/Oct/2015	05.08	Boiler Tube Leakage
MSPGCL	Khaparkheda Unit 4	210MW	02/Oct/2015	21.12	06/Oct/2015	18.14	Turbine Problem.
MSPGCL	Chandrapur Unit-8	500MW	03/Oct/2015	09.31	05/Oct/2015	18.58	High Drum level
MSPGCL	Nasik Unit 4	210MW	04/Oct/2015	11.32	10/Oct/2015	15.12	Boiler Tube Leakage
MSPGCL	Bhusawal Unit 3	210MW	06/Oct/2015	11.48	06/Oct/2015	13.03	LV Side Station T/F Tripped.
IPP	RPL(AMT) U-1	270MW	06/Oct/2015	18.20	09/Oct/2015	04.38	ID Fan Problem
MSPGCL	Bhusawal Unit 3	210MW	06/Oct/2015	13.12	06/Oct/2015	14.21	Turbine Problem Hunting in Turbine.

GENERATING UNITS OUTAGES FOR THE WEEK FROM 05/10/2015 TO 11/10/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
IPP	RPL(AMT) U-4	270MW	08/Oct/2015	17.48	08/Oct/2015	19.33	Flame Failure
IPP	REL Unit 2	250MW	09/Oct/2015	23.29	11/Oct/2015	21.53	BTL
MSPGCL	Koradi Unit 7	210MW	09/Oct/2015	16.14	10/Oct/2015	04.42	Auxiliary supply failure
MSPGCL	Koradi Unit 8	660MW	09/Oct/2015	10.21	10/Oct/2015	10.12	Boiler Tripped.
IPP	WPCL U-4	135MW	10/Oct/2015	05.25		Continued.	ID Fan Problem
IPP	RPL(AMT) U-4	270MW	10/Oct/2015	05.48	11/Oct/2015	18.56	ID Fan Problem
MSPGCL	Chandrapur Unit 6	500MW	11/Oct/2015	16.50		Continued.	ACW line Outage leakage

LINE OUTAGES FOR THE WEEK FROM 05/10/2015 TO 11/10/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
500 KV	HVDC Pole-I	07/Oct/2015	07.56		Continued.	Annual Overhaul.
400 KV	Akola II - Taptitanda ckt-I	05/Sep/2015	21.56	06/Oct/2015	09.40	Over Voltage
400 KV	Babhaleshwar-Taptitanda ckt-I	29/Sep/2015	17.35	07/Oct/2015	12.51	Over Voltage
400 KV	karad -kolhapur-II	04/Oct/2015	10.38	05/Oct/2015	11.04	Current found zero at karad end RFC 10.40
400 KV	Kolhapur Mapusa I	04/Oct/2015	15.11	05/Oct/2015	08.32	Over Voltage
400 KV	Karad-Jaigad - I	04/Oct/2015	16.15	07/Oct/2015	07.24	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	04/Oct/2015	17.13	05/Oct/2015	09.20	Over Voltage
400 KV	Bhusawal-Aurangabad	04/Oct/2015	17.15	05/Oct/2015	08.29	Over Voltage
400 KV	Dhule Sar'Sarovar I	04/Oct/2015	18.10	05/Oct/2015	09.57	Over Voltage
400 KV	Chandrapur II- Warora ckt II	05/Oct/2015	12.31	05/Oct/2015	19.27	Line Maintenance work
400 KV	Kolhapur Mapusa II	05/Oct/2015	13.42	06/Oct/2015	07.03	Over Voltage
400 KV	karad -kolhapur-I	05/Oct/2015	16.48	07/Oct/2015	06.56	Over Voltage
400 KV	Bhusawal-Aurangabad	05/Oct/2015	18.12	06/Oct/2015	07.27	Over Voltage
400 KV	Dhule Sar'Sarovar I	05/Oct/2015	20.32	06/Oct/2015	06.56	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	06/Oct/2015	01.27	06/Oct/2015	08.29	Over Voltage
400 KV	Kolhapur Solapur(PG) I	06/Oct/2015	07.32	06/Oct/2015	20.10	Routine Maintenance Work
400 KV	Babhaleshwar - Padghe-II	06/Oct/2015	08.46	06/Oct/2015	17.10	Hot Line Work.(Shifted on TBC)
400 KV	Akola II - Taptitanda ckt-II	06/Oct/2015	09.44		Continued.	For Controlling Line Loading.
400 KV	Dabhol Nagothane I	06/Oct/2015	10.16	06/Oct/2015	10.52	Routine Maintenance Work
400 KV	Lonikand 1 -Jejuri	06/Oct/2015	10.24	06/Oct/2015	14.02	To Attend Hot Spot On 298 Isolator At Lonikand End (T shifted On TBC).
400 KV	Babhaleshwar- Aurangabad (Waluj)	06/Oct/2015	10.53	06/Oct/2015	19.25	To attend Hot Spot
400 KV	Dabhol New koyna I	06/Oct/2015	11.21		Continued.	Line Maintenance work
400 KV	Kolhapur Mapusa II	06/Oct/2015	17.02	07/Oct/2015	09.23	Over Voltage
400 KV	Bhusawal-Aurangabad	06/Oct/2015	20.04	07/Oct/2015	06.35	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	07/Oct/2015	00.50	07/Oct/2015	08.14	Over Voltage
400 KV	karad -kolhapur-II	07/Oct/2015	16.39	08/Oct/2015	09.03	Over Voltage
400 KV	Waluj Aurangabad(PG) II	07/Oct/2015	17.06	07/Oct/2015	18.16	Attending of SF6 Gas Low Alarm.
400 KV	Bhusawal-Aurangabad	07/Oct/2015	20.40	08/Oct/2015	06.40	Over Voltage
400 KV	Karad - Jaigad - II	07/Oct/2015	21.02	08/Oct/2015	09.12	Over Voltage
400 KV	Kolhapur Mapusa I	07/Oct/2015	22.02	08/Oct/2015	07.12	Over Voltage
400 KV	Dhule Sar'Sarovar I	07/Oct/2015	22.03	08/Oct/2015	07.16	Over Voltage
400 KV	Chandrapur II - Dhariwal -I	08/Oct/2015	10.52		Continued.	Tree Cutting Work.
400 KV	Karad-Jaigad - I	08/Oct/2015	17.05	10/Oct/2015	08.57	Over Voltage
400 KV	Bhusawal-Aurangabad	08/Oct/2015	17.39	09/Oct/2015	07.00	Over Voltage
400 KV	Kolhapur Mapusa II	08/Oct/2015	21.01	09/Oct/2015	07.22	Over Voltage
400 KV	Dhule Sar'Sarovar I	08/Oct/2015	22.26	09/Oct/2015	07.16	Over Voltage
400 KV	Dabhol Nagothane II	09/Oct/2015	16.05	09/Oct/2015	18.00	Insolatar Maint. Work
400 KV	karad -kolhapur-II	09/Oct/2015	17.05	10/Oct/2015	07.41	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	09/Oct/2015	18.05	10/Oct/2015	06.46	Over Voltage
400 KV	Karad - Jaigad - II	09/Oct/2015	21.05	10/Oct/2015	08.54	Over Voltage
400 KV	Kolhapur Mapusa I	09/Oct/2015	22.03	10/Oct/2015	06.38	Over Voltage
400 KV	Dhule Sar'Sarovar I	09/Oct/2015	22.15	10/Oct/2015	06.42	Over Voltage
400 KV	Nagothane - Dabhol-II	10/Oct/2015	09.57	10/Oct/2015	16.09	Distance Protection
400 KV	karad -kolhapur-II	10/Oct/2015	16.36	11/Oct/2015	07.03	Over Voltage
400 KV	Karad-Jaigad - I	10/Oct/2015	17.15	11/Oct/2015	10.35	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	10/Oct/2015	17.51	11/Oct/2015	07.06	Over Voltage
400 KV	Dhule Sar'Sarovar I	10/Oct/2015	23.15	11/Oct/2015	07.02	Over Voltage
400 KV	Kolhapur Mapusa I	10/Oct/2015	23.55	11/Oct/2015	07.00	Over Voltage
400 KV	Warora-Tirora-I	11/Oct/2015	14.08	11/Oct/2015	16.47	Attending Hot Spot
400 KV	karad -kolhapur-II	11/Oct/2015	16.14		Continued.	Over Voltage

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Karad - Jaigad - II	11/Oct/2015	16.16		Continued.	Over Voltage
400 KV	Kolhapur Mapusa I	11/Oct/2015	16.42		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	11/Oct/2015	17.19		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar I	11/Oct/2015	18.06		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Kalwa - Borivali	16/Aug/2015	08.00	11/Oct/2015	15.39	Erection of Loc.No.12 and shifting of conductor on NER M/C Tower
220 KV	New Koyna - Niwali	03/Oct/2015	16.00	05/Oct/2015	10.41	Distance Protection
220 KV	Kalwa-TIFIL	04/Oct/2015	06.56	05/Oct/2015	00.08	Tifil bay strengthring work
220 KV	Warora - Hinganghat	05/Oct/2015	09.01	05/Oct/2015	18.40	Measurement of Tan Delta of CTs
220 KV	Karad - Vita Ckt- II	05/Oct/2015	10.18	05/Oct/2015	13.57	To attend Hot Spot
220 KV	Gcr Chandrapur - Grace Ltd	05/Oct/2015	10.37	05/Oct/2015	20.46	To check Healthiness of PDR
220 KV	Waluj - Jalna 2	05/Oct/2015	11.55	05/Oct/2015	14.50	Attending Hot Spot
220 KV	Raymond - Washala	05/Oct/2015	13.40	05/Oct/2015	22.31	Bus Fault at Washala
220 KV	Washala - Ghatghar	05/Oct/2015	13.40	05/Oct/2015	15.35	Bus Fault at Washala
220 KV	Kalwa-TIFIL	05/Oct/2015	13.41	05/Oct/2015	18.06	stringing work
220 KV	Pedhambe - Oni	05/Oct/2015	16.00	05/Oct/2015	16.27	Distance Protection
220 KV	Jambhul - Pal	05/Oct/2015	18.13	06/Oct/2015	14.21	Distance Protection
220 KV	Talandage - Sawantwadi I	05/Oct/2015	18.40	05/Oct/2015	19.00	Distance Protection
220 KV	Flagship-Chinchwad	06/Oct/2015	01.42	06/Oct/2015	06.20	To attend Hot Spot
220 KV	Nasik Navsari I	06/Oct/2015	03.58	06/Oct/2015	04.24	Distance Protection
220 KV	Dasturi-Kandalgaon Line	06/Oct/2015	09.10	06/Oct/2015	13.15	Jumper Replacement Work.
220 KV	Badnera-Akola I	06/Oct/2015	09.10	06/Oct/2015	17.28	Tan Delta Measurment of CTs
220 KV	Bableshtar- Ranjangaon	06/Oct/2015	09.19	06/Oct/2015	17.19	For Ict Loading.
220 KV	Karad - Vita Ckt- I	06/Oct/2015	10.20	06/Oct/2015	19.58	Insulator Replacement Work.
220 KV	220/132 KV 200MVA ICT II @ Tilwani	06/Oct/2015	10.22	06/Oct/2015	13.20	Testing Work
220 KV	Mudshingi-Wathar	06/Oct/2015	10.34	06/Oct/2015	13.50	To attend Hot Spot
220 KV	Parli 2-(Girwali) -Murud	06/Oct/2015	11.03	06/Oct/2015	13.12	Quarterly Maintainance Work
220 KV	Warora - Wardha	06/Oct/2015	11.04	06/Oct/2015	13.45	For Attending Hot Spot On B Ph Ct.
220 KV	Gcr Chandrapur - Grace Ltd	06/Oct/2015	12.24	06/Oct/2015	14.11	Sparking on B PH Isolator.
220 KV	Kalmeshwar-Pandhurna	06/Oct/2015	12.35	06/Oct/2015	19.24	Routine Maintenance Work
220 KV	Loteparshuram- Dasturi Line	06/Oct/2015	13.50	06/Oct/2015	16.59	Attending Hot Spot
220 KV	Nasik Navsari I	06/Oct/2015	15.55	06/Oct/2015	19.40	Replacement of Faulty String.
220 KV	Bableshtar- Alephata	07/Oct/2015	06.18	07/Oct/2015	17.09	To Control Load on ICT.
220 KV	Bableshtar- Ranjangaon	07/Oct/2015	07.09	07/Oct/2015	17.08	To Control Load on ICT.
220 KV	Karad - Kadegaon	07/Oct/2015	09.12	07/Oct/2015	19.20	String Replacement Work.
220 KV	Gadchandur - Grace	07/Oct/2015	10.22	07/Oct/2015	19.28	Conversion of SSN to DSN.
220 KV	Uran - Hoc 1	07/Oct/2015	10.45	07/Oct/2015	19.42	CT Tan Delta Measurment Work.
220 KV	Dhule-Amalner(220kv)	07/Oct/2015	12.33	07/Oct/2015	17.50	Distance Protection Operated Zone-I B Ph A/R Oprtd.
220 KV	REL Borivali Aarey Line	08/Oct/2015	00.34	08/Oct/2015	04.06	For Fixing of Insulation Sleeves.
220 KV	Padgha - Temghar I	08/Oct/2015	06.24	08/Oct/2015	09.38	Testing Work
220 KV	Pophli Pedhmbe Line- 2	08/Oct/2015	08.15	08/Oct/2015	16.05	Maintenance Work.
220 KV	Lonand-Baramati	08/Oct/2015	10.10	08/Oct/2015	11.55	Conductor Repairing Work.
220 KV	Topworth - Kharghar	08/Oct/2015	11.44	08/Oct/2015	19.22	Testing Work
220 KV	Jejuri (400 Kv)- Baramati li	08/Oct/2015	14.00	08/Oct/2015	17.32	CT Tandelta Testing & Half Yearly Maint.Work.
220 KV	Padegaon-Sawangi	08/Oct/2015	18.17	09/Oct/2015	00.47	R Phase String Insulator Decapped,R-E Fault.
220 KV	REL Borivali Aarey Line	09/Oct/2015	00.31	09/Oct/2015	03.42	Fixing of Insulation Sleeves.
220 KV	Kalwa - Colouchem	09/Oct/2015	08.26	09/Oct/2015	18.39	Line Maintenance work

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Adlabs - Pedambe	09/Oct/2015	08.30	09/Oct/2015	23.00	Bay Maintenance Work.
220 KV	Uran - Kharghar 2	09/Oct/2015	09.50	09/Oct/2015	18.06	Relay testing Work.
220 KV	Raymond - Washala	09/Oct/2015	10.19	09/Oct/2015	16.42	Replacement of Faulty WaveTrap.
220 KV	Padghe - Kamba	09/Oct/2015	10.36	09/Oct/2015	15.08	Line Maintenance work
220 KV	Bombay Dyeing - Sahara	09/Oct/2015	11.41	09/Oct/2015	17.39	Relay Testing Work and R & M work.
220 KV	Uran - Ongc Uran	09/Oct/2015	15.17	09/Oct/2015	17.34	Line Maintenance work
220 KV	Pigasus-Hinjewadi-II	10/Oct/2015	10.12	10/Oct/2015	12.11	isolator maintance work
220 KV	Padghe - Jambhul 2	10/Oct/2015	10.38	10/Oct/2015	16.05	conductor repairing work
220 KV	Main Bus I @ Dahanu	10/Oct/2015	12.46	10/Oct/2015	14.17	Line Maintenance work
220 KV	Pegasus - Infosys	10/Oct/2015	12.46	10/Oct/2015	14.17	Line Maintenance work
220 KV	Kandalgaon - Bhira	10/Oct/2015	15.15	10/Oct/2015	18.05	Attending Hot Spot
220 KV	Chalisgaon - Babhaleshwar	10/Oct/2015	16.33	10/Oct/2015	19.19	CT raio change
220 KV	Borivali - Ghodbunder	11/Oct/2015	06.54	11/Oct/2015	12.39	Replacement work
220 KV	Boisar(M) - Ghodbunder	11/Oct/2015	16.01	12/Oct/2015	00.39	To control boiser-boiserPG line loading
132 KV	Killari Tap On Ujani-Omerga	06/Oct/2015	06.02	06/Oct/2015	06.20	Distance Protection
132 KV	Bhusawal - Yaval	06/Oct/2015	11.42	06/Oct/2015	11.45	LTS Optd Due to Bhusawal Unit-3 Generation Huaning.
132 KV	Deepnagar- Nimbhora	06/Oct/2015	11.42	06/Oct/2015	11.45	LTS Optd Due to Bhusawal Unit-3 Generation Huaning.
132 KV	Pachora-Chalisgaon-1	06/Oct/2015	12.09	06/Oct/2015	12.23	Backup Protection
132 KV	Pachora-Chalisgaon-2	06/Oct/2015	12.09	06/Oct/2015	16.24	Distance Protection Operated Z-II Sof,AR Optd.
132 KV	Chikhali-Buldana	07/Oct/2015	08.34	07/Oct/2015	08.49	Distance Protection
132 KV	Chikhali-Khamgaon	07/Oct/2015	11.07	07/Oct/2015	15.52	Distance Protection Operated Zone-I B Ph,Guard Wire Broken.
132 KV	Malkapur - Khamgaon	07/Oct/2015	11.21	07/Oct/2015	11.25	Distance Protection Operated Zone-I B-E Fault.
132 KV	Mouda-Bhandara	07/Oct/2015	15.50	08/Oct/2015	05.02	Distance Protection Operated Zone-I R-Y Fault.
132 KV	Sawangi (220kv) - Harsool	08/Oct/2015	18.17	08/Oct/2015	19.52	Backup Protection
132 KV	Padegaon - Sawangi	08/Oct/2015	18.17	08/Oct/2015	19.22	Backup Protection
132 KV	Boisar li - Viraj	09/Oct/2015	10.46	09/Oct/2015	13.54	Attending Hot Spot
132 KV	Jindal - lol	09/Oct/2015	15.20	09/Oct/2015	17.10	Attending Hot Spot
132 KV	Chalisgaon-Pimparkhed	09/Oct/2015	17.40	09/Oct/2015	19.20	Bay Maintenance Work.
132 KV	Bableshwar - Kopergaon	10/Oct/2015	11.55	10/Oct/2015	18.05	Line Maintenance work
110 KV	Tata Borivli MSETCL Borivli 2	11/Oct/2015	09.35	11/Oct/2015	19.30	Annual Maintenance Work