

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 09/Nov/2015 to 15/Nov/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/11/2015	12 Hrs	5870	849	281	7000	5788	132	5588	161	-1352	17317	382	17699	1195	514	20378	20760	49.93
10/11/2015	12 Hrs	5640	419	415	6474	5044	377	5455	138	-1216	16272	289	16561	1160	517	19165	19454	49.97
11/11/2015	11 Hrs	4848	255	432	5535	3107	1227	4906	141	-784	14132	150	14282	961	393	16270	16420	50.00
12/11/2015	10 Hrs	5020	257	424	5701	2910	1178	4893	127	-774	14035	229	14264	943	394	16146	16375	49.99
13/11/2015	11 Hrs	4976	309	426	5711	4314	312	4987	160	-1080	14404	229	14633	882	396	16762	16991	49.94
14/11/2015	11 Hrs	5190	362	420	5972	4276	658	5005	143	-891	15163	38	15201	1033	407	17494	17532	49.97
15/11/2015	12 Hrs	5286	563	415	6264	3985	464	5470	168	-812	15539	16	15555	901	404	17656	17672	49.95
Maximum		5870	849	432	7000	5788	1227	5588	168	-774	17317	382	17699	1195	517	20378	20760	50.00
Minimum		4848	255	281	5535	2910	132	4893	127	-1352	14035	16	14264	882	393	16146	16375	49.93
Average		5261	431	402	6094	4203	621	5186	148	-987	15266	190	15456	1011	432	17696	17886	49.96

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/11/2015	13 Hrs	5902	919	280	7101	5317	135	5595	162	-1354	16956	400	17356	1189	516	20015	20415	49.99
10/11/2015		5425	347	410	6182	4875	392	5459	161	-1222	15847	334	16181	1153	515	18737	19071	49.97
11/11/2015		4615	117	424	5156	2823	1363	4912	194	-937	13511	149	13660	860	393	15701	15850	50.05
12/11/2015		4811	516	409	5736	3299	911	4809	182	-1073	13864	82	13946	765	396	16098	16180	49.98
13/11/2015		5044	210	415	5669	4105	118	5037	171	-1134	13966	242	14208	911	401	16412	16654	49.97
14/11/2015		5150	140	416	5706	3924	817	5162	194	-1056	14747	40	14787	1002	401	17206	17246	50.00
15/11/2015		5235	397	415	6047	3779	618	5254	167	-866	14999	16	15015	867	399	17131	17147	50.00
Maximum		5902	919	424	7101	5317	1363	5595	194	-866	16956	400	17356	1189	516	20015	20415	50.05
Minimum		4615	117	280	5156	2823	118	4809	161	-1354	13511	16	13660	765	393	15701	15850	49.97
Average		5169	378	396	5942	4017	622	5176	176	-1092	14842	180	15022	964	432	17329	17509	49.99

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/11/2015	19 Hrs	5622	207	283	6112	5054	133	5479	0	-1391	15387	177	15564	1184	394	18356	18533	49.96
10/11/2015	19 Hrs	4973	320	427	5720	4509	592	5055	0	-1275	14601	122	14723	1148	392	17416	17538	49.96
11/11/2015	19 Hrs	4677	754	423	5854	2874	761	4264	0	-1236	12517	79	12596	821	392	14966	15045	50.01
12/11/2015	19 Hrs	4800	351	422	5573	4059	137	4297	0	-1124	12942	14	12956	848	395	15309	15323	49.94
13/11/2015	20 Hrs	4810	406	439	5655	4455	152	4353	0	-1257	13358	20	13378	832	401	15848	15868	49.99
14/11/2015	20 Hrs	4991	470	424	5885	4223	82	4853	0	-1280	13763	12	13775	847	401	16291	16303	50.01
15/11/2015	20 Hrs	5012	396	421	5829	4101	148	4799	0	-1223	13654	16	13670	685	401	15963	15979	49.99
Maximum		5622	754	439	6112	5054	761	5479	0	-1124	15387	177	15564	1184	401	18356	18533	50.01
Minimum		4677	207	283	5573	2874	82	4264	0	-1391	12517	12	12596	685	392	14966	15045	49.94
Average		4984	415	406	5804	4182	286	4729	0	-1255	13746	63	13809	909	397	16307	16370	49.98

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
09/11/2015	3 Hrs	5481	257	198	5936	4156	389	4287	0	-914	13854	41	13895	640	388	15796	15837	49.98
10/11/2015	24 Hrs	4856	389	442	5687	3229	1133	4222	0	-1256	13015	44	13059	700	393	15364	15408	50.00
11/11/2015	23 Hrs	4638	172	442	5252	2062	1111	4353	0	-1231	11547	13	11560	687	396	13861	13874	50.01
12/11/2015	4 Hrs	4657	143	450	5250	1835	1080	4090	0	-753	11502	14	11516	687	393	13335	13349	49.99
13/11/2015	4 Hrs	4583	116	449	5148	2649	379	4362	0	-735	11803	13	11816	700	394	13632	13645	49.94
14/11/2015	4 Hrs	4843	151	452	5446	2510	439	4324	0	-720	11999	20	12019	696	402	13817	13837	49.96
15/11/2015	24 Hrs	4909	102	437	5448	3040	276	4393	0	-1158	11999	10	12009	675	403	14235	14245	49.98
Maximum		5481	389	452	5936	4156	1133	4393	0	-720	13854	44	13895	700	403	15796	15837	50.01
Minimum		4583	102	198	5148	1835	276	4090	0	-1256	11502	10	11516	640	388	13335	13349	49.94
Average		4852	190	410	5452	2783	687	4290	0	-967	12246	22	12268	684	396	14291	14314	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
09/11/2015	136.748	6.811	6.302	149.861	0.685	115.849	117.100	6.945	124.584	1.078	22.636	10.577	-28.026	370.291	61.239	431.530
10/11/2015	127.159	6.204	10.086	143.449	0.537	99.185	106.287	12.524	124.544	0.974	22.286	10.787	-26.250	354.426	59.326	413.752
11/11/2015	113.588	5.780	10.473	129.841	0.464	68.097	88.801	25.718	109.042	1.074	18.717	9.452	-22.381	311.390	50.550	361.940
12/11/2015	115.958	6.840	10.087	132.885	0.289	70.604	80.556	16.613	108.510	1.230	18.704	9.479	-23.186	306.657	51.369	358.026
13/11/2015	114.701	5.982	10.274	130.957	0.686	88.620	88.360	6.715	109.685	1.222	18.329	9.583	-25.155	312.044	53.067	365.111
14/11/2015	118.924	7.019	10.417	136.360	0.620	87.048	88.285	9.024	112.040	1.210	19.352	9.800	-23.930	321.752	53.079	374.831
15/11/2015	121.486	8.028	10.418	139.932	0.779	87.581	90.744	5.911	117.516	1.172	17.094	9.660	-22.603	329.509	49.357	378.866
Maximum	136.748	8.028	10.473	149.861	0.779	115.849	117.100	136.748	124.584	1.230	22.636	10.787	-22.381	370.291	61.239	431.530
Minimum	113.588	5.780	6.302	129.841	0.289	68.097	80.556	113.588	108.510	0.974	17.094	9.452	-28.026	306.657	49.357	358.026
Average	121.223	6.666	9.722	137.612	0.580	88.141	94.305	121.223	115.132	1.137	19.588	9.905	-24.504	329.438	53.998	383.437

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
09/11/2015	0.073	1.646	42.656
10/11/2015	0.074	1.720	42.582
11/11/2015	0.055	1.775	42.527
12/11/2015	0.077	1.852	42.450
13/11/2015	0.075	1.927	42.375
14/11/2015	0.053	1.980	42.322
15/11/2015	0.140	2.120	42.182

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 09/Nov/2015 to 15/Nov/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
09/11/2015	MONDAY	98.341	4860	18.759	782	117.100	4879	115.849	4827	-1.251	-52
10/11/2015	TUESDAY	88.606	4411	17.681	737	106.287	4429	99.185	4133	-7.102	-296
11/11/2015	WEDNESDA	81.884	3693	6.917	288	88.801	3700	68.097	2837	-20.704	-863
12/11/2015	THURSDAY	76.811	3353	3.745	156	80.556	3356	70.604	2942	-9.952	-415
13/11/2015	FRIDAY	81.131	3674	7.229	301	88.360	3682	88.620	3692	0.260	11
14/11/2015	SATURDAY	79.581	3670	8.704	363	88.285	3679	87.048	3627	-1.237	-52
15/11/2015	SUNDAY	80.513	3771	10.231	426	90.744	3781	87.581	3649	-3.163	-132
Total		586.867		73.266		660.133		616.984		-43.149	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 09/11/2015 TO 15/11/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
Cent_Sect	Tarapur 2	160MW	10/Sep/2015	12.55		Continued.	Refuelling work
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 2A	230MW	06/Jun/2013	09.10		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3A	230MW	06/Jun/2013	08.28		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2X	230MW	15/Jul/2013	15.09		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2B	230MW	08/Aug/2013	15.03		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3X	230MW	29/Dec/2013	05.47		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3B	230MW	29/Dec/2013	06.14		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12.43		Continued.	Economic shutdown
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	RPL(AMT) U-5	270MW	03/Apr/2015	14.22		Continued.	turbine Shaft Vibration high.
MSPGCL	Uran Unit 7	108MW	17/Apr/2015	00.07		Continued.	Gas turbine problem
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12.58		Continued.	Water Shortage
IPP	WPCL U-2	135MW	16/Jun/2015	00.00		Continued.	No Schdule
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown
IPP	WPCL U-1	135MW	23/Oct/2015	17.31		Continued.	ESP filter problem
MSPGCL	Koradi Unit 5	200MW	04/Nov/2015	07.39		Continued.	ID Fan Problem
IPP	JSW (J) U4	300MW	05/Nov/2015	21.58		Continued.	Turbine Bearing Inspection.
IPP	Adani U-4	660MW	07/Nov/2015	15.51		Continued.	Hot Air Outlet Leakage.
MSPGCL	Uran Unit 6	108MW	08/Nov/2015	06.52	09/Nov/2015	00.59	Due to Excitation Problem.
MSPGCL	Uran Unit 5	108MW	08/Nov/2015	06.54	10/Nov/2015	00.48	Voltage Regulator Off
MSPGCL	Uran Unit A0	120MW	08/Nov/2015	06.52	09/Nov/2015	04.50	Due to Excitation Problem.
MSPGCL	Koradi Unit-8	660MW	09/Nov/2015	01.07		Continued.	Coal mill problem
IPP	RPL(AMT) U-5	270MW	10/Nov/2015	10.19	13/Nov/2015	10.57	Cooling water Line leakage
MSPGCL	Chandrapur Unit-8	500MW	10/Nov/2015	12.10		Continued.	Drum level low
MSPGCL	Khaparkheda Unit 3	210MW	11/Nov/2015	12.30	13/Nov/2015	09.58	Boiler Tube Leakage
MSPGCL	Uran Unit 6	108MW	12/Nov/2015	22.08	12/Nov/2015	23.48	Boiler Protection
MSPGCL	Khaparkheda Unit 4	210MW	13/Nov/2015	00.25	14/Nov/2015	08.31	Turbine bearing Vabration high
IPP	RPL(AMT) U-3	270MW	14/Nov/2015	22.41	15/Nov/2015	00.56	Tripped due to sps operated

LINE OUTAGES FOR THE WEEK FROM 09/11/2015 TO 15/11/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
500 KV	Chandrapur - Padghe HvdC Pole 2	09/Nov/2015	20.43	10/Nov/2015	01.47	Converter blocked from C'Pur end
400 KV	Akola II - Taptitanda ckt-II	06/Oct/2015	09.44		Continued.	For Controlling Line Loading.
400 KV	Kolhapur Mapusa II	07/Nov/2015	12.54	09/Nov/2015	01.13	LiLo of Kolhapur Mapusa D/C.
400 KV	Babhaleshwar-Taptitanda ckt-I	07/Nov/2015	14.41	11/Nov/2015	10.39	Controlling Line Loading.
400 KV	Karad - Jaigad - II	08/Nov/2015	16.32	09/Nov/2015	09.22	Over Voltage
400 KV	karad -kolhapur-I	08/Nov/2015	17.08	09/Nov/2015	09.20	Over Voltage
400 KV	Bhusawal-Aurangabad	08/Nov/2015	18.03	09/Nov/2015	06.46	Over Voltage
400 KV	Dhule Sar'Sarovar I	08/Nov/2015	20.16	09/Nov/2015	06.41	Over Voltage
400 KV	Kolhapur(M)-Kolhapur(GIS) cktII	09/Nov/2015	01.13	09/Nov/2015	01.14	First Time Charged
400 KV	Koradi - Koradi II	09/Nov/2015	14.39	09/Nov/2015	18.59	Testing Work
400 KV	karad -kolhapur-II	09/Nov/2015	16.01		Continued.	Over Voltage
400 KV	Karad-Jaigad - I	09/Nov/2015	16.04		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	09/Nov/2015	17.39	10/Nov/2015	06.47	Over Voltage
400 KV	Dhule Sar'Sarovar I	09/Nov/2015	18.10	10/Nov/2015	07.00	Over Voltage
400 KV	Koradi-India Bulls	10/Nov/2015	11.28	10/Nov/2015	22.47	Changing CT Ratio of Metering and LBB Core
400 KV	Girwali - Lonikand 1	10/Nov/2015	14.31	10/Nov/2015	14.41	To take Line Reactor in service
400 KV	Lonikand I - Koyna stage-IV	10/Nov/2015	16.57		Continued.	Over Voltage
400 KV	Kolhapur Solapur (PG) II	10/Nov/2015	17.06	11/Nov/2015	07.34	Over Voltage
400 KV	Bhusawal-Aurangabad	10/Nov/2015	17.09	11/Nov/2015	07.29	Over Voltage
400 KV	Dhule Sar'Sarovar I	10/Nov/2015	17.30	11/Nov/2015	07.34	Over Voltage
400 KV	Babhaleshwar-Taptitanda ckt-II	11/Nov/2015	10.42		Continued.	Attend hot spot RFC 14.42 12/11/2015
400 KV	Padghe - Kalwa- I	11/Nov/2015	12.36	11/Nov/2015	18.36	Distance Protection
400 KV	Dhule Sar'Sarovar I	11/Nov/2015	14.17	12/Nov/2015	07.54	Over Voltage
400 KV	Dabhol New koyna I	11/Nov/2015	16.38	12/Nov/2015	07.14	Over Voltage
400 KV	Kolhapur Solapur(PG) I	11/Nov/2015	17.00	12/Nov/2015	08.16	Over Voltage
400 KV	Dabhol Nagothane II	11/Nov/2015	17.04	14/Nov/2015	10.10	Over Voltage
400 KV	Dabhol Nagothane I	11/Nov/2015	17.04	12/Nov/2015	11.25	Over Voltage
400 KV	Bhusawal-Aurangabad	11/Nov/2015	17.09	12/Nov/2015	06.32	Over Voltage
400 KV	Koradi-Bhusawal	11/Nov/2015	17.26	11/Nov/2015	17.59	Distance Protection
400 KV	Babhaleshwar - Padghe-II	12/Nov/2015	12.12	13/Nov/2015	09.17	Earth Fault
400 KV	Kolhapur Solapur(PG) I	12/Nov/2015	12.38	12/Nov/2015	15.15	Distance Protection
400 KV	Kolhapur Solapur (PG) II	12/Nov/2015	17.05	13/Nov/2015	19.52	Over Voltage
400 KV	Dhule Sar'Sarovar I	12/Nov/2015	17.34	13/Nov/2015	06.46	Over Voltage
400 KV	Bhusawal-Aurangabad	12/Nov/2015	17.37	13/Nov/2015	06.53	Over Voltage
400 KV	Padghe - Kalwa- I	12/Nov/2015	21.45	12/Nov/2015	23.09	Taken on TBC,To Attend Hot Spot @ Padgha.
400 KV	Dhule Sar'Sarovar I	13/Nov/2015	16.16	14/Nov/2015	06.43	Over Voltage
400 KV	Bhusawal-Aurangabad	13/Nov/2015	17.20	14/Nov/2015	09.23	Over Voltage
400 KV	Kolhapur Solapur (PG) II	13/Nov/2015	21.48	14/Nov/2015	07.13	Over Voltage
400 KV	New Koyna - Dabhol - II	14/Nov/2015	12.17	15/Nov/2015	11.56	Attend broken insulator dtring.rfc at 19.20 hrs
400 KV	Padgha-HVDC(AC)-II	14/Nov/2015	12.20	14/Nov/2015	20.03	Attending Hot Spot
400 KV	Bhusawal-Aurangabad	14/Nov/2015	18.05	15/Nov/2015	07.08	Over Voltage
400 KV	Dhule Sar'Sarovar I	14/Nov/2015	18.16	15/Nov/2015	07.09	Over Voltage
400 KV	Dabhol Nagothane II	15/Nov/2015	11.50		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	15/Nov/2015	17.05	16/Nov/2015	06.24	Over Voltage
400 KV	Dhule Sar'Sarovar I	15/Nov/2015	17.30		Continued.	Over Voltage
400 KV	Kolhapur Solapur (PG) II	15/Nov/2015	21.54	16/Nov/2015	06.44	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Wadkhal - Ndil 2	06/Nov/2015	10.45	12/Nov/2015	17.40	Replacement of 220KV Panels,Bay Equipments(6 Days)
220 KV	Wadkhal - Ipcl 1	06/Nov/2015	11.50		Continued.	Replacement of Conductors (for 15 Days).
220 KV	Miraj - Ichalkaranji II	07/Nov/2015	12.27	09/Nov/2015	07.11	Aviling outage on 400kv Kolhapur Mapusa Line.
220 KV	Kalwa Saisette III	08/Nov/2015	06.40	09/Nov/2015	00.12	Saishet for bay shifting work.
220 KV	Trombay Saisette 1 Backbay	08/Nov/2015	07.48	10/Nov/2015	04.45	Modification work

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Kalwa-Salsette-VI	09/Nov/2015	07.28	10/Nov/2015	03.40	Bay swapping work at Salsette
220 KV	Padghe - Vasai	09/Nov/2015	09.42	09/Nov/2015	12.55	To attend Hot Spot
220 KV	Halkarni - Tillari II	09/Nov/2015	10.02	09/Nov/2015	15.50	Half yearly maint.work
220 KV	Padghe - Wada	09/Nov/2015	14.25	09/Nov/2015	20.12	Relay replacement work
220 KV	Uran - Apta IV	10/Nov/2015	01.52	10/Nov/2015	02.14	Distance Protection
220 KV	Kalwa-Salsette-IV	10/Nov/2015	06.03	10/Nov/2015	06.27	Current Unbalance
220 KV	Uran - Apta IV	10/Nov/2015	15.15	10/Nov/2015	19.32	To change Disc Insulator
220 KV	Pedambe-Pophali	11/Nov/2015	09.00	11/Nov/2015	10.45	Gas Leakage and Oil Top Up in Compressor
220 KV	Boisar-Viraj	11/Nov/2015	11.50	11/Nov/2015	14.26	B Phase PT Burst at consumer end and Bus Bar operated
220 KV	Dahanu-Viraj	11/Nov/2015	11.50	11/Nov/2015	14.33	B Phase PT Burst at consumer end and Bus Bar operated
220 KV	Nagar-Babhaleshwar Ckt II	11/Nov/2015	20.22	11/Nov/2015	20.48	Distance Protection
220 KV	Talandge(400kv) - Sawantwadi(Insul	12/Nov/2015	06.02	12/Nov/2015	06.16	Distance Protection
220 KV	Ranjangaon-Lonikand	12/Nov/2015	12.36	13/Nov/2015	19.44	Distance Protection
220 KV	Talandage(400kv) - Five Star Midc	12/Nov/2015	13.50	12/Nov/2015	16.45	Unbalance current
220 KV	Kalwa-Salsette-IV	14/Nov/2015	08.20		Continued.	Conductor uprating work (35 days outage)
220 KV	Nasik Navsari I	14/Nov/2015	11.10	14/Nov/2015	18.32	insulator cold washing work
220 KV	Ghodbunder MSETCL Borivali line	14/Nov/2015	11.17	14/Nov/2015	14.27	isolator maintenance work
220 KV	Tillari Amona	14/Nov/2015	13.38	14/Nov/2015	13.50	Tripped at amona end
220 KV	Kharghar Trombay	15/Nov/2015	09.12	15/Nov/2015	14.33	Relay Testing Work
220 KV	Trombay Salsette 1 Backbay	15/Nov/2015	09:35	15/Nov/2015	19:56	Work in vicinity for Kalwa-Salsette IV Line
132 KV	Dhule- Nardane	09/Nov/2015	15.22	09/Nov/2015	15.30	Tripped without Indication
132 KV	Mul-Sindewahi	09/Nov/2015	19.17	09/Nov/2015	19.33	Distance Protection
132 KV	Kurunda - Hingoli	11/Nov/2015	08.25	11/Nov/2015	08.43	Distance Protection
100 KV	Kalwa - Vashi 1	08/Nov/2015	02.08	09/Nov/2015	15.15	Distance Protection